

ORIGINAL

SALLQUIST & DRUMMOND, P.C.
ATTORNEYS AT LAW
2525 EAST ARIZONA BILTMORE CIRCLE
SUITE A-117
PHOENIX, ARIZONA 85016-2129



0000004170

14LF

RICHARD L. SALLQUIST

PHONE (602) 224-9222
FACSIMILE (602) 224-9366
E-MAIL dick@sd-law.com

June 30, 2004

Judge Marc Stern
Hearing Division
Arizona Corporation Commission
1200 W. Washington
Phoenix, AZ 85007

Re: Beardsley Water Company; Certificate of Convenience and Necessity Application;
Docket No. W-02074A-04-0241; Late Filed Exhibits.

Dear Judge Stern:

At the June 22, 2004 hearing on this matter, you requested that the Company provide as late filed exhibits copies of Maricopa County Environmental Services Department Compliance Status Reports for the four Public Water Systems ("PWS's") presently operated by the Company.

Attached please find said reports indicating Substantial Compliance for the following;

- PWS #07-007 - Beardsley 1
- PWS #07-509 - Beardsley 2
- PWS #07-511 - Beardsley 3
- PWS #07-517 - Beardsley 4 (Patton Place Estates)

Arizona Corporation Commission
DOCKETED

JUL - 2 2004

| | |
|-------------|-----------|
| DOCKETED BY | <i>CR</i> |
|-------------|-----------|

In the event you have further questions in this regard, please do not hesitate to call.

Sincerely,

Richard L. Sallquist
For the Firm

cc: Docket Control (15 copies)
Jason Gelman
Jim Fisher
Dorothy Hains
Ted Wilkinson

RECEIVED
2004 JUL - 2 11: 11
AZ CORP COMMISSION
DOCUMENT CONTROL



ENVIRONMENTAL SERVICES DEPARTMENT
WATER AND WASTE MANAGEMENT DIVISION
DRINKING WATER PROGRAM
MEMORANDUM

PUBLIC WATER SYSTEM COMPLIANCE STATUS REPORT

TO: Arizona Corporation Commission
Utilities Engineering
Fax: (602) 542-2129

FROM: John Kolman R.S.
Drinking Water/Solid Waste Programs Manager

DATE: May 4, 2004

SUBJECT: REQUEST FOR COMPLIANCE STATUS INFORMATION RECEIVED

COMPLIANCE STATUS INFORMATION HAS BEEN REQUESTED FOR THE FOLLOWING WATER COMPANY:

System Name: Beardsley Water Company

PWS ID#: 07-007

Assigned Monitoring Dates - Initial: 1/1/93. Phase II: 1/1/93. Phase V: 1/1/96.

Does the water system have a Certified Operator? Yes

Does the system have major physical/plant (treatment) deficiencies? No

Please describe: _____

Date of last inspection: November 26, 2003

Does the system have major O & M deficiencies? No

Please describe: _____

Does the system have water quality monitoring/reporting deficiencies? Minor

Please describe: System needs to submit to this Department for review and approval a microbiological site sampling plan (MSSP) which includes disinfection monitoring. The water system needs to submit a disinfection byproduct monitoring plan for review and approval.

Is enforcement action pending? No

Overall Public Water System Compliance Status? Substantial Compliance

Number of Service Connections: 146. Population Served: 438

Type of System: Community. Number of POE's: 2. Surface Water: N/A.

Date of compliance review: May 4, 2004. By: Doug Taylor R.S. Initials: DT

Phone: (602) 506-6631

A handwritten signature in black ink, appearing to be "DT" followed by a stylized flourish.



**ENVIRONMENTAL SERVICES DEPARTMENT
WATER AND WASTE MANAGEMENT DIVISION
DRINKING WATER PROGRAM
MEMORANDUM**

PUBLIC WATER SYSTEM COMPLIANCE STATUS REPORT

TO: Arizona Corporation Commission
Utilities Engineering
Fax (602) 542-3129

FROM: John Kolman, P.S.
Drinking Water Program Manager

DATE: May 13, 2004

SUBJECT: REQUEST FOR COMPLIANCE STATUS INFORMATION RECEIVED 4/16/04

COMPLIANCE STATUS INFORMATION HAS BEEN REQUESTED FOR THE FOLLOWING WATER COMPANY:

System Name Beardsley Water Co.
PWS ID#: 07-509
Assigned Monitoring Dates - Initial: 1-1-00 . Phase II: 1-1-00 . Phase V: 1-1-00 .

Does the water system have a Certified Operator? Yes

Does the system have major physical/plant (treatment) deficiencies? N/A
Please describe: _____

Date of last inspection: 11-29-01

Does the system have major O & M deficiencies? Minor only
Please describe: _____

Does the system have water quality monitoring/reporting deficiencies? Minor only
Please describe: System has not submitted required Microbiological Site Sampling Plan.

General Public Water System Compliance Status? Substantial compliance

Number of Service Connections: 24 . Population Served: 70

Type of System: Community . Number of POE's: 1 . Surface Water: no

Date of compliance review: May 13, 2004 . By: Jenny Young, P.S. Initials: JY

Phone: (602) 506-0462



ENVIRONMENTAL SERVICES DEPARTMENT
WATER AND WASTE MANAGEMENT DIVISION
DRINKING WATER PROGRAM
MEMORANDUM

PUBLIC WATER SYSTEM COMPLIANCE STATUS REPORT

TO: Brad Morton
Arizona Corporation Commission

FROM: John Kolman R.S.
Drinking Water Program Manager

DATE: 05/04/04

SUBJECT: REQUEST FOR COMPLIANCE STATUS INFORMATION RECEIVED

COMPLIANCE STATUS INFORMATION HAS BEEN REQUESTED FOR THE FOLLOWING
WATER COMPANY:

System Name: Beardsley Water Company #3

PWS ID#: 07-511

Assigned Monitoring Dates - Initial: 1/1/01 Phase II: 1/1/01 Phase V: 1/1/01

Does the water system have a Certified Operator? yes Joe Flano (480) 837-6438

Does the system have major physical/plant (treatment) deficiencies? no
Please describe:

Date of last inspection: 07/09/02

Does the system have major O & M deficiencies? No
Please describe: minor; pull weeds; install vacuum breaker on spigot; install sign

Does the system have water quality monitoring/reporting deficiencies? No
Please describe:

General Public Water System Compliance Status? Compliant

Number of Service Connections: 26 Population Served: 60
Type of System: Community Number of POB's: 1 Surface Water: 0

Date of compliance review: May 4, 2004 By: Mike Mallette Initials: MM
Phone: (602) 506-6644



ENVIRONMENTAL SERVICES DEPARTMENT
WATER AND WASTE MANAGEMENT DIVISION
DRINKING WATER PROGRAM
MEMORANDUM

PUBLIC WATER SYSTEM COMPLIANCE STATUS REPORT

TO: Arizona Corporation Commission
Utilities Engineering
Fax: (602) 542-2129

FROM: John Kolman R.S.
Drinking Water/Solid Waste Programs Manager

DATE: May 4, 2004

SUBJECT: REQUEST FOR COMPLIANCE STATUS INFORMATION RECEIVED

COMPLIANCE STATUS INFORMATION HAS BEEN REQUESTED FOR THE FOLLOWING WATER COMPANY:

System Name: Beardsley Water Company #4

PWS ID#: 07-517

Assigned Monitoring Dates - Initial: 1/1/04. Phase II: 1/1/04. Phase V: 1/1/04.

Does the water system have a Certified Operator? Yes

Does the system have major physical/plant (treatment) deficiencies? No
Please describe: _____

Date of last inspection: September 29, 2003

Does the system have major O & M deficiencies? Minor
Please describe: _____

Does the system have water quality monitoring/reporting deficiencies? Minor
Please describe: System needs to initiate lead and copper monitoring and four consecutive quarters of radiochemical monitoring as stated in the NSA dated 10/1/02. System needs to inform MCESD about population and service connection changes. System needs to update MSSP to include TTHM/HAA5. System needs to report monthly total coliform properly.

Is enforcement action pending? No

Overall Public Water System Compliance Status? Substantial Compliance

Number of Service Connections: 83. Population Served: 249.
Type of System: Community. Number of POE's: 1. Surface Water: N/A.

Date of compliance review: May 4, 2004. By: Doug Taylor R.S. Initials: DT
Phone: (602) 506-6631