

ORIGINAL



0000004541

OPEN MEETING AGENDA ITEM  
RECEIVED

305M

2004 MAY 11 A 9:20

TO: Docket Control

AZ CORP COMMISSION  
DOCUMENT CONTROL

FROM: Ernest G. Johnson  
Director  
Utilities Division

DATE: May 11, 2004

RE: ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY  
CURRENT COMPLIANCE STATUS FOR  
ARIZONA-AMERICAN WATER COMPANY

- DOCKET NO. WS-01303A-02-0867
- DOCKET NO. WS-01303A-02-0868
- DOCKET NO. W -01303A-02-0869
- DOCKET NO. WS-01303A-02-0870
- DOCKET NO. W -01303A-02-0908

Decision No. 66941 adopted a recommendation that Staff file in the above referenced rate case dockets, updated results of the compliance status of Arizona American Water Company with the Arizona Department of Environmental Quality. A table summarizing those compliance results is attached. The Arizona Department of Environmental Quality has indicated that all the listed drinking water systems are delivering water that meets water quality standards required by the Safe Drinking Water Act and Arizona Administrative Code, Title 18, Chapter 4.

Arizona Corporation Commission  
**DOCKETED**

MAY 11 2004

EGJ:LRH:

Originator: L. R. Hammon

Attachment: Original and twenty-one copies

DOCKETED BY	
-------------	--

Service List For: Arizona American Water Company

Docket Nos. WS-01303A-02-0867  
WS-01303A-02-0868  
W -01303A-02-0869  
WS-01303A-02-0870  
W -01303A-02-0908

The original and twenty-one (21) copies  
of the foregoing were filed this  
\_\_\_\_\_ day of May 2004 with:

Docket Control  
Arizona Corporation Commission  
1200 West Washington Street  
Phoenix, Arizona 85007

Copies of the foregoing were mailed  
this \_\_\_ day of March 2004 to:

Norman D. James  
Jay L. Shapiro  
Fennemore Craig  
3003 N. Central Avenue, Suite 2600  
Phoenix, AZ 85012  
Attorneys for Arizona-American Water Company

Daniel Pozefsky  
RUCO  
1110 W. Washington, Suite 220  
Phoenix, Arizona 85007

William P. Sullivan  
Martinez & Curtis  
2712 North 7<sup>th</sup> Street  
Phoenix, Arizona 85006  
Attorneys for the Town of Youngtown

Carlton G. Young  
3203 W. Steinbeck Drive  
Anthem, Arizona 85068-1540

Frank J. Grimmelmann  
42441 N. Cross Timbers Court  
Anthem, Arizona 85086

Raymond E. Dare  
Sun City Taxpayers Association  
12630 N. 103<sup>rd</sup> Ave., Suite 144  
Sun City, Arizona 85351-3467

Walter W. Meek, Pres.  
AUIA  
2100 N. Central Ave., Suite 210  
Phoenix, Arizona 85004

John A. Buric  
Warner Angle Hallam Jackson & Formanek PLC  
3550 N. Central Ave., Suite 1500  
Phoenix, AZ 85012  
Attorneys for Fiesta RV Resort Limited Partnership

Kenneth C. Sundlof, Jr.

Robert Taylor  
Jennings Strouss & Salmon PLC  
The Collier Center, Floor 11  
201 E. Washington Street  
Phoenix, AZ 85004-2385  
Attorneys for Sun Health Corporation

Mr. David P. Stephenson  
Director of Rates and Revenues  
American Water Works Service Co., Inc.  
303 H Street, Suite 250  
Chula Vista, California 91910

Arizona American Water And Wastewater Systems  
Compliance Status With  
The Arizona Department of Environmental Quality

	System ID	Date Requested	IN COMPLIANCE ? (Yes or No)	Date of status
<b>Drinking Water</b>				
Anthem	07-504	15 Mar 04	Yes	23 Mar 04
Agua Fria	07-695	15 Mar 04	Yes	28 Apr 04
Camp Mohave	07-037	15 Mar 04	Yes	22 Mar 04
Desert Foothills	08-137	Jan 04	Yes	19 Feb 04
Havasu	08-015	15 Mar 04	Yes	4 Mar 04 (see note 2)
Lake Mohave Highland	08-062	15 Mar 04	Yes	22 Mar 04
Mohave - Main	08-032	Jan 04	Yes	19 Feb 04
Paradise Valley	07-056	15 Mar 04	Yes	1 Apr 2004
Rio Vista	08-333	Jan 04	Yes	7 Jan 04
Sun City	07-099	15 Mar 04	Yes	20 Apr 04
Sun City West	07-150	15 Mar 04	Yes	28 Apr 04
Tubac	12-001	15 Mar 04	Yes	18 Mar 04
Waddell	07-151	16 Mar 04	Yes	30 Apr 04
<b>Wastewater</b>				
Anthem	37-184	15 Mar 04	Groundwater sample exceedance	7 Apr 04 (see note 1)
Sun City West	37-018	15 Mar 04	Yes	27 Apr 04

Explanatory Notes:

1. Anthem wastewater meets total compliance for frequency of testing, effluent quality, and operation and maintenance. Four nitrogen exceedances at a groundwater monitoring well near the recharge site, did occur in 2002 and 2003. Those exceedances were not for the treated wastewater and do not directly represent the water quality from the wastewater treatment plant. The source of the groundwater contamination is in question and sample constituents point to another facility as a possible source. The cause and source of the groundwater anomaly is under investigation by the Company.
  
2. An April 16, 2004 letter from Stephen A. Owens, Director, Arizona Department of Environmental Quality, to the Honorable William A. Mundell, Commissioner, Arizona Corporation Commission, indicated that the nitrate concentration was now 8.36 milligrams per liter (mg/l), which "...meets state and federal standards". (The nitrate maximum contaminant level is 10.0 mg/l.)