

ORIGINAL



Santa Rosa Utility Company
9532 East Riggs Rd., Sun Lakes, Arizona 85248

50

May 13, 2005

Arizona Corporation Commission
DOCKETED

MAY 16 2005

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

DOCKETED BY	<i>KJ</i>
-------------	-----------

Re: Docket No.'s SW-04136A-02-0691 and W-04137A-02-0692

Dear Sir or Madam:

Enclosed is a copy of Santa Rosa Utility Company's State Aquifer Protection Permit that is required to be filed pursuant to Decision No. 65753.

An original and 15 copies of the are submitted.

Sincerely,

Jim Poulos

JP:th

Docketcontrol94.doc

AZ CORP COMMISSION
DOCUMENT CONTROL

2005 MAY 16 P 2:37

RECEIVED

STATE OF ARIZONA
AQUIFER PROTECTION PERMIT NO. P - 105297
LTF ID 28867 PLACE ID 17944

1.0 AUTHORIZATION

In compliance with the provisions of Arizona Revised Statutes (A.R.S.) Title 49, Chapter 2, Articles 1, 2 and 3, Arizona Administrative Code (A.A.C.) Title 18, Chapter 9, Articles 1 and 2, A.A.C. Title 18, Chapter 11, Article 4 and amendments thereto, and the conditions set forth in this permit, Santa Rosa Utility Company, is hereby authorized to operate the Santa Rosa Water Reclamation Plant located approximately 1½ miles west of the intersection of Teel Road and White Parker Road, Arizona, in Pinal County, over the Phoenix A.M.A. in Township 5 South, Range 3 East, Section 26, SE¼ NE¼ NE¼ - Gila and Salt River Base Line and Meridian.

This permit becomes effective on the date of the Water Quality Division Director's signature and shall be valid for the life of the facility (operational, closure, and post-closure periods), provided that the facility is constructed, operated, and maintained:

1. Following all the conditions of this permit including the design and operational information documented or referenced below, and
2. such that Aquifer Water Quality Standards (AWQS) are not violated at the applicable point(s) of compliance (POC) set forth below, or if an AWQS for a pollutant has been exceeded in an aquifer at the time of permit issuance, that no additional degradation of the aquifer relative to that pollutant, and as determined at the applicable POC, occurs as a result of the discharge from the facility.

1.1 PERMITTEE INFORMATION

Facility Name: Santa Rosa Water Reclamation Plant

Permittee:

Santa Rosa Utility Company

Mailing Address:

Santa Rosa Utility Company
9532 East Riggs Road
Sun Lakes, Arizona 85248

Facility Street Address:

Approximately 1½ miles west of
the intersection of Teel Road and
White Parker Road in Maricopa,
Arizona

Facility Contact: Jim Poulos, General Manager

Emergency Telephone Number: 480-895-9200

Latitude:

32° 57' 46" N

Longitude: 112° 01' 47" W

Legal Description: Township 5 South, Range 3 East, Section 26 SE¼ NE¼ NE¼, Gila and Salt River Base Line and Meridian.

1.2 AUTHORIZING SIGNATURE



Charles G. Graf, Acting Director
Water Quality Division
Arizona Department of Environmental Quality

Signed this 4th day of May, 2005

2.0 SPECIFIC CONDITIONS [A.R.S. §§ 49-203(4), 49-241(A)]**2.1 Facility / Site Description A.R.S. § 49-243(K)(8)]**

The permittee is authorized to operate a tertiary wastewater treatment plant (WRP) that consists of biological nutrient removal using activated sludge sedimentation, filtration and ultraviolet disinfection. The plant shall treat no more than 1.4 million gallons per day of domestic sewage. There shall be no sludge drying beds. Sludge shall be aerobically digested and dewatered onsite by a centrifuge process. The dewatered sludge shall be hauled off site to a facility approved to accept these wastes. The effluent will be transported to reuse sites under the authority of an Individual or General Reclaimed Water Permit issued by ADEQ and/or recharged at basins at the pollutant management area (PMA) of the WRP, or at Aquifer Storage & Recovery wells at the PMA. These wells shall be constructed according to plans submitted with the application.

The site includes the following permitted discharging facility:

Facility	Latitude	Longitude
WRF	32° 57' 46"N	112° 01' 47"N
Recharge Basins/Recharge Wells	32° 57' 38"N	112° 01' 42"N

2.2 Best Available Demonstrated Control Technology [A.R.S. § 49-243(B) and A.A.C. R18-9-A202(A)(5)]

The WRF shall be designed, constructed and operated to meet the treatment performance criteria for new facilities as specified in Arizona Administrative Code R18-9-B204. The facility's basins are exempt from BADCT requirements.

The facility meets the requirements for the pretreatment by conducting monitoring as per R18-9-B204(A)(6)(b)(ii).

2.2.1 Engineering Design

The design of the WRP is according to design report dated January 9, 2003 and approved by the ADEQ Wastewater Design Review Unit.

2.2.2 Site-specific Characteristics

Not required.

2.2.3 Pre-Operational Requirements

Within 60 days of the signature date of the permit, the operator shall inspect the facility to verify that all aspects of the WRP and recharge processes function as designed. The permittee shall provide written certification to ADEQ Water Permits compliance, that inspection of all components was performed and indicate the results of inspection.

2.2.4 Operational Requirements

1. The permittee shall maintain a copy of the O & M manual at the WWTP site at all times and shall be available upon request during inspections by ADEQ personnel.

2. The pollution control structures shall be inspected for the items listed in Section 4.0, TABLE III. A log of inspections shall be kept at the facility for ten (10) years from the date of each inspection and shall be made available to ADEQ personnel upon request.
3. If any damage of pollution control structures is identified during inspection, proper repair procedures shall be performed. All repair procedures and material(s) used shall be documented on the Self-Monitoring Report Form (SMRF) submitted quarterly to the ADEQ Water Quality Enforcement.

2.2.5 Wastewater Treatment Plant Classification
A.C. R18-9-703(C)(2)(a), A.A.C. R18-11-303 THROUGH 307]

This facility is classified as generating Class B+ reclaimed water according to Arizona Administrative Code R18-11-303.

2.3 Discharge Limitations [A.R.S. §§ 49-201(14), 49-243 and A.A.C. R18-9-A205(B)]

The permittee is authorized to discharge up to 1.4 million gallons per day of effluent to the recharge basins, or for reuse under the authority of a Reclaimed Water Permit.

2.4 Point(s) of Compliance (POC) [A.R.S. § 49-244]

POC Location	Latitude	Longitude
North West Side of Recharge Basin #1	32° 57' 49"N	112° 01' 49"W

A monitor well shall be installed at the POC location. Groundwater monitoring shall be performed at this well in accordance with Section 2.5 and Table IIA

The Director may designate additional points of compliance if information on groundwater gradients or groundwater usage indicates the need.

2.5 Monitoring Requirements [A.R.S. § 49-243(K)(1), A.A.C. R18-9-A206(A)]

All monitoring required in this permit shall continue for the duration of the permit, regardless of the status of the facility. All sampling, preservation and holding times shall be in accordance with currently accepted standards of professional practice. Trip blanks, equipment blanks and duplicate samples shall also be obtained, and chain of custody procedures shall be followed, in accordance with currently accepted standards of professional practice. The permittee shall consult the most recent version of the ADEQ Quality Assurance Project Plan (QAPP) and EPA 40 CFR PART 136 for guidance in this regard. Copies of laboratory analyses and chain of custody forms shall be maintained at the permitted facility. Upon request these documents shall be made immediately available for review by ADEQ personnel.

2.5.1 Discharge Monitoring

The permittee shall monitor the wastewater daily, monthly and quarterly according to Table I. A representative sample shall be collected at the effluent weir.

The permittee shall also monitor effluent according to Table IA whenever water is transported for reuse.

2.5.2 Facility / Operational Monitoring

Operational monitoring inspections shall be conducted according to Section 4.0, Table III.

- a. If any damage of the pollution control structures is identified during inspection, proper repair

procedures shall be performed. All repair procedures and materials used shall be documented on the Self-Monitoring Report Form (SMRF) submitted quarterly to the ADEQ Water Quality Compliance. If none of the conditions occur, the report shall say "no event" for a particular reporting period. If the facility is not in operation, the permittee shall indicate that fact in the SMRF.

- b. The permittee shall submit data required in Section 4.0, Table III regardless of the operating status of the facility unless otherwise approved by the Department or allowed in this permit.

2.5.3 Groundwater Monitoring and Sampling Protocols

The permittee shall conduct routine groundwater monitoring according to Section 4.0, Table II. The permittee shall conduct ambient groundwater monitoring as per Table IIA.

Static water levels shall be measured and recorded prior to sampling. Wells shall be purged of at least three borehole volumes (as calculated using the static water level) or until indicator parameters (pH, temperature, conductivity) are stable, whichever represents the greater volume. If evacuation results in the well going dry, the well shall be allowed to recover to 80% of the original borehole volume, or for 24 hours, whichever is shorter, prior to sampling. If after 24 hours there is not sufficient water for sampling, the well shall be recorded as "dry" for the monitoring event. An explanation for reduced pumping volumes, a record of the volume pumped, and modified sampling procedures shall be reported and submitted with the Self-Monitoring Report Form (SMRF).

2.5.4 Surface Water Monitoring and Sampling Protocols

Routine surface water monitoring is not required under the terms of this permit.

2.5.5 Analytical Methodology

All samples collected for compliance monitoring shall be analyzed using Arizona state approved methods. If no state approved method exists, then any appropriate EPA approved method shall be used. Regardless of the method used, the detection limits must be sufficient to determine compliance with the regulatory limits of the parameters specified in this permit. Analyses shall be performed by a laboratory licensed by the Arizona Department of Health Services, Office of Laboratory Licensure and Certification. For results to be considered valid, all analytical work shall meet quality control standards specified in the approved methods. A list of Arizona state certified laboratories can be obtained at the address below:

Arizona Department of Health Services
Office of Laboratory Licensure and Certification
1740 W. Adams Street, Room 203 North
Phoenix, AZ 85007
Phone: (602) 364-0720

2.5.6 Installation and Maintenance of Monitoring Equipment

Monitoring equipment required by this permit shall be installed and maintained so that representative samples required by the permit can be collected. If new groundwater wells are determined to be necessary, the construction details shall be submitted to the ADEQ Water Permits Section for approval prior to installation and the permit shall be amended to include any new points.

2.6 Contingency Plan Requirements

[A.R.S. § 49-243(K)(3), (K)(7) and A.A.C. R18-9-A204 and R18-9-A205]

2.6.1 General Contingency Plan Considerations

At least one copy of the approved contingency and emergency response plan(s) submitted in the application shall be maintained at the location where day-to-day decisions regarding the operation of the facility are made. The permittee shall be aware of and follow the contingency and emergency plans.

Any alert level (AL) that is exceeded or any violation of an aquifer quality limit (AQL), discharge limit (DL), or other permit condition shall be reported to ADEQ following the reporting requirements in Section 2.7.3.

Some contingency actions involve verification sampling. Verification sampling shall consist of the first follow-up sample collected from a location that previously indicated a violation or the exceedance of an AL. Collection and analysis of the verification sample shall use the same protocols and test methods to analyze for the pollutant or pollutants that exceeded an AL or violated an AQL. The permittee is subject to enforcement action for the failure to comply with any contingency actions in this permit. Where verification sampling is specified in this permit, it is the option of the permittee to perform such sampling. If verification sampling is not conducted within the timeframe allotted, ADEQ and the permittee shall presume the initial sampling result to be confirmed as if verification sampling has been conducted. The permittee is responsible for compliance with contingency plans relating to the exceedance of an AL or violation of a DL, AQL or any other permit condition.

2.6.2 Exceeding of Alert Levels/Performance Levels

2.6.2.1 Exceeding of Performance Levels (PL) Set for Operational Conditions

1. If the operational PL set in Section 4.0, TABLE III has been exceeded (permit condition violated) the permittee shall:
 - a. Notify the ADEQ Water Quality Compliance Section within five (5) days of becoming aware of a violation of any permit condition.
 - b. Submit a written report within thirty (30) days after becoming aware of a violation of a permit condition. The report shall document all of the following:
 1. A description of the violation and its cause;
 2. the period of violation, including exact date(s) and time(s), if known, and the anticipated time period during which the violation is expected to continue;
 3. any action taken or planned to mitigate the effects or the violation, or the spill, or to eliminate or prevent recurrence of the violation;
 4. any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an Aquifer Water Quality Standard; and
 5. any malfunction or failure of pollution control devices or other equipment or process.
2. The facility is no longer on alert status once the operational indicator no longer indicates that an PL is being exceeded. The permittee shall, however, complete all tasks necessary to return the facility to its pre-alert operating condition.

2.6.2.2 Exceeding of Alert Levels Set for Discharge Monitoring

1. If an AL set in Section 4.3, TABLE I has been exceeded, the permittee shall immediately investigate to determine the cause of the AL being exceeded. The investigation shall include the following:
 - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant discharge control systems that may have contributed to the AL being exceeded.
 - b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences;
2. The permittee shall initiate actions identified in the approved contingency plan referenced in Section 5.0 and specific contingency measures identified in Section 2.6 to resolve any problems identified by the investigation which may have led to an AL being exceeded. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6.
3. Within thirty (30) days after confirmation of an AL being exceeded, the permittee shall submit the laboratory results to the ADEQ Water Quality Compliance Section, Data Unit, along with a summary of the findings of the investigation, the cause of the AL being exceeded, and actions taken to resolve the problem.
4. Upon review of the submitted report, the Department may require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

2.6.2.3 Exceeding of Alert Levels in Groundwater Monitoring**2.6.2.3.1 Alert Levels for Indicator Parameters**

Not required at time of permit issuance.

2.6.2.3.2 Alert Levels for Pollutants with Numeric Aquifer Water Quality Standards

1. If an AL for a pollutant set in Section 4.0, TABLE II has been exceeded, the permittee may conduct verification sampling within 5 days of becoming aware of an AL being exceeded.
2. If verification sampling confirms the AL being exceeded or if the permittee opts not to perform verification sampling, then the permittee shall increase the frequency of monitoring to Daily', 'Weekly', and 'Monthly' for constituents that have a permit monitoring frequency of 'Weekly', 'Monthly', and 'Quarterly', 'Semi-Annual' or 'Annual' respectively. In addition, the permittee shall immediately initiate an investigation of the cause of the AL being exceeded, including inspection of all discharging units and all related pollution control devices, review of any operational and maintenance practices that might have resulted in an unexpected discharge, and hydrologic review of groundwater conditions including upgradient water quality.
3. The permittee shall initiate actions identified in the approved contingency plan referenced in Part 5.0 and specific contingency

measures identified in Part 2.6 to resolve any problems identified by the investigation which may have led to an AL being exceeded. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6. Alternatively, the permittee may submit a technical demonstration, subject to written approval by the Water Permits Section, that although an AL is exceeded, pollutants are not reasonably expected to cause a violation of an AQL. The demonstration may propose a revised AL or monitoring frequency for approval in writing by the Water Permits Section.

4. Within thirty (30) days after confirmation of an AL being exceeded, the permittee shall submit the laboratory results to the Water Quality Compliance Section, Data Unit along with a summary of the findings of the investigation, the cause of the AL being exceeded, and actions taken to resolve the problem.
5. Upon review of the submitted report, the Department may require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.
6. The increased monitoring required as a result of ALs being exceeded may be reduced to 4.0, TABLE I frequencies, if the results of four sequential sampling events demonstrate that no parameters exceed the AL.

2.6.2.3.3 Alert Levels to Protect Downgradient Users from Pollutants Without Numeric Aquifer Water Quality Standards

Not required at time of issuance.

2.6.3 Discharge Limitations (DL) Violations

1. If a DL set in Section 4.0, Table I and IA has been violated, the permittee shall immediately investigate to determine the cause of the violation. The investigation shall include the following:
 - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant discharge control systems that may have contributed to the violation;
 - b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences;
 - c. Sampling of individual waste streams composing the wastewater for the parameters in violation.

The permittee also shall submit a report according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. The permittee shall consider and ADEQ may require corrective action that may include control of the source of discharge, cleanup of affected soil, surface water or groundwater, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ approved contingency plan, or separately approved according to Section 2.6.6.

2. Upon review of the submitted report, the Department may require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

2.6.4 Aquifer Quality Limit (AQL) Violation

1. If an AQL set in Section 4.0, TABLE II has been exceeded, the permittee may conduct verification sampling within 5 days of becoming aware of an AQL being exceeded.
2. If verification sampling confirms that the AQL is violated for any parameter or if the permittee opts not to perform verification sampling, then, the permittee shall increase the frequency of monitoring to 'Daily', 'Weekly', and 'Monthly' for constituents that have a permit monitoring frequency of 'Weekly', 'Monthly', and 'Quarterly', 'Semi-Annual' or 'Annual' respectively. In addition, the permittee shall immediately initiate an evaluation for the cause of the violation, including inspection of all discharging units and all related pollution control devices, and review of any operational and maintenance practices that might have resulted in unexpected discharge.

The permittee also shall submit a report according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. The permittee shall consider and ADEQ may require corrective action that may include control of the source of discharge, cleanup of affected soil, surface water or groundwater, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ approved contingency plan, or separately approved according to Section 2.6.6.

3. Upon review of the submitted report, the Department may require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

2.6.5 Emergency Response and Contingency Requirements for Spills and Unauthorized Discharges

2.6.5.1 Duty to Respond

The permittee shall act immediately to correct any condition resulting from a discharge if that condition could pose an imminent and substantial endangerment to public health or the environment.

2.6.5.2 Discharge of Hazardous Substances or Spills of Toxic Pollutants

In the event of any unauthorized discharge (A.R.S. § 49-201(12)) of suspected hazardous substances (A.R.S. § 49-201(18)) or any spills of toxic pollutants (A.R.S. § 49-243(I)) on the facility site, the permittee shall promptly isolate the area and attempt to identify the spilled material. The permittee shall record information, including name, nature of exposure and follow-up medical treatment, if necessary, on persons who may have been exposed during the incident. Spilled materials, absorbents, and contaminated media generated during emergency response shall be removed and disposed of according to applicable federal, state and local regulations. The permittee shall notify the ADEQ Water Quality Field Service Unit at (602) 771-4841 within 24-hours upon discovering the discharge of hazardous material which: a) has the potential to cause an AWQS or AQL to be exceeded; or b) could pose an endangerment to public health or the environment.

2.6.5.3 Discharge of Non-hazardous Materials

In the event of any unauthorized discharge of non-hazardous materials from the facility, the permittee shall promptly attempt to cease the discharge and isolate the discharged material. Discharged material shall be removed and the site cleaned up as soon as possible. The permittee shall notify the ADEQ Water Quality Field Services Unit at (602) 771-4841, within 24-hours upon discovering the discharge of non-hazardous

material which: a) has the potential to cause an AQL to be exceeded; or b) could pose an endangerment to public health or the environment.

2.6.5.4 Reporting Requirements

The permittee shall submit a written report for any unauthorized discharges described in Sections 2.6.5.2 and 2.6.5.3 to ADEQ Water Quality Field Services Unit, Mail Code: 5415B-1, 1110 West Washington Street, Phoenix, AZ, within thirty days of the discharge or as required by subsequent ADEQ action. The report shall summarize the event, including any human exposure, and facility response activities and include all information specified in Section 2.7.3. If a notice is issued by ADEQ subsequent to the discharge notification, any additional information requested in the notice shall also be submitted within the time frame specified in that notice. Upon review of the submitted report, ADEQ may require additional monitoring or corrective actions.

2.6.6 Corrective Actions

Specific contingency measures identified in Part 2.6 have already been approved by ADEQ and do not require written approval to implement.

With the exception of emergency response actions taken under Section 2.6.5, the permittee shall obtain written approval from the Water Permits Section prior to implementing a corrective action to accomplish any of the following goals in response to exceeding an AL or violation of an AQL, DL, or other permit condition:

1. Control of the source of an unauthorized discharge;
2. Soil cleanup;
3. Cleanup of affected surface waters;
4. Cleanup of affected parts of the aquifer;
5. Mitigation to limit the impact of pollutants on existing uses of the aquifer.

Within 30 days of completion of any corrective action, the operator shall submit to the ADEQ Water Quality Compliance Section, a written report describing the causes, impacts, and actions taken to resolve the problem.

2.7 Reporting and Recordkeeping Requirements

[A.R.S. § 49-243(K)(2) and A.A.C. R18-9-A206(B) and R18-9-A207]

2.7.1 Self Monitoring Report Forms (SMRF)

1. The permittee shall complete the SMRFs provided by ADEQ, and submit them to the Water Quality Compliance Section, Data Unit.
2. The permittee shall complete the SMRF to the extent that the information reported may be entered on the form. If no information is required during a quarter, the permittee shall enter "not required" on the SMRF and submit the report to ADEQ. The permittee shall use the format devised by ADEQ.
3. The tables contained in Sections 4.0 list the parameters to be monitored and the frequency for reporting results for groundwater compliance monitoring. Monitoring methods shall be recorded on the SMRFs.

4. In addition to the SMRF, the information contained in Section 6.9.3 shall be included for exceeding an AL or violation of an AQL, DL, or any other permit condition being reported in the current reporting period.

2.7.2 Operation Inspection / Log Book Recordkeeping

A signed copy of this permit shall be maintained at all times at the location where day-to-day decisions regarding the operation of the facility are made. A log book (paper copies, forms or electronic data) of the inspections and measurements required by this permit shall be maintained at the location where day-to-day decisions are made regarding the operation of the facility. The log book shall be retained for ten years from the date of each inspection, and upon request, the permit and the log book shall be made immediately available for review by ADEQ personnel. The information in the log book shall include, but not be limited to, the following information as applicable:

1. Name of inspector;
2. Date and shift inspection was conducted;
3. Condition of applicable facility components;
4. Any damage or malfunction, and the date and time any repairs were performed;
5. Documentation of sampling date and time;
6. Any other information required by this permit to be entered in the log book, and
7. Monitoring records for each measurement shall comply with R18-9 A206(B)(2).

2.7.3 Permit Violation and Alert Level Status Reporting

1. The permittee shall notify the Water Quality Compliance Section, Enforcement Unit in writing within five days (except as provided in Section 2.6.5) of becoming aware of a violation of any permit condition, discharge limitation or of an Alert Level being exceeded.
2. The permittee shall submit a written report to the Water Quality Compliance Section, Enforcement Unit within 30 days of becoming aware of the violation of any permit condition or discharge limitation. The report shall document all of the following:
 - a. Identification and description of the permit condition for which there has been a violation and a description of its cause.
 - b. The period of violation including exact date(s) and time(s), if known, and the anticipated time period during which the violation is expected to continue.
 - c. Any corrective action taken or planned to mitigate the effects of the violation, or to eliminate or prevent a recurrence of the violation.
 - d. Any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an Aquifer Water Quality Standard.
 - e. Proposed changes to the monitoring which include changes in constituents or increased frequency of monitoring.
 - f. Description of any malfunction or failure of pollution control devices or other equipment or processes.

2.7.4 Operational, Other or Miscellaneous Reporting

The permittee shall complete the Self-Monitoring Report Form provided by the Department to reflect facility inspection requirements designated in Section 4.0, TABLE III and submit to the ADEQ, Water Quality Compliance quarterly along with other reports required by this permit.

Facility inspection reports shall be submitted no less frequently than quarterly, regardless of operational status.

The permittee shall submit the results of water quality testing for total nitrogen, fecal coliform, turbidity and flow volumes to any of the following in accordance with A.A.C. R18-9-703(C)(2)(c):

1. Any reclaimed water agent who has contracted for delivery of reclaimed water from the permittee;
2. Any end user who has not waived interest in receiving this information

2.7.5 Reporting Location

All SMRFs shall be submitted to:

Arizona Department of Environmental Quality
 Water Quality Compliance Section, Data Unit
 Mail Code: 5415B-1
 1110 W. Washington Street
 Phoenix, AZ 85007
 Phone (602) 771-4681

All documents required by this permit to be submitted to the Water Quality Compliance Section shall be directed to:

Water Quality Compliance Section, Enforcement Unit
 Mail Code: 5415B-1
 1110 W. Washington Street
 Phoenix, AZ 85007
 Phone (602) 771-4614

All documents required by this permit to be submitted to the Water Permits Section shall be directed to:

Arizona Department of Environmental Quality
 Water Permits Section
 Mail Code: 5415B-3
 1110 W. Washington Street
 Phoenix, AZ 85007
 Phone (602) 771-4428

2.7.6 Reporting Deadline

The following table lists the quarterly report due dates:

Monitoring conducted during quarter:	Quarterly Report due by:
January-March	April 30
April-June	July 30
July-September	October 30
October-December	January 30

2.7.7 Changes to Facility Information in Section 1.0

The Water Permits Section and Water Quality Compliance Section shall be notified within 10 days of any change of facility information including Facility Name, Permittee Name, Mailing or Street Address, Facility Contact Person or Emergency Telephone Number.

2.8 Temporary Cessation [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A209(A)]

The permittee shall give written notice to the Water Quality Compliance Section upon ceasing operation of the facility for a period of 60 days or greater. The permittee shall take the following measures upon temporary cessation:

1. If applicable, direct the wastewater flows from the facility to another State approved wastewater treatment facility.
2. Correct the problem that caused the temporary cessation of the facility.
3. Notify ADEQ with a monthly facility Status Report describing the activities conducted on the WWTP to correct the problem

At the time of notification the permittee shall submit for ADEQ approval a plan for maintenance of discharge control systems and for monitoring during the period of temporary cessation. Immediately following ADEQ's approval, the permittee shall implement the approved plan. If necessary, ADEQ shall amend permit conditions to incorporate conditions to address temporary cessation. If the facility ceases operation, the permittee shall submit closure notification, as set forth in Section 2.9 below.

2.9 Closure [A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9-A209(B)]

The permittee shall give written notice of closure to the Water Quality Compliance Section before closing, or before ceasing use of a facility addressed under this permit if the cessation is projected to last more than three years

2.9.1 Closure Plan

Within 90 days following notification of closure, the permittee shall submit for approval to the Water Permits Section, a detailed Closure Plan which meets the requirements of A.R.S. § 49-252 and A.A.C. R18-9-A209(B)(1)(a).

If the closure plan achieves clean closure immediately, ADEQ shall issue a letter of approval to the permittee. If the closure plan contains a schedule for bringing the facility to a clean closure configuration at a future date, ADEQ may incorporate any part of the schedule as an amendment to this permit.

2.9.2 Closure Completion

Upon completion of closure activities, the permittee shall give written notice to the Water Permits Section indicating that the approved Closure Plan has been implemented fully and providing supporting documentation to demonstrate that clean closure has been achieved (soil sample results, verification sampling results, groundwater data, as applicable). If clean closure has been achieved, ADEQ shall issue a letter of approval to the permittee at that time. If any of the following conditions apply, the permittee shall follow the terms of Post Closure stated in this permit:

1. Clean closure cannot be achieved at the time of closure notification or within one year thereafter under a diligent schedule of closure actions;

2. Further action is necessary to keep the facility in compliance with aquifer water quality standards at the applicable point of compliance;
3. Continued action is required to verify that the closure design has eliminated discharge to the extent intended;
4. Remedial or mitigative measures are necessary to achieve compliance with Title 49, Ch. 2;
5. Further action is necessary to meet property use restrictions.

2.10 Post-Closure [A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9 A209(C)]

Post-closure requirements shall be established based on a review of facility closure actions and will be subject to review and approval by the Water Permits Section.

In the event clean closure cannot be achieved pursuant to A.R.S. § 49-252, the permittee shall submit for approval to the Water Permits Section a Post-Closure Plan that addresses post-closure maintenance and monitoring actions at the facility. The Post-Closure Plan shall meet all requirements of A.R.S. §§ 49-201(29) and 49-252 and A.A.C. R18-9-A209(C). Upon approval of the Post-Closure Plan, this permit shall be amended or a new permit shall be issued to incorporate all post-closure controls and monitoring activities of the Post-Closure Plan.

2.10.1 Post-Closure Plan

A specific post closure plan may be required upon the review of the closure plan.

2.10.2 Post-Closure Completion

Not required at the time of permit issuance.

3.0 COMPLIANCE SCHEDULE [A.R.S. § 49-243(K)(5) and A.A.C. R18-9-A208]

The POC monitor well shall be installed no later than 30 days of operation of the WRP and shall be constructed according to the well design and location submitted with the application. A total of eight monthly samples shall be taken for each constituent according to Table IIA. After eight samples are taken, monitoring according to Table IIA shall cease. Wastewater recharge shall not be initiated until all eight samples have been taken. Within 45 days of the last sample event, the permittee shall apply for an amendment to this permit and submit an Ambient Groundwater Monitoring Report with proposed values for Alert Levels and Aquifer Quality Limits based on statistical analysis of the 8 rounds of ambient data (Section 2.5). This data will be used to place limits in Table II of this permit. The amendment application shall include methods and calculations for determining the alert levels and groundwater quality limits. The proposed numeric levels shall be subject to approval by the Wastewater, Recharge & Reuse Unit.

Within 30 days of the construction of the monitor well and ASR wells, the permittee shall submit a final design drawing of the completed wells, as well as the well drillers log of each well, and a site map with location of each completed well.

4.0 TABLES OF MONITORING REQUIREMENTS

TABLE I
DISCHARGE MONITORING¹

Sampling Point Number	Identification	Latitude	Longitude
1	Effluent Pump Station	32° 57' 45" N	112° 01' 41" W

Parameter	AL	DL ² ,	Units	Sampling Frequency	Reporting Frequency
-----------	----	-------------------	-------	--------------------	---------------------

Total Flow: Daily	NE ³	NE	MGD ⁴	Daily ⁵	Quarterly
Total Flow: Average monthly yearly flow	1.3 MGD	1.4 ⁶	MGD	Monthly ⁷	Quarterly
Fecal Coliform (single sample maximum)	NA	23	CFU ⁸ or MPN ⁹	Monthly	Quarterly
Fecal Coliform (Seven sample median)	NA	2.2	CFU or MPN	Monthly	Quarterly
Total Nitrogen (5 month rolling geometric mean)	8.0	10.0	mg/l	Monthly	Quarterly

Metals:

Antimony	0.0048	0.006	mg/l	Quarterly	Quarterly
Arsenic	0.04	0.05	mg/l	Quarterly	Quarterly
Barium	1.60	2.00	mg/l	Quarterly	Quarterly
Beryllium	0.0032	0.004	mg/l	Quarterly	Quarterly
Cadmium	0.004	0.005	mg/l	Quarterly	Quarterly
Chromium	0.08	0.1	mg/l	Quarterly	Quarterly
Cyanide (As free cyanide)	0.16	0.2	mg/l	Quarterly	Quarterly
Fluoride	3.2	4.0	mg/l	Quarterly	Quarterly
Lead	0.04	0.05	mg/l	Quarterly	Quarterly
Mercury	0.0016	0.002	mg/l	Quarterly	Quarterly
Nickel	0.08	0.1	mg/l	Quarterly	Quarterly
Selenium	0.04	0.05	mg/l	Quarterly	Quarterly
Thallium	0.0016	0.002	mg/l	Quarterly	Quarterly

¹ Monitoring for all types of discharges shall be conducted as per this table. If effluent is discharged to reuse sites then additional monitoring shall be conducted as per Table IA.

² All Discharge Limits in this table are listed in mg/l except flow, which is in million gallons per day (MGD).

³ NE means not established

⁴ Million gallons per day.

⁵ Flow shall be measured using a continuous recording flow meter.

⁶ This discharge limit represents the total flow generated by the WWTP.

⁷ Calculated on an annual average flow based on monthly average

⁸ CFU means colony forming units.

⁹ MPN means most probable number

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Volatile Organic Compounds (VOCs):					
Benzene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	0.48	0.6	mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	0.06	0.075	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	0.0056	0.007	mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	0.05	0.07	mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Dichloromethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Ethylbenzene	0.56	0.7	mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Styrene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Toluene	0.8	1.0	mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) ¹⁰	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	0.16	0.2	mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	0.0016	0.002	mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	8.0	10.0	mg/l	Semi-Annually	Semi-Annually

¹⁰ Total Trihalomethanes comprises of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

TABLE IA¹¹
RECLAIMED WATER MONITORING - CLASS B+¹²

Sampling Point Number	Sampling Point Identification	Latitude	Longitude
1	Discharge Line to Reclaimed Water Sites	33° 21' 40"N	111° 33' 30"W

Parameter	DL	Units	Sampling Frequency	Reporting Frequency
Flow: Daily	Reserved	MGD ¹³	Everyday ¹⁴	Quarterly
Flow: Total monthly flow provided for reuse	Reserved	MGD	Monthly Calculation	Quarterly
Total Nitrogen ¹⁵ : Five-sample rolling geometric mean	10.0	mg/l	Monthly	Quarterly
Fecal Coliform: Single-sample maximum	800	CFU or MPN ¹⁶	Daily ¹⁷	Quarterly
Fecal Coliform: Four (4) of last seven (7) samples	200 ¹⁸	CFU or MPN	Daily	Quarterly

¹¹ The monitoring requirements in this table shall apply only when effluent is transferred to a facility that is operating under a general or individual reclaimed water permit.

¹² Reclaimed water monitoring is in addition to routine discharge monitoring.

¹³ Million Gallons per Day

¹⁴ Flow rate shall be measured using a continuously recording flow meter.

¹⁵ Nitrate N, plus Nitrite N, plus Total Kjeldahl Nitrogen (TKN)

¹⁶ CFU = Colony Forming Units per 100 ml: MPN = Most Probable Number per 100 ml.

¹⁷ For fecal coliform, "daily" sampling means every day in which a sample can practicably be obtained and delivered in sufficient time for proper analysis, provided that no less than four (4) samples in each calendar week are obtained and analyzed.

¹⁸ If at least four (4) of the last seven (7) samples are equal to or less than 200 CFU or MPN per 100 ml, report "yes" in the appropriate space on the SMRF (indicating that the standard has been met). If at least four (4) of the last seven (7) samples are greater than 200 CFU or MPN per 100 ml, report "no" in the appropriate space on the SMRF (indicating that the standard has **not** been met).

**TABLE II
ROUTINE GROUNDWATER MONITORING**

Sampling Point Number	Sampling Point Identification	Latitude	Longitude		
1	North West Side of Recharge Basin #1	32° 57' 49"N	112° 01' 49"W		
Parameter	AL ¹⁹	AQL ²⁰	Units	Sampling Frequency	Reporting Frequency
Nitrate as N	Reserved	Reserved	mg/l	Monthly	Quarterly
Nitrate-Nitrite as N	Reserved	Reserved	mg/l	Monthly	Quarterly
Nitrite	Reserved	Reserved	mg/l	Monthly	Quarterly
Total Coliform	Reserved	Absent ²¹	CFU or MPN ²²	Monthly	Quarterly

Parameter	AL	AQL	Units	Sampling Frequency	Reporting Frequency
Metals (Total):					
Antimony	Reserved	Reserved	mg/l	Quarterly	Quarterly
Arsenic	Reserved	Reserved	mg/l	Quarterly	Quarterly
Barium	Reserved	Reserved	mg/l	Quarterly	Quarterly
Beryllium	Reserved	Reserved	mg/l	Quarterly	Quarterly
Cadmium	Reserved	Reserved	mg/l	Quarterly	Quarterly
Chromium	Reserved	Reserved	mg/l	Quarterly	Quarterly
Cyanide (As free cyanide)	Reserved	Reserved	mg/l	Quarterly	Quarterly
Fluoride	Reserved	Reserved	mg/l	Quarterly	Quarterly
Lead	Reserved	Reserved	mg/l	Quarterly	Quarterly
Mercury	Reserved	Reserved	mg/l	Quarterly	Quarterly
Nickel	Reserved	Reserved	mg/l	Quarterly	Quarterly
Selenium	Reserved	Reserved	mg/l	Quarterly	Quarterly
Thallium	Reserved	Reserved	mg/l	Quarterly	Quarterly

Parameter	AL	AQL	Units	Sampling Frequency	Reporting Frequency
Volatile Organic Compounds (VOCs):					
Benzene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	0.48	0.6	mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	0.06	0.075	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	0.0056	0.007	mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	0.05	0.07	mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Dichloromethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually

¹⁹ AL = Alert Level

²⁰ AQL = Aquifer Quality Limit

²¹ A positive result for total coliform may be verified with an analysis for fecal coliform. A positive result for fecal coliform shall be considered an exceedance of the AQL for total coliform.

²² CFU = Colony Forming Units per 100 ml, MPN = Most Probable Number per 100 ml.

Ethylbenzene	0.56	0.7	mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Styrene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Toluene	0.8	1.0	mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) ²³	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	0.16	0.2	mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	0.0016	0.002	mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	8.0	10.0	mg/l	Semi-Annually	Semi-Annually

²³Total Trihalomethanes comprises of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

**TABLE IIA
AMBIENT GROUNDWATER MONITORING**

Sampling Point Number	Identification	Latitude	Longitude
1	North West Side of Recharge Basin #1	32° 57' 49"N	112° 01' 49"W

Parameter	Units	Sampling Frequency	Reporting Frequency
-----------	-------	--------------------	---------------------

Total Coliform	CFU/100ml or MPN/100ml	Monthly	Monthly
Fecal Coliform	CFU/100ml or MPN/100ml	Monthly	Monthly

Nitrate as N	mg/l	Monthly	Monthly
Nitrate and nitrite (as N)	mg/l	Monthly	Monthly
Nitrite as N	mg/l	Monthly	Monthly

Major Cations & Anions:

pH (field)	S.U.	Monthly	Monthly
Iron	mg/l	Monthly	Monthly
Manganese	mg/l	Monthly	Monthly
Total Organic Carbon	mg/l	Monthly	Monthly
Total Dissolved Solids	mg/l	Monthly	Monthly
Sodium	mg/l	Monthly	Monthly
Potassium	mg/l	Monthly	Monthly
Calcium	mg/l	Monthly	Monthly
Magnesium	mg/l	Monthly	Monthly
Chloride	mg/l	Monthly	Monthly
Sulfate	mg/l	Monthly	Monthly
Bicarbonate	mg/l	Monthly	Monthly
Specific Conductance(field)	umhos/cm	Monthly	Monthly

Metals (Total):

Antimony	mg/l	Quarterly	Quarterly
Arsenic	mg/l	Quarterly	Quarterly
Barium	mg/l	Quarterly	Quarterly
Beryllium	mg/l	Quarterly	Quarterly
Cadmium	mg/l	Quarterly	Quarterly
Chromium	mg/l	Quarterly	Quarterly
Cyanide (As free cyanide)	mg/l	Quarterly	Quarterly
Fluoride	mg/l	Quarterly	Quarterly
Lead	mg/l	Quarterly	Quarterly
Mercury	mg/l	Quarterly	Quarterly

Selenium	mg/l	Quarterly	Quarterly
Thallium	mg/l	Quarterly	Quarterly

Volatile Organic Compounds (VOCs):

Parameter	Units	Sampling Frequency	Reporting Frequency
Benzene	mg/l	Monthly	Monthly
Carbon tetrachloride	mg/l	Monthly	Monthly
o-Dichlorobenzene	mg/l	Monthly	Monthly
para-Dichlorobenzene	mg/l	Monthly	Monthly
1,2-Dichloroethane	mg/l	Monthly	Monthly
1,1-Dichloroethylene	mg/l	Monthly	Monthly
cis-1,2-Dichloroethylene	mg/l	Monthly	Monthly
trans-1,2-Dichloroethylene	mg/l	Monthly	Monthly
1,2-Dichloropropane	mg/l	Monthly	Monthly
Dichloromethane	mg/l	Monthly	Monthly
Ethylbenzene	mg/l	Monthly	Monthly
Monochlorobenzene	mg/l	Monthly	Monthly
2,3,7,8-TCDD (Dioxin)	mg/l	Monthly	Monthly
Styrene	mg/l	Monthly	Monthly
Tetrachloroethylene	mg/l	Monthly	Monthly
Toluene	mg/l	Monthly	Monthly
Trihalomethanes (total)	mg/l	Monthly	Monthly
1,1,1-Trichloroethane	mg/l	Monthly	Monthly
1,1,2-Trichloroethane	mg/l	Monthly	Monthly
Trichloroethylene	mg/l	Monthly	Monthly
Vinyl Chloride	mg/l	Monthly	Monthly
Xylenes (Total)	mg/l	Monthly	Monthly

TABLE III
FACILITY INSPECTION (OPERATIONAL MONITORING)

Parameter	Performance Levels	Inspection Frequency
Berm Integrity	No Visible Erosion	Monthly
Pump Integrity	Good Working Condition	Weekly
WWTP Components	Good Working Condition	Weekly
ASR Wells	Good Working Condition	Weekly

5.0 REFERENCES AND PERTINENT INFORMATION

The terms and conditions set forth in this permit have been developed based upon the information contained in the following, which are on file with the Department:

1. APP Application dated: January 10 2003
2. Contingency Plan, dated: January 10, 2003
3. Final Hydrologist Report dated: December 29, 2004
4. Final Engineering Report dated: June 12, 2003
2. Public Notice, dated: February 1, 2005
3. Public Hearing, dated: Not Applicable
4. Responsiveness Summary dated: Not Applicable

6.0 GENERAL CONDITIONS AND RESPONSIBILITIES

6.1 Annual Registration Fees

The permittee is notified of the obligation to pay an Annual Registration Fee to ADEQ. The Annual Registration Fee is based upon the amount of daily influent or discharge of pollutants in gallons per day as established by A.R.S. § 49-242(D). This fee is payable to ADEQ each year. The design flow is 1.4 mgd.

6.2 Duty to Comply [A.R.S. §§ 49-221 through 263]

The permittee is notified of the obligation to comply with all conditions of this permit and all applicable provisions of Title 49, Chapter 2, Articles 1, 2 and 3 of the Arizona Revised Statutes, Title 18, Chapter 9, Articles 1 through 4, and Title 18, Chapter 11, Article 4 of the Arizona Administrative Code. Any permit non-compliance constitutes a violation and is grounds for an enforcement action pursuant to Title 49, Chapter 2, Article 4 or permit amendment, suspension, or revocation.

6.3 Duty to Provide Information [A.R.S. §§ 49-243(K)(2) and 49-243(K)(8)]

The permittee shall furnish to the Director, or an authorized representative, within a time specified, any information which the Director may request to determine whether cause exists for amending or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

6.4 Severability [A.R.S. § 49-243(K)(8)]

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

6.5 Proper Operation and Maintenance [A.R.S. § 49-243(K)(8)]

The permittee shall properly operate and maintain all facilities, treatment processes, and discharge control systems which are installed or used by the permittee to achieve compliance with the terms and conditions of this permit.

6.6 Compliance with Aquifer Water Quality Standards [A.R.S. §§ 49-243(B)(2) and 49-243(B)(3)]

The permittee shall not cause or contribute to a violation of an aquifer water quality standard at the applicable point of compliance for the facility. Where, at the time of issuance of the permit, an aquifer already exceeds an aquifer water quality standard for a pollutant, the permittee shall not discharge that pollutant so as to further degrade, at the applicable point of compliance for the facility, the water quality of any aquifer for that pollutant.

6.7 Technical and Financial Capability [A.R.S. §§ 49-243(K)(8) and 49-243(N) and A.A.C. R18-9-A202(B) and R18-9-A203(E) and (F)]

The permittee shall have and maintain the technical and financial capability necessary to fully carry out the terms and conditions of this permit. Any bond, insurance policy, trust fund, or other financial assurance mechanism provided as a demonstration of financial capability in the permit application, pursuant to A.A.C. R18-9-A203(D), shall be in effect prior to any discharge authorized by this permit and shall remain in effect for the duration of the permit.

6.8 Reporting of Bankruptcy or Environmental Enforcement [A.A.C. R18-9-A207(C)]

The permittee shall notify the Director within five days after the occurrence of any one of the following:

1. The filing of bankruptcy by the permittee.
2. The entry of any order or judgment not issued by the Director against the permittee for the enforcement of any environmental protection statute or rule.

6.9 Monitoring and Records [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A206]

The permittee shall conduct any monitoring activity necessary to assure compliance with this permit, with the applicable water quality standards established pursuant to A.R.S. §§ 49-221 and 49-223 and §§ 49-241 through 49-252.

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. The permittee shall retain records of all monitoring information, including copies of all reports required by this permit and records of all data used to complete the application for this permit, for a period of 10 years from the date of the sample, measurement report, or application. This period may be extended by request of the Director at any time.
3. At a minimum, records of monitoring information shall include:
 - a. Date, time, and exact place of sampling or measurements;
 - b. Individual(s) who performed the sampling or measurements;
 - c. Date(s) analyses were performed;
 - d. Individual(s) or laboratory who performed the analyses;
 - e. Analytical techniques or methods used;
 - f. Results of such analyses;
 - g. Chain of custody records;
 - h. Names of samples;
 - i. Static water level in monitor well prior to sampling;
 - j. Sampling method;
 - k. Purging volume;
 - l. Indicator parameters including field conductance ($\mu\text{mhos/cm}$), field temperature ($^{\circ}\text{C}$), and field pH (standard units);
 - m. Preservation and transportation procedures;
 - n. Name of the analytical facility, and;
 - o. Any field notes relating to the information described in (a) – (n) above.

6.10 Other Information [A.R.S. § 49-243(K)(8)]

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, the permittee shall promptly submit the correct facts or information.

6.11 Inspection and Entry [A.R.S. §§ 49-203(B) and 49-243(K)(8)]

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to enter and inspect the facility as reasonably necessary to ensure compliance with Title 49, Chapter 2, Article 3 of the Arizona Revised

Statutes, and Title 18, Chapter 9, Articles 1 through 4 of the Arizona Administrative Code and the terms and conditions of this permit. In so doing, the Department representative may:

1. Enter upon the operator's premises where a regulated facility or activity is located or conducted, or locations where records must be kept under the conditions of this permit.
2. Have access to and copy, at reasonable times, any records required to be kept under the conditions of this permit.
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
4. Sample or monitor at reasonable times, for the purposes of assuring permit compliance, any substances or parameters at any location.
5. Take photographs or video tape.
6. Take other actions reasonably necessary to determine compliance with Aquifer Protection Permit statutes or rules or the terms and conditions of this permit.

6.12 Duty to Modify [A.R.S. § 49-243(K)(8)]

The permittee shall apply for and receive a written amendment before deviating from any of the designs or operational practices authorized by this permit.

6.13 Permit Action: Amendment, Transfer, Suspension & Revocation [A.R.S. §§ 49-201, 49-241 through 251, A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213]

This permit may be amended, transferred, renewed, or revoked for cause, under the rules of the Department. The filing of a request by the permittee for a permit action does not stay or suspend the effectiveness of any existing permit condition. The Director shall issue a public notice of all proposed permit actions pursuant to A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213.

6.13.1 Permit Reopen

The Director may reopen this permit and amend it pursuant to A.A.C. R18-9-A211.

6.13.2 Permit Transfer

This permit may not be transferred to any other person except after notice to and approval of the transfer by the Department. No transfer will be approved until the applicant complies with all transfer requirements as specified in A.A.C. R18-9-A212(B) and (C).

The permittee shall notify the Water Permits Section in writing within 15 days after any change in the owner or operator of the facility. The notification shall state the permit number, the name of the facility, the date of property transfer, and the name, address, and phone number where the new owner or operator can be reached. The operator shall advise the new owner or operators of the terms of this permit and the need for permit transfer in accordance with the rules.