

ORIGINAL

NEW APPLICATION



0000020410

Brooke Utilities, Inc.

P. O. Box 82218 • Bakersfield, California 93380-2218
Customer Call Center • P.O. Box 9016 • San Dimas, California 91773-9016 • (800) 270-6084

RECEIVED

2005 MAY -3 A 9 24

ROBERT T. HARDCASTLE
(661) 633-7526
Fax (781) 823-3070
RTH@brookeutilities.com

AZ CORP COMMISSION
DOCUMENT CONTROL

May 2, 2005

Docket Control
Arizona Corporation Commission
1200 West Washington Ave.
Phoenix, AZ 85007

W-03512A-05-0320

Re: **Cross Connection Tariff for Pine Water Co., Inc.**

Gentlemen,

Attached please find an application by the above referenced water company for approval of a Cross-Connection Tariff. The purpose of this Tariff is to protect the above referenced water company from the possibility of contamination that may be present on the customer's premises.

Sincerely,

Robert T. Hardcastle
President

cc:

RTH correspondence file
Pine Water Co., Inc. Tariff file
MI, DS, DA, SZ

Arizona Corporation Commission
DOCKETED
MAY 03 2005
DOCKETED BY

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Pine Water Co., Inc. ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405(B)(6) and A.A.C. R18-4-115.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission (the "Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405 (B)(6) and A.A.C. R18-4-115 relating to backflow prevention:

- (1) The Company may require a customer to pay for and to have installed a backflow prevention assembly if A.A.C. R18-4-115 (B) or (C) applies.
- (2) A backflow prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-115 (D) and (E).
- (3) Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraph 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.
- (4) The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410 (B)(1) is **NOT** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the device within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.



****FOR OFFICIAL USE ONLY****

Effective Date: June 1, 2005

Company Name: Pine Water Co., Inc.

- (5) Testing shall be in conformance with the requirements of A.A.C. R18-4-115 (F). The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
- (6) The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - (a) Assembly identification and description
 - (b) Location
 - (c) Date (s) of test (s)
 - (d) Description of repairs and recommendations for repairs made by the tester
 - (e) Tester's name and certification number
- (7) In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410 (B)(1)(a) exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
- (8) In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirements, and A.A.C. R14-2-410 (B)(1)(a) is NOT applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of service in accordance with A.A.C. R14-2-410.



****FOR OFFICIAL USE ONLY****

Effective Date: ____ / ____ / ____