

ORIGINAL



0000022133

Santa Rosa Water Company  
Santa Rosa Utility Company  
9532 East Riggs Rd., Sun Lakes, Arizona 85248

July 12, 2005

Docket Control  
Arizona Corporation Commission  
1200 West Washington Street  
Phoenix, AZ 85007

**Re: Docket No's: SW-04136A-02-0691 and W-04137A-02-0692**

Dear Docket Control:

Enclosed is a copy of Santa Rosa Water Company's Approval to Construct (ATC) from ADEQ that is required to be submitted pursuant to Decision No. 65753. The due date for filing the ATC is September 20, 2006, as extended by Procedural Order dated December 20, 2004.

An original and 15 copies submitted.

Sincerely,

Jim Poulos

JP:rc

Enclosures

Docketcontrol99.doc

AZ CORP COMMISSION  
DOCUMENT CONTROL

2005 JUL 12 A 11:56

RECEIVED




**ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY  
 CERTIFICATE OF APPROVAL TO CONSTRUCT  
 DRINKING WATER WELL FACILITIES**

<b>ADEQ File No:</b> 20050194	<b>LTF No:</b> 35723
<b>System Name:</b> Santa Rosa Wtr Co	<b>System Number:</b> NEW
<b>Project Owner:</b> Santa Rosa Wtr Co	
<b>Address:</b> 9532 E. Riggs Rd., Sun Lakes, AZ 85248	
<b>Project Location:</b> Sun Lakes	<b>County :</b> Pinal
<b>Description:</b> CONSTRUCT RANCH SIERRA WATER PRODUCTION WELL #14 (DWR# 55-625561) AND EQUIP FOR 550 GPM TO SERVE RANCHO SIERRA PHASE-I PER PLANS B & R JOB# 825001.	

***Approval to construct the above-described facilities as represented in the approved documents on file with the Arizona Department of Environmental Quality is hereby given subject to provisions 1 through 5 continued on page 2 through 2***

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Central Regional office located in Phoenix. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin.Code. At the project owner's request, the Department **may** conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.
3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-5-507(A), Ariz. Admin. Code.

Reviewed by : RK1

By:  7/01/05  
 Kwame A. Agyare, P.E. Date

Manager, Drinking Water and  
 Wastewater Engineering Review  
 Water Quality Division

cc: File No : 20050194  
 Regional Office: Central  
 Owner: Santa Rosa Wtr Co  
 County Health Department: Pinal  
 Engineer: B & R Engineering, Inc.  
 Planning and Zoning/Az Corp. Commission  
 Engineering Review Database - Etr022

**APPROVAL TO CONSTRUCT  
WATER FACILITIES  
ADEQ FILE NO. 20050194  
PAGE 2 OF 2: PROVISIONS CONTINUED**

5. Before approval of the well as a drinking water source can be made the following items must be submitted:
  - a. Inorganic, asbestos, radiochemical, microbiological, volatile organic compounds and synthetic organic analyses must be submitted for well from a lab certified by the Arizona Department of Health Services.
  - b. Pump test data for the wells at steady state for at least 4-hours.
  - c. Well drillers log.
  - d. Department of Water Resources Well Completion Report.