

ORIGINAL



0000035452

2802

WATCO

P.O. Box 1270
Show Low, Arizona 85902
(928) 537-8739

November 28, 2005

Arizona Corporation Commission
1200 West Washington
Phoenix, AZ 85007

Dear Sir or Madam:

Re: Docket Number W-01979A-05-0645

Per my telephone conversation with Del Smith, enclosed for your files is supplemental information to that which was sent on October 31, 2005. Due to the high percentage of rock the additional estimate for the hard dig is \$273,753.00 above the cost estimate provided in the original numbers. I have also included copies of:

- Drilling and Pump Construction Invoices
- Department of Water Resources Well Driller Report and Well Log
- Department of Water Resources Pump Installation Completion Report
- Department of Environmental Quality Compliance Report

For your review and to supply pumping information.

If you have any further questions, please contact me at the address listed above.

Sincerely,

Mark Grapp
President and CEO

RECEIVED
2005 NOV 30 P 2:21
AZ CORP COMMISSION
DOCUMENT CONTROL

Willis Drilling & Pump

1351 South Main St.
 Snowflake, AZ 85937
 Fax: (928) 536-2091
 Phone: (928) 536-4414

Invoice

DATE	INVOICE #
12/14/2004	6366

BILL TO
Canyon Vista job 1

SHIP TO
Shumway rd.

P.O. NO.	TERMS	PROJECT
Otis #1	Due on receipt	

QTY	DESCRIPTION	RATE	AMOUNT
1	State Permit fee	150.00	150.00
20	Ft. of 14" bore hole with 12" surface casing	40.00	800.00T
463	Ft. of 11 " bore hole	30.00	13,890.00T
2	11" Bit costs	1,500.00	3,000.00
465	Ft. of 8" steel casing	16.50	7,672.50T
1	Labor to weld & install 8" casing in well	1,950.00	1,950.00T
1	Seal top 20 Ft. of well per State Law	500.00	500.00T
10	Hrs Labor to developed well with surge & bail (ready to set pump)	50.00	500.00
	AZ Sales Tax@ Contractor rate	3.965%	983.82

PAID
10,000.00
 11-22-04

Thank you for the opportunity to be of service.	Total	\$29,446.32
---	--------------	-------------

Willis Drilling & Pump

1351 South Main St.
 Snowflake, AZ 85937
 Fax: (928) 536-2091
 Phone: (928) 536-4414

Invoice

DATE	INVOICE #
1/17/2005	6384

BILL TO
Canyon Vista

SHIP TO
Shumway rd.

P.O. NO.	TERMS	PROJECT
Otis	Due on receipt	

QTY	DESCRIPTION	RATE	AMOUNT
1	20-HP 460 V. 3-PH 225 GPM Model 6T-225 pump & motor Berkeley	5,722.00	5,722.00T
1	20-HP 460 V. 3-PH pumping plant panel	1,285.00	1,285.00T
360	Ft. of 3" PVC Scd 80 Certa lock drop pipe	7.88	2,836.80T
380	Ft. of #8-4 submersible pump cable	2.35	893.00T
1	8" X 3 " sanitary well seal	250.00	250.00T
1	3" Stainless steel Tee	106.00	106.00T
1	3" Stainless steel check valve with Certa lock adapters	364.00	364.00T
2	Stainless steel 3" nipples with Certa lock adapters	48.00	96.00T
1	Labor to install new pump in well	600.00	600.00
1	Lab. Fees and paper work for water testing to satisfy DEQ	2,800.00	2,800.00
1	Labor to set up and pump test well, plus rental & fuel for Generator	800.00	800.00
	AZ Sales Tax@ Contractor rate	3.965%	458.07
<p>PAID <u>3382.60</u> 1-28-05 #01007 Cedar Vista Prop.</p> <p>PAID <u>12,828.60</u> # 2031 2-7-05</p>			.33¢

Thank you for the opportunity to be of service.

Total \$16,210.87



Arizona Department of Water Resources
 Records Management Section
 500 N. 3rd Street ❖ Phoenix, Arizona 85004
 (602) 417-2405 ❖ (800) 352-8488
 www.water.az.gov

**Well Driller Report
 and
 Well Log**

- ❖ Review instructions prior to completing form
- ❖ This report should be prepared by the driller in detail and filed with the Department within 30 days following completion of the well.

** PLEASE PRINT CLEARLY **

FILE NUMBER A(12-22)31 BDA
WELL REGISTRATION NUMBER 55 - 901337
PERMIT NUMBER (IF ISSUED)

SECTION 1. REGISTRY INFORMATION						
Well Owner			Location of Well			
FULL NAME OF COMPANY, ORGANIZATION, OR INDIVIDUAL Canyon Vista Estates LLC			WELL LOCATION ADDRESS (IF ANY) Shumway			
MAILING ADDRESS 1850 N. Central Ave. Suite 2100			TOWNSHIP (N/S) 12N	RANGE (E/W) 22E	SECTION 31	160 ACRE NW ¼
CITY / STATE / ZIP CODE Phoenix, AZ, 85004-4584			LATITUDE 34 ° 23 ' 943 "N		LONGITUDE 110 ° 03 ' 372 "W	
CONTACT PERSON NAME AND TITLE			LAND SURFACE ELEVATION AT WELL 5960 Feet Above Sea Level			
TELEPHONE NUMBER 602 212 8551	FAX		METHOD OF LATITUDE / LONGITUDE (CHECK ONE) <input checked="" type="checkbox"/> Hand-Held			
			<input type="checkbox"/> USGS Quad Map <input type="checkbox"/> Conventional Survey <input checked="" type="checkbox"/> GPS <input type="checkbox"/> Survey-Grade			
			COUNTY ASSESSOR'S PARCEL ID NUMBER			
			BOOK 204	MAP 8	PARCEL 012F	
			COUNTY WHERE WELL IS LOCATED Navajo			

SECTION 2. DRILLING AUTHORIZATION	
Drilling Firm	
NAME MCCRAY WELL DRILLING CO INC dba Willis Drig & Pump Co	
DWR LICENSE NUMBER 88	
TELEPHONE NUMBER 928-536-4414	FAX 928-536-2091

SECTION 3. WELL CONSTRUCTION DETAILS		
DATE WELL CONSTRUCTION STARTED 12-25-04	DATE WELL CONSTRUCTION COMPLETED 1-4-05	IF FLOWING WELL, METHOD OF FLOW REGULATION <input type="checkbox"/> Valve <input type="checkbox"/> Other:
Drill Method CHECK ONE <input checked="" type="checkbox"/> Air Rotary <input type="checkbox"/> Bored or Augered <input type="checkbox"/> Cable Tool <input type="checkbox"/> Dual Rotary <input type="checkbox"/> Mud Rotary <input type="checkbox"/> Reverse Circulation <input type="checkbox"/> Driven <input type="checkbox"/> Jetted <input type="checkbox"/> Air Percussion / Odex Tubing <input type="checkbox"/> Other (please specify):	Method of Well Development CHECK ONE <input checked="" type="checkbox"/> Airlift <input type="checkbox"/> Bail <input type="checkbox"/> Surge Block <input type="checkbox"/> Surge Pump <input type="checkbox"/> Other (please specify):	Method of Sealing at Reduction Points CHECK ONE <input checked="" type="checkbox"/> None <input type="checkbox"/> Packed <input type="checkbox"/> Swedged <input type="checkbox"/> Welded <input type="checkbox"/> Other (please specify):
Water Level Information		
STATIC WATER LEVEL 217 Feet Below Land Surface		
DATE MEASURED Dec 15, 2004		

ORIG MAILED TO ADWR
 COPY MAILED TO CLIENT
COPY 1-10-05



Arizona Department of Water Resources
 Records Management Section
 500 N. 3rd Street • Phoenix, Arizona 85004
 (602) 417-2405 • (800) 352-8488
 www.water.az.gov

Pump Installation Completion Report

- ❖ Review instructions prior to completing form in black or blue ink.
- ❖ The registered well owner should file this report with the Department within 30 days following installation of pump equipment.

FILE NUMBER A(12-22)31 BDA
WELL REGISTRATION NUMBER 55-901337

** PLEASE PRINT CLEARLY **

SECTION 1. REGISTRY INFORMATION	
Well Owner FULL NAME OF COMPANY, ORGANIZATION, OR INDIVIDUAL Canyon Vista Estates LLC	Location of Well WELL LOCATION ADDRESS (IF ANY) Shumway.
MAILING ADDRESS 1850 N. Central Ave. Suite 2100	TOWNSHIP (N/S) RANGE (E/W) SECTION 160 ACRE 40 ACRE 10 ACRE 12N 22E 31 NW ¼ SE ¼ NE ¼
CITY / STATE / ZIP CODE Phoenix AZ 85004-4584	COUNTY ASSESSOR'S PARCEL ID NUMBER (MOST RECENT) BOOK 204 MAP 8 PARCEL 012F
CONTACT PERSON NAME AND TITLE T. Michael Daggett	COUNTY WHERE WELL IS LOCATED NAVASO
TELEPHONE NUMBER FAX 602 212 8551 602-240-6925	

SECTION 2. EQUIPMENT INSTALLED	
DATE PUMP INSTALLED 1-12-05	
Pump Type CHECK ONE <input type="checkbox"/> Air Lift <input type="checkbox"/> Bucket <input type="checkbox"/> Centrifugal <input type="checkbox"/> Jet <input type="checkbox"/> Piston <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Other (please specify):	Power Type CHECK ONE <input type="checkbox"/> Diesel Engine <input checked="" type="checkbox"/> Electric Motor <input type="checkbox"/> Gasoline Engine <input type="checkbox"/> Hand <input type="checkbox"/> Natural Gas <input type="checkbox"/> Windmill <input type="checkbox"/> Other (please specify):
RATED PUMP CAPACITY 200 Gallons Per Minute	HORSE POWER RATING OF MOTOR 20 HP

SECTION 3. PUMP TEST		
Pump Test Data DATE WELL TESTED 1-17-05 STATIC WATER LEVEL (A) 232 Feet Below Land Surface PUMPING WATER LEVEL (B) 242 Feet Below Land Surface DRAWDOWN [(B) - (A)] 10 Feet Below Land Surface TEST PUMPING RATE 200 Gallons Per Minute DURATION OF PUMP TEST (Minimum 4 Hours) 7 Hours TOTAL PUMPING LIFT 242 Feet FOR FLOWING WELL. <input type="checkbox"/> FT MEASURED SHUT IN HEAD <input type="checkbox"/> PSI	Method of Discharge Measurement CHECK ONE <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Bucket - Barrel - Stopwatch <input type="checkbox"/> Current <input type="checkbox"/> Estimated - Air Lift <input type="checkbox"/> Gauge <input type="checkbox"/> Meter <input type="checkbox"/> Orifice <input type="checkbox"/> Volume <input type="checkbox"/> Weir - Flume <input type="checkbox"/> Other (please specify):	Method of Measuring Water Level CHECK ONE <input type="checkbox"/> Air Line <input checked="" type="checkbox"/> Electric Measuring Line (Sounder) <input type="checkbox"/> Steel Tape <input type="checkbox"/> Other (please specify):
ORIGINAL MAILED TO ADWR 1-19-05 COPY TO OWNER 1-19-05 <h1 style="font-size: 4em; margin: 0;">COPY</h1>		

I HEREBY CERTIFY that the above statements are true to the best of my knowledge and belief according to A.R.S. § 45-600(B).	
SIGNATURE OF WELL OWNER Kelly J Walker agent FOR Canyon Vista Estates	DATE 1-19-05

SECTION 6. WELL SITE PLAN

NAME OF WELL OWNER

Canyon Vista Estates LLC


COUNTY ASSESSOR'S PARCEL ID NUMBER

BOOK
204

MAP
8

PARCEL
012F

- ❖ Please draw the following: (1) the boundaries of property on which the well was located; (2) the well location; (3) the locations of all septic tank systems and sewer systems on the property or within 100 feet of the well location, even if on neighboring properties; and (4) any permanent structures on the property that may aid in locating the well.
- ❖ Please indicate the distance between the well location and any septic tank system or sewer system.



McCray Well Drilling Co Inc
dba
Willis Drilling & Pump Co
1351 S. Main St.
Snowflake, AZ 85937

Kelly J Well 1-10-05
SIGNATURE of Qualifying Party

Arizona Department of Environmental Quality
Water Quality Compliance Assurance Unit
1110 W. Washington Street, 5415B-1
Phoenix, AZ 85007

Drinking Water Compliance Status Report

Public Water System Name: Silver Well Service Corp.

Public Water System ID #: 09-027

Public Water System Type: CO Non-transient Non-community Transient Non-community

Overall Compliance Status: No Major Deficiencies Major Deficiencies

Monitoring and Reporting Status: No Major Deficiencies Major Deficiencies
Comments:

Operation and Maintenance Status: No Major Deficiencies Major Deficiencies
Comments:

Major unresolved/ongoing operation and maintenance deficiencies:

- | | |
|---|---|
| <input type="checkbox"/> unable to maintain 20psi | <input type="checkbox"/> inadequate storage |
| <input type="checkbox"/> cross connection/backflow problems | <input type="checkbox"/> surface water treatment rule |
| <input type="checkbox"/> treatment deficiencies | <input type="checkbox"/> approval of construction |
| <input type="checkbox"/> certified operator | <input type="checkbox"/> other |

Date of last inspection / sanitary survey: 5-13-02

Administrative Orders:

Is an ADEQ administrative order in effect? Yes No
Comments:

System information:

Number of Points of Entry 1 Number of Sources 1 Population Served 706

Service Connections 752 Initial Monitoring Year 1994 Initial MAP Year 2000

Evaluation completed by: **Jim Puckett**

Phone: 602-771-4649 **Date:** 10-31-05

Based upon data submitted by the water system, ADEQ has determined that this system is currently delivering water that meets water quality standards required by Arizona Administrative Code, Title 18, Chapter 4. This compliance status report does not guarantee the water quality for this system in the future. This compliance status report does not reflect the status of any other water system owned by this utility company.