

LAGO DEL ORO WATER COMPA

9532 East Riggs Road, Sun Lakes, Arizona 85248-~~7~~



0000037547

RECEIVED

2002 JUN -7 A 11:43

AZ CORP COMMISSION
DOCUMENT CONTROL

June 4, 2002

Docket Control
Arizona Corporation Commission
1200 West Washington
Phoenix, Arizona 85007

Re: Decision No. 64093, Docket No. W-01944A-01-0400

Dear Sir or Madam:

Lago Del Oro Water Company was issued an extension to the area of its water certificate of convenience and necessity ("CC&N") by the Arizona Corporation Commission ("Commission") on October 4, 2001. A condition of the CC&N for the extension area is to obtain an approval to construct ("ATC") in the extension area from ADEQ within one year. On April 4, 2002, the Company requested that the Commission extend the date for the ATC in the extension area to December 31, 2003. This request for an extension of time to obtain the ATC has not yet been granted. Attached is a copy of the ATC issued by ADEQ for the extension area on May 28, 2002. The condition of the order in Decision No. 64093 is therefore fulfilled and the extension of time to submit the ATC is no longer required.

An original and ten copies submitted.

Sincerely,

Jim Poulos
General Manager

JP:ab

Enclosure

DocketControl61.doc

Arizona Corporation Commission

DOCKETED

JUN - 7 2002

DOCKETED BY	
-------------	--

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY
CERTIFICATE OF APPROVAL TO CONSTRUCT
DRINKING WATER FACILITIES

Page 1 of 2


ADEQ FILE NO.: 20020174
SUPPLYING SYSTEM NAME: Lago Del Oro Water Company PUBLIC WATER SYSTEM NO.: 11117
PROJECT NAME: Drinking water distribution system extension to serve Saddlebrooke Unit 46
PROJECT OWNER: Saddlebrooke Development Company
ADDRESS: 9235 E. Riggs Road, Sun Lakes, AZ 85248
LOCATION: Near the intersection of Edwin Rd. and Clubhouse Dr. near Catalina, AZ COUNTY: Pinal
PROJECT DESCRIPTION: Approximately 676 feet of 12-inch PVC water main in the following streets: Clubhouse Dr. Approx. 1,665 feet of 8-inch PVC water main in the following streets: Northwood Rd., Clubhouse Dr., Moonwood Dr., McHaney Ct., and Sand Crest Dr. Approx. 7,716 feet of 6-inch PVC water main in the following streets: Moonwood Dr., Northwood Dr., Sand Crest Dr., Sandwood Rd., Briarwood Dr., and Redwood Dr. 21 fire hydrants, 2 air release valves, and 7 flushing valves are incorporated. The average daily design flow for the project is 39,609 gallons per day.

Approval to Construct the above-described facility as represented in approved plan documents on file with the Arizona Department of Environmental Quality is hereby given:

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 4, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion, and forward it to ADEQ's Drinking Water Technical Engineering Unit, Phoenix Office. If all requirements have been completed, that office will issue a Certificate of Approval of Construction. R18-4-507(B), Ariz. Admin. Code. At the project owner's request, the Department *may* conduct the final inspection required pursuant to R18-4-507(B); such a request must be made in writing in accordance with the time requirements of R18-4-507(C), Ariz. Admin. Code.

Provisions 3 through 9 are continued on Page 2 of 2 total pages

AH:shl

Jacqueline E. Schafer, Director
Arizona Department of Environmental Quality
By:  5/28/02
Aofad Hossain, P.E., Manager Date Approved
Technical Engineering Unit
Drinking Water Section
Water Quality Division

cc: File No: 20020174
County Health Department: Pinal
Drinking Water Technical Engineering Unit - Phoenix Office
Water Company: Lago Del Oro Water Company
Planning & Zoning: Pinal
Engineer: Kenneth A. Marks, P.E.
Engineering Review Database

CERTIFICATE OF APPROVAL TO CONSTRUCT DRINKING WATER FACILITIES:
DRINKING WATER DISTRIBUTION SYSTEM
REQ FILE NO. 20020174 Extension to serve Saddlebrooke Unit 46
PAGE 2 OF 2: PROVISIONS, CONTINUED

3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-4-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-4-507(A), Ariz. Admin. Code.
5. Dead-ends should be avoided if possible; where they cannot be avoided, they must have blow-off valves with a minimum diameter of two inches. R18-4-502(A), Ariz. Admin. Code.
6. Before construction of a modification, expansion, or alteration of this distribution system begins, a separate Approval to Construct applicable to each addition must be obtained. R18-4-505(B), Ariz. Admin. Code.
7. This Approval to Construct applies only to Saddlebrooke Unit 46 at the location indicated above. The average daily demand of the facilities which will connect to the water main extension hereby approved is 39,609 gallons per day. The peak hour flow demand of the facilities which will connect to the water main extension hereby approved is 83 gallons per minute. When additional portions are constructed, the mains therein will be configured such that the distribution system approved herewith is looped by connection to those additions.
8. The water system storage capacity shall comply with A.A.C. R18-4-503.
9. Separation between the water and any sewer mains shall comply with Arizona Administrative Code (A.A.C.) R18-4-502(C).

LAGO DEL ORO WATER COMPANY

9532 East Riggs Road, Sun Lakes, Arizona 85248-7411

COPY

RECEIVED

2002 JUN -7 A 11:43

AZ CORP COMMISSION
DOCUMENT CONTROL

June 4, 2002

Docket Control
Arizona Corporation Commission
1200 West Washington
Phoenix, Arizona 85007

Re: Decision No. 64093, Docket No. W-01944A-01-0400

Dear Sir or Madam:

Lago Del Oro Water Company was issued an extension to the area of its water certificate of convenience and necessity ("CC&N") by the Arizona Corporation Commission ("Commission") on October 4, 2001. A condition of the CC&N for the extension area is to obtain an approval to construct ("ATC") in the extension area from ADEQ within one year. On April 4, 2002, the Company requested that the Commission extend the date for the ATC in the extension area to December 31, 2003. This request for an extension of time to obtain the ATC has not yet been granted. Attached is a copy of the ATC issued by ADEQ for the extension area on May 28, 2002. The condition of the order in Decision No. 64093 is therefore fulfilled and the extension of time to submit the ATC is no longer required.

An original and ten copies submitted.

Sincerely,


Jim Poulos
General Manager

JP:ab

Enclosure

DocketControl61.doc

Arizona Corporation Commission

DOCKETED

JUN - 7 2002

DOCKETED BY



ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY
CERTIFICATE OF APPROVAL TO CONSTRUCT
DRINKING WATER FACILITIES

Page 1 of 2


ADEQ FILE NO.: 20020174
SUPPLYING SYSTEM NAME: Lago Del Oro Water Company PUBLIC WATER SYSTEM NO.: 11117
PROJECT NAME: Drinking water distribution system extension to serve Saddlebrooke Unit 46
PROJECT OWNER: Saddlebrooke Development Company
ADDRESS: 9235 E. Riggs Road, Sun Lakes, AZ 85248
LOCATION: Near the intersection of Edwin Rd. and Clubhouse Dr. near Catalina, AZ COUNTY: Pinal
PROJECT DESCRIPTION:. Approximately 676 feet of 12-inch PVC water main in the following streets: Clubhouse Dr. Approx. 1,665 feet of 8-inch PVC water main in the following streets: Northwood Rd., Clubhouse Dr., Moonwood Dr., McHaney Ct., and Sand Crest Dr. Approx. 7,716 feet of 6-inch PVC water main in the following streets: Moonwood Dr., Northwood Dr., Sand Crest Dr., Sandlewood Rd., Briarwood Dr., and Redwood Dr. 21 fire hydrants, 2 air release valves, and 7 flushing valves are incorporated. The average daily design flow for the project is 39,609 gallons per day.

Approval to Construct the above-described facility as represented in approved plan documents on file with the Arizona Department of Environmental Quality is hereby given:

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 4, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion, and forward it to ADEQ's Drinking Water Technical Engineering Unit, Phoenix Office. If all requirements have been completed, that office will issue a Certificate of Approval of Construction. R18-4-507(B), Ariz. Admin. Code. At the project owner's request, the Department *may* conduct the final inspection required pursuant to R18-4-507(B); such a request must be made in writing in accordance with the time requirements of R18-4-507(C), Ariz. Admin. Code.

Provisions 3 through 9 are continued on Page 2 of 2 total pages

AH:shl

Jacqueline E. Schafer, Director
Arizona Department of Environmental Quality
By:  5/28/02.
Aofad Hossain, P.E., Manager Date Approved
Technical Engineering Unit
Drinking Water Section
Water Quality Division

cc: File No: 20020174
County Health Department: Pinal
Drinking Water Technical Engineering Unit - Phoenix Office
Water Company: Lago Del Oro Water Company
Planning & Zoning: Pinal
Engineer: Kenneth A. Marks, P.E.
Engineering Review Database

CERTIFICATE OF APPROVAL TO CONSTRUCT DRINKING WATER FACILITIES:
DRINKING WATER DISTRIBUTION SYSTEM
REQ FILE NO. 20020174 Extension to serve Saddlebrooke Unit 46
PAGE 2 OF 2: PROVISIONS, CONTINUED

3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-4-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-4-507(A), Ariz. Admin. Code.
5. Dead-ends should be avoided if possible; where they cannot be avoided, they must have blow-off valves with a minimum diameter of two inches. R18-4-502(A), Ariz. Admin. Code.
6. Before construction of a modification, expansion, or alteration of this distribution system begins, a separate Approval to Construct applicable to each addition must be obtained. R18-4-505(B), Ariz. Admin. Code.
7. This Approval to Construct applies only to Saddlebrooke Unit 46 at the location indicated above. The average daily demand of the facilities which will connect to the water main extension hereby approved is 39,609 gallons per day. The peak hour flow demand of the facilities which will connect to the water main extension hereby approved is 83 gallons per minute. When additional portions are constructed, the mains therein will be configured such that the distribution system approved herewith is looped by connection to those additions.
8. The water system storage capacity shall comply with A.A.C. R18-4-503.
9. Separation between the water and any sewer mains shall comply with Arizona Administrative Code (A.A.C.) R18-4-502(C).