

ORIGINAL



0000043843

50

EAGLETAIL WATER CO., LLC

P.O. Box 157
Tonopah, AZ 85354
928-372-2236

February 25, 2006

Docket Control Section
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Re: Docket No. W-03936A-04-0840
Decision No. 67982

Yearly water loss report

Enclosed are copies of water loss and water sold for the calendar year 2005. As of the first of the year 2005, we have repaired (9) major leaks and have replaced two 6" valves. Our water loss has been greatly reduced. We have had several leaks that we had trouble determining the amount of water lost. We also had an agreement with the local Fire Department to furnish water for fire or emergencies. We have had a problem with them taking water without keeping track of it so now we are monitoring them more closely. We hope to reach your goal of 10 percent in the near future. If you have any questions regarding this report please call 928-372-2236 or contact us by mail at the address above.

Yours truly,

Susan Haas
Statutory Agent
Eagletail Water Co., LLC

AZ CORP COMMISSION
DOCUMENT CONTROL

2006 MAR -2 1 P 3: 42

RECEIVED

COMPANY NAME: EAGLE TAIL WATER CO. LLC

WATER USE DATA SHEET BY MONTH FOR CALENDAR YEAR 2005

MONTH	NUMBER OF CUSTOMERS	GALLONS SOLD	GALLON PUMPED (Thousands)
JANUARY	54	197080	929400
FEBRUARY	52	239178	418500
MARCH	52	177330	613700
APRIL	56	359100	992800
MAY	58	451117	962300
JUNE	59	914890	1182400
JULY	54	1053127	1430400
AUGUST	54	1121017	1355100
SEPTEMBER	58	801909	903400
OCTOBER	58	449044	631700
NOVEMBER	57	466191	602800
DECEMBER	56	395982	959000
TOTAL		6625965	10981500

Is the Water Utility located in an ADWR Active Management Area (AMA)?

() Yes (X) No

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement?

() Yes (X) No

If yes, provide the GPCPD amount: _____

What is the level of arsenic for each well on your system. 0.0050 mg/l
(If more than one well, please list each separately.)

Note: If you are filing for more than one system, please provide separate data sheets for each system.