



0000050651

BEFORE THE ARIZONA CORPORATION COMMISSION
RECEIVED

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

COMMISSIONERS

- Jeff Hatch-Miller, Chairman
- William A. Mundell
- Marc Spitzer
- Mike Gleason
- Kristin K. Mayes

2006 MAY 18 P 4: 38
AZ CORP COMMISSION
DOCUMENT CONTROL

IN THE MATTER OF THE APPLICATION OF
PALO VERDE UTILITIES COMPANY FOR AN
EXTENSION OF ITS EXISTING CERTIFICATE
OF CONVENIENCE AND NECESSITY.

Docket No. SW-03575A-04-0767

IN THE MATTER OF THE APPLICATION OF
SANTA CRUZ WATER COMPANY FOR AN
EXTENSION OF ITS EXISTING CERTIFICATE
OF CONVENIENCE AND NECESSITY.

Docket No. W-03576A-04-0767

**NOTICE OF FILING IN COMPLIANCE WITH
DECISION NO. 67830**


(Neely WTP ATC)

Palo Verde Utilities Company, LLC and Santa Cruz Water Company, LLC, (collectively, Global), in compliance with Decision No. 67830 (May 5, 2005), provide notice of filing the compliance item described below. Decision No. 67830 required Global to submit "a copy of the ADEQ Approval to Construct for the Neely Well Production / Treatment Plant" by December 31, 2005. This deadline was extended to June 30, 2006 by the Commission's Procedural Order in these dockets dated February 1, 2006. Attached is the ADEQ Approval to Construct the Neely Well Production / Treatment Plant, which is also known as the Rancho El Dorado Plant.

ROSHKA DEWULF & PATTEN, PLC
ONE ARIZONA CENTER
400 EAST VAN BUREN STREET - SUITE 800
PHOENIX, ARIZONA 85004
TELEPHONE NO 602-256-6100
FACSIMILE 602-256-6800

1 RESPECTFULLY submitted this 18th day of May 2006.

2 ROSHKA DEWULF & PATTEN, PLC

3
4 By 

5 Michael W. Patten
6 One Arizona Center
7 400 East Van Buren Street, Suite 800
8 Phoenix, Arizona 85004

9 Original + 15 copies of the foregoing
10 filed this 18th day of May 2006, with:

11 Docket Control
12 ARIZONA CORPORATION COMMISSION
13 1200 West Washington
14 Phoenix, Arizona 85007

15 Copies of the foregoing hand-delivered/mailed
16 this 18th day of May 2006, to:

17 Dwight Nodes, Esq.
18 Administrative Law Judge
19 Hearing Division
20 Arizona Corporation Commission
21 1200 West Washington
22 Phoenix, Arizona 85007

23 David Ronald, Esq.
24 Legal Division
25 Arizona Corporation Commission
26 1200 West Washington
27 Phoenix, Arizona 85007

Brian Bozzo
Compliance Manager, Utilities Division
Arizona Corporation Commission
1200 West Washington
Phoenix, Arizona 85007

23
24 By 

EXHIBIT

"A"

**ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY
CERTIFICATE OF APPROVAL TO CONSTRUCT
DRINKING WATER FACILITIES**

Page 1 of 2

ADEQ FILE NO.: 20050847	LTF No.: 38064
SUPPLYING SYSTEM NAME: Santa Cruz Water Co., LLC PUBLIC WATER SYSTEM NO.: 11-131	
PROJECT NAME: Rancho El Dorado Pumping Improvements	
PROJECT OWNER: Graham Symmonds, Santa Cruz Water Company	
ADDRESS: 22601 N. 19 th Ave. #210, Phoenix, AZ 85027	
LOCATION: Smith-Enke Road and Santa Rosa Road, City of Maricopa	COUNTY: Pinal
PROJECT DESCRIPTION: Installation of water treatment facility upgrades, including pumps, chlorinating facility, and related piping and fittings, to increase the pumping capacity from 4,000 GPM to 9,100 GPM at Rancho Ed Dorado, City of Maricopa.	

Approval to Construct the above-described facility as represented in approved plan documents on file with the Arizona Department of Environmental Quality is hereby given subject to the following provisions:

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion, and forward it to the Drinking Water Field Engineering and Inspection Unit - Phoenix. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin. Code. At the project owner's request, the Department *may* conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.

Provisions 3 through 5 are continued on Page 2 of 2 total pages

MAH:mah
50847dbm.5nt

By: 
Kwame Agyare, P.E., Manager
Technical Engineering Unit
Drinking Water Section
Water Quality Division

11/21/05
Date Approved

cc: **File No:** 20050847, **LTF No.** 38064
County Health Department: Pinal
Drinking Water Field Engineering/Inspection Unit - Phoenix
Water System: Santa Cruz Water Co.
Planning & Zoning: Pinal County
Engineer: William D. Roberts, P.E.
Engineering Review Database
Romann Diaz, Manager, Field Service Unit

CERTIFICATE OF APPROVAL TO CONSTRUCT DRINKING WATER DISTRIBUTION SYSTEM:
ADEQ FILE NO. 20050847: RANCHO EL DORADO PUMPING IMPROVEMENTS
PAGE 2 OF 2 PROVISIONS, CONTINUED

3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department.
5. Before construction of a modification, expansion, or alteration of this distribution system begins, a separate Approval to Construct applicable to each addition must be obtained. R18-5-505(B), Ariz. Admin. Code.