

ORIGINAL
AJO IMPROVEMENT COMPANY
P. O. DRAWER 9
AJO, ARIZONA 85321



0000054124

06

Telephone: 520-387-7151 Fax: 520-387-7627

May 11, 2006

Docket Control
Arizona Corporation Commission
Compliance Section
Utilities Division
1200 West Washington
Phoenix, AZ 85007

AZ CORP COMMISSION
DOCUMENT CONTROL

2006 MAY 17 P 1:04

RECEIVED

RE: Docket Number E-⁰¹⁰²⁵~~1025~~A-01-0200
2005 Annual Meter Testing and Maintenance Report

COMPLIANCE DELINQUENCY

To Whom It May Concern:

Enclosed are 13 copies of the annual report summarizing the results of the meter maintenance and testing program for 2005.

Sincerely,

Frank J. Nides
Maintenance Supervisor

AJO IMPROVEMENT COMPANY
P. O. DRAWER 9
AJO, ARIZONA 85321

Telephone: 520-387-7151 Fax: 520-387-7627

May 5, 2006

Arizona Corporation Commission
Compliance Section
Utilities Division
1200 West Washington
Phoenix, AZ 85007

RE: 2005 Annual Meter Testing and Maintenance Report

To Whom It May Concern:

Per Commission Rule R-14-2-309, subparagraph E, the following data is provided for the year 2005:

	<u>Electric</u>	<u>Water</u>
Meters in service December 31, 2005	1012	1106
Meters changed out during the year	73	26
Meters tested at Company initiative	76	36
Meters tested at customer request	0	0
Number of meters tested outside acceptable error	0	0
Meters not tested due to complete stoppage	0	17

In no cases were meters found to exceed the allowable error in the Company's favor.

ELECTRIC

Ajo Improvement Company will continue changing the "A" base type meter to socket type meter when customer upgrades home meter loop and/or request change of service voltage from 120 to 240 single-phase service. The number of meter changes is expected to be less than 5% of the total meters in service.

At present, Ajo Improvement Company is having Morenci Water and Electric Company test and calibrate our electric meters.

WATER

The company uses a sealed register type meter. This is done as stopped or low consumption conditions occur. Expect to change 5% of the total meters in service.

Ajo Improvement Company is using a Ford Meter Box calibrated tank, size 1 for test purposes.

Very truly yours,



Frank J. Nides
Maintenance Supervisor

FJN:mgs