

**ORIGINAL**

THIS AMENDMENT:

Passed as amended by \_\_\_\_\_

Failed \_\_\_\_\_

Not Offered \_\_\_\_\_



0000060605

RECEIVED

**MUNDELL PROPOSED AMENDMENT #3**

2002 APR -8 A 10:02

AZ CORP COMMISSION  
DOCUMENT CONTROL

TIME/DATE PREPARED: Monday, April 01, 2002

COMPANY: Allegheny Energy Supply Company  
Case 116

AGENDA ITEM NO. 1

DOCKET NO. L-00000-01-0116

OPEN MEETING DATE: 4-8-02

**INSERT proposed additional condition:**

Applicant shall construct and operate the proposed La Paz Generating Facility with the first power block as a wet cooled block and the second power block as a parallel wet dry-cooled power block. Applicant shall limit groundwater pumping for cooling purposes to no more than 4600 acre-feet per year, based on a 60% reduction in the water to be used in the second power block. Applicant shall acquire on an annual basis, through another or by contract with the Arizona Water Banking Authority ("AWBA"), an amount of water equivalent to the amount of groundwater actually pumped for use by the project in the preceding year, to be recharged at the Vidler Recharge Facility.

Arizona Corporation Commission  
**DOCKETED**

APR 08 2002

DOCKETED BY 