

ORIGINAL

COMMISSIONERS
JEFF HATCH-MILLER - Chairman
WILLIAM A. MUNDELL
MIKE GLEASON
KRISTIN K. MAYES
GARY PIERCE



0000063033

06D

ARIZONA CORPORATION COMMISSION

2007 JAN 17 P 12:40

AZ CORP COMMISSION
DOCUMENT CONTROL
January 17, 2007

Mr. Tim Sabo
Roshka, DeWulf & Patten, PLC
One Arizona Center
400 East Van Buren Street, Suite 800
Phoenix, Arizona 85004

Arizona Corporation Commission
DOCKETED

JAN 17 2007

Mr. Graham Symmonds
Global Water Management
22601 North 19th Avenue, Suite 210
Phoenix, Arizona 85027

DOCKETED BY

RE: WATER UTILITY OF GREATER TONOPAH, DOCKET NO. W-02450A-06-0626

SECOND INSUFFICIENCY LETTER

Dear Mr. Sabo:

The application of the Water Utility of Greater Tonopah, for an extension of its Certificate of Convenience and Necessity, Docket No. W-02450A-06-0626 has not met the sufficiency requirements as outlined in the Arizona Administrative Code ("A.A.C.").

To correct the deficiencies, please provide the following information:

1. The submitted Master Plan includes the Hassayampa Ranch development. Please provide a Request for Water Service.
2. According to the Application, Desert Whisper has not requested wastewater service from Hassayampa. Please state which utility will provide wastewater service to Desert Whisper.
3. Please coordinate the engineering matters discussed in Engineering Memorandum ("E.M.") - Exhibits 7&8 and the Master Report (M.R.).
 - a). E.M. water demand design criteria is based on 245 GPD / DU. However, M.P. water demands are based on 480 GPD / DU. Also, Hassayampa Utilities Company's estimated wastewater flow is based on 187 GPD /DU.
 - b). Revise the Backbone Water Infrastructure capacities and costs in all documents accordingly (including Exhibit 8).

4. Pursuant to Exhibit 8, please provide the justification for the estimated Arsenic Treatment Unit Cost of \$1,500,000 and Surface Water Treatment Unit Cost of \$4,800,000.
5. Provide detailed information for the initial development within the requested extension area:
 - a). Identify the subdivision where the initial development activity will occur.
 - b). Number of dwelling units.
 - c). Water infrastructure components including
 - description (water production, treatment, storage, booster and distribution)
 - location (layout plans)
 - capacities (including wells)
 - costs
 - projected date of operation
6. Provide updated Drinking Water Compliance Reports for water systems # 07-618 and # 07-733 demonstrating full compliance status.

Pursuant to the A.A.C. R14-2-212.E.5., the Commission has 150 calendar days to approve or reject this application after it is deemed sufficient. This time period will encompass a hearing, a Recommended Opinion and Order and a Decision from the Commission.

If you have any questions concerning this matter, please do not hesitate to contact me at 602-542-0859 or Katrin Stukov at 602-542-0941.

Yours truly,



Linda A. Jaress
Executive Consultant III

LAJ:red

cc: Docket Control
Del Smith
Lyn Farmer
Brian Bozzo