

ORIGINAL



0000072405

COMMISSIONERS
JEFF HATCH-MILLER- Chairman
WILLIAM MUNDELL
MIKE GLEASON
KRISTIN K. MAYES
GARY PIERCE



RECEIVED

06D

2007 MAY -8 P 3:39

ARIZONA CORPORATION COMMISSION

AZ CORP COMMISSION
DOCUMENT CONTROL

Arizona Corporation Commission
DOCKETED

MAY -8 2007

Michael W. Patten
Roshka DeWulf & Patten, PLC
One Arizona Center Street
400 East Van Buren Street, Suite 800
Phoenix, Arizona 85004

DOCKETED BY
nr

RE: Valencia Water Company, Inc. ("Valencia") and Water Utility of Greater Buckeye, Inc. ("WUGB") – Joint Application requesting approval to transfer Water Utility of Greater Buckeye, Inc.'s assets, including its Certificate of Convenience and Necessity (CC&N), to Valencia Water Company, Inc.
Docket Nos. W-01212A-06-0666 and W-02451A-06-0666
INSUFFICIENCY LETTER #3

Dear Sir:

In reference to the above mentioned application filed on October 16, 2006, and the supporting documents filed on January 16, 2007, and April 13, 2007 this letter is to inform you that the application still has not met the sufficiency requirements as outlined in the Arizona Administrative Code. The deficiency is:

1. According to MCESD Compliance Status Reports, WUGB's two water systems: Sweetwater II/PWS# 07-129 and Bulfer/Primrose /PWS# 07-114 are in **Substantial Compliance** (see attached reports).

Therefore, the company should resolve all deficiencies and submit an updated MCESD Compliance Status Report confirming **full** compliance status.

Staff would like to use this opportunity to bring the following to your attention:

- Pursuant to the Arizona Administrative Code ("A.A.C.") R-14-2-411(C), the time-frame for administrative completeness review shall be suspended from the time the notice of deficiency is issued until staff determines that the application is complete. Upon meeting sufficiency requirements, the Commission has 150 calendar days for its substantive review. This includes conducting a hearing and preparing Opinion and Order to present to the Commission at an Open Meeting.

Please file your response to this Insufficiency Letter with Docket Control.

Valencia and Buckeye (Docket Nos. W-01212A-06-0666 and W-02451A-06-0666)

Insufficiency Letter

5/8/2007

Page 2 of 2

If you have any questions concerning this matter, please do not hesitate to contact me at 602-542-0840 or Katrin Stukov at 602-542-0941.

Very truly yours,

A handwritten signature in black ink, appearing to be 'BNC', written over a horizontal line that extends across the page.

Blessing N. Chukwu
Executive Consultant III

BNC

cc: Docket Control
Del Smith
Lyn Farmer
Brian Bozzo
Vicki Wallace



PUBLIC WATER SYSTEM COMPLIANCE STATUS REPORT

System Name: Sweetwater 2
PWS ID#: 07-129

Type of System: Community Number of POE's: 1 Surface Water: No
Number of Service Connections: 291 Population Served: 94

Assigned Monitoring Dates - Initial: 1/1/95 Phase II: 1/1/95 Phase V: 1/1/98

Does the water system have a Certified Operator? Yes

Does the system have major treatment plant deficiencies? No
Please describe: _____

Date of last inspection: July 8, 2004

Does the system have major O & M deficiencies? No
Please describe: System obtained emergency interim approval for connection to City of Goodyear on 1/12/07 due to nitrate MCL. System has submitted ATC applications for Goodyear connection and blending plan - both plans currently being reviewed by Ken James. System is effectively a consecutive system, serving water from City of Goodyear only, pending approval of plans described above. Corrections from last inspection have been documented. System must update MSSP and include DBP sampling plan and submit to Dept to review. System has arsenic levels which will exceed the new MCL.

Does the system have water quality monitoring/reporting deficiencies? No
Please describe: System has Nitrate MCL exceedance but is now serving Goodyear water

General Public Water System Compliance Status? **Substantial Compliance**

Date of compliance review: 04/19/07 By: **Mike Mallette** Initials: **MKM**
Phone: **(602) 506-6644**

Requested By: _____ Fax Number/ Contact: _____ Tracking Number: _____
Supervisor Initials: _____ Date: _____



PUBLIC WATER SYSTEM COMPLIANCE STATUS REPORT

System Name: Bulfer Water System
PWS ID#: 07-114

Type of System: Community Number of POE's: 1 Surface Water: n/a
Number of Service Connections: 84 Population Served: 246

Assigned Monitoring Dates - Initial: 1/1/95 Phase II: 1/1/95 Phase V: 1/1/98

Does the water system have a Certified Operator? yes

Does the system have major treatment plant deficiencies? No
Please describe: _____

Date of last inspection: November 1, 2006

Does the system have major O & M deficiencies? No
Please describe: system is implementing Backflow prevention plan as a result of Coliform MCL exceedance.

Does the system have water quality monitoring/reporting deficiencies? No
Please describe: System shows a nitrate concentration of 6.3mg/L 1st Q of 2007. System must begin quarterly sampling for nitrate.

General Public Water System Compliance Status? Substantial Compliance

Date of compliance review: 3/08/07 By: Duncan Wright Initials: dw
Phone: (602) 506-5173

Requested By: ACC Fax Number/ Contact: _____ Tracking Number: 1250
Supervisor Initials: GY Date: 3/12/07