



0000074361

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**BEFORE THE ARIZONA CORPORATION COMMISSION**

MIKE GLEASON  
Chairman  
WILLIAM A. MUNDELL  
Commissioner  
JEFF HATCH-MILLER  
Commissioner  
KRISTIN K. MAYES  
Commissioner  
GARY PIERCE  
Commissioner

Arizona Corporation Commission

**DOCKETED**

**JUN 28 2007**

DOCKETED BY	nr
-------------	----

IN THE MATTER OF INTERCONNECTION )  
OF DISTRIBUTED GENERATION )  
FACILITIES IN THE GENERIC )  
INVESTIGATION OF DISTRIBUTED )  
GENERATION. )

DOCKET NO.E-00000A-99-0431  
DECISION NO. 69674  
ORDER

Open Meeting  
June 26 and 27, 2007  
Phoenix, Arizona

BY THE COMMISSION:

FINDINGS OF FACT

Introduction

1. Commission Decision No. 67744 directed Staff to schedule workshops to consider outstanding issues concerning distributed generation ("DG"). The first issue to be addressed by the workshops was DG interconnection. Workshops were held on July 8, 2005; August 26, 2005; September 23, 2005; October 21, 2005; November 18, 2005; December 15, 2005; and March 17, 2006. Participants in the Workshops included representatives from utilities, government agencies, energy efficiency and environmental advocacy groups, utility investors, large industrial consumers, advocates for renewable resources, competitive power providers, advocates for distributed generation, product suppliers, research entities, and others.

...  
...  
...

1           2.       In addition, the Energy Policy Act of 2005 requires each state regulatory authority  
2 to consider certain PURPA<sup>1</sup> standards, including one on interconnection. The Commission may  
3 decline to implement the standard or adopt a modified standard. The Commission was required to  
4 begin its consideration by August 8, 2006, and must complete its consideration by August 8, 2007.  
5 On January 23, 2006, Staff filed a memo in Docket Control that interconnection was being  
6 addressed in Docket No. E-00000A-99-0431.

7           3.       The Workshop participants developed an Interconnection Document that includes  
8 proposed processes and procedures for standardizing the interconnection of DG facilities of 10  
9 MW or less. It was a difficult process that led to facilitating the installation of distributed  
10 generation while protecting the reliability and safety of the grid.

11          4.       On January 24, 2007, Staff filed a Staff Report which contained its proposed  
12 version of the Interconnection Document. There were some parts of the document in which the  
13 group could not achieve consensus. Staff chose positions for those issues and made other changes  
14 as described in the Staff Report. The Staff Report also contained descriptions of each section in  
15 the Interconnection Document as well as participant positions on the controversial issues. In  
16 addition, Staff made minor edits throughout the Interconnection Document.

17          5.       In the Staff Report, Staff recommended that the Commission adopt a modified  
18 version of the PURPA standard on interconnection that would apply to all electric distribution  
19 companies in Arizona that are regulated by the Commission. Staff also recommended that the  
20 Commission direct Staff to begin a rulemaking process to convert the Interconnection Document  
21 into rules. In addition, Staff recommended that the electric distribution companies use the  
22 Interconnection Document as a guide for interconnecting DG facilities until such time as  
23 interconnection rules go into effect.

24          6.       On January 30, 2007, Staff issued a letter that requested comments from interested  
25 parties on the proposed Interconnection Document. Comments were to be filed on or before  
26 February 21, 2007. Comments were received by Arizona Municipal Power Users' Association

27 \_\_\_\_\_  
28 <sup>1</sup> Public Utility Regulatory Policies Act of 1978.

1 ("AMPUA"), Arizonans for Electric Choice and Competition ("AECC"), the Cooperatives,<sup>2</sup> the  
 2 DG Advocates,<sup>3</sup> the Joint Utilities,<sup>4</sup> and UniSource Energy.<sup>5</sup> The comments are summarized in the  
 3 discussions below.

4 **Consideration of the PURPA Standard on Interconnection**

5 7. The Energy Policy Act of 2005 requires each state regulatory authority to consider  
 6 a PURPA standard on interconnection. The standard would apply to utilities with greater than  
 7 500,000 MWh in annual retail sales. The Commission may decline to implement the standard or  
 8 adopt a modified standard. The standard is as follows:

9 *Each electric utility shall make available, upon request, interconnection service to*  
 10 *any electric consumer that the electric utility serves. For purposes of this*  
 11 *paragraph, the term 'interconnection service' means service to an electric consumer*  
 12 *under which an on-site generating facility on the consumer's premises shall be*  
 13 *connected to the local distribution facilities. Interconnection services shall be*  
 14 *offered based upon the standards developed by the Institute of Electrical and*  
 15 *Electronics Engineers: IEEE Standard 1547 for Interconnecting Distributed*  
 16 *Resources with Electric Power Systems, as they may be amended from time to time.*  
 17 *In addition, agreements and procedures shall be established whereby the services*  
 18 *are offered shall promote current best practices of interconnection for distributed*  
 19 *generation, including but not limited to practices stipulated in model codes adopted*  
 20 *by associations of state regulatory agencies. All such agreements and procedures*  
 21 *shall be just and reasonable, and not unduly discriminatory or preferential.*

22 <sup>2</sup> The Grand Canyon State Electric Cooperative Association filed comments on behalf of the Cooperatives which  
 23 include Duncan Valley Electric Cooperative, Inc.; Graham County Electric Cooperative, Inc.; Mohave Electric  
 24 Cooperative, Inc.; Navopache Electric Cooperative, Inc.; Sulphur Springs Valley Electric Cooperative, Inc.; and  
 25 Trico Electric Cooperative, Inc.

26 <sup>3</sup> The Distributed Energy Association of Arizona filed comments on behalf of the DG Advocates which include  
 27 Annan Group; the Arizona Solar Energy Industries Association; the Distributed Energy Association of Arizona;  
 28 Energy Innovations; the Greater Tucson Coalition for Solar Energy; the Intermountain Combined Heat and Power  
 Application Center; the Southwest Energy Efficiency Project; SunEdison; Venture Catalyst, Inc.; and Vote Solar.  
 Some of the members of the DG Advocates who filed these comments are different from the members of the DG  
 Advocates who participated in the Workshops.

<sup>4</sup> Arizona Public Service Company filed comments on behalf of the Joint Utilities which include Arizona Public  
 Service Company; Duncan Valley Electric Cooperative, Inc.; Graham County Electric Cooperative, Inc.; Mohave  
 Electric Cooperative, Inc.; Navopache Electric Cooperative, Inc.; Sulphur Springs Valley Electric Cooperative, Inc.;  
 and Trico Electric Cooperative, Inc.

<sup>5</sup> UniSource Energy includes Tucson Electric Power Company and UNS Electric, Inc.

1           8.       The Commission is required to consider the three purposes of PURPA in its  
2 determination of whether to adopt the interconnection standard. The three purposes of PURPA are  
3 as follows:

- 4                   •       conservation of energy supplied by electric utilities,
- 5                   •       optimal efficiency of electric utility facilities and resources, and
- 6                   •       equitable rates for electric consumers

7           9.       Having interconnection standards may facilitate the installation of DG and thus  
8 reduce the amount of energy to be supplied by electric utilities. The presence of DG may improve  
9 the efficiency of electric utility facilities and thus reduce costs for electric consumers.

10          10.       Staff's proposed Interconnection Document is consistent with the PURPA standard  
11 in that it includes reference to IEEE<sup>6</sup> Standard 1547; however, the Interconnection Document also  
12 includes references to other standards, including other IEEE standards. In addition, the  
13 Interconnection Document addresses features of agreements and the procedures for  
14 interconnection.

15          11.       Staff recommended in the Staff Report that the Commission adopt a modified  
16 version of the PURPA standard on interconnection. The modified standard would be as follows:

17               *Each electric utility shall make available, upon request, interconnection service to*  
18               *any electric consumer that the electric utility serves. For purposes of this*  
19               *paragraph, the term 'interconnection service' means service to an electric consumer*  
20               *under which an on-site generating facility on the consumer's premises shall be*  
21               *connected to the local distribution facilities. Interconnection services shall be*  
22               *offered based upon the Arizona Corporation Commission's rules for*  
23               *interconnection when such rules are adopted and become effective. Until such*  
24               *rules are adopted and become effective, the Interconnection Document shall serve*  
25               *as a guide for interconnection unless otherwise ordered by the Commission.*

26          12.       Staff's proposed standard would apply to all electric distribution companies in  
27 Arizona that are regulated by the Commission. This would be in contrast to the PURPA standard  
28 that applies only to electric distribution companies with retail sales of more than 500,000 MWh.

29 ...

30 \_\_\_\_\_

<sup>6</sup> The Institute of Electrical and Electronics Engineers.

1           13.     The Cooperatives request that an exemption be granted to electric distribution  
2 companies with retail sales of less than 500,000 MWh because "these systems are not equipped  
3 with the manpower or financial resources to meet the requirements" of the standard. AMPUA  
4 agrees with the Cooperatives due to the operational and financial impacts on small electric  
5 distribution companies. While most AMPUA members are non-jurisdictional, AMPUA states that  
6 "actions of the Commission do set precedent and act as a public guide which influences the  
7 members of AMPUA which are non-jurisdictional." AECC supports Staff's recommendation that  
8 a modified version of the PURPA standard should apply to all Commission-jurisdictional utilities  
9 irrespective of size. AECC believes that the development and implementation of viable DG  
10 projects requires the application of the same fair and reasonable interconnection standards to all  
11 electric utilities regulated by the Commission.

12           14.     Staff continues to believe that the standard should apply to all jurisdictional electric  
13 distribution companies. A customer of a small electric utility may choose to install DG. Both the  
14 customer and the utility would benefit by the existence of interconnection standards to both  
15 streamline the interconnection process and ensure that the interconnection does not impair the  
16 safety and reliability of the grid.

17 **Discussion of Comments by Section of the Interconnection Document**

18           15.     The Interconnection Document describes procedures for customer-owned  
19 Generating Facilities with power ratings of 10 MW or less to connect with an electric distribution  
20 system. All sections of the Interconnection Document are summarized below along with  
21 discussion of the comments that were filed in response to the Interconnection Document as filed  
22 by Staff on January 24, 2007. The Interconnection Document is attached as an exhibit.

23 **1 Applicability**

24           16.     This section of the Document describes the generating facilities that could be  
25 interconnected to utility distribution systems using the procedures contained in the Document.

26 ...

27 ...

28 ...

1 1.1 Applicable Generating Facilities

2 17. This subsection states that the Document applies to generating facilities with a size  
3 of 10 MW or less interconnecting or applying to interconnect with electric public utilities subject  
4 to the jurisdiction of the Arizona Corporation Commission.

5 1.2 Types of Generating Facilities

6 18. A distributed generator can operate as either a Parallel system or as a Separate  
7 system in connection with the utility grid. With a Parallel System, the distributed generator is  
8 connected to the Utility's system (either on a continuous basis or momentarily), resulting in a  
9 transfer of power between the two systems. A Separate System is one in which there is no  
10 possibility of electrically connecting or operating the distributed generator in parallel with the  
11 Utility's system.

12 19. One type of a Parallel System is an Islandable System. An Islandable System is a  
13 Generating Facility interconnected to the Utility's system, where the Generating Facility is  
14 designed to serve part of the Utility grid that has become or is purposefully separated from the rest  
15 of the grid.

16 20. The Interconnection Document contains the following language: "*Currently there*  
17 *are no rules, standards, or protocols governing this type of system operation. As such, an*  
18 *Islandable System as defined herein is not allowed.*"

19 21. The DG Advocates suggest that Islandable Systems be recognized as the "legitimate  
20 approach to DG, and be given the proper consideration and response from utilities." The DG  
21 Advocates state that the Commission may revisit Islandable Systems after a successful balloting of  
22 IEEE Standard 1547.4. They claim that Islandable Systems already exist on the Arizona service  
23 grid, and that the terms and conditions of their operation are negotiated. The recognition would  
24 protect DG developers from arbitrary, irrelevant and costly negotiating postures from the utilities,  
25 and create a fair and level playing field. By recognizing Islandable Systems, Arizona would send a  
26 "clear message that it is responsive to the market-place and the growing concern with energy  
27 security."

28 ...

1           22.    The Joint Utilities strongly support the language in the Interconnection Document  
2 that disallows Islandable Systems for following reasons:

- 3           a.    there are no industry-wide rules, standards, or protocols governing this type of  
4           system;
- 5           b.    Islandable Systems present a safety hazard for utility personnel because it is a  
6           source of power that is not under the Utility's control;
- 7           c.    the Utility is unable to resynchronize with an islanded system;
- 8           d.    Islandable Systems present a potential for degradation of Utility power quality  
9           because the Generating Facility is not under the Utility's control; and
- 10          e.    Islandable Systems pose Utility reliability concerns.

11          23.    Staff agrees with the Joint Utilities on the topic of Islandable System. Industry-  
12 wide standards do not yet exist. The 1547.4<sup>7</sup> is still a draft standard. The safety and reliability  
13 issues are too important to ignore, and the Commission could revisit the issue in the future if  
14 warranted.

15 2. Rights and Responsibilities

16          24.    This section describes the rights and responsibilities of both the customer with a  
17 generating facility and the utility.

18 2.1 Customer Rights and Responsibilities

19          25.    This subsection describes the rights and responsibilities of a customer with a  
20 generating facility and desiring to interconnect it with the utility's grid. A customer has the right to  
21 interconnect with a utility's grid and the right to receive prompt and reasonable responses from the  
22 utility. The customer has responsibilities to provide information to the utility and meet various  
23 requirements that will help to maintain utility grid reliability and safety.

24 ...

25 ...

26 ...

27 <sup>7</sup> IEEE Standard 1547 was adopted by the Institute of Electrical and Electronics Engineers to establish criteria and  
28 requirements for interconnection of distributed resources with electric power systems; 1547.4 is a draft guide for  
design, operation, and integration of distributed resource island systems with electric power systems.

1 2.2 Utility Rights and Responsibilities

2 26. This subsection describes the utility's rights and responsibilities regarding  
3 interconnection. A utility is obligated to interconnect generating facilities, but also has the  
4 responsibility to safeguard its system, other consumers, and the general public.

5 27. In the subsection, Customer Rights and Responsibilities, there is a statement that  
6 the customer is responsible for all interconnection facilities required to be installed to interconnect  
7 the customer's generating facility to the utility system at the customer's sole expense. Staff  
8 believes that including the value of benefits when calculating costs may be beneficial; however, it  
9 may not always be practical to do so. The wording in the Document is as follows:

10 *If facility upgrades are needed to accommodate the Generating Facility, a Utility*  
11 *will reduce the charge to the customer by the amount of any benefits to the grid that*  
12 *are readily quantifiable.*

13 28. The Joint Utilities state that the quantification of any grid-specific benefits related  
14 to the generating facility depends on utility-specific information and circumstances. They believe  
15 that it is imperative that any such benefits be quantified by the utility to prevent other customers  
16 from providing a subsidy to DG. The Joint Utilities support Staff's language with the  
17 modifications as shown below:

18 *If facility upgrades are needed to accommodate the Generating Facility, a Utility*  
19 *will reduce the charge of the upgrade to the customer by the amount of any benefits,*  
20 *if any, to the grid that are readily quantifiable by the Utility.*

21 29. Staff finds the above language modifications proposed by the Joint Utilities to be  
22 acceptable.

23 30. The DG Advocates suggest including a quick and efficient process to resolve  
24 interconnection disputes between the utility and an applicant. They suggest language from Texas  
25 PUCT Rule 25.211(o) which requires the Texas Commission to attempt to resolve interconnection  
26 disputes informally within 20 days of filing. The DG Advocates believe that a similar process may  
27 prove useful for resolving disputes regarding facility upgrades. The Texas language is as follows:

28 ...



1 *Complaints relating to interconnection disputes under this section shall be handled*  
2 *in an expeditious manner pursuant to §22.242 (relating to Complaints). In*  
3 *instances where informal dispute resolution is sought, complaints shall be*  
4 *presented to the Electric Division. The Electric Division shall attempt to informally*  
5 *resolve complaints within 20 business days of the date of receipt of the complaint.*  
6 *Unresolved complaints shall be presented to the commission at the next available*  
7 *open meeting.*

8 31. Staff believes that the Texas language on dispute resolution is not necessary for  
9 Arizona. Section 3.8 of the Interconnection Document already contains language on dispute  
10 resolution; however, if the Interconnection Document were to be converted into rules, the Dispute  
11 Resolution subsection would be more appropriate to be placed in the Interconnection Agreements  
12 instead of in the rules.

13 32. Staff had also included the following language in the Interconnection Document:

14 *In addition, a Utility cannot reject an Application on the basis of distribution*  
15 *system conditions that are already deficient, or charge a Customer for facility*  
16 *upgrades that are overdue or soon to be required to ensure compliance with good*  
17 *utility practice, except that applications can be rejected in instances where*  
18 *reliability or safety would be further compromised by a DG installation.*

19 33. The Joint Utilities generally support the basic premise of the above language, but  
20 they propose modified language to allow the utility to continue to charge generating facilities for  
21 upgrades consistent with the manner in which it charges any of its customers. They believe that  
22 DG should be treated in a non-discriminatory fashion. Their proposed language is the following:

23 *In addition, a Utility cannot reject an Application on the basis of distribution*  
24 *system conditions that are already deficient, ~~or charge a Customer for facility~~*  
25 *~~upgrades that are overdue or soon to be required to ensure compliance with good~~*  
26 *~~utility practice, except that an Applications can be rejected in instances where~~*  
27 *~~reliability or safety would be further compromised by a DG installation. A Utility~~*  
28 *shall not charge a Generating Facility Customer differently than any other*  
*Customer for facility upgrades needed to ensure compliance with good Utility*  
*practices in accordance with generally applicable Commission approved tariffs and*  
*service schedules.*

31. Staff believes that a utility has an obligation to maintain its grid in good condition,  
and the utility should not unfairly block a DG installation. However, if reliability or safety would  
be further compromised by a DG installation, the utility has an obligation to prevent or delay the  
installation until the reliability or safety situation is alleviated, regardless of who is responsible for

1 the grid problem. Staff believes that DG should be treated in a non-discriminatory fashion, but  
2 that a utility should not take unfair advantage of a DG installation. Staff proposes to modify the  
3 language in the Interconnection Document as follows:

4 *In addition, a Utility cannot reject an Application on the basis of distribution*  
5 *system conditions that are already deficient, or charge a Customer for facility*  
6 *upgrades that are overdue or soon to be required to ensure compliance with good*  
7 *utility practice, except that applications can be rejected in instances where*  
8 *reliability or safety would be further compromised by a DG installation. A Utility*  
*shall not charge a Generating Facility Customer differently than any other*  
*Customer for facility upgrades in accordance with generally applicable*  
*Commission-approved tariffs.*

9 2.3 Easements/Rights of Way

10 35. The customer must provide or obtain and provide any easements and rights of way  
11 necessary for an interconnection.

12 2.4 Insurance

13 36. This subsection of the Document contains language regarding insurance as follows:

14 *The Customer is not required to provide general liability insurance coverage as a*  
15 *condition for Interconnection. Due to the risk of incurring damages, it is*  
16 *recommended that every Interconnection Customer protect itself with insurance or*  
17 *other suitable financial instrument sufficient to meet its construction, operating,*  
*and liability responsibilities. At no time shall the Utility require that the Customer*  
*negotiate any policy or renewal of any policy covering any liability through a*  
*particular insurance provider, agent, solicitor, or broker.*

18 *The inability of the Utility to require the Customer to provide general liability*  
19 *insurance coverage for operation of the Generating Facility is not a waiver of any*  
20 *rights the Utility may have to pursue remedies at law against the Customer to*  
*recover damages.*

21  
22 37. The Joint Utilities strongly recommend that there be an insurance requirement.  
23 They believe that not having the requirement creates a potentially enormous risk to both the  
24 interconnection customer and the utility (and its customers) from third-party personal injury  
25 claims. In addition, they state that an insurance requirement is not redundant to an indemnification  
26 provision in an interconnection contract. An indemnification provision is an agreement to assume  
27 financial responsibility for liability, while insurance addresses the financial ability to honor the  
28 indemnification responsibility. The Joint Utilities propose the following language:

1        *The Customer shall maintain public liability and property damage insurance in*  
2        *amounts not less than ONE MILLION DOLLARS (\$1,000,000) per occurrence.*  
3        *Residential customers who operate a static inverter based Generating Facility rated*  
4        *less than 50 kW are exempt from this requirement. At no time shall the Utility*  
5        *require that the Customer negotiate any policy or renewal of any policy covering*  
6        *any liability through a particular insurance company, agent, solicitor, or broker.*

5        38.     The DG Advocates had stated in an earlier position paper that any owner of  
6        interconnected distributed generation equipment will already have sufficient general liability  
7        insurance to cover the "infinitesimal" risk that its operation will result in a liability claim. They  
8        support a simple attestation on the interconnection application form that the owner or operator has  
9        in place a general liability insurance policy. The DG Advocates point out that other states have  
10       rejected the need for DG owners to hold additional insurance. They believe that DG owners  
11       should decide how much insurance they want to hold to protect their equipment. Each side of the  
12       interconnection should protect themselves. The DG Advocates believe that an insurance  
13       requirement also creates an arbitrary financial burden.

14       39.     Staff supports the language in the Interconnection Document. The language (based  
15       on the NARUC interconnection model) alerts customers about their liability responsibilities  
16       without creating an undue burden on the customer.

17       2.5 Non-Circumvention

18       40.     This subsection provides that information given to the utility for interconnection to  
19       only be used for that purpose. The language is as follows:

20       *A utility and its affiliates shall not use knowledge of proposed distributed*  
21       *generation projects submitted to it for interconnection or study to initiate*  
22       *competing proposals to the customer that offer either discounted rates in return for*  
23       *not installing the distributed generation, or offer competing distributed generation*  
24       *projects. Customers are not precluded from sharing information in their*  
25       *possession regarding a potential distributed generation project with a utility or its*  
26       *affiliates, or from using information regarding a potential distributed generation*  
27       *project to negotiate a discounted rate or other mutually beneficial arrangement*  
28       *with a utility or its affiliates.*

26       41.     AECC had supplied the above language and believes that it represents the  
27       appropriate standard for protection of customer rights with respect to their information regarding  
28       DG projects.

1           42.     The Joint Utilities propose that the following language be added to clarify that the  
2 above language does not preclude the utility from keeping the customer informed of all current and  
3 pending rate schedules that may be applicable to the customer:

4           *The Utility shall be permitted to inform the Customer of existing or pending*  
5 *(awaiting approval by the ACC) rate schedules that may economically benefit or*  
6 *otherwise affect the Customer's project.*

7           43.     The DG Advocates believe that the language in the Interconnection Document does  
8 not offer protection to a DG project developer. They mention a case where the Commission had  
9 approved a utility offer to a customer not to install DG. They propose the following language:

10           *A Utility and/or its affiliates shall not use information or knowledge of proposed*  
11 *distributed generation projects submitted to it for interconnection or study to*  
12 *initiate competing proposals to the customer that offer either discounted rates in*  
13 *return for not installing the distributed generation, or offer competing distributed*  
14 *generation projects, unless the rate offered is pursuant to an existing published*  
15 *tariff rate and the rate is available to all other customers in that rate class.*

16           *Customers are not precluded from sharing information in their possession*  
17 *regarding a potential distributed generation project with a utility or its affiliates, or*  
18 *from using information regarding a potential distributed generation project to*  
19 *negotiate a discounted rate or other mutually beneficial arrangement with a utility*  
20 *or its affiliates, so long as any negotiated discounted rates or arrangements are 1)*  
21 *pursuant to an existing published tariff rate, or 2) available to all other customers*  
22 *in that rate class.*

23           44.     As an alternative, the DG Advocates propose that at a minimum the language  
24 should acknowledge that neither the customer nor the utility should be allowed to disclose or  
25 discuss any information that the DG developer has contractually designated as confidential.

26           45.     Staff supports the language in the Interconnection Document. It does not allow the  
27 utility to initiate competing proposals, but it allows a customer to negotiate with the Utility for a  
28 discounted rate if it so chooses. Any negotiated rate would have to be approved by the  
Commission before going into effect. The Commission only approves such a rate if it is in the  
public interest. Staff only recommends approval of a special contract containing a discounted rate  
if the customer has a viable alternative to the tariffed rate, and other ratepayers would benefit by  
the customer remaining on the Utility's system. Similarly situated customers are treated equally.

1 A discounted rate is recommended only for a customer in a situation that is not similar to the  
2 situation of other customers.

3 46. Staff agrees with the addition of the language proposed by the Joint Utilities. The  
4 customer should be informed about existing or pending rate schedules. Staff rejects the DG  
5 Advocates' alternative language because the Commission should not have to remind someone to  
6 honor a contract.

7 3. General Process and Procedures for All Levels

8 47. This section contains the general process and procedures to be used for all  
9 interconnections regardless of the three interconnection tracts.

10 3.1 Designation of Contact Persons

11 48. Each customer applying for interconnection and each utility shall designate a  
12 contact person or persons. The utility will also provide its contact names to the Commission and  
13 on the utility's website.

14 3.2 Non-discrimination

15 49. The utility shall process all applications for interconnection in a non-discriminatory  
16 manner.

17 3.3 Application Submission Requirements

18 50. This subsection describes some additional information that may be required by the  
19 utility.

20 3.4 Minor Modifications

21 51. Minor modifications to an application are allowed without the application being  
22 considered incomplete or treated as new.

23 3.5 Certification

24 52. In order for equipment to qualify as "certified," it must comply with specific codes  
25 and standards and other requirements listed in this subsection.

26 ...

27 ...

28 ...

1 3.6 No Additional Requirements

2 53. A utility may not require additional controls or tests if a customer's generating  
3 facility complies with all requirements in the Interconnection Document, unless agreed to by the  
4 parties or required by the Commission.

5 3.7 Disconnect from or Reconnect with the Grid Procedure

6 54. This subsection lists the conditions under which a utility may disconnect a  
7 customer's generating facility from the utility system. Those conditions are: (a) expiration or  
8 termination of the Interconnection Agreement; (b) non-compliance with the technical  
9 interconnection requirements; (c) system emergency; (d) routine maintenance, repairs, and  
10 modifications; and (e) absence of executed Interconnection Agreement.

11 55. The DG Advocates had previously proposed that a paragraph on incremental  
12 demand charges be included in this subsection of the Document. The paragraph was the  
13 following:

14 *During the term of an Interconnection Agreement a Utility may require that a*  
15 *Customer disconnect its Generating Facility and/or take it off-line as a result of*  
16 *Utility system conditions described in subsection (c) and (d) above. Incremental*  
17 *demand charges arising from disconnecting the Generating Facility as directed by*  
18 *the Utility during such periods shall not be assessed by Utility to the Customer.*

19 56. Staff had not included the above paragraph in the Interconnection Document filed  
20 on January 24, 2007. The Joint Utilities strongly agree with Staff that the proposed paragraph  
21 should not be included in the Document since the issue of incremental demand charges has not  
22 been fully vetted with the current Workshop participants. In addition, they believe that it is a rates  
23 issue which does not belong in a technical interconnection document.

24 57. The DG Advocates believe that the issue of incremental demand charges is not a  
25 rate issue because they did not propose reduced or modified demand charges when the utility takes  
26 a customer's DG system offline; instead, they proposed that no incremental demand charges be  
27 assessed.

28 58. Staff continues to agree with the Joint Utilities that the DG Advocates' proposed  
language on incremental demand charges should not be included in the Interconnection Document.

1 Whether or not to assess a demand charge is a rate issue. The topic of rates in regard to DG will  
2 be addressed separately. Many of the participants in the DG Workshops to date are those with  
3 expertise in the technical/engineering field rather than in the accounting/ratemaking field.

#### 4 3.8 Dispute Resolution

5 59. This subsection describes the steps that would be followed in the event of a dispute.  
6 Those steps are notification and response, good faith negotiation, dispute resolution by mediation,  
7 and the Arizona Corporation Commission.

8 60. If the Interconnection Document were to be converted into rules, the Dispute  
9 Resolution subsection would be more appropriate to be placed in the Interconnection Agreements  
10 instead of in the rules.

#### 11 Other Issues

12 61. The DG Advocates had previously proposed adding subsection 3.9 which would  
13 consist of two parts: **Distribution or transmission line charge** and **Interconnection operations**  
14 **and maintenance costs**. The language was as follows:

15 *Distribution or transmission line charge. No distribution or transmission line*  
16 *charge shall be assessed to a customer for exporting energy to the utility system.*  
17 *For purposes of this paragraph distribution and transmission charges means*  
*access and line charges, transformation charges, and line loss charges.*

18 *Interconnection operations and maintenance costs. No charge for operation and*  
19 *maintenance of the utility system's facilities shall be assessed against a customer*  
*for exporting energy to the utility system.*

20 62. Staff had not included the above paragraphs in the Interconnection Document filed  
21 on January 24, 2007, because the topic of rates in regard to DG will be addressed separately.  
22 Many of the participants in the DG Workshops to date are those with expertise in the  
23 technical/engineering field rather than in the accounting/ratemaking field.

24 63. The Joint Utilities believe that the issues of transmission line charges, operations  
25 costs, and maintenance costs should not be included in the Interconnection Document since the use  
26 of transmission facilities is FERC jurisdictional and subject to FERC transmission rates. In  
27 addition, they believe that it is a rate issue, and there is no justification why generating facility  
28

1 customers should receive different and more favorable rate treatment than any other customer  
2 using the utility's distribution or transmission system.

3         64. The DG Advocates state that there are two issues. The first issue is whether such  
4 charges are appropriate at all. Secondly, what should those charges be if the first issue is resolved  
5 in favor of the utilities. The DG Advocates claim that the Staff recommendation, taken at face  
6 value, appears to de facto decide that access and line charges, transformation charges, line loss  
7 charges, and charges for operation and maintenance of the utility system's facilities are already  
8 acceptable. They state that they do not believe that this was Staff's intent. The DG Advocates  
9 believe that when a DG facility produces energy in excess of its consumption and exports it to the  
10 grid, the utility will not have to deliver that energy across its transmission and distribution  
11 facilities, thus reducing the load on the utility's existing systems.

12         65. Staff continues to believe that the DG Advocates' proposed language on distribution  
13 or transmission line charge and interconnection operations and maintenance costs should not be  
14 included in the Interconnection Document. Staff clarifies that it has not decided whether such  
15 charges are appropriate. The appropriateness of such charges is a rate issue, and the topic of rates  
16 in regard to DG will be addressed separately.

17 4. Specific Process and Procedures for Each Level

18         66. This section provides the process and procedures for three interconnection levels or  
19 tracks.

20 4.1 Summary of Interconnection Levels/Tracks

21         67. This subsection defines the three interconnection levels or tracts. Level 1 is the  
22 Super Fast Track for the least complex interconnections and facilities with a power rating of 10  
23 kW or less. Level 2 is the Fast Track for interconnections that are more complex and facilities  
24 with a power rating of 2 MW or less. Level 3 is the Study Track for the most complex  
25 interconnections and facilities having a power rating of 10 MW or less. Each level progressively  
26 has more requirements.

27 ...

28 ...



1           68. Also contained here is a paragraph about generating facilities being allowed on  
2 distribution networks on a trial basis at the discretion of the utility. Additional details are in  
3 subsection 4.6.

4 4.2 Screens

5           69. This subsection lists nine screens or technical criteria that are used to determine  
6 which level or track the interconnection application will follow. To qualify for the Level 1 Super  
7 Fast Track, the fifth and sixth screens must be met. To qualify for the Level 2 Fast Track, all nine  
8 screens must be met. All proposed generating facilities that do not meet the screens for the other  
9 levels would go through the Level 3 Study Track.

10 4.3 Level 1 Super Fast Track Process

11           70. This subsection describes the steps and timeline of the Level 1 Super Fast Track  
12 process. The first step is the customer submitting an application. The utility then receives the  
13 application and notifies the customer as to whether the application is complete or incomplete. The  
14 utility reviews the complete application. After approval of the application, an Interconnection  
15 Agreement is signed. The utility performs a site inspection. After the generating facility meets all  
16 applicable requirements, the utility notifies the customer of approval for parallel operation or of  
17 any deficiencies. If the generating facility does not pass the initial site inspection, the customer  
18 corrects outstanding issues and schedules a re-inspection.

19 4.4 Level 2 Fast Track Process

20           71. This subsection describes the steps and timeline of the Level 2 Fast Track process.  
21 The customer is encouraged to contact the utility to discuss the project prior to applying for  
22 interconnection. The customer then submits an application. The utility receives the application  
23 and notifies the customer as to whether the application is complete or incomplete. The utility  
24 reviews the complete application. After approval of the application, an Interconnection Agreement  
25 is signed. The utility performs a site inspection. After the generating facility meets all applicable  
26 requirements, the utility notifies the customer of approval for parallel operation or of any  
27 deficiencies. If the generating facility does not pass the initial site inspection, the customer  
28 corrects outstanding issues and schedules a re-inspection.

1 Timelines

2 72. The Cooperatives had previously proposed adding the words "*normally not more*  
3 *than*" before the number of business days in the Level 2 process for the five business days to  
4 determine whether an application is complete and the 15 business days to review the application  
5 and notify the customer of the result.

6 73. The DG Advocates had opposed any softening of the timeframes in the Level 2  
7 process. Level 3 timeframes had been softened to reflect the fact that Level 3 interconnections can  
8 be more complicated or variable. However, the Level 1 and Level 2 processes only apply to  
9 simpler and problem-free interconnections.

10 74. Staff had not included the Cooperatives' proposed language in the Interconnection  
11 Document filed on January 24, 2007. If the Level 2 timeframes are set at reasonable levels, they  
12 should be firm.

13 75. The Cooperatives continue to propose, and AMPUA supports, the language  
14 "*normally not more than*" for the following reasons:

- 15 a. The Level 2 time frames may be set at reasonable levels for large utilities, but small  
16 municipal and other non-jurisdictional electric distribution companies as well as  
17 cooperatives may not have the level of staff or expertise to process the applications  
18 in the listed time frames.
- 19 b. There is the potential of having to process a very complicated system under level 2.  
20 There may be a need to consult an expert in generators and/or protection equipment  
21 to determine the completeness of an application.
- 22 c. More time may be needed when several applications are filed within a short amount  
23 of time or when an employee or consultant with specific expertise is not available.
- 24 d. An application may meet all of the screens for Level 2, but the utility will need to look  
25 at its own system to see if any changes need to be made to accommodate the generator.  
26 Examples are needing to modify breaker settings or needing to install a capacitor to  
27 correct power factor problems.

28 76. Staff continues to agree with the DG Advocates on this issue. If the Level 2  
timeframes are set at reasonable levels, they should be firm. If a project is more complex than a  
typical Level 2 project and requires extra time to process, it should be moved to Level 3 unless the  
customer agrees that the Utility can have more time in Level 2.

1 Application Fees

2 77. Staff included the following sentence in the Interconnection Document filed on  
3 January 24, 2007:

4 *A Utility may charge an application fee, if a tariff containing such a fee is approved*  
5 *by the Commission.*

6 78. The Joint Utilities support the proposal on application fees and recommend that  
7 initial tariffs be approved during the compliance phase of the rulemaking portion of this  
8 proceeding. The DG Advocates concur in setting these fees in a process before the Commission.  
9 Staff believes that a utility could file a request for Commission approval of a tariff containing an  
10 application fee at any time.

11 Additional Review

12 79. When a generating facility has failed to meet one or more of the screens, the utility  
13 may offer to perform an "Additional Review" (typically about three hours of study) to determine  
14 whether minor modifications to the electric distribution system would enable the interconnection  
15 to be made consistent with safety, reliability, and power quality. The utility would provide to the  
16 customer a non-binding, good faith estimate of the costs of such Additional Review and/or such  
17 minor modifications. The utility would not undertake the Additional Review or minor  
18 modifications until the customer consents to pay for the review and/or modifications.

19 80. Staff had included the following language in the Interconnection Document filed on  
20 January 24, 2007:

21 *A Utility may charge a fee for an Additional Review, if a tariff containing the hourly*  
22 *rate for Additional Review is approved by the Commission. In addition, costs for*  
23 *Utility facilities and/or equipment modifications necessary to accommodate the*  
*Customer's generator interconnection will be the responsibility of the Customer.*

24 81. The Joint Utilities believe that the utility should be permitted to collect the  
25 estimated costs for any additional review from the customer prior to conducting such review. This  
26 would ensure that the customer is serious about the project and alleviates any issues associated  
27 with collecting dollars after the review is performed. The Joint Utilities also recommend that  
28 initial tariffs be approved during the compliance phase of the rulemaking portion of this

1 proceeding They propose the following modifications to the language in the Interconnection  
2 Document:

3 *A Utility may charge a fee for an Additional Review, if a tariff containing the hourly*  
4 *rate for Additional Review is approved by the Commission. Upon receipt of the*  
5 *Utility's non-binding good faith estimate of the costs of such additional review, the*  
6 *Customer must agree in writing within 15 Business Days of the offer and submit a*  
7 *deposit for the estimated costs. The Customer must pay any review costs that*  
8 *exceed the deposit within 20 Business Days of receipt of the invoice. In addition,*  
9 *costs for Utility facilities and/or equipment modifications necessary to*  
10 *accommodate the Customer's generator interconnection will be the responsibility of*  
11 *the Customer.*

12 82. Staff agrees that the utility should provide an estimate of the cost of an additional  
13 review and that the customer should pay a deposit before the work begins. However, Staff is not  
14 sure that the time limits should be imposed on the customer. Staff proposes the following  
15 language:

16 *A Utility may charge a fee for an Additional Review, if a tariff containing the hourly*  
17 *rate for Additional Review is approved by the Commission. The Utility shall*  
18 *provide a non-binding good faith estimate of the fee for such additional review.*  
19 *The Customer must submit a deposit for the estimated fee before the Additional*  
20 *Review will be initiated. In addition, costs for Utility facilities and/or equipment*  
21 *modifications necessary to accommodate the Customer's generator interconnection*  
22 *will be the responsibility of the Customer.*

#### 23 Inspections and Re-inspections

24 83. After approval of the application and an Interconnection Agreement is signed, the  
25 utility performs a site inspection within ten business days of request from the customer. Staff  
26 included the following sentence in the Interconnection Document filed on January 24, 2007:

27 *A Utility may charge for the initial site inspection, if a tariff containing such a fee is*  
28 *approved by the Commission.*

84. If the Generating Facility does not pass the initial site inspection, the customer  
corrects outstanding issues and schedules a re-inspection. Staff included the following sentence in  
the Interconnection Document filed on January 24, 2007:

*A Utility may charge for a re-inspection, if a tariff containing such a fee is*  
*approved by the Commission.*

1           85.     The Joint Utilities support the proposals on both inspection and re-inspection fees  
2 and recommends that initial tariffs be approved during the compliance phase of the rulemaking  
3 portion of this proceeding. Staff believes that a utility could file a request for Commission  
4 approval of a tariff containing an inspection or re-inspection fee at any time.

5 4.5 Level 3 Study Track Process

6           86.     This subsection describes the steps and timeline of the Level 3 Study Track process.  
7 The customer is encouraged to contact the utility to discuss the project prior to applying for  
8 interconnection. The customer then submits an application. The utility receives the application  
9 and notifies the customer as to whether the application is complete or incomplete. The utility  
10 reviews the complete application. If further information is needed, a scoping meeting is held  
11 where the customer describes the proposed generating facility design and the utility talks about  
12 system conditions at the proposed point of interconnection. The utility will send an  
13 acknowledgement letter about the scope to the customer upon request. If requested by the  
14 customer, the utility undertakes an interconnection feasibility study to provide a preliminary  
15 review of potential impacts resulting from the proposed interconnection. If deemed necessary by  
16 either party, the utility undertakes a system impact study which is a full engineering review of all  
17 aspects of the generator's impact on the utility system. If deemed necessary by the utility, the  
18 utility undertakes a facilities study which is a comprehensive analysis of the actual construction  
19 needed to take place based on the outcome of the impact study. After all requirements are met and  
20 all items identified in the studies are resolved, an Interconnection Agreement is signed. The utility  
21 performs a site inspection and witnesses the testing of protective devices. After the utility verifies  
22 that the generating facility is in compliance with all applicable requirements, the utility notifies the  
23 customer of approval for parallel operation or of any deficiencies. If the generating facility does  
24 not pass the initial site inspection, the customer corrects outstanding issues and schedules a re-  
25 inspection.

26 Application Fees

27           87.     Staff included the following sentence in the Interconnection Document filed on  
28 January 24, 2007:

1 *A Utility may charge an application fee, if a tariff containing such a fee is approved*  
2 *by the Commission.*

3 88. The Joint Utilities support the proposal on application fees and recommend that  
4 initial tariffs be approved during the compliance phase of the rulemaking portion of this  
5 proceeding. Staff believes that a utility could file a request for Commission approval of a tariff  
6 containing an application fee at any time.

7 Engineering Review

8 89. Staff included the following language in the Interconnection Document filed on  
9 January 24, 2007:

10 *A Utility may charge a fee for an engineering review, if a tariff containing the*  
11 *hourly rate for engineering review is approved by the Commission. In addition,*  
12 *costs for Utility facilities and/or equipment modifications necessary to*  
13 *accommodate the Customer's generator interconnection will be the responsibility of*  
*the Customer. The Customer may not be charged for the review of a certified*  
*generator's protection equipment.*

14 90. The Joint Utilities believe that the utility should be permitted to collect the  
15 estimated costs for engineering reviews from the customer prior to conducting such review. This  
16 would ensure that the customer is serious about the project and alleviates any issues associated  
17 with collecting dollars after the review is performed. The Joint Utilities also recommend that  
18 initial tariffs be approved during the compliance phase of the rulemaking portion of this  
19 proceeding. They propose the following modifications to the language in the Interconnection  
20 Document:

21 *A Utility may charge a fee for an engineering review, if a tariff containing the*  
22 *hourly rate for engineering review is approved by the Commission. Upon receipt of*  
23 *the Utility's non-binding good faith estimate of the costs of such engineering*  
24 *review, the Customer must agree in writing within 15 Business Days of the offer*  
25 *and submit a deposit for the estimated costs. The Customer must pay any review*  
26 *costs that exceed the deposit within 20 Business Days of receipt of the invoice. In*  
*addition, costs for Utility facilities and/or equipment modifications necessary to*  
*accommodate the Customer's generator interconnection will be the responsibility of*  
*the Customer. The Customer may not be charged for the review of a certified*  
*generator's protection equipment.*

27 91. Staff agrees that the utility should provide an estimate of the cost of an engineering  
28 review and that the customer should pay a deposit before the work begins. However, Staff is not

1 sure that the time limits should be imposed on the customer. Staff proposes the following  
2 language:

3 *A Utility may charge a fee for an engineering review, if a tariff containing the*  
4 *hourly rate for engineering review is approved by the Commission. The Utility*  
5 *shall provide a non-binding good faith estimate of the fee for such engineering*  
6 *review. The Customer must submit a deposit for the estimated fee before the*  
7 *engineering review will be initiated. In addition, costs for Utility facilities and/or*  
8 *equipment modifications necessary to accommodate the Customer's generator*  
9 *interconnection will be the responsibility of the Customer. The Customer may not*  
10 *be charged for the review of a certified generator's protection equipment.*

### 8 Inspections and Re-inspections

9 92. After approval of the application and an Interconnection Agreement is signed, the  
10 utility performs a site inspection within ten business days of request from the customer. Staff  
11 included the following sentence in the Interconnection Document filed on January 24, 2007:

12 *A Utility may charge for the initial site inspection, if a tariff containing such a fee is*  
13 *approved by the Commission.*

14 93. If the Generating Facility does not pass the initial site inspection, the customer  
15 corrects outstanding issues and schedules a re-inspection. Staff included the following sentence in  
16 the Interconnection Document filed on January 24, 2007:

17 *A Utility may charge for a re-inspection, if a tariff containing such a fee is*  
18 *approved by the Commission.*

19 94. The Joint Utilities support the proposals on both inspection and re-inspection fees  
20 and recommends that initial tariffs be approved during the compliance phase of the rulemaking  
21 portion of this proceeding. Staff believes that a utility could file a request for Commission  
22 approval of a tariff containing an inspection or re-inspection fee at any time.

23 95. If updated documentation is required to reflect "as-built" conditions, the Customer  
24 submits it to the Utility for review and approval. Staff included the following sentence in the  
25 Interconnection Document filed on January 24, 2007:

26 *The Utility may charge a fee, if a tariff containing such a fee is approved by the*  
27 *Commission.*

28 ...

1           96.     The Joint Utilities support the above language and recommend that initial tariffs be  
2 approved during the compliance phase of the rulemaking portion of this proceeding. Staff believes  
3 that a utility could file a request for Commission approval of a tariff containing a correction fee at  
4 any time.

5 4.6 Interconnection to Secondary Spot Network Systems

6           97.     This subsection describes a pilot program that Arizona Public Service Company  
7 ("APS") has developed for interconnecting a small amount of inverter-based customer generation  
8 to a Secondary Spot Network System. Currently, APS is the only utility in Arizona that has a  
9 Secondary Spot Network System.

10 5. Utility Reporting Requirements

11           98.     This subsection describes an Interconnection Manual that each utility would file for  
12 Commission approval within 90 days after adoption of the Interconnection Document. Each  
13 Utility would also maintain records concerning applications for interconnection. In addition, Staff  
14 had included language in the Interconnection Document that provided for an annual  
15 interconnection report. The language is the following:

16           *By March 30 of each year, every Utility shall file with the Commission a distributed*  
17 *generation Interconnection report for the preceding calendar year that lists the new*  
18 *Generating Facilities interconnected with the system since the previous year's*  
19 *report, any distributed generation facilities no longer interconnected with the*  
20 *Utility's system since the previous report, and the capacity of each facility. The*  
21 *annual report shall include, for the reporting period, a summary of the number of*  
22 *complete Applications received, the number of complete Applications approved, the*  
23 *number of complete Applications denied by level, and the reasons for denial.*

24           99.     The Joint Utilities support the above language and believe that the reporting  
25 requirements, as proposed, will not place an undue burden on the Utility.

26           100.    UniSource Energy proposes that the reasons for denial listed in the annual report be  
27 limited to systems above 10 kW. Otherwise, there would be a large volume of data of reasons for  
28 denial, much of which would not be useful for the purpose of monitoring how well the  
interconnection process is working. UniSource Energy states that systems of 10 kW and below  
will generally fall into the Level 1 screen criteria. As this screen is simple and straightforward,



1 there is little to be gained in reporting specific reasons for denial. UniSource proposes the  
2 following modification to the last sentence in the language on reporting requirements:

3 *The annual report shall include, for the reporting period, a summary of the number*  
4 *of complete Applications received, the number of complete Applications approved,*  
5 *the number of complete Applications denied by level, and for systems above 10 kW,*  
*the reasons for denial.*

6 101. Staff finds it difficult to believe that the reporting requirement would produce the  
7 voluminous amount of data that UniSource Energy fears. The reasons for denial could be  
8 summarized. If the number of denials is so great, there is even more need to know why.

9 102. The DG Advocates propose that the reports also list specific customers that receive  
10 special rate considerations in lieu of connecting to a generating facility. The DG Advocates state  
11 that, while such considerations must be approved through a Commission proceeding, it is  
12 administratively difficult to monitor all such proceedings, and compiling the data in one place will  
13 allow ratepayers to analyze whether their funds are being used appropriately.

14 103. Staff has expanded the items in the annual report to include a list of special  
15 contracts approved by the Commission that provide discounted rates to customers as an alternative  
16 to self-generation. Since the number of such contracts is small, this should not be burdensome to  
17 the utilities. The language is as follows:

18 *The annual report shall also include a list of special contracts, approved by the*  
19 *Commission during the reporting period, that provide discounted rates to*  
20 *customers as an alternative to self-generation.*

21 6. Definitions

22 104. This subsection includes definitions of terms used in the Document.

23 Waiver Provision

24 105. UniSource Energy suggests that the upcoming rulemaking on interconnection  
25 standards include a provision for utility-requested waivers of specific details of the interconnection  
26 standards to allow for changing generation technologies and the aggregate impacts of  
27 interconnected DG.

28 ...

1 Staff Recommendations

2 106. Staff has recommended that the Commission adopt a modified version of the  
3 PURPA standard on interconnection, as included in Finding of Fact No. 11, that would apply to all  
4 electric distribution companies in Arizona that are regulated by the Commission.

5 107. Staff has also recommended that the Commission direct Staff to begin a rulemaking  
6 process to convert the Interconnection Document into rules. The DG Advocates and AECC agree  
7 with Staff that a rulemaking process should begin on the subject of interconnection.

8 108. In addition, Staff has recommended that the electric distribution companies use the  
9 Interconnection Document as a guide for interconnecting distributed generation facilities until such  
10 time as interconnection rules go into effect.

11 CONCLUSIONS OF LAW

12 1. The Commission has jurisdiction the subject matter of the application.

13 2. The Commission, having reviewed the application and Staff's Memorandum dated  
14 June 15, 2007, concludes that it is in the public interest to direct Staff to begin a rulemaking  
15 process on interconnection.

16 ORDER

17 IT IS THEREFORE ORDERED that a modified version of the PURPA standard on  
18 interconnection, as included in Finding of Fact No. 11, that would apply to all electric distribution  
19 companies in Arizona that are regulated by the Commission is adopted.

20 ...  
21 ...  
22 ...  
23 ...  
24 ...  
25 ...  
26 ...  
27 ...  
28 ...

1 IT IS FURTHER ORDERED that Staff is to begin a rulemaking process to convert the  
2 Interconnection Document into rules.

3 IT IS FURTHER ORDERED that this Decision shall become effective immediately.


4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**BY THE ORDER OF THE ARIZONA CORPORATION COMMISSION**




CHAIRMAN

COMMISSIONER

  
COMMISSIONER  
COMMISSIONER  
COMMISSIONER

IN WITNESS WHEREOF, I BRIAN C. McNEIL, Executive  
Director of the Arizona Corporation Commission, have  
hereunto, set my hand and caused the official seal of this  
Commission to be affixed at the Capitol, in the City of  
Phoenix, this 28<sup>th</sup> day of June, 2007.

  
BRIAN C. McNEIL  
Executive Director

DISSENT: Lance S. [unclear]

DISSENT: \_\_\_\_\_

EGJ:BEK:red/KL

1 SERVICE LIST FOR: Generic Investigation of Distributed Generation  
2 DOCKET NO. E-00000A-99-0431

3 Mr. Jeff Schiegel  
4 SWEEP  
5 1167 West Samalayuca Drive  
6 Tucson, Arizona 84704

7 Mr. Robert Arman  
8 Annan Group  
9 6605 East Evening Glow  
10 Scottsdale, Arizona 85262

11 Ms. Deborah R. Scott  
12 Ms. Kimberly A. Grouse  
13 Snell & Wilmer  
14 One Arizona Center  
15 400 East Van Buren  
16 Phoenix, Arizona 85004

17 Mr. David Berry  
18 Western Resource Advocates  
19 Post Office Box 1064  
20 Scottsdale, Arizona 85252

21 Mr. Eric C. Guidry  
22 Western Resource Advocates  
23 2260 Baseline, Suite 200  
24 Boulder, Colorado 80302

25 Mr. C. Webb Crockett  
26 Mr. Patrick I. Black  
27 Fennemore Craig  
28 3003 North Central Avenue, Suite 2600  
Phoenix, Arizona 85012

Mr. Andrew Bettwy  
Southwest Gas Corporation  
5421 Spring Mountain Road  
Las Vegas, Nevada 89102

Mr. Michael Patten  
Ms. Laura Sixkiller  
Roshka Dewulf & Patten  
One Arizona Center  
400 East Van Buren Street, Ste. 800  
Phoenix, Arizona 85004

1 Mr. Dave Couture  
Tucson Electric Power Company  
2 Post Office Box 711  
Tucson, Arizona 85702  
3

4 Mr. Jerry Payne  
Cooperative International Forestry  
5 333 Broadway S.E.  
Albuquerque, New Mexico 87102  
6

7 Mr. Brian Hageman  
Ms. Caren Peckerman  
8 Mr. Richard Briul  
Deluge, Inc.  
9 4116 East Superior Avenue, Suite D3  
Phoenix, Arizona 85040  
10

11 Mr. Scott S. Wakefield  
Mr. Stephen Ahearn  
12 RUCO  
1110 West Washington Street, Suite 220  
13 Phoenix, Arizona 85007

14 Mr. John Wallace  
Grand Canyon State Electric Cooperative Association, Inc.  
15 120 North 44th Street, Suite 100  
16 Phoenix, Arizona 85034

17 Ms. Jana Brandt  
Ms. Kelly Barr  
18 Salt River Project  
19 Post Office Box 52025, MS PAB221  
Phoenix, Arizona 85072  
20

21 Mr. Gary Mirich  
Energy Strategies  
22 One North Central Avenue, Suite 1120  
Phoenix, Arizona 85004

23 Ms. Amy LeGere  
24 4850 Reata Road  
Flagstaff, Arizona 86004  
25

26 Mr. Cohn Murchie  
Solar Energy Industries  
27 ASSOCIATION  
805 15th N.W., #510  
28 Washington, DC 20005

- 1 Mr. Adam Browning
- 2 The Vote Solar Initiative
- 3 182-2 Street, Suite 400
- 4 San Francisco, California 94105
  
- 5 Mr. Aaron Stallings
- 6 Mohave Electric Cooperative
- 7 Post Office Box 1045
- 8 Bullhead City, Arizona 86430
  
- 9 Ms. Valerie Rauluk
- 10 Greater Tucson Coalition For Solar Energy
- 11 Post Office Box 42708
- 12 Tucson, Arizona 85733
  
- 13 Mr. Ernest G. Johnson
- 14 Director, Utilities Division
- 15 Arizona Corporation Commission
- 16 1200 West Washington
- 17 Phoenix, Arizona 85007
  
- 18 Mr. Christopher C. Kempley
- 19 Chief Counsel, Legal Division
- 20 Arizona Corporation Commission
- 21 1200 West Washington
- 22 Phoenix, Arizona 85007
  
- 23
- 24
- 25
- 26
- 27
- 28

EXHIBIT  
INTERCONNECTION  
DOCUMENT

# INTERCONNECTION DOCUMENT

## TABLE OF CONTENTS

1. APPLICABILITY.....	3
1.1 Applicable Generating Facilities.....	3
1.2 Types of Generating Facilities.....	3
2. RIGHTS AND RESPONSIBILITIES .....	<u>66</u>
2.1 Customer Rights and Responsibilities .....	<u>66</u>
2.2 Utility Rights and Responsibilities .....	<u>77</u>
2.3 Easements/Rights of Way.....	<u>88</u>
2.4 Insurance.....	<u>88</u>
2.5 Non-Circumvention .....	<u>88</u>
3. GENERAL PROCESS AND PROCEDURES FOR ALL LEVELS .....	<u>1010</u>
3.1 Designation of Contact Persons.....	<u>1010</u>
3.2 Non-discrimination .....	<u>1010</u>
3.3 Application Submission Requirements.....	<u>1010</u>
3.4 Minor Modifications .....	<u>1010</u>
3.5 Certification .....	<u>1010</u>
3.6 No Additional Requirements .....	<u>1212</u>
3.7 Disconnect from or Reconnect with the Grid Procedure .....	<u>1212</u>
3.8 Dispute Resolution.....	<u>1414</u>
4. SPECIFIC PROCESS AND PROCEDURES FOR EACH LEVEL.....	<u>1515</u>
4.1 Summary of Interconnection Levels / Tracks .....	<u>1515</u>
4.2 Screens .....	<u>1515</u>



4.3 Level 1 Super Fast Track Process ..... 1616

4.4 Level 2 Fast Track Process ..... 2020

4.5 Level 3 Study Track Process..... 2424

4.6 Interconnection to Secondary Spot Network Systems..... 303029

5. UTILITY REPORTING REQUIREMENTS ..... 3131

6. DEFINITIONS..... 3232

## 1. APPLICABILITY

### 1.1 Applicable Generating Facilities

This Document applies to all Generating Facilities with power ratings of 10 MW or less, operating (or applying to operate) in parallel with an electric public utility distribution system in Arizona.<sup>1</sup> This Document establishes technical and procedural requirements, terms, and conditions that will promote the safe and effective parallel operation of Customer-owned Generating Facilities. This Document includes provisions for interconnecting to a radial or secondary spot network system. It includes the three distinct types of generators: (a) solid-state or static inverters, (b) induction machines, and (c) synchronous machines.

These Interconnection procedures are limited to 10 MW or less. The total capacity of an individual Customer's Generating Facility may exceed 10 MW; however, no more than 10 MW of a facility's capacity will be interconnected at a single Point of Interconnection as provided for in these procedures.

The electric rates and schedules, terms and conditions of service, or other contract provisions governing the electric power sold by an electric public utility to an Arizona retail customer are subject to the jurisdiction of the Arizona Corporation Commission ("ACC"). The ACC also has jurisdiction when the Utility purchases excess power from Customer-owned Qualifying Facilities ("QFs") under 18 C.F.R. §§292.303, 292.306(2004).

The Federal Energy Regulatory Commission has jurisdiction over all Interconnections with facilities that are subject to the electric public Utility's Open Access Transmission Tariff ("OATT") at the time the interconnection request was made.

### 1.2 Types of Generating Facilities

Generating Facilities include induction and synchronous electrical generators as well as any type of electrical inverter capable of producing A/C power. The Customer may elect to run his Generating Facility in Parallel with the Utility's system (either on a continuous basis or momentarily), or he may run it as a Separate System with non-parallel load transfer between the two independent power systems. A description and the basic requirements for these methods of operation are outlined below.

#### **Parallel System**

A Parallel, or interconnected, generator is connected to a bus common with the Utility's system, and a transfer of power between the two systems is a direct result. A consequence of such interconnected operation is that the Customer's Generating Facility becomes an integral part of the distribution system, and it must be considered in the electrical protection and operation of the distribution system.

---

<sup>1</sup> subject to Commission jurisdiction.

Parallel Systems include any type of Generating Facility that can electrically parallel with, or potentially backfeed the Utility system. Additionally, any Generating Facility system using a "closed transition" type transfer switch or a multi-breaker transfer scheme, or an electrical inverter that can be configured or programmed to operate in a "utility interactive mode," may be required to have relays to prevent potential backfeeding to the Utility system, and is classified as a Parallel System. Continuous uninterruptible power supply, units without grid tie capability, and islanding inverter technologies are not considered Parallel Systems provided they are not a potential backfeed source to the Utility.

The Utility has specific interconnection, contractual, and inspection requirements, as outlined in these provisions, that must be complied with and information that needs to be submitted for all interconnected Generating Facilities. These may include protective relaying, metering, special rate schedules, applicable safety devices, and information requirements (as specified in each Utility's Interconnection Manual).

There are two sub-types of Parallel Systems, as described below: Momentary Parallel Systems and Islandable Systems. Momentary Parallel Systems have similar requirements as regular Parallel Systems, whereas Islandable Systems are unique.

- **Momentary Parallel System.** A Momentary Parallel System is one that transfers electrical load between the Utility grid and the Customer's Generating Facility by means of a "make-before break" transfer scheme. Momentary Parallel Systems synchronize the Generating Facility with the Utility grid for a period not to exceed ten seconds for the purpose of uninterrupted load transfer.

Momentary Parallel Systems are useful for customers who wish to have greater reliability of electric service without experiencing the momentary outage of service that occurs under a "break-before-make" transfer switch scheme. Additionally, this approach allows the customer to more effectively test the switchgear and generator with load during weekly and monthly testing.

- **Islandable System.** An Islandable System is a Generating Facility interconnected to a bus common with the Utility's system, where the Generating Facility is designed to serve part of the Utility grid that has become or is purposefully separated from the rest of the grid. Currently there are no rules, standards, or protocols governing this type of system operation. As such, an Islandable System as defined herein is not allowed.

### **Separate System**

A Separate System is one in which there is no possibility of electrically connecting or operating the Customer's Generating Facility in parallel with the Utility's system. The Customer's equipment must transfer load between the two power systems in an open transition or non-parallel mode. If the Customer claims a Separate System, the Utility may require verification that the transfer scheme meets the non-parallel requirements.

Separate Systems used to supply part or all of the Customer's load during a Utility power outage must be connected to the Customer's wiring through a double throw, "break-before-make" transfer switch specifically designed and installed for that purpose. The transfer switch must be of a fail-safe design, which, under no circumstances, will allow the Generating Facility to electrically interconnect or parallel with Utility's system. The transfer switch must always

disconnect the Customer's load from the Utility's power system prior to connecting it to the Generating Facility. Conversely, the transfer switch must also disconnect the load from the Generating Facility prior to re-connecting it with the Utility's system. These requirements apply to both actual emergency operations as well as any testing of the Generating Facility. All transfer switches and transfer schemes must be listed by a Nationally Recognized Testing Laboratory ("NRTL") for the purpose as used, and also inspected and approved by the jurisdictional electrical inspection agency.

Separate Systems that are not connected with the Utility system and do not pose a potential backfeed source are not subject to ACC jurisdiction or the provisions in this Document, short of verifying that the transfer scheme meets the non-parallel requirements.

There is one sub-type of Separate System, as described below: Portable Generators.

- **Portable Generators.** Portable Generators are not designed to be connected to a building's permanent wiring system, and are not to be connected to any such wiring unless a permanent and approved transfer switch is used. Failure to use a transfer switch can result in backfeed into the Utility system. (The generator voltage can backfeed through the Utility transformer and be stepped up to a very high voltage.) This can pose an electrocution hazard to anyone working on the power lines or on Utility equipment.

Portable Generators that are not connected with the Utility system and do not pose a potential backfeed source are not subject to ACC jurisdiction or the provisions in this Document short of verifying that the transfer scheme meets the non-parallel requirements.

## 2. RIGHTS AND RESPONSIBILITIES

### 2.1 Customer Rights and Responsibilities

A Customer has the right to interconnect a Generating Facility with the electric Utility system. A Customer has the right to expect prompt, reasonable, and professional responses from the Utility at every step of the interconnection process. A Customer has the right to expect reasonable cost estimates, outlines of the proposed work, supporting data, and justification for proposed work before the Utility undertakes any studies or system upgrades to accommodate the Generating Facility.

A Customer has the responsibility of disclosing to the Utility items specified herein on the Generating Facility and its operation. The Customer also has the responsibility of ensuring that:

- (a) the Generating Facility meets all minimum safety and protection requirements outlined in these provisions and the Utility's Interconnection Manual;
- (b) the Generating Facility meets all applicable construction codes, safety codes, electric codes, laws, and requirements of government agencies having jurisdiction;
- (c) all the necessary protection equipment is installed and operated to protect its equipment, Utility personnel, the public, and the Utility system;
- (d) the Generating Facility design, installation, maintenance, and operation reasonably minimizes the likelihood of causing a malfunction or other disturbance, damaging, or otherwise impairing the Utility system;
- (e) the Generating Facility will not adversely affect the quality of service to other customers (but no more or less than the present standard of care observed by regular Utility/consumer connections);
- (f) the Generating Facility will minimally hamper efforts to restore a feeder to service (specifically when a clearance is required);
- (g) the Generating Facility is maintained in accordance with applicable manufacturers' maintenance schedule; and
- (h) the Utility is notified of any emergency or hazardous condition or occurrence with the Customer's Generating Facility, which could affect safe operation of the Utility system. (This notification can be through electronic communication.)

The Customer is required to meet the timeframes specified in this Document unless the Utility and Customer mutually agree on other time frames and so long as the project moves forward in a fair and reasonable manner.

The Customer is responsible for all Interconnection facilities required to be installed to interconnect the Customer's Generating Facility to the Utility system. These may include connection, transformation, switching, protective relaying, metering and safety equipment, and any other requirements as outlined in these provisions or other special items specified by the Utility. All such interconnection facilities are to be installed by the Customer at its sole expense.

The Customer will own and be responsible for designing, installing, operating and maintaining control and protective devices, in addition to minimum protective relays and devices specified in the Utility's Interconnection Manual, to protect its facilities from abnormal operating conditions such as, but not limited to, electric overloading, abnormal voltages, and fault currents. Such

protective devices must promptly disconnect the Generating Facility from the Utility's system in the event of a power outage on the Utility's system. The Customer will also own and be responsible for designing, installing, operating and maintaining interconnection facilities on the Customer's premises as may be required to deliver power from the Customer's Generating Facility to the Utility's system at the Point of Interconnection.

In the event that additional facilities are required to be installed on the Utility's system to accommodate the Customer's generation, the Utility will install such facilities at the Customer's expense. The Utility shall provide notice to the Customer of intent to install such facilities early in the process. The Customer is not responsible for Utility upgrades for other customers unrelated to the Generating Facility installation.

All Customers interconnecting a Generating Facility with the Utility system shall (a) sign an Interconnection/Connection Agreement, and all other applicable purchase, supply, and standby agreements, in accordance with the prevailing Document in effect at that time; and (b) comply with all applicable tariffs, rate schedules and Utility service requirements.

## **2.2 Utility Rights and Responsibilities**

A Utility is obligated to interconnect Generating Facilities, subject to the requirements set forth in these provisions and in each Utility's Interconnection Manual.

A Utility has the right to expect prompt, reasonable, and professional responses from the Customer during the interconnection process.

Because a Utility is required to safeguard its system, other consumers, and the general public, a Utility has the right and responsibility to ensure that an interconnected Generating Facility:

- (a) will not present any unreasonable hazards to Utility personnel, other customers, or the public;
- (b) minimizes the possibility of damage to the Utility and other customers' equipment; and
- (c) minimally hampers efforts to restore a feeder to service (specifically when a clearance is required).

The Utility will notify the Customer if there is any evidence that the Customer's Generating Facility operation causes disruption or deterioration of service to other customers served from the utility system or if such operation causes damage to the utility system.

A Utility is required to meet the time frames specified in this Document unless the Utility and Customer mutually agree on other time frames and so long as the project moves forward in a fair and reasonable manner.

A Utility has the responsibility to make its Interconnection Manual, standard Application form(s) and Interconnection Agreement(s) readily available to Customers, and as soon as practical, readily accessible on its website.

A Utility has the responsibility to ensure that Customers with Generating Facilities are treated without discrimination.

Before the Utility undertakes any studies or system upgrades that will be charged to the Customer, a Utility has the responsibility to provide a detailed cost estimate, outline of the proposed work, supporting data, and justification for the proposed work.

A Utility must show good cause why a Customer's Generating Facility that satisfies the requirements of this Document and the Utility's Interconnection Manual should not be approved for interconnected operation.

If facility upgrades are needed to accommodate the Generating Facility, a Utility will reduce the charge of the upgrade to the customer by the amount of ~~any~~ benefits, if any, to the grid that are readily quantifiable by the Utility. In addition, a Utility cannot reject an Application on the basis of distribution system conditions that are already deficient, or charge a Customer for facility upgrades that are overdue or soon to be required to ensure compliance with good utility practice, except that applications can be rejected in instances where reliability or safety would be further compromised by a DG installation. A Utility shall not charge a Generating Facility Customer differently than any other Customer for facility upgrades in accordance with generally applicable Commission-approved tariffs.

### 2.3 Easements/Rights of Way

**Utility Right to Access Utility-Owned Facilities and Equipment.** Where an easement or right of way does not exist, but is required to accommodate the interconnection, the Customer must provide to the Utility suitable easements or rights of way, in the Utility's name, on the premises owned, leased, or otherwise controlled by the Customer. If the required easement or right of way is on another's property, the Customer must obtain and provide to the Utility a suitable easement or right of way, in the Utility's name, at the Customer's sole cost and in sufficient time to comply with the Interconnection Agreement requirements. The Utility will use reasonable efforts to utilize existing easements to accommodate the interconnection to the extent possible and will assist the Customer in securing necessary easements at the Customer's expense that do not exist but are necessary to accommodate the interconnection.

### 2.4 Insurance

The Customer is not required to provide general liability insurance coverage as a condition for Interconnection. Due to the risk of incurring damages, it is recommended that every Interconnection Customer protect itself with insurance or other suitable financial instrument sufficient to meet its construction, operating, and liability responsibilities. At no time shall the Utility require that the Customer negotiate any policy or renewal of any policy covering any liability through a particular insurance provider, agent, solicitor, or broker.

The inability of the Utility to require the Customer to provide general liability insurance coverage for operation of the Generating Facility is not a waiver of any rights the Utility may have to pursue remedies at law against the Customer to recover damages.

### 2.5 Non-Circumvention

A Utility and its affiliates shall not use knowledge of proposed distributed generation projects submitted to it for interconnection or study to initiate competing proposals to the customer that offer either discounted rates in return for not installing the distributed generation, or offer competing distributed generation projects. Customers are not precluded from sharing information in their possession regarding a potential distributed generation project with a Utility or its affiliates, or from using information regarding a potential distributed generation project to negotiate a discounted rate or other mutually beneficial arrangement with a Utility or its affiliates. The Utility shall be permitted to inform the Customer of existing or pending (awaiting approval by the ACC) rate schedules that may economically benefit or otherwise affect the Customer's project.



### 3. GENERAL PROCESS AND PROCEDURES FOR ALL LEVELS

#### 3.1 Designation of Contact Persons

Each Utility shall designate a person or persons who will serve as the Utility's contact for all matters related to distributed generation Interconnection, identify to the Commission its distributed generation contact person, and provide convenient access through its internet web site to the names, telephone numbers, mailing addresses and electronic mail addresses for its distributed generation contact person(s).

Each customer applying for Interconnection shall designate a contact person or persons, and provide to the Utility the contact's name, telephone number, mailing address, and electronic mail addresses.

#### 3.2 Non-discrimination

All Applications for interconnection and parallel operation of distributed generation shall be processed by the Utility in a non-discriminatory manner.

#### 3.3 Application Submission Requirements

The Utility may require additional documentation to be submitted with the Application. Each Utility's Application form will specify what additional documentation is required. Additional documentation may include an electrical one-line diagram, an electrical three-line diagram, AC and DC control schematics, plant location diagram, and site plan. Upon request, the Utility will provide the Customer with sample diagrams that indicate the preferred level of detail and type of information required for a typical inverter-based system.

#### 3.4 Minor Modifications

It is recognized that certain Applications may require minor modifications to the Generating Facility or the Application while they are being reviewed by the Utility. Such minor modifications to a pending Application shall not require that it be considered incomplete and treated as a new or separate Application.

#### 3.5 Certification

**Compliance with codes and standards.** In order to qualify as "Certified" for any interconnection procedures, relevant equipment shall comply with the following codes, guides, and standards as applicable, and as specified in this document:

- (a) IEEE 1547 Standard for Interconnecting Distributed Resources with Electric Power Systems (including use of IEEE 1547.1 testing protocols to establish conformity);

- (b) IEEE 1547.1 Standard for Conformance Testing Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems;
- (c) UL 1741 Inverters, Converters, and Controllers for Use in Independent Power Systems;
- (d) IEEE Std 929-2000 IEEE Recommended Practice for Utility Interface of Photovoltaic (PV) Systems;
- (e) NFPA 70 (2002), National Electrical Code;
- (f) IEEE Std C37.90.1-1989 (R1994), IEEE Standard Surge Withstand Capability (SWC) Tests for Protective Relays and Relay Systems;
- (g) IEEE Std C37.90.2 (1995), IEEE Standard Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers;
- (h) IEEE Std C37.108-1989 (R2002), IEEE Guide for the Protection of Network Transformers;
- (i) IEEE Std C57.12.44-2000, IEEE Standard Requirements for Secondary Network Protectors;
- (j) IEEE Std C62.41.2-2002, IEEE Recommended Practice on Characterization of Surges in Low Voltage (1000V and Less) AC Power Circuits;
- (k) IEEE Std C62.45-1992 (R2002), IEEE Recommended Practice on Surge Testing for Equipment Connected to Low-Voltage (1000V and Less) AC Power Circuits;
- (l) ANSI C84.1-1995 Electric Power Systems and Equipment – Voltage Ratings (60 Hertz);
- (m) IEEE Std 100-2000, IEEE Standard Dictionary of Electrical and Electronic Terms NEMA MG 1-1998, Motors and Small Resources, Revision 3;
- (n) IEEE Std 519-1992, IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems; and
- (o) NEMA MG 1-2003 (Rev 2004), Motors and Generators, Rev. 1.

**Requirements for Certification.** Generating Facility equipment proposed for use separately or packaged with other equipment in an Interconnection system shall be considered Certified for interconnected operation if:

- (a) it has been tested in accordance with industry standards for continuous utility interactive operation in compliance with the appropriate codes and standards referenced above by any Nationally Recognized Testing Laboratory (NRTL) recognized by the U. S. Occupational Safety and Health Administration to test and certify Interconnection equipment pursuant to the relevant codes and standards listed above;

- (b) it has been labeled and is publicly listed by such NRTL at the time of the Interconnection application; and
- (c) such NRTL makes readily available for verification all test standards and procedures it utilized in performing such equipment certification, and, with consumer approval, the test data itself. The NRTL may make such information available on its website and by encouraging such information to be included in the manufacturer's literature accompanying the equipment.

The Customer must verify that the intended use of the equipment falls within the use or uses for which the equipment was tested, labeled, and listed by the NRTL.

Certified equipment shall not require further type-test review, testing, or additional equipment to meet the requirements of this Interconnection procedure and the Utility's Interconnection Manual. Nothing herein shall preclude the need for project Interconnection review and approval by the Utility or on-site commissioning testing prior to the Interconnection nor follow-up production testing by the NRTL.

If the certified equipment includes only interface components (switchgear, inverters, or other interface devices), then a Customer must show that the Generating Facility is compatible with the interface components and is consistent with the testing and listing specified for this type of Interconnection equipment.

Certified equipment does not include equipment provided by the Utility.

### **3.6 No Additional Requirements**

If a Customer's Generating Facility complies with all applicable requirements in this Document and the Utility's Interconnection Manual, a Utility may not require the Customer to install additional controls, or perform or pay for additional tests, in order to obtain approval to interconnect except as mutually agreed to by the parties or required by the Commission. Additional equipment may be installed by the Utility at its own expense.

### **3.7 Disconnect from or Reconnect with the Grid Procedure**

A Utility may disconnect a Customer's Generating Facility from the Utility system under the following conditions:

- (a) **Expiration or termination of Interconnection Agreement.** The Interconnection Agreement specifies the effective term and termination rights of the Utility and the Customer. Upon expiration or termination of the Interconnection Agreement with a Customer, in accordance with the terms of the agreement, the Utility may disconnect a Customer's Generating Facility.
- (b) **Non-compliance with technical Interconnection requirements.** A Utility may disconnect a Customer's Generating Facility if the facility is not in compliance with the

technical requirements. Normally within two business days from the time the Customer notifies the Utility that the facility has been restored to compliance with the technical requirements, the Utility shall have an inspector verify such compliance. Upon such verification, the Customer in coordination with the Utility may reconnect the facility.

- (c) **System emergency.** A Utility may temporarily disconnect a Customer's Generating Facility without prior written notice in cases where continued Interconnection of the Generating Facility will endanger persons or property. During the forced outage of a Utility system, the Utility shall have the right to temporarily disconnect a Customer's facility to make immediate repairs on the Utility's system. When possible, the Utility shall provide the Customer with reasonable notice and reconnect the Customer as quickly as reasonably practical.
- (d) **Routine maintenance, repairs, and modifications.** A Utility may disconnect a Customer's Generating Facility from the grid with reasonable prior notice of a service interruption for routine maintenance, repairs, and Utility system modifications. The Utility shall allow reconnection of the Customer's Generating Facility as quickly as reasonably possible following any such service interruption.
- (e) **Absence of executed Interconnection Agreement.** In order to interconnect a Customer's Generating Facility to a Utility system, the Customer and the Utility must execute an Interconnection Agreement. The Utility may refuse to connect or may disconnect the Customer's Generating Facility if an executed Interconnection Agreement is not in effect.

The Parties shall cooperate with each other to restore the Generating Facility and the Utility system to their normal operating state as soon as reasonably practicable.

**Temporary disconnection by Customer.** The Customer retains the option to temporarily disconnect its Generating Facility from the Utility's system at any time. Such temporary disconnection shall not be a termination of the Interconnection Agreement unless specified as such.

**Agreement survival rights.** The Interconnection Agreement between the Utility and the Customer shall continue in effect after disconnection or termination of electric service to the extent necessary to allow or require either party to fulfill rights or obligations that arose under the agreement.

**Duration and Termination of the Interconnection Agreement.** The Interconnection Agreement shall become effective on the effective date specified in the Agreement and shall remain in effect thereafter unless and until:

- (a) it is terminated by mutual agreement of the parties;
- (b) it is replaced by another Interconnection Agreement with mutual consent of the parties;
- (c) it is terminated by either party pursuant to a breach or default of the Agreement; or

- (d) the Customer terminates its electric Utility service with the Utility and/or vacates or abandons the property on which the Generating Facility is located, or the Generating Facility, without mutual agreement of the parties.

Upon termination of the Interconnection Agreement, the Customer shall be responsible for ensuring that the electrical conductors connecting the Generating Facility to the Utility system are immediately lifted and permanently removed, so as to preclude any possibility of interconnected operation in the future. The Utility reserves the right to inspect the Customer's Generating Facility to verify that it is permanently disconnected.

### 3.8 Dispute Resolution

If a dispute arises between the parties regarding a provision contained in this Document and/or Agreement, or a party's performance of its obligations as stated in this Document and/or Agreement, or any other matter governed by the terms of the Document and/or Agreement, the parties agree that such dispute will be resolved in the manner prescribed in this section.

- (a) **Notification and Response.** Promptly upon the occurrence of the dispute, the aggrieved party will notify the other party in writing (the "Claimant's Statement"), setting forth in sufficient detail the basis for the dispute, the aggrieved party's position, and its proposal for resolution of the dispute. Within ten (10) business days following receipt of the Claimant's Statement, the other party will respond in writing (the "Responsive Statement") setting forth in sufficient detail the respondent's position and its proposal for resolution of the dispute.
- (b) **Good Faith Negotiation.** Within ten (10) business days after the aggrieved party's receipt of the Responsive Statement, the parties will meet and attempt in good faith to expeditiously negotiate a resolution to the dispute. In attendance for each party at that opening session and throughout the dispute resolution procedure described in this section will be a representative or representatives of each party who are authorized to act for the party and resolve this dispute without resort to higher authority.
- (c) **Dispute Resolution by Mediation.** Any dispute(s) arising out of or relating to this Document shall be subject to binding mediation by a mutually acceptable mediator. If no mediator is mutually acceptable, then a mediator shall be appointed by the Arizona Office of the American Arbitration Association, at the request of any party. The costs of mediation shall be borne by the losing party and as prescribed by the mediator.
- (d) **Arizona Corporation Commission.** In the event such dispute is not resolved by mediation, then the parties consent to jurisdiction to resolve any such dispute by the Arizona Corporation Commission of the State of Arizona.

## 4. SPECIFIC PROCESS AND PROCEDURES FOR EACH LEVEL

### 4.1 Summary of Interconnection Levels / Tracks

**Level 1 Super Fast Track:** Certified inverter-based facilities that have a power rating of 10 kW or less, are interconnected on a radial line, and meet screens (e) and (f) in section 4.2 below. Refer to Section 4.3 for additional details.

**Level 2 Fast Track:** Generating Facilities that have a power rating of 2 MW or less, are interconnected on a radial line, and meet screens (a) through (i) in section 4.2 below. Refer to Section 4.4 for additional details.

**Level 3 Study Track:** Generating Facilities that have a power rating of 10 MW or less that do not meet the criteria or screens for other Levels. Interconnection studies may be required. Refer to Section 4.5 for additional details.

**Distribution Networks:** On an interim basis, certified inverter-based Generating Facilities that have a power rating of 10 kW or less will be allowed to be interconnected on a secondary spot network system and otherwise as approved by the Utility. Generators will only be interconnected on a trial, pilot basis, at the discretion of the Utility, under the interconnection process set forth in the Utility's Interconnection Manual. This process may be revised upon completion of IEEE 1547.6. Refer to subsection 4.6 for additional details.

### 4.2 Screens

- (a) For Interconnection of a proposed generator to a radial distribution circuit, the aggregated generation, including the proposed generator, on the circuit will not exceed 15 percent of the total circuit annual peak load as most recently measured at the substation or on a line section. In the case of generators certified to UL 1741 and IEEE 1547, a line section is that portion of a distribution system connected to a customer's facility bounded by automatic sectionalizing devices, or the end of the distribution line. For non-certified generators, a line section is that portion of a distribution system connected to a customer's facility bounded by automatic sectionalizing devices, a fused lateral, or the end of the distribution line. The aggregated generation, including the proposed generator, must also be less than 50 percent of the minimum daytime feeder or line section load, where these data are available, unless the minimum load is zero.
- (b) The proposed generator, and new motors associated with the proposed generator, in aggregation with other generation on the distribution circuit, will not contribute more than 10 percent to the distribution circuit's maximum fault current at any point on the Utility's distribution system, including normal contingency conditions that may occur due to reconfiguration of the feeder or the distribution substation.
- (c) The proposed generator, in aggregate with other generation on the distribution circuit, will not cause any distribution protective devices and equipment (including but not limited to substation breakers, fuse cutouts, and line reclosers), or customer equipment on the system, to exceed 90 percent of the short circuit interrupting capability; nor is the Interconnection

proposed for a circuit that already exceeds 90 percent of the short circuit interrupting capability.

(d) The proposed generator is interconnected to the Utility as shown in the table below:

Primary distribution line configuration	Interconnection to primary distribution line
Three-phase, three wire	If a three-phase or single phase generator, Interconnection must be phase-to-phase
Three-phase, four wire	If a three-phase (effectively grounded) or single-phase generator, Interconnection must be line-to-neutral

- (e) If the proposed generator is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed generator, cannot exceed 10 kW, and the proposed generator must be listed to UL 1741.
- (f) If the proposed generator is single-phase and is to be interconnected on a transformer center tap neutral of a 240 volt service, its addition will not create an imbalance between the two sides of the 240 volt service of more than 20 percent of nameplate rating of the service transformer.
- (g) The proposed generator, in aggregate with other generation interconnected to the distribution low voltage side of the substation transformer feeding the distribution circuit where the generator proposes to interconnect, will not exceed 10 MW in an area where there are known or posted transient stability limitations to generating units located in the general electrical vicinity (e.g., 3 or 4 transmission voltage level busses from the Point of Interconnection).
- (h) The proposed generator's Point of Interconnection will not be on a transmission line.
- (i) The generator cannot exceed the capacity of the customer's existing electrical service.

#### 4.3 Level 1 Super Fast Track Process

The Level 1 Process is available to Customers interconnecting either a single certified static inverter, with a continuous output power nameplate rating of 10 kW or less, or multiple certified static inverters with a combined continuous power nameplate rating of 10 kW or less (screen "e") to the Utility's distribution system. The inverter(s) must be UL 1741 listed, and certified to meet the shutdown protective functions (under/over voltage, under/over frequency and anti-islanding) specified in IEEE 929 (screen "f"). The Generating Facility must also meet all applicable codes and standards, as well as comply with the Utility Interconnection and contractual requirements.

Nothing in this process precludes the Customer and Utility from mutually agreeing to different timeframes or other procedures for the approval of interconnected operation of a Generating Facility, so long as the project moves along in a fair and reasonable manner. Nothing in this process precludes the Customer from starting construction prior to contacting the Utility;

however, the Customer accepts the risk of potentially needing to modify or substantially change the installation.

The Level 1 Process steps are as follows:

- (a) **Customer Submits Application.** The Customer completes the Interconnection Application and submits it to the Utility along with all required supplemental information which shall be noted on the Application form. The Customer may submit a pre-executed Interconnection Agreement together with the Interconnection Application, if permitted by the Utility. No initial application fee or processing fee will be charged.
- (b) **Application is Received and is Complete or Incomplete.** The Utility notifies the Customer within five (5) business days of receipt of the Application as to whether it is complete or incomplete.
  - (i) If the Application is incomplete, the Utility will specify what information or material is necessary to complete the Application.
  - (ii) The Customer has thirty (30) business days after receipt of such notification to submit the required information or materials (or request an extension), or the Application may be considered withdrawn.
- (c) **Utility Reviews Application.** Within ten (10) business days following the receipt of a complete Interconnection Application, the Utility reviews the proposed Interconnection and notifies the Customer of one of the following determinations:
  - (i) The proposed Generating Facility design appears to meet all Interconnection requirements and the Interconnection Application is approved as submitted. An Interconnection Agreement (if not already pre-executed) will be prepared by the Utility and forwarded to the Customer for review and signature in accordance with Step (d) below; or
  - (ii) The proposed Generating Facility design has failed to meet one or more of the Interconnection requirements, and the Interconnection Application is denied. The Utility provides an explanation of the reason(s) for the denial (in writing, if requested by the Customer), and specifies what additional information and/or modifications to the Customer's Generating Facility or Utility system are required in order to obtain approval of the proposed design.

If the Application is denied, the Customer notifies the Utility within twenty (20) business days whether or not it wishes to proceed with the project. If the Customer does not wish to proceed with the project, or the Utility is not notified within the specified time frame, the Application may be considered withdrawn. If the Customer wishes to proceed with the project, then a new Application shall be submitted to the Utility for review and processing (Step (a) above is re-initiated), along with any additional information and/or modifications to the Customer's Generating Facility. Alternatively, the Customer may request processing under Level 2 or Level 3 and shall provide any additional information requested by the Utility and necessary to process the request under Levels 2 or 3.



- (d) **Interconnection Agreement.** If the Generating Facility meets all of the applicable interconnection requirements and the Application is approved, then:
- (i) Within five (5) business days after the notice of Application approval, or following receipt of any "as built" or final diagrams from the Customer, the Utility sends to the Customer the appropriate Interconnection Agreement for review and signature. (This step may be omitted if the Utility has received a pre-executed Interconnection Agreement).
  - (ii) The Customer reviews, signs, and returns the Interconnection Agreement to the Utility.
  - (iii) The Customer then completes installation of the Generating Facility within 180 days after execution of the Interconnection Agreement, unless an extension is mutually agreed to by the parties, which extension shall not be unreasonably withheld. The Utility has the right to terminate any Agreements, and the Interconnection Application may be considered withdrawn, in the event that this timeframe is exceeded without extension.
- (e) **Inspection and Testing.** The Customer will give the Utility at least five (5) business days notice to schedule the Utility site inspection and inverter shutdown testing. The Utility may schedule metering replacement, if necessary, and labeling of Utility equipment to occur at the same time. There will be no charge for one initial site inspection by the Utility.

The Utility performs the site inspection as arranged and verifies that the Generating Facility, as best as can be determined, is in compliance with all applicable interconnection and safety requirements. At a minimum, it is suggested that the Utility shall verify the following:

- (i) An electrical permit and/or clearance has been issued by the authority having jurisdiction, if required;
- (ii) All Generating Facility equipment is properly labeled;
- (iii) Generating Facility system layout is in accordance with the plant location and site plan(s) submitted to the Utility;
- (iv) Inverter nameplate ratings are consistent with the information submitted to the Utility;
- (v) Utility has unrestricted 24-hour access to the Disconnect Switch (if required), and the switch meets all applicable requirements;
- (vi) The inverter shuts down as required upon simulated loss of Utility voltage; and
- (vii) The Generating Facility is wired, as best as can be determined, in accordance with the electrical diagrams submitted to the Utility.

The Utility will normally before or at the time of the site inspection:

- (i) Install appropriate metering if required;

- (ii) Label all Utility equipment; and
- (iii) Ensure that the Generating Facility is properly incorporated onto Utility operating maps and identified as a backfeed source.

The Utility does not have the right to fail a site inspection in the event that any of the above three requirements (metering, Utility equipment labeling, and the identification of the Generating Facility on the operating maps) are not in place at the time of the Site Inspection. The Utility does have the right to fail any Generating Facility that does not meet the applicable Interconnection requirements, is not installed substantially in accordance with the documentation submitted to the Utility, or as a result of any safety or protection violation.

- (f) **Notification.** Immediately following completion of the site inspection (and upon receipt of all final applicable signed interconnection documents), the Utility shall determine whether or not the Generating Facility meets all applicable requirements, and notify the Customer that:
  - (i) The Generating Facility is approved for parallel operation with the Utility's distribution system per the agreed terms and conditions. Within one (1) business day, following such oral notification, the Utility shall provide the Customer with such notice in writing; or
  - (ii) The Generating Facility has failed to meet one or more of the applicable requirements or a safety or protection violation has been identified, and the Generating Facility is not approved for parallel operation. The Utility must provide the reason(s) (in writing, if requested by the Customer) for not approving parallel operation. Furthermore, the Utility has the right to take any reasonable steps (including locking open the Disconnect Switch) to prevent the Generating Facility from parallel operation. Operation of a generator in parallel without Utility approval may result in immediate termination of electric service to the Customer.
- (g) **Corrections (if necessary).** In the event that the Generating Facility does not pass the initial Utility site inspection:
  - (i) The Customer must correct any outstanding issues and schedule a re-inspection. The Utility shall re-inspect upon five (5) business days notice from the Customer to verify that the deficiencies have been remedied. A fee not exceeding one hundred dollars (\$100) may be assessed for each re-inspection conducted by the Utility. Within one (1) business day following any site re-inspection, where the Utility approves parallel operation of the Generating Facility, the Utility will provide written notification to the Customer that the Generation Facility is approved for parallel operation.
  - (ii) If updated diagrams are required to reflect "as-built" conditions, the Customer must submit these to the Utility for review and approval within ten (10) business days following the site inspection. The Utility will process and mail an amendment to the Interconnection Agreement within five (5) business days after receipt and acceptance of the revised diagrams for Customer review and signature.

#### 4.4 Level 2 Fast Track Process

The Level 2 Process is available to Customers interconnecting a Generating Facility with a continuous output power nameplate rating of 2 MW or less to the Utility's distribution system. In order to qualify for Level 2, the Generating Facility must meet screens (a) through (i) in subsection 4.2 above. The Generating Facility must also meet all applicable codes and standards, as well as comply with the Utility Interconnection and contractual requirements.

Nothing in this process precludes the Customer and Utility from mutually agreeing to different timeframes or other procedures for the approval of interconnected operation of a Generating Facility, so long as the project moves along in a fair and reasonable manner. Also, nothing in this process precludes the Customer from starting construction prior to contacting the Utility; however, in such case the Customer accepts the risk of potentially needing to modify or substantially change the installation.

The Level 2 Process steps are as follows:

- (a) **Prior to applying.** The Customer is encouraged to contact and work closely with the Utility at the conceptual stages of the design to discuss the proposed design, installation, and operation. A preliminary electrical one-line diagram would be very helpful at this stage. This step will ensure that proposed projects proceed in a smooth and timely manner, and that the Utility and Customer understand whether any special considerations, protective equipment, system modifications, or studies may be required. Upon the Customer's request, the Utility shall meet with the Customer prior to submission of an Application.
- (b) **Customer Submits Application.** The Customer completes the standard Interconnection Application and submits it to the Utility along with all required supplemental information which shall be noted on the Application form. A Utility may charge an application fee, if a tariff containing such a fee is approved by the Commission.
- (c) **Application is Received and is Complete or Incomplete.** The Utility notifies the Customer within five (5) business days of receipt of the Application as to whether it is complete or incomplete.
  - (i) If the Application is incomplete, the Utility will specify what information or material is necessary to complete the Application.
  - (ii) The Customer has thirty (30) business days after receipt of such notification to submit the required information or materials (or request an extension), or the Application may be considered withdrawn.
- (d) **Utility Reviews Application.** Within fifteen (15) business days following the receipt of a complete Interconnection Application, the Utility reviews the proposed Interconnection and notifies the Customer of one of the following determinations:
  - (i) The proposed Generating Facility design appears to meet all Interconnection requirements and the Interconnection Application is approved as submitted. An Interconnection Agreement will be prepared by the Utility and forwarded to the Customer for review and signature in accordance with Step (e) below; or

- (ii) The proposed Generating Facility has failed to meet one or more of the screens, but the initial review indicates that Additional Review may enable the Utility to determine that the Customer's Generating Facility can be interconnected consistent with safety, reliability, and power quality. In such case, the Utility shall offer to perform Additional Review (typically about 3 hours of study) to determine whether minor modifications to the electric distribution system (for example, changing meters, fuses, or relay settings) would enable the Interconnection to be made consistent with safety, reliability and power quality. The Utility shall provide to the Customer a non-binding, good faith estimate of the costs of such Additional Review, and/or such minor modifications. The Utility shall undertake the Additional Review or minor modifications only after the Customer consents to pay for the review and/or modifications. Such Additional Review shall take place within 20 business days after the Customer has submitted payment for the estimated costs; or
- (iii) The proposed Generating Facility design has failed to meet one or more of the Interconnection requirements, and the Interconnection Application is denied. The Utility provides an explanation of the reason(s) for the denial (in writing, if requested by the Customer), and specifies what additional information and/or modifications to the Customer's Generating Facility or Utility system are required in order to obtain approval of the proposed design.

If the Application is denied, the Customer notifies the Utility within twenty (20) business days whether or not it wishes to proceed with the project. If the Customer does not wish to proceed with the project, or the Utility is not notified within the specified time frame, the Application may be considered withdrawn. If the Customer wishes to proceed with the project, then a new Application shall be submitted to the Utility for review and processing (Step (a) above is re-initiated), along with any additional information and/or modifications to the Customer's Generating Facility. Alternatively, the Customer may request processing under Level 3 and shall provide any additional information requested by the Utility and necessary to process the request under Level 3.

(e) **Interconnection Agreement.** If the Generating Facility meets all of the applicable Interconnection requirements and the Application is approved, then:

- (i) Within normally not more than ten (10) business days after the notice of Application approval, or following receipt of any "as built" or final diagrams from the Customer, the Utility sends to the Customer the appropriate Interconnection Agreement for review and signature.
- (ii) The Customer reviews, signs, and returns the Interconnection Agreement to the Utility.
- (iii) The Customer then completes installation of the Generating Facility within 180 days after execution of the Interconnection Agreement, unless an installation schedule has been submitted with an alternative in-service date, or the parties have mutually agreed to an extension. The Utility has the right to terminate any Agreements, and the Interconnection Application may be considered withdrawn, in the event that this timeframe is exceeded without extension.

- (f) **Inspection and Testing.** The Customer will contact the Utility to schedule the Utility site inspection and witness of the testing of the protective devices. The Utility site inspection and witness of the testing of the protective devices will normally occur within ten (10) business days of request from the Customer. The Utility may schedule metering replacement, if necessary, and labeling of Utility equipment to occur at the same time. A Utility may charge for the initial site inspection, if a tariff containing such a fee is approved by the Commission.

The Utility performs the site inspection as arranged and verifies that the Generating Facility, as best as can be determined, is in compliance with all applicable interconnection and safety requirements. At a minimum, it is suggested that the Utility shall verify the following:

- (i) An electrical permit and/or clearance has been issued by the authority having jurisdiction, if required;
- (ii) All Generating Facility equipment is properly labeled;
- (iii) Generating Facility system layout is in accordance with the plant location and site plan(s) submitted to the Utility;
- (iv) Generator nameplate ratings are consistent with the information submitted to the Utility;
- (v) Utility has unrestricted 24-hour access to the Disconnect Switch (if required), and the switch meets all applicable requirements;
- (vi) The Utility will witness the required protective relay calibration and functional tests. (The Utility may accept a certified test report in lieu of witnessing the tests); and
- (vii) The Generating Facility is wired, as best as can be determined, in accordance with the electrical diagrams submitted to the Utility.

The Utility will normally, before or at the time of the site inspection:

- (i) Install appropriate metering if required;
- (ii) Label all Utility equipment; and
- (iii) Ensure that the Generating Facility is properly incorporated onto Utility operating maps and identified as a backfeed source.

The Utility does not have the right to fail a site inspection in the event that any of the above three requirements (metering, Utility equipment labeling, and the identification of the Generating Facility on the operating maps) are not in place at the time of the site inspection. The Utility does have the right to fail any Generating Facility that does not meet the applicable Interconnection requirements, is not installed substantially in accordance with the documentation submitted to the Utility, or as a result of any safety or protection violation.

- (h) **Notification.** Immediately following completion of the site inspection (and upon receipt of all final applicable signed Interconnection documents) the Utility shall determine whether or

not the Generating Facility meets all applicable requirements. The Utility shall provide the Customer oral notification within twenty-four (24) hours and written notification within three (3) business days that:

- (i) The Generating Facility is approved for parallel operation with the Utility's distribution system per the agreed terms and conditions; or
  - (ii) The Generating Facility has failed to meet one or more of the applicable requirements or a safety or protection violation has been identified, and the Generating Facility is not approved for parallel operation. The Utility must provide the reason(s) (in writing, if requested by the Customer) for not approving parallel operation. Furthermore, the Utility has the right to take any reasonable steps (including locking open the Disconnect Switch) to prevent the Generating Facility from parallel operation. Operation of a generator in parallel without Utility approval may result in immediate termination of electric service to the Customer.
- (i) **Corrections (if necessary).** In the event that the Generating Facility does not pass each Utility site inspection:
- (i) The Customer must correct any outstanding issues and schedule a re-inspection. The Utility shall re-inspect upon ten (10) business days notice from the Customer to verify that the deficiencies have been remedied. A Utility may charge a fee for a re-inspection, if a tariff containing such a fee is approved by the Commission. Following any site re-inspection where the Utility approves parallel operation of the Generation Facility, the Utility will provide to the Customer such oral notification within twenty-four (24) hours and such written notification within three (3) business days that the Generation Facility is approved for parallel operation.
  - (ii) If updated diagrams are required to reflect "as-built" conditions, the Customer must submit these to the Utility for review and approval within ten (10) business days following the site inspection. The Utility will process and mail an amendment to the Interconnection Agreement within five (5) business days after acceptance of the revised diagrams for Customer review and signature.

**Customer Timeframes.** The Utility timeframes contained herein do not include the time for the Customer to execute agreements or submit needed documentation. If at any point in the Level 2 Fast Track process, the Customer does not submit requested materials necessary to process the interconnection Application, or submit applicable executable agreements within thirty (30) business days, or request an extension, the Application may be considered withdrawn.

**Fees for Level 2 Additional Review.** A Utility may charge a fee for an Additional Review, if a tariff containing the hourly rate for Additional Review is approved by the Commission. The Utility shall provide a non-binding good faith estimate of the fee for such additional review. The Customer must submit a deposit for the estimated fee before the Additional Review will be initiated. In addition, costs for Utility facilities and/or equipment modifications necessary to accommodate the Customer's generator interconnection will be the responsibility of the Customer.

#### 4.5 Level 3 Study Track Process

Level 3, also called the Study Track, is the interconnection procedure to be used for all Generating Facilities that do not meet the screening requirements for Level 1 Super Fast Track or Level 2 Fast Track. It is an in-depth engineering review of whatever aspects of generator performance and/or grid interaction the Utility deems necessary to study. More details are available in each Utility's Interconnection Manual. For generators that are certified, no review of the generator's protection equipment is required, although the Utility may study the interface between the Generating Facility and the Utility. The Generating Facility is required to meet applicable local electric codes and standards, as well as comply with all terms and conditions of the Utility's Interconnection Manual and Interconnection Agreement.

Nothing in these procedures shall preclude the Customer and Utility from mutually agreeing to different timeframes or other procedures for the approval of interconnected operation of a Generating Facility, so long as the project moves along in a fair and reasonable manner.

The Level 3 Study Track interconnection process is as follows:

- (a) **Prior to applying.** The Customer is encouraged to contact and work closely with the Utility at the conceptual stages of the design to discuss the proposed design, installation, and operation. A preliminary electrical one-line diagram would be very helpful at this stage. This step will ensure that proposed projects proceed in a smooth and timely manner, and that the Utility and the Customer understand whether any special considerations, protective equipment, system modifications, or studies may be required. Upon the Customer's request, the Utility shall meet with the Customer prior to submission of an Application.
- (b) **Customer Submits Application.** The Customer completes the Interconnection Application and submits it to the Utility along with all required supplemental information (which shall be noted on the Application form). A Utility may charge an application fee, if a tariff containing such a fee is approved by the Commission.
- (c) **Application is Received and is Complete or Incomplete.** The Utility notifies the Customer in normally not more than ten (10) business days of receipt of the Application (or transfer from Level 1 or 2) as to whether it is complete or incomplete.
  - (i) If the Application is incomplete, the Utility will specify what information or material is necessary to complete the Application.
  - (ii) The Customer has normally not more than thirty (30) business days after receipt of such notification to submit the missing information or materials (unless other mutually agreeable arrangements are made); otherwise the Application may be considered withdrawn.
  - (iii) Once the Customer submits any missing information, the Utility has normally not more than another ten (10) business days to determine if the Application is complete or incomplete and notify the Customer.

- (d) **Utility Reviews Application.** Normally within ten (10) business days following the receipt of a complete Interconnection Application, the Utility reviews the proposed interconnection and notifies the Customer of one of the following determinations:
- (i) The Generating Facility design as submitted appears to meet all of the applicable Interconnection requirements and no further studies, special protective requirements, or system modifications are required. An Interconnection Agreement will be prepared by the Utility and forwarded to the Customer for review and signature in accordance with Step (j) below; or
  - (ii) The Generating Facility cannot be interconnected without further information, data, engineering studies, and/or modifications to the Utility system or Generating Facility. In this case, the Interconnection proceeds according to the following meeting and study process, as deemed necessary by the Utility. All itemized costs and timelines for the studies are to be disclosed and agreed upon by the Utility and Customer prior to the start of each one. In addition, all studies are to be made available to the Customer directly after their completion.
- (e) **Scoping Meeting.** This is a high-level, initial review meeting between the Utility and the Customer, where the Customer describes the proposed Generating Facility design and the Utility talks about system conditions at the proposed Point of Interconnection. This meeting can also allow the Utility and Customer to discuss which of the following study elements are needed. The Utility and the Customer will bring to the meeting personnel, including system engineers and other resources as may be reasonably required to accomplish the purpose of the meeting. This meeting shall be held in normally not more than ten (10) business days after an Application is deemed complete unless other mutual agreements are made.
- (f) **Acknowledgement Letter.** The Utility will provide an Acknowledgement Letter following the Scoping Meeting upon request from the Customer. The letter will describe the project scope and include a good faith cost estimate by the Utility. If requested, the Acknowledgement Letter will be sent out normally within 10 business days following the Scoping Meeting.
- (g) **Interconnection Feasibility Study.** If requested by the Customer, the Utility shall undertake an Interconnection Feasibility Study. The Utility shall provide the Customer, as soon as possible, but in normally not more than ten (10) business days after the Scoping Meeting, an Interconnection Feasibility Study Agreement including an outline of the scope of the study and a non-binding, good faith, detailed estimate of the materials and labor costs to perform the study. Once the interconnecting Customer executes the Interconnection Feasibility Study Agreement, provides all requested Customer information necessary to complete the Study, and pays pursuant to the good faith estimate contained therein, the Utility will conduct the Interconnection Feasibility Study.

The Feasibility Study will be completed in normally not more than twenty (20) business days, unless other mutually agreeable terms are made.

The Interconnection Feasibility Study provides a preliminary review of the potential impacts on the distribution system that will result from the proposed Interconnection. The Interconnection Feasibility Study will review short circuit currents including contribution



from the proposed generator as well as coordination of and potential overloading of distribution circuit protection devices. This study principally benefits the Customer by providing initial details and ideas on the complexity and likely costs to interconnect prior to commitment of costly engineering review. The Interconnection Feasibility Study may also be used to focus or eliminate some or all of the more intensive System Impact study.

- (h) **System Impact Study.** If deemed necessary by either party, the Utility shall undertake a System Impact Study. The Utility shall provide the Customer as soon as possible, but in normally not more than fifteen (15) business days after completing the previous study or meeting, a System Impact Study Agreement including an outline of the scope of the study and a non-binding, good faith, detailed estimate of the materials and labor costs to perform the study. Once the Customer executes the System Impact Study Agreement, provides all requested Customer information necessary to complete the Study, and pays any required deposit pursuant to the good faith estimate contained therein, the Utility will conduct the Impact Study.

The System Impact Study will be completed in normally not more than thirty (30) business days, unless other mutually agreeable terms are made.

The System Impact Study is a full engineering review of all aspects of the generator's impact on the Utility system, including power flow, Utility system protective device coordination, generator protection schemes (if not certified), stability, voltage collapse, frequency impacts, and short circuit duty. The System Impact Study reveals all areas where the Utility system would need to be upgraded to allow the generator to be built and interconnected as designed. It may include discussions with the Customer about potential alterations to generator design, including downsizing to limit grid impacts.

If the Utility determines, in accordance with Good Utility Practice, that the Utility electric system modifications required to accommodate the proposed Interconnection are not substantial, the System Impact Study shall identify the scope and detailed cost of the modifications.

If the Utility determines, in accordance with Good Utility Practice, that the system modifications to the Utility electric system are substantial, a Facilities Study shall be performed.

Each Utility shall include in its Interconnection Manual a description of the various elements of a System Impact Study it would typically undertake pursuant to this Section including:

- (i) Load Flow Study;
- (ii) Short-Circuit Study;
- (iii) Circuit Protection and Coordination Study;
- (iv) Impact on System Operation;
- (v) Stability Study (and the conditions that would justify including this element in the Impact Study); and

(vi) Voltage Collapse Study (and the conditions that would justify including this element in the Impact Study).

- (i) **Facilities Study.** If deemed necessary by the Utility, the Utility shall undertake a Facilities Study. The Utility shall provide the Customer as soon as possible, but in normally not more than five (5) business days after completing the previous study or meeting, a Facilities Study Agreement including an outline of the scope of the study and a non-binding, good faith, detailed estimate of the materials and labor cost to perform the study. Once the interconnecting Customer executes the Facilities Study Agreement, provides all requested Customer information necessary to complete the Study, and pays pursuant to the good faith estimate contained therein, the Utility will conduct the Facilities Study. The Facilities Study will be completed in normally not more than thirty (30) business days, unless other mutually agreeable terms are made.

The Facilities Study is a comprehensive analysis of the actual construction needed to take place based on the outcome of the Impact Study. It delineates the detailed costs of construction and milestones. Construction may include new circuit breakers, relocation of reclosers, new construction of Utility grid extensions, reconductoring lines, new transformers, protection requirements and interaction. Where no Utility construction is required there would be no Facilities Study.

- (j) **Interconnection Agreement.** If the Generating Facility meets all of the applicable Interconnection requirements, all items identified in any Meeting or Study have been resolved and agreed to (if applicable), and the Utility has received the final design drawings, then:

- (i) The Utility shall send to the Customer in normally not more than ten (10) business days an executable Interconnection Agreement, which shall include as an exhibit the cost for any required Utility system modifications.
- (ii) The Customer reviews, signs, and returns the signed Interconnection Agreement and any balance due for Interconnection studies or required deposit for facilities.
- (iii) The Customer then completes installation of the Generating Facility and the Utility completes any utility system modifications, according to the milestones set forth in the Interconnection Agreement. The Utility shall employ best reasonable efforts to complete such system upgrades in the shortest time reasonably practical.

- (k) **Inspection and Testing.** The Customer will contact the Utility to schedule the Utility site inspection and witness of the testing of the protective devices. The Utility site inspection and witness of the testing of the protective devices will normally occur within ten (10) business days of notice from the Customer. The Utility may schedule metering replacement, if necessary, and labeling of Utility equipment to occur at the same time.

The Utility performs the site inspection as arranged and verifies that the Generating Facility, as best as can be determined, is in compliance with all applicable Interconnection and code requirements. At a minimum, it is suggested that the Utility verify the following:

- (i) An electrical permit and/or clearance has been issued by the authority having jurisdiction, if required;
- (ii) All Generating Facility equipment is properly labeled;
- (iii) Generating Facility system layout is in accordance with the plant location and site plan(s) submitted to the Utility;
- (iv) Generator nameplate ratings are consistent with the information submitted to the Utility;
- (v) The Utility has unrestricted access to the Disconnect Switch (if required), and the switch meets all requirements;
- (vi) The Utility will witness the required protective relay calibration and functional tests. (The Utility may accept a certified test report in lieu of witnessing the tests); and
- (vii) The Generating Facility is wired, as best can be determined, in accordance with the electrical diagrams submitted to the Utility.

The Utility will normally, before or at the time of the site inspection:

- (i) Install all appropriate metering, if required;
- (ii) Label all Utility equipment; and
- (iii) Ensure that Generating Facility is properly incorporated onto Utility operating maps and identified as a backfeed source.

The Utility shall not have the right to fail a site inspection in the event that any of the above three requirements (metering, Utility equipment labeling, and the identification of the Generating Facility on the operating maps) are not in place at the time of the site inspection.

The Utility does have the right to fail any Generating Facility that does not meet the applicable Interconnection requirements, is not installed substantially in accordance with the documentation submitted to the Utility, or as a result of any safety or protection violation.

- (l) **Notification.** Immediately following completion of the site inspection (and upon receipt of all final applicable signed Interconnection documents) the Utility shall determine whether or not the Generating Facility meets all applicable requirements. The Utility shall provide the Customer oral notification normally within twenty-four (24) hours and written notification normally within three (3) business days that:
  - (i) The Generating Facility is approved for parallel operation with the Utility's distribution system per the Interconnection Agreement. The Utility shall provide the Customer with such notification in writing in normally not more than three (3) business day following the Utility inspection under (k) above; or

- (ii) The Generating Facility has failed to meet one or more of the applicable requirements or a safety violation has been identified, and the Generating Facility is not approved for parallel operation. The Utility shall provide the reason(s) (in writing, if requested by the Customer) for not approving parallel operation. Furthermore, the Utility has the right to disconnect and lock out the Generating Facility to prevent the Generating Facility from parallel operation, and the Customer must reschedule the site inspection with the Utility. The Customer may not operate in parallel until it receives written approval from the Utility, and violation of this condition may result in immediate termination of electric service to the Customer.

(m) **Correction (if necessary).** In the event that the Generating Facility does not pass the initial Utility site inspection:

- (i) The Customer must correct the deficiencies identified by the Utility and schedule a re-inspection. The Utility shall re-inspect normally not more than ten (10) business days notice from the Customer to verify that the deficiencies have been remedied. Following any site re-inspection where the utility approves parallel operation of the Generation Facility, the Utility will provide to the Customer such oral notification normally within twenty-four (24) hours and such written notification normally within three (3) business days that the Generation Facility is approved for parallel operation.
- (ii) If updated documentation is required to reflect "as-built" conditions, the Customer must submit these to the Utility for review and approval within ten (10) business days following the site inspection. The Utility may charge a fee, if a tariff containing such a fee is approved by the Commission. The Utility will process and mail an amendment to the Interconnection Agreement normally not more than five (5) business days after receipt and acceptance of the revised diagrams for Customer review and signature.

**Customer Timeframes.** The Utility timeframes contained herein do not include the time for the Customer to execute agreements or submit needed documentation. If at any point in the Level 3 Study Track process, the Customer does not submit requested materials necessary to process the Interconnection Application, or submit applicable executable agreements in normally not more than thirty (30) business days, or request an extension, the Application may be considered withdrawn.

**Fees for Level 3 Interconnection.** A Utility may charge a fee for an engineering review, if a tariff containing the hourly rate for engineering review is approved by the Commission. The Utility shall provide a non-binding good faith estimate of the fee for such engineering review. The Customer must submit a deposit for the estimated fee before the engineering review will be initiated. In addition, costs for Utility facilities and/or equipment modifications necessary to accommodate the Customer's generator interconnection will be the responsibility of the Customer. The Customer may not be charged for the review of a certified generator's protection equipment. The utility may charge a fee for an initial inspection or for a re-inspection, if a tariff containing such a fee is approved by the Commission.

#### 4.6 Interconnection to Secondary Spot Network Systems

The requirements for interconnecting generating facilities to Secondary Spot Network Systems are different than those for Interconnection to radial distribution systems. In the Secondary Spot Network System, there are technical requirements to be considered particularly with the design and operational aspects of network protectors that are not required on radial systems.

Currently, Arizona Public Service ("APS") is the only Utility in Arizona that has Secondary Spot Networks. As such, APS has developed the following interim criteria for interconnecting a small amount of inverter-based customer generation to a Secondary Spot Network System. Because the maximum level of generation that could be interconnected to a Secondary Spot Network System is unknown at this time, this "Pilot" effort should be viewed as a trial basis only. APS reserves the right to suspend it at any time. APS has initiated this Pilot effort in a proactive attempt to include distributed generation in the State of Arizona on Secondary Spot Network Systems.

The Pilot criteria require that the generation meet all of the following conditions simultaneously:

- (a) Inverter based units must be less than 10 kW;
- (b) Units must be "Certified" as prescribed in this Document, and must meet current IEEE 1547 and UL 1741 standards; and
- (c) Must be less than or equal to 10% of the interconnecting customer's verifiable minimum load during the operation of the inverter. (For photovoltaics, the minimum load refers to the daytime minimum.)

APS reserves the right to suspend, change, modify, or add to the above conditions based on the results from future test reports or guidelines as they become available.

Once the 1547.6 standards are completed, APS (and any other Arizona Utilities who have since added Secondary Spot Networks) will review the Pilot criteria for possible modification to include guidelines for Interconnection to the Secondary Spot Network Systems.

The process for interconnecting to a Secondary Spot Network System will be determined by the Utility.

## 5. UTILITY REPORTING REQUIREMENTS

**Interconnection Manual.** Each Utility shall file an Interconnection Manual for approval with the Commission no later than ninety (90) calendar days after adoption of this document. Each Interconnection Manual shall contain procedural and technical requirements necessary to interconnect a Generating Facility to each Utility's respective distribution system but shall not be inconsistent with this Document. An updated Interconnection Manual shall be provided to the Commission upon any substantive revision by the Utility and shall become effective within sixty (60) days unless otherwise acted upon by the Commission.

**Documentation of projects.** Each electric Utility shall maintain records concerning Applications received for Interconnection and parallel operation of distributed generation. Such records will include the date each Application is received, documents generated in the course of processing each Application, correspondence regarding each Application, the final disposition of each Application, and the date on which the Application was approved (if approved).

**Annual Interconnection report to the Commission.** By March 30 of each year, every Utility shall file with the Commission a distributed generation Interconnection report for the preceding calendar year that lists the new Generating Facilities interconnected with the system since the previous year's report, any distributed generation facilities no longer interconnected with the Utility's system since the previous report, and the capacity of each facility. The annual report shall include, for the reporting period, a summary of the number of complete Applications received, the number of complete Applications approved, the number of complete Applications denied by level, and the reasons for denial. The annual report shall also include a list of special contracts, approved by the Commission during the reporting period, that provide discounted rates to customers as an alternative to self-generation.

## 6. DEFINITIONS

**ANSI:** American National Standards Institute. See [www.ansi.org](http://www.ansi.org).

**Application:** The standard form for applying to interconnect a Generating Facility with the Utility system.

**Arizona Corporation Commission ("ACC" or "Commission"):** The regulatory agency of the state of Arizona having jurisdiction over public service corporations operating in Arizona.

**Backfeed:** To energize a section of a Utility electric system that is supplied from a source other than its normal source.

**Business Day:** Monday through Friday, excluding Federal and Arizona State Holidays.

**Certified Equipment:** A specific generating and protective equipment system or systems that have been certified as meeting the requirements in subsection 3.4 relating to testing, operation, safety, and reliability by an entity approved by the Commission.

**Customer:** A electric consumer that generates electricity on the consumer's side of the Utility meter.

**Disconnect Switch:** A device that the Customer may be required to install and maintain that is a visible open, manual, gang operated, load break disconnect device, capable of being locked in a "visible open" position by a standard Utility padlock that will completely isolate the Customer's Generating Facility from the Utility grid. "Visible open" has the same definition as used in the National Electric Code. If the voltage is over 500 volts, it has to be capable of being grounded on the Utility side.

**Distributed Generation ("DG"):** Any type of Customer electrical generator, static inverter, or Generating Facility interconnected with the distribution system that either (a) has the capability of being operated in electrical parallel with the Utility's distribution system, or (b) can feed a customer load that can also be fed by the Utility's electrical system. A distributed generator is often referred to as a "Generating Facility" in this Document.

**Distribution System:** The infrastructure constructed, maintained, and operated by an electric Utility to deliver electric service to retail customers.

**Electric Supply or Purchase Agreement:** An agreement, together with appendices, signed between the Utility and the Customer covering the terms and conditions under which electrical power is supplied to and/or purchased from the Utility.

**Equipment Package:** A group of components connecting an electric generator with a Utility distribution system, and includes all interface equipment including switchgear, inverters, or other interface devices. An equipment package may include an integrated generator or electric source.

**Fault Current:** The level of current that can flow if a short circuit is applied to a voltage source.

**Generating Facility:** All or part of the Customer's electrical generator(s) or inverter(s) together with all protective, safety, and associated equipment necessary to produce electric power at the Customer's facility. A Generating Facility also includes any Qualifying Facility ("QF").

**Good Utility Practice:** Any of the practices, methods, and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods, and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety, and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

**IEEE:** The Institute of Electrical and Electronic Engineers. See [www.ieee.org](http://www.ieee.org).

**Interconnection Agreement:** An agreement, together with appendices, signed between the Utility and the Customer, covering the terms and conditions governing the Interconnection and operation of the Generating Facility with the Utility.

**Interconnection:** The physical connection of Customer's Generating Facility to the Utility system.

**Interconnection Manual:** A separate document developed and maintained by each Utility, made available on each Utility's website, and approved by the Commission, containing detailed technical, safety, and protection requirements necessary to interconnect a Generating Facility to each Utility's respective distribution system. The Interconnection Manual shall be consistent with this Document.

**Interconnection Study:** A study or studies that may be undertaken by a Utility (or a Utility-designated third party) in response to its receipt of a completed Application for Interconnection and parallel operation with the Utility system. Interconnection studies may include, but are not limited to, Interconnection Feasibility Studies, System Impact Studies, and Facilities Studies.

**Island:** A condition in which a portion of a Utility electric power system is energized solely by one or more local electric power systems throughout the associated Point of Interconnection while that portion of the Utility electric power system is electrically separated from the rest of the Utility electric power system. Islands can either be intentional (planned) or unintentional (unplanned).

**Islandable System:** A Generating Facility interconnected to a bus common with the Utility's system, where the Generating Facility is designed to serve part of the Utility grid that has become or is purposefully separated from the rest of the grid.

**Minimum Protective Devices, Relays, and Interconnection Requirements:** The minimum required protective relaying and/or safety devices or requirements specified in this Document, are for the purpose of protecting only the Utility and its other customer facilities from damage or disruptions caused by a fault, malfunction, or improper operation of the Customer's Generating Facility. Minimum Protective Relaying and Interconnection Requirements do not include relaying, protective, or safety devices as may be required by industry and/or government codes



and standards, equipment manufacturing and prudent engineering design and practice to fully protect the Customer's Generating Facility; those are the sole responsibility of the Customer.

**NEMA:** National Electrical Manufacturers Association. See [www.nema.org](http://www.nema.org).

**NFPA:** National Fire Protection Association. See [www.nfpa.org](http://www.nfpa.org).

**Parallel System:** The operation of a Generating Facility that is electrically interconnected to a bus common with the Utility's electric distribution system, either on a momentary or continuous basis.

**Point of Interconnection:** The physical location where the Utility's service conductors are connected to the Customer's service conductors to allow parallel operation of the Customer's Generating Facility with the Utility's electric distribution system.

**Primary Network:** An AC power distribution system that uses two or more dedicated primary voltage feeders, connected in parallel, to simultaneously supply power to one customer. The system includes automatic protective devices intended to isolate faulted primary feeders, while maintaining uninterrupted service to the customer served from the other primary feeder circuit(s).

**Qualifying Facility ("QF"):** Any cogeneration or small power production facility that meets the criteria for size, fuel use, efficiency, and ownership as promulgated in 18 CFR, Chapter I, Part 292, Subpart B of the Federal Energy Regulatory Commission's Regulations.

**Radial Line:** A distribution line that originates from a substation and is normally not connected to another substation or another circuit sharing the common supply of electric power.

**Relay:** An electric device that is designed to interpret input conditions in a prescribed manner and after specified conditions are met to respond to cause contact operation or similar abrupt change in associated electric control circuits.

**Secondary Spot Network System:** An AC power distribution system in which a Customer is simultaneously served from three-phase, four-wire low-voltage (typically 480V) circuits supplied by two or more network transformers whose low-voltage terminals are connected to the low-voltage circuits through network protectors. The low voltage circuits do not have ties to adjacent or nearby secondary network systems. The secondary spot network system has two or more high-voltage primary feeders. These primary feeders are either dedicated network feeders that serve only other network transformers, or a non-dedicated network feeder that serves radial transformers in addition to the network transformer(s), depending on network size and design. The system includes automatic protective devices and fuses intended to isolate faulted primary feeders, network transformers, or low-voltage cable sections while maintaining uninterrupted service to the customers served from the low-voltage circuits.

**Separate System:** The operation of a Generating Facility that has no possibility of operating in parallel with the Utility's system.

**Transmission System:** Utility-owned high-voltage lines (69 kVa or higher) and associated equipment for the movement or transfer of electric energy between power plants and the distribution system.

**UL:** Underwriters Laboratories Inc. See [www.ul.com](http://www.ul.com).

**Utility:** An electric distribution company that constructs, operates, and maintains the electrical distribution system for the receipt and/or delivery of power.