

ORIGINAL



A subsidiary of Pinnacle West Capital Corporation

RECEIVED

50

2007 SEP 19 P 4: 51

Barbara Klemstine
Director
Regulation and Pricing

Tel. 602-250-4563
Fax 602-250-3003
e-mail Barbara.Klemstine@aps.com

AZ CORP COMMISSION
DOCKET CONTROL
Mail Station #708
Phoenix, Arizona 85072-3999

September 19, 2007

Docket Control
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, Arizona 85007

RE: PALO VERDE OUTAGE REPORT
DECISION NO. 69663
DOCKET NO. E-01345A-05-0816, E-01345A-05-0826, E-01345A-05-0827

Dear Sir or Madame:

Pursuant to Decision No. 69663, enclosed please find the Company's initial Outage Report for planned or unplanned outages at the Palo Verde Nuclear Generating Station.

If you have any questions, please call Jeff Johnson at 602-250-2661.

Sincerely,

Barbara Klemstine

BK/bgs

cc: Brian Bozzo
Ernest Johnson

Arizona Corporation Commission
DOCKETED
SEP 19 2007

DOCKETED BY
nr

**OUTAGE REPORT
PALO VERDE NUCLEAR GENERATING STATION
PURSUANT TO DECISION NO. 69663**

Type of Outage: Planned (Unit 1 Refueling)

Date(s) of Outage: May 19, 2007 through July 19, 2007

Duration of Outage: 61 days

Description of Outage:

The Unit 1 Refueling Outage scope included routine refueling and major projects including full structural weld overlay on select pressurizer and reactor coolant nozzles, upgrades on the refueling machine and transfer equipment, first time implementation of the containment sump modification, inspections on Reactor Coolant Pump 2B, overhauls and replacements of several key pumps and/or motors, significant check valve disassembly and inspection, and safety injection vent valve modification. The outage scope was expanded to include emergent maintenance and repair work as a result of events occurring and findings identified during the outage.

Root Cause of Outage (if determined): Not Applicable

Replacement Net Fuel and Purchased Power Costs Incurred as a result of Planned Outage:

\$14.4 million

Amount of Reduced Off-System Sales as a result of Outage: Not Applicable

Lost Opportunity Sales Margins as a result of Outage: Not Applicable