

ORIGINAL



SALLQUIST, DRUMMOND & O'CONNOR, P.C.
ATTORNEYS AT LAW
TEMPE OFFICE
4500 S. LAKESHORE DRIVE
SUITE 339
TEMPE, ARIZONA 85282

RICHARD L. SALLQUIST

PHONE (602) 224-9222
FACSIMILE (480) 345-0412
E-MAIL dick@sd-law.com

October 23, 2007

HAND DELIVERY

Shauna Lee-Rice
Arizona Corporation Commission
Docket Control
1200 West Washington Street
Phoenix, Arizona 85007

Re: Little Park Water Company; Docket No. W-02192A-07-0326; Late Filed Exhibit

Dear Ms. Lee-Rice:

The October 1, 2007 Staff Report in the Subject Docket recommended that the Company file a Curtailment Tariff. Enclosed please find fifteen (15) copies of a proposed Curtailment Tariff in the Engineering Division's recommended form.

The Company requests that this Tariff be considered as a late-filed exhibit and be approved as part of this Docket.

In the event you have any request is regarding this matter, please do not hesitate to contact Steve Gudovic at the Company or the undersigned.

Sincerely,

Richard L. Sallquist

Cc: Linda Jaress
Legal Division
Hearing Division
Engineering Division
Steve Gudovic

Arizona Corporation Commission
DOCKETED

OCT 23 2007

DOCKETED BY *nr*

RECEIVED
2007 OCT 23 P 12:42
AZ CORP COMMISSION
DOCKET CONTROL

DOCKET W-02192

Cancelling Sheet No.

Applies to all WATER service areas

PART TWO

**STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE**

I. CURTAILMENT PLAN FOR LITTLE PARK WATER COMPANY, INC.

ADEQ Public Water System Number: AZ 13-075

Little Park Water Company, Inc. ("Company") is authorized to curtail water service to all customers, within its certificated area under the terms and conditions listed in this tariff.

This curtailment plan shall become part of the Arizona Department of Environmental Quality Emergency Operations Plan, and the Drought Preparedness Plan and Water Conservation Plan to the Arizona Department of Water Resources applicable to the Company.

The Company shall notify its customers of this new tariff as part of its next regularly scheduled billing after the effective date of the tariff or no later than sixty (60) days after the effective date of the tariff.

The Company shall provide a copy of the curtailment tariff to any customer, upon request.

Stage 1 Exists When:

Company is able to maintain water storage in the system at 100 percent of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Issued: _____, 2007

Effective: _____, 2007

ISSUED BY:

Stevan Guodvic, President
Little Park Water Company, Inc.
45 Castle Rock Road, Suite #4
Sedona, Arizona 86351

DOCKET W-02192

Cancelling Sheet No.

Applies to all WATER service areas

PART TWO

**STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE**

Stage 2 Exists When:

- a. Company's water storage or well production has been less than 80 percent of capacity for at least 48 consecutive hours, and
- b. Company has identified issues such as steadily declining water table, an increased draw-down threatening pump operations, or poor water production creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

c. Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 percent. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

Notice Requirements: Under Stage 2, the Company is required to notify customers by delivering written notice door to door at each service address, or by United States first class mail to the billing address or, at the Company's option both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.

Issued: _____, 2007

Effective: _____, 2007

ISSUED BY:

Stevan Guodvic, President
 Little Park Water Company, Inc.
 45 Castle Rock Road, Suite #4
 Sedona, Arizona 86351

DOCKET W-02192

Cancelling Sheet No.

Applies to all WATER service areas

PART TWO

**STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE**

Stage 3 Exists When:

- a. Company's total water storage or well production has been less than 50 percent of capacity for at least 24 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 3, Company shall request the customer to voluntarily employ water conservation measures to reduce daily consumption by approximately 50 percent. All outside watering should be eliminated, except livestock, and indoor water conservation techniques should be employed whenever possible. Standpipe service shall be suspended.

Notice Requirements:

- 1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.
- 2. Beginning with Stage 3, Company shall post at least four signs showing the curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to the major subdivision served by the Company.

Issued: _____, 2007

Effective: _____, 2007

ISSUED BY:

Stevan Guodvic, President
Little Park Water Company, Inc.
45 Castle Rock Road, Suite #4
Sedona, Arizona 86351

DOCKET W-02192

Cancelling Sheet No.

Applies to all WATER service areas

PART TWO

**STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE**

- 3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 3.

Once Stage 3 has been reached, the Company must begin to augment the supply of water by either hauling or through an emergency interconnect with an approved water supply in an attempt to maintain the curtailment at a level no higher than stage three until a permanent solution has been implemented.

Stage 4 Exists When:

- a. Company's total water storage or well production has been less than 25 percent of capacity for at least 12 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 4, Company shall inform the customers of a **mandatory** restriction to employ water conservation measures to reduce daily consumption. Failure to comply will result in customer disconnection. The following uses of water shall be prohibited:

Issued: _____, 2007

Effective: _____, 2007

ISSUED BY:

Stevan Guodvic, President
Little Park Water Company, Inc.
45 Castle Rock Road, Suite #4
Sedona, Arizona 86351

DOCKET W-02192

Cancelling Sheet No.

Applies to all WATER service areas

PART TWO

**STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE**

- ◆ Irrigation of outdoor lawns, trees, shrubs, or any plant life is prohibited
- ◆ Washing of any vehicle is prohibited
- ◆ The use of water for dust control or any outdoor cleaning uses is prohibited
- ◆ The use of drip or misting systems of any kind is prohibited
- ◆ The filling of any swimming pool, spas, fountains or ornamental pools is prohibited
- ◆ The use of construction water is prohibited
- ◆ Restaurant patrons shall be served water only upon request
- ◆ Any other water intensive activity is prohibited

The Company's operation of its standpipe service is prohibited. The addition of additional service lines and meter installations is prohibited.

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Company shall post at least four (4) signs showing curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to the major subdivision served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 4.

Issued: _____, 2007

Effective: _____, 2007

ISSUED BY:

Stevan Guodvic, President
Little Park Water Company, Inc.
45 Castle Rock Road, Suite #4
Sedona, Arizona 86351

DOCKET W-02192

Cancelling Sheet No.

Applies to all **WATER** service areas

PART TWO

STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE

Customers who fail to comply with cessation of outdoor use provisions will be given a written notice to end all outdoor use. Failure to comply with in two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outdoor water. To restore service, the customer shall be required to pay all authorized reconnection fees. If a customer believes he/she has been disconnected in error, the customer may contact the Commission's Consumer Services Section at 1-800-222-7000 to initiate an investigation.

Once Stage 4 has been reached, the Company must augment the supply of water by hauling or through an emergency interconnect from an approved supply in an attempt to maintain the supply until a permanent solution has been implemented.

Issued: _____, 2007

Effective: _____, 2007

ISSUED BY:

Stevan Guodvic, President
Little Park Water Company, Inc.
45 Castle Rock Road, Suite #4
Sedona, Arizona 86351