

ORIGINAL

# CEDAR GROVE WATE



0000078244

P. O. Box 1270, Show Low AZ 85902, Phone (928) 537-8739, Fax (928) 537-1270

50

October 26, 2007

Re: DOCKET NO. W-02597A-04-0456, DECISION NO. 68304

To Whom It May Concern:

Attached is the Approval to Construct issued by ADEQ and pertaining to the above referenced Docket and Decision Number. Please contact my office with any questions. Thank you.

Sincerely,

Thomas Grapp

Arizona Corporation Commission  
**DOCKETED**  
OCT 29 2007

DOCKETED BY	nr
-------------	----

AZ CORP COMMISSION  
DOCKET CONTROL

2007 OCT 29 A 10:28

RECEIVED




**ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY  
 CERTIFICATE OF APPROVAL TO CONSTRUCT  
 DRINKING WATER WELL FACILITIES**

<b>ADEQ File No:</b> 20070343	<b>LTF No:</b> 44134
<b>System Name:</b> Cedar Grove Water Inc.	<b>System Number:</b> 01-049
<b>Project Owner:</b> Cedar Grove Water Inc.	
<b>Address:</b> Po Box 1270, Show Low, AZ 85902	
<b>Project Location:</b> Show Low	<b>County :</b> Apache
<b>Description:</b> CEDAR GROVE WELL #5 AND STORAGE TANK. MODIFY EXISTING 380 FOOT DEEP WELL, WHICH PUMPS 30 GPM AND 15,000 GAL STORAGE TANK TO DRINKING WATER STANDARDS. BUILD PUMP HOUSE, INSTALL BOOSTER PUMP.	

*Approval to construct the above-described facilities as represented in the approved documents on file with the Arizona Department of Environmental Quality is hereby given subject to provisions 1 through 5 continued on page 2 through 2*

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Northern Regional Office located in Flagstaff. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin.Code. At the project owner's request, the Department may conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.
3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-5-507(A), Ariz. Admin. Code.

Reviewed by : NLS

By:  10/22/07  
 Kwame A. Agyare., P.E. Date  
 Manager, Drinking Water and  
 Wastewater Engineering Review  
 Water Quality Division

cc: File No : 20070343  
 Regional Office: Northern  
 Owner: Cedar Grove Water Inc.  
 County Health Department: Apache  
 Engineer: Fleetwood Engineering Llc  
 Planning and Zoning/Az Corp. Commission  
 Engineering Review Database - Etr022

**APPROVAL TO CONSTRUCT  
WATERLINE EXTENSION  
ADEQ FILE No. 20070343  
PAGE 2 OF 2: PROVISIONS CONTINUED**

5. It is recommended that the storage tank inlet be connected to the top of the tank with an appropriate air gap in order to minimize water quality problems associated with stagnant water and to maximize disinfection contact time in the event that chlorination is required. Since this drinking water storage tank's inlet is on the bottom of the tank, it is recommended that the low level alarm be disabled on occasion in order to circulate the standing water.