



0000080159

W-02105A-07-0510

699/3

ORIGINAL

Arizona De
Drinking Water Monitoring and Protection Unit
1110 W. Washington Street, 5415B-1
Phoenix, AZ 85007

Quality

RECEIVED

JAN 03 2008

Drinking Water Compliance Status Report

AZ CORP COMM
Director Utilities

Public Water System Name: Mt. Tipton Water Co.

Public Water System ID #: 08-059

Public Water System Type: Community Non-transient Non-community Transient Non-community

Overall Compliance Status: No Major Deficiencies Major Deficiencies

Monitoring and Reporting Status: No Major Deficiencies Major Deficiencies

Comments:

Total Coliform

This system exceeded the MCL for total coliform in April 2007. In order to resolve the violation, the system must issue a Public Notice, and ADEQ does not have a record of a Public Notice being issued at this time.

The ADEQ database does not show that we have received the required total coliform samples for the month of September 2007.

Nitrate

The ADEQ data base does not show that this water system has provided the required four consecutive quarters of increased nitrate monitoring analyses after exceeding a trigger for increased nitrate monitoring at EPDS002 on 2/03/04 and 2/15/06. The system should have sampled during the 4th quarter of 2007, and the 1st and 2nd quarters of 2008, to have 4 consecutive quarters beginning with the 3rd quarter sample taken on 8/23/07.

The ADEQ data base does not show that this water system has provided the required four consecutive quarters of increased nitrate monitoring analyses after exceeding a trigger for increased nitrate monitoring at EPDS010 on 3/29/06. A sample was taken on 4/5/06 and 8/23/07. The system should have sampled during the 4th quarter of 2007, and the 1st and 2nd quarters of 2008, to have 4 consecutive quarters beginning with the 3rd quarter sample taken on 8/23/07.

Operation and Maintenance Status: No Major Deficiencies Major Deficiencies

Comments: *None*

Major unresolved/ongoing operation and maintenance deficiencies:

- unable to maintain 20psi
- inadequate storage
- cross connection/backflow problems
- surface water treatment rule
- treatment deficiencies
- approval of construction
- certified operator
- other

Date of last inspection / sanitary survey: 3-15-2007

Administrative Orders:

Is an ADEQ administrative order in effect? Yes No

Comments: *None*

Arizona Corporation Commission
DOCKETED

JAN 04 2008

DOCKETED BY

AZ CORP COMM
DOCKET CONTROL

2008 JAN -4 A 9:23

RECEIVED

System information:

Number of Entry Points to the Distribution System 6 Number of Sources 8
Population Served 2000 Service Connections 890 Initial Monitoring Year 1994

Evaluation completed by: Donna Calderon, Manager, Drinking Water Monitoring and Protection Unit

Phone: 602-771-4641

Date: January 3, 2008

Because of the previously identified exceedance and compliance monitoring deficiencies, ADEQ cannot determine if this system is currently delivering water that meets water quality standards required by Arizona Administrative Code, Title 18, Chapter 4. This compliance status report does not guarantee the water quality for this system in the future. This compliance status report does not reflect the status of any other water system owned by this utility company.