



0000081648



ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY
CERTIFICATE OF APPROVAL TO CONSTRUCT
WATER FACILITIES

RECEIVED

SD

2008 FEB 11 A 11:20
Page 1 of 2

ADEQ File No: 20070864	LTF No: 46324	AZ CORP COMMISSION DOCKET CONTROL
System Name: Ashcreek Water Co.	System Number: 05-007	Arizona Corporation Commission
Project Owner: Ashcreek Water Co.	DOCKETED	
Address: Po Box 825, Thatcher, AZ 85552	FEB 11 2008	
Project Location: Thatcher	County: Graham	DOCKETED BY
Description: RELOCATE 20,000 GAL STORAGE TANK, USE FOR BLENDING WATER FROM WELL #6 & WELL #2 WITH SL ARSENIC MCL EXDNC. CONNECT TO SYSTEM W/ 1,450 LF 4-INCH C900 PVC & 120 LF OF 2-INCH PRESSURE CLASS 160 PVC. BLENDING PLAN ALSO SUBMITTED AND APPROVED.		

Approval to construct the above-described facilities as represented in the approved documents on file with the Arizona Department of Environmental Quality is hereby given subject to provisions 1 through 6 continued on page 2 through 2

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Southern Regional Office located in Tucson. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin. Code. At the project owner's request, the Department may conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.
3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-5-507(A), Ariz. Admin. Code.

Reviewed by: NLS

By:
 Kwame A. Agyare, P.E. Date: 1/29/08
 Manager, Drinking Water and
 Wastewater Engineering Review
 Water Quality Division

cc: File No: 20070864
 Regional Office: Southern
 Owner: Ashcreek Water Co.
 County Health Department: Graham
 Engineer: Trueline Engineering
 Planning and Zoning/Az Corp. Commission
 Engineering Review Database - Etr021

Re: Docket No. W-02494A-06-0561
 Docket No. W-02494A-06-0562
 Decision No. 69581

**APPROVAL TO CONSTRUCT
WATERLINE EXTENSION
ADEQ FILE No. 20070864
PAGE 2 OF 2: PROVISIONS CONTINUED**

5. The public water system shall monitor on at least a quarterly basis of both of the following:
 - a. All sources contributing to the blend; and
 - b. Blended water to ensure that the provisions of this Section are met.

6. A public water system shall submit an amended blending plan to the Department to confirm that the new blend achieves compliance with MCLs whenever sources are added to or removed from service or the relative flow rates from blended sources are changed in a way that changes the blend.