

ORIGINAL



SALLQUIST, DRUMMOND & O'CONNOR, .

14LF

ATTORNEYS AT LAW
TEMPE OFFICE
4500 S. LAKESHORE DRIVE
SUITE 339
TEMPE, ARIZONA 85282

RICHARD L. SALLQUIST

PHONE (602) 224-9222
FACSIMILE (480) 345-0412
E-MAIL dick@sd-law.com

February 20, 2008

HAND DELIVERY

Judge Yvette Kinsey
Arizona Corporation Commission
Hearing Division
1200 West Washington Street
Phoenix, Arizona 85007

Re: Little Park Water Company; Docket No. W-02192A-07-0326; Late Filed Exhibits

Dear Judge Kinsey:

The Recommended Opinion and Order (the "ROO") in this matter is scheduled for Commission's consideration on March 11, 2008. That ROO contemplates, among other things, the Company filing as a compliance item the Approval to Construct (the "ATC") for the new facilities within the extension area.

A copy of that ATC is attached hereto. Although the signature line indicates it was approved on "1/25/07", that was misdated as indicted by the revisionor's footnote indicating a "1/23/2008 11:00am" change. Also, page 2 of the ATC indicates the plans were only submitted on December 28, 2007. The Company received their copy on February 8, 2008. We have today docketed that ATC in this proceeding under separate cover. We have also filed Exceptions to the ROO asking that compliance requirement be removed.

In the event you have any questions regarding this matter, please do not hesitate to contact the undersigned.

Sincerely,

Richard L. Sallquist
Richard L. Sallquist

cc: Docket Control (15 copies)
Legal Division
Utilities Division
Engineering Division
Steve Gudovic

Arizona Corporation Commission
DOCKETED

FEB 20 2008

DOCKETED BY *nr*

AZ CORP COMMISSION
DOCKET CONTROL

2008 FEB 20 P 2:49

RECEIVED

YAVAPAI COUNTY

Development Services

Prescott - (928) 771-3214 Fax: (928) 771-3443
Cottonwood - (928) 639-8151 Fax: (928) 639-8153



Flood Control District

Prescott - (928) 771-3197 Fax: (928) 771-3427
Cottonwood - (928) 639-8151 Fax: (928) 639-8118

RECEIVED
FEB 08 2008

500 S. Marina Street, Prescott, AZ 86303 and 10 S. 6th Street, Cottonwood, AZ 86326

Addressing - Building Safety - Customer Service & Permitting - Environmental - Flood Control District - Land Use - Planning & Design Review

CERTIFICATE OF APPROVAL TO CONSTRUCT WATER FACILITIES


Y. C. D. S.-E.U. File No: A52008000075	
System Name: Little Big Park Water Company	13-075
System Owner/Address: Little Big Park Water Co., 45 Castle Rock Rd. suite 4, Sedona, AZ 86351	
Project Name: Verde Valley School Water Line Extension	
Project Owner/Address: Verde Valley School, 3511 Verde Valley School Rd., Sedona, AZ 86351	
Project Location: Sedona, Arizona	
Project Description: Extend existing water distribution system to serve Verde Valley School	

Approval to construct the above-described facilities, as represented in the approved plan documents on file at Yavapai County Development Services- Environmental Unit, is hereby subject to the following Provisions:

- Construction shall be in accordance with plans and specifications stamped "YCDS-EU Construction Authorization (Approval to Construct)", which are dated and signed by the authorized Environmental Unit staff.
- Issuance of this "Approval to Construct" does not authorize construction in any County, Town, City or State road rights-of-way for this project. A separate permit may be required. Please contact the appropriate jurisdiction for this permit.

Provisions are continued on following pages.

The state law, A. R. S. §49-104.B.10, requires that construction of the project must be in accordance with rules and regulations of Arizona Department of Environmental Quality and Yavapai County Development Services-Environmental Unit. If construction has not started within one year of the date of this approval, this certificate will be void and a written extension of time shall be required.


Date Approved 1-25-07
Geoff Meek, RS, Manager
Environmental Unit

CC: Y.C.D.S-EU. File No: A52008000075
Project Owner: Verde Valley School
System Owner: Little Big Park Water Co.
Engineer: SWI

- The Project Owner shall retain the services of a professional engineer before starting project construction to provide detailed construction inspection of this project. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Environmental Unit staff with sealed "As- Built" plans, construction and test data. "clouding" or other effective identification method shall conspicuously identify the changes shown in the "as-built" plans. Upon receipt of these materials, the Environmental Unit staff will review the file and if in order, issue an APPROVAL TO OPERATE.
- The Project Owner shall not begin operation of the newly constructed facility until an APPROVAL TO OPERATE is issued by the Department.
- Approval to Construct is based on plans submitted by Shephard Wesnitzer, Inc., signed by Arthur H. Beckwith, PE, and dated December 28, 2007.
- Microbiological testing must be completed in accordance with AWWA requirements.
- System must have an agreement with an appropriate Certified Operator for system operation.
- This approval does not supersede or eliminate the necessity of obtaining permits or approvals from other county, state or federal agencies or departments.