

THIS AMENDMENT:		 0000091460
_____ Passed _____	Passed as amended by _____	
_____ Failed _____	Not Offered _____	

60
CF

ORIGINAL

MAYES PROPOSED AMENDMENT # 2

TIME/DATE PREPARED December 2, 2008, noon

COMPANY: AZ Solar One Linesiting Case No. 140

AGENDA ITEM: U-4

DOCKET NO: L-00000GG-08-0408-00140
L-00000GG-08-0407-00139


OPEN MEETING DATE: 12/3-5/08

Amend Sample Order 2 modifying the CEC issued by the linesiting committee. The purpose of this amendment is to add another condition concerning pole separation.

ADD condition #18 as follows:

“The Applicant shall maintain appropriate distance between the Project Gen-Tie towers and existing 230 kV transmission lines in the same corridor. Except when crossing existing substations, this distance should be at a minimum equal to or greater than the height of the tallest wooden 230kV transmission tower in each span.”

Make all conforming changes.

Arizona Commission
DOCKETED
 DEC 2 2008
 DOCKETED BY 

AZ COMMISSION
 DOCKET CONTROL

2008 DEC - 2 P 4: 55

RECEIVED