



ORIGINAL



0000096072

Jana Van Ness
Manager
Regulatory Compliance

Tel 602/250-2310
Fax 602/250-3003
e-mail: Jana.VanNess@aps.com
<http://www.apsc.com>

Mail Station 9908
P.O. Box 53999
Phoenix, AZ 85072-3999

February 19, 2004

Docket Control
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, Arizona 85007

RE: REVISED ELECTRIC METER MAINTENANCE AND TESTING ANNUAL REPORT
DOCKET NO. ~~RE~~-00000C-00-0275

67924

Attached is a revised filing related to the meter testing information for the years 2002 and 2003, previously provided pursuant to ACC Rules and Regulations R14-2-209(E)(2). This revised filing corrects meter error rates that were erroneously reported in previous filings.

If you have any questions regarding this filing, please contact me at (602) 250-2310.

Sincerely,

Jana Van Ness
Manager
Regulatory Compliance

JVN/srm

Attachment

Cc: Docket Control (Original, plus 13 copies)

AZ CORP COMMISSION
DOCUMENT CONTROL

2004 FEB 19 P 1:30

RECEIVED

Arizona Corporation Commission
DOCKETED

FEB 19 2004

DOCKETED BY

Electric Meter Maintenance and Testing Program

Reporting Year	Revised
<u>Year 2002</u>	
Single phase meters over the allowable 3%	37
Single phase meters under the allowable 3%	15
Three phase meters over the allowable 3%	0
Three phase meters under the allowable 3%	2
<u>Year 2003</u>	
Single phase meters over the allowable 3%	19
Single phase meters under the allowable 3%	34
Three phase meters over the allowable 3%	4
Three phase meters under the allowable 3%	0