



0000104134

ORIGINAL

Tucson Electric Power Company

P.O. Box 711, Tucson, AZ 85702

October 22, 2009

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Re: Notice of Errata to Tucson Electric Power Company's Direct Access Rules and Regulations
Docket Nos. E-01933A-05-0650, E-01933A-07-0402

On December 22, 2008, in compliance with Decision No. 70628 (December 1, 2008) Tucson Electric Power Company ("TEP") filed its Direct Access Rules and Regulations. Page 23 of those Rules and Regulation contained an error. Please find enclosed the corrected version of page 23.

If you have any questions, please contact me at (520) 884-3680.

Sincerely,

Jessica Bryne
Regulatory Services

cc: Barbara Keene, ACC


Arizona Corporation Commission

DOCKETED

OCT 22 2009

DOCKETED BY

RECEIVED
2009 OCT 22 1 P 4: 09
AZ CORP COMMISSION
DOCKET CONTROL



Tucson Electric Power Company Direct Access Rules and Regulations

A UniSource Energy Company

- e. National Electric Code ("NEC") & Local Requirements
- f. TEP Electric Service Requirements Handbook
- g. National Electrical Safety Code
- h. ESPs or their contractors providing competitive metering services shall also comply with such other specifications or standards determined to be applicable or appropriate by the ACC's Director of Utilities Division.

7. Meter Conformity

- a. All Direct Access meters shall have a visual kWh display and must have a physical interface to enable on-site interrogation of all stored meter data. All meters installed must support the Customer's TEP Pricing Plan.
- b. If TEP is providing MRSP functions for the ESP, meters must be compatible with TEP's meter reading system.
- c. No meter or associated metering equipment shall be set or allowed to remain in service if it is determined that the meter or its associated equipment did not meet TEP's existing approved specifications, as set forth in TEP's Electric Service Requirements Manual in place at the time of installation.

8. Meter Testing

- a. If a manufacturer's sealed meter has not previously been set and the meter was tested within the last twelve (12) months, the meter shall be deemed in compliance with ACC standards without additional testing.
- b. Any meter removed from service shall receive a calibration test prior to reinstallation.
- c. Records on calibration shall be maintained by the MSP and provided to the requesting parties within three (3) working days of such a request for such records. The latest calibration record shall be kept as long as the meter is in service.

9. Meter Test Requests

- a. Pursuant to A.A.C. R14-2-209 (F), either party may request that the other party perform a meter test, in which instance the requesting party is entitled to witness the test if it so chooses.
- b. The requesting party shall be notified of the test date and written test results from the testing party. If the meter is found to be within ACC-approved standards, the requesting party shall reimburse the other party for all costs incurred in the process of testing the meter (per ACC-approved Pricing Plans).

Filed By:	Raymond S. Heyman	Tariff No.:	Direct Access Rules & Regulations
Title:	Senior Vice President and General Counsel	Effective:	December 1, 2008
District:	Entire Electric Service Area Pag	e No.:	Page 23 of 29