

ORIGINAL

THIS AMENDMENT:

Passed

Passed as amended by



0000105810

Failed

Not Offered

RECEIVED

Leo

2009 DEC -4 P 3: 49

MAYES PROPOSED AMENDMENT # 3

AZ CORP COMMISSION  
DOCKET CONTROL

DATE PREPARED: December 4, 2009

COMPANY: Arizona Public Service

AGENDA ITEM NO. U-2

DOCKET NO. E-01345A-08-0172

OPEN MEETING DATE: 12-7-09

Page 53, line 18, INSERT New Finding of Fact: "While we appreciate the Settlement Agreement's provisions increasing the amount of Demand Response on APS' system, we do not believe they go far enough, in light of the recent report by the Federal Energy Regulatory Commission ("FERC") highlighting the under-utilization of Demand Response in Arizona and other states. Demand response poses enormous potential to shave electric utility companies' peak usage periods, thereby preventing the need for incremental new generation and saving ratepayers from the costs associated with generating electricity during peak times. A 2008 Demand Response & Load Management program study conducted for APS estimated an achievable range of 2 to 5 percent of peak demand reduction, or 140 - 350 MW of peak load reduction. Therefore, we believe that APS should implement at least 250 additional Megawatts of Commercial and Industrial Demand Response, and will require the Company to file for Commission approval a proposal for adding at least 250 Megawatts of Commercial and Industrial Demand Response for Commission consideration no later than 60 days from the effective date of this Order."

Page 55, line 5, INSERT New Ordering Paragraph: "IT IS FURTHER ORDERED that Arizona Public Service Company shall file a plan for Commission for adding at least 250 Megawatts of Commercial and Industrial Demand Response with Docket Control for Commission consideration no later than 60 days from the effective date of this Order."

Make all conforming changes.

Arizona Corporation Commission

DOCKETED

DEC - 4 2009

DOCKETED BY