

**Ash Fork Development Association**

P.O. Box 436 – 518 Lewis Ave.  
Ash Fork, AZ 86320  
(928) 637-2774  
(928) 637-0394 fax



0000107061

**ORIGINAL  
RECEIVED**

2/1/2010

2010 FEB -2 A 9:51


To: **Docket Control**  
AZ CORP COMMISSION  
DOCKET CONTROL  
Arizona Corporation Commission  
1200 West Washington  
Phoenix, AZ 85007

From: Ash Fork Development Association  
Db: Ash Fork Water Service  
P.O. box 436  
Ash Fork, AZ 86320

Docket # W-01004B-08-0508

Decision # 71181, Date 6/30/09

Arizona Corporation Commission  
**DOCKETED**  
FEB - 2 2010



Referencing Compliance Action  
“meter testing at Ash Fork Well #2”  
and “greater than 10% unaccounted for water”.

The output meter for Ash Fork Well #2 was removed from service and tested by a certified testing agency. This was completed in November 2009.

Unaccounted for water was at the 10% level but not greater than.  
Ash Fork Water Service plans to:

- Repair all reported leaks as a priority
- Test output meter from Ash Fork Well #1 for accuracy
- Replace 10% of the oldest residential meters in system
- Attend training on “Reducing Your Water Loss”

Submitted by: Lewis Hume, Manager Ash Fork Water Service  
928-637-2774