

COMMISSIONERS
KRISTIN K. MAYES - Chairman
GARY PIERCE
PAUL NEWMAN
SANDRAD. KENNEDY
BOB STUMP



0000107587

ARIZONA CORPORATION COMMISSION

January 14, 2010

Mr. William P. Sullivan
Curtis, Goldwin, Sullivan,
Udall & Schwab, P.L.C.
501 East Thomas Road
Phoenix, Arizona 85012-3205

RE: Q MOUNTAIN MOBILE HOME PARK
DOCKET NO. W-02518A-09-0442

Notice of Administrative Approval/Closure

Dear Mr. Sullivan:

Enclosed is a stamped copy of the amended cross-connection/backflow tariffs that became effective by operation of law on November 1, 2009.

By copy of this letter, the Docket Control Center is instructed to administratively close Docket No. W-02518A-09-0442. If you have questions regarding the filing of these tariffs, please contact me at (602) 542-4251.

Sincerely,

Lori H. Miller
Programs & Projects Specialist II
Utilities Division

/lhm

Enclosures

cc: Docket Control Center (w/enclosures)
Legal Division

Arizona Corporation Commission

DOCKETED

JAN 15 2010

DOCKETED BY

RECEIVED
2010 JAN 15 P 4:34
AZ CORPORATION COMMISSION
DOCKET CONTROL

UTILITY: <u>Q Mountain Mobile Home Park</u>	TARIFF SHEET NO.: <u>CC</u>
DOCKET NO.: <u>W-02518A-09-0442</u>	REPLACES SHEET NO.: <u>N/A</u>
PHONE: <u>(928) 927-3088</u>	DECISION NO.: <u>N/A</u>
	EFFECTIVE: <u>November 1, 2009</u>

CROSS-CONNECTION/BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Q Mountain Mobile Home Park (“Company”) water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer’s premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code (“A.A.C.”) R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules and Regulations of the Arizona Corporation Commission (“Commission”) and the Arizona Department of Environmental Quality (“ADEQ”), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this Tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with paragraphs 1 and 7 of this Tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this Tariff.
4. Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is not applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or the Commission Staff may suspend this requirement for a reasonable period of time.

ADMINISTRATIVELY
APPROVED FOR FILING

UTILITY: Q Mountain Mobile Home Park**TARIFF SHEET NO.: CC****DOCKET NO.: W-02518A-09-0442****REPLACES SHEET NO.: N/A****PHONE: (928) 927-3088****DECISION NO.: N/A****EFFECTIVE: November 1, 2009****CROSS-CONNECTION/BACKFLOW TARIFF**

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. Company may require the customer to pay to have the backflow-prevention assembly tested as long as Company does not require an unreasonable number of tests.
6. The customer shall provide Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location;
 - c. date(s) of test(s);
 - d. *description of repairs and recommendations for repairs made by tester; and*
 - e. tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is not applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or disfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

INSPECTIONS/TESTING/REPORTING:

The customer shall cooperate fully with Company in its efforts to investigate and determine the degree of potential health hazard to the public water supply which may result from conditions existing on the customer's premises. Customers shall annually provide Company an inspection checklist and affidavit relating to the customer's plumbing and potential backflow hazards. Each backflow-prevention device must be tested at least once per year and the customer must provide the Company with the information specified in Section 6 and indicating that the backflow-prevention assembly is functioning properly.

UTILITY: Q Mountain Mobile Home Park**TARIFF SHEET NO.: CC****DOCKET NO.: W-02518A-09-0442****REPLACES SHEET NO.: N/A****PHONE: (928) 927-3088****DECISION NO.: N/A****EFFECTIVE: November 1, 2009**

CROSS-CONNECTION/BACKFLOW TARIFF

The failure of the customer to annually provide Company with the information required by this Section shall be grounds for termination of water utility service in accordance with A.A.C. R14-2-410.

DISCONTINUANCE OF SERVICE:

In accordance with A.A.C. R14-2-407 and 410 and provisions of this Tariff, Company may terminate service or deny service to a customer who fails to install and/or test a backflow-prevention assembly or provide annual reports as required by this Tariff.

ADMINISTRATIVELY
APPROVED FOR FILING