

THIS AMENDMENT:		 0000109329
_____ Passed _____	Passed as amended by _____	
_____ Failed _____	Not Offered _____	

LD
CE

ORIGINAL

MAYES PROPOSED AMENDMENT 1

TIME/DATE PREPARED: March 25, 2010

COMPANY: Hualapai Valley Solar Project

AGENDA ITEM NO. 15

DOCKET NO. L-00000NN-09-0541-00151

OPEN MEETING DATE: 3-31-10

Using Form of Order that modifies the CEC, add the following condition to the CEC regarding proximity to natural gas or hazardous liquid pipelines:

“Before commencing construction of Project facilities located within 100 feet of any existing natural gas or hazardous liquid pipeline, the Applicant, or its assignee(s), shall:

- a. Perform the appropriate grounding and cathodic protection studies to show that the Project’s location within 100 feet of such pipeline results in no material adverse impacts to the pipeline or to public safety when both the pipeline and the Project are in operation. If material adverse impacts are noted in the studies, Applicant, or its assignee(s), shall take appropriate steps to ensure that such materials adverse impacts are mitigated. Applicant, or its assignee(s), shall file in Commission Docket Control reports of the studies performed; and
- b. Perform a technical study simulating an outage of the Project that may be caused by the collocation of the Project within 100 feet of the existing natural gas or hazardous liquid pipeline. This study should either: (i) show that such outage does not result in customer outages; or (ii) include operating plans to minimize any resulting customer outages. Applicant, or its assignee(s), shall file a copy of this study in Commission Docket Control.”

Make All Conforming Changes

Arizona Corporation Commission
DOCKETED

MAR 25 2010

DOCKETED BY	
-------------	---------------------------------------------------------------------------------------

AZ CORP COMMISSION
DOCKET CONTROL

2010 MAR 25 P 3:26

RECEIVED