



0000109923

Mountain Glen Water Service, Inc.
PO Box 4230
Show Low, AZ 85902
(928) 532-4688 phone/fax
(928) 205-1867 cell

ORIGINAL

April 6, 2010

Docket Control Center
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Docket NO: W-03875A-08-0421

Decision No: 70954

RECEIVED
2010 APR - 8 P 3: 04
AZ CORP COMMISSION
DOCKET CONTROL

The attached documentation will satisfy the following compliance actions for the above decision no.

1. Within one year after the effective date of this Decision, REPLACE the 7,500 gallon STORAGE TANK currently in use for its CLAY SPRINGS system with a storage tank that has a minimum storage capacity of 10,000 gallons.
2. Within 18 months after the effective date of this Decision, file with the Commission's Docket Control, as a compliance item in this docket, a copy of the APPROVAL OF CONSTRUCTION issued by the ADEQ for the new Clay Springs storage tank.
3. Within one year after the effective date of this Decision, REPLACE the 2,500 gallon STORAGE TANK currently in use for its PINEDALE water system with a storage tank that has a minimum storage capacity of 5,000 gallons.
4. Within 18 months after the effective date of this Decision, file with the Commission's Docket Control, as a compliance item for this docket, a copy of the APPROVAL OF CONSTRUCTION issued by the ADEQ for the new PINEDALE storage tank.

Thank you,

Alice Ferrell
Mountain Glen Water Service

Arizona Corporation Commission
DOCKETED

APR - 8 2010

DOCKETED BY



Janice K. Brewer
Governor

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY

1110 West Washington Street • Phoenix, Arizona 85007
(602) 771-2300 • www.azdeq.gov



Benjamin H. Grumbles
Director

APPROVAL OF CONSTRUCTION

Project Description: Install a new 10,000 gallon polyethylene potable water storage tank with appurtenances to serve Claysprings.

Location: Show Low/Navajo County

Project Owner: Mountain Glen Water Company
Address: P.O. Box 4230, Show Low, AZ 85902

The Arizona Department of Environmental Quality (ADEQ) hereby issues an Approval of Construction for the above-described facility based on the following provisions of Arizona Administrative Code (A.A.C.) R18-5-507 et seq.

On August 11, 2009, ADEQ issued a Certificate of Approval to Construct for the referenced project.

On January 7, 2010, Douglas Lee Brimhall, Sr., P.E. certified the following:

- a final construction inspection was conducted on December 17, 2009
- the referenced project was constructed according to the as-built plans and specifications and ADEQ's Certificate of Approval to Construct;
- the potable water storage tank was disinfected according to an ADEQ-approved method.

Microbiological samples were collected on December 3, 2009, and analyzed on December 4, 2009, by Mohave environmental Laboratory, ADHS License No. AZ0037. The sample results were negative for total coliform.

This Approval of Construction authorizes the owner to begin operating the above-described facilities as represented in the approved plan on file with the ADEQ. Be advised that A.A.C. R18-5-124 requires the owner of a public water system to maintain and operate all water production, treatment and distribution facilities in accordance with ADEQ Safe Drinking Water Rules.

NLS

PWS No. 09-081
LTF No.: 51801

Janak K. Desai
Janak K. Desai, P.E., Manager
Drinking Water Facilities Review Unit
Engineering Review Section
1/27/2010
Date Approved

cc: ERU File No.: 20090184
CRO Approval of Construction File
Navajo County Health Department
Navajo County Planning & Zoning Department
AZ Corporation Commission
Engineer

Northern Regional Office
1801 W. Route 66 • Suite 117 • Flagstaff, AZ 86001
(928) 779-0313

Southern Regional Office
400 West Congress Street • Suite 433 • Tucson, AZ 85701
(520) 628-6733