



0000110259

**ORIGINAL**



**Mount Tipton  
Water Co, inc.**

P.O. Box 38  
15996 Ironwood Drive,  
Dolan Springs, AZ 86441  
928-767-3713 Fax: 928-767-3053

April 12th, 2010

Compliance Department  
Arizona Corporation Commission  
1200 W. Washington St.  
Phoenix, AZ 85007

Re: Docket W-02105A-03-0303 Decision 67162  
W-02105A-04-0880

Here is our quarterly water report for the first quarter of 2010. Old meters are being replaced on an ongoing basis to improve water loss. We have changed the way we are figuring our water loss primarily due to computer programming errors that have given us erroneous data regarding the gallons pumped and sold. We are now figuring the water loss directly from our well meter read spreadsheet rather than entering the information into a "third party" program. Also, due to the slow meter in our water haul standpipe, I am now adjusting the gallons sold to reflect this by calculating the actual gallons by the amount of quarters we receive instead of relying on the inaccurate meter readings. During her recent visit, Dorothy Hains brought to our attention the fact that we are not supposed to be subtracting water use for line breaks, blow offs; etc. This is what we have been doing in the past. Now that we have made these corrections, our water loss numbers should be accurate from now on.

Please let me know if you have any questions.  
Thank you.

Michelle Monzillo  
Business Administrator  
Mt. Tipton Water Co.

Arizona Corporation Commission  
**DOCKETED**

APR 19 2010

DOCKETED BY

RECEIVED  
2010 APR 19 P 4: 01  
ARIZONA CORPORATION COMMISSION  
DOCKET CONTROL

**Mt. Tipton Water Company Water Pumped and Sold**

**1st, 2nd, 3rd & 4th Quarters 2010**

**Docket No. W-20105A-03-0303 and Decision No. 67162**

Month	Gal. Sold	Gal. Pumped	Gal. Lost	% Mth Loss	% Qtrly Loss	% Yrly Lost	#of Cust.
January	1,804,546	2,723,151	918,605	33.7%			696
February	2,612,992	2,414,135	-198,857	-8.2%			695
March	2,319,944	2,368,844	48,900	2.1%			690
<b>1st Qrt</b>					<b>9.2%</b>		

**This quarter we had 3 line breaks, 25 blow offs and 14 over flows.**

**We installed 28 new meters. Negative water loss in Feb. due to billing cycle being longer than the calendar month.**

April  
May  
June  
**2 nd Qrt**