

ROSHKA HEY



0000112764

ORIGINAL ⁵⁰

RECEIVED

ROSHKA HEYMAN & SHERO, P.C.
ATTORNEYS AT LAW
TWO ARIZONA CENTER
400 NORTH 5TH STREET
SUITE 1000
PHOENIX, ARIZONA 85004-3906
TELEPHONE NO 602-256-6100
FACSIMILE 602-256-6800

APR 13 P 4:27

ARIZONA CORPORATION COMMISSION
DOCUMENT CONTROL

April 13, 2000

Arizona Corporation Commission
DOCKETED

APR 13 2000

DOCKETED BY 

HAND-DELIVERED

Ms. Carmen Madrid
Docket Control
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, Arizona 85007-2996

Re: Unbundled Distribution Tariffs and Direct Access Fees
Docket Nos. E-01933A-98-0471, E-01933A-97-0772, E-01933A-99-0729,
And RE-00000C-94-0165

Dear Ms. Madrid:

Enclosed please find an original and ten copies of revised page number 65 to
Tariff RR of Tucson Electric Power Company's ("TEP") Rules and Regulations filed
pursuant to Decision No. 62340. The revision has been made to Article 13.F.1
"Customer Requested Meter Tests" and changes the flat charge from \$60.00 to \$40.00
pursuant to TEP's agreement with Commission Staff.

Thank you for your assistance in the filing of this revised document. If you have
any questions, please do not hesitate to contact me.

Sincerely,

Raymond S. Heyman
For the Firm

cc: Mr. Steve Glaser
Mr. Leland Snook
Distribution Service List

TUCSON ELECTRIC POWER COMPANY

Tucson, Arizona

Filed by: Steven J. Glaser

Title: V.P., Rates and Regulatory Support

District: Entire Electric Service Area

Tariff No. RR

Page No. 65

Revision No. 1

Effective: _____

As revised

- a. Total number of meters tested at Company initiative or upon customer request.
- b. Number of meters tested which were outside the acceptable error allowance of $\pm 3\%$.

F. Customer Requested Meter Tests

- 1. The Company shall test a meter upon customer request and may charge the customer a flat charge of \$40.00 if the meter is found to be accurate within the specified percentages. However, if the meter is found to be in error by more than three percent (3%), no meter testing fee will be charged to the customer.

ARTICLE NO. 14 - DEMANDS

- A. The customer's demand may be measured by a demand meter, under all rate schedules involving billings based on demand, unless appropriate investigation or tests indicate that the customer's demand will not be such as to require a demand meter for correct application of the rate schedule. In cases where billings under a rate schedule requiring determination of the customer's demand must be made before a demand meter can be installed, such billings may be made on an estimated demand basis pending installation of the demand meter; provided, however, that billings made on the basis of estimated demands shall be appropriately adjusted, if indicated to be greater or less than the actual demands recorded after the demand meter is installed.
- B. Demand meters may be installed at any metering location if the nature of the customer's equipment and operation is such as to indicate that a demand meter is required for correct application of the rate schedule.
- C. All demands used for billing purposes will be recorded, or computed to the nearest whole kW.