

THIS AMENDMENT:
____ Passed _____ Passed as amended by _____
____ Failed _____ Not Offered



MUNDELL PROPOSED AMENDMENT #3

TIME/DATE PREPARED: Monday, January 07, 2002

COMPANY: Duke Energy Arlington Valley

AGENDA ITEM NO. LS-1

DOCKET NO. L-00000P-01-0117
Case 0117

OPEN MEETING DATE: January 8, 2002

Page 4, paragraph b, line14

Insert:

If during the first 20 years of commercial operation of the Project (I) an air quality permit is issued in EPA Region IX requiring a combined cycle combustion turbine generator located in an area having the same designation at that time (attainment or nonattainment) as the Project site to control NOx emissions to a level less than 2.5 ppm, and (ii) the Commission or the Applicant has determined that use of the technology required to comply with such lower standard would be economically feasible for this Project, then within 24 months of such determination Applicant shall install and operate control technology to control NOx emissions at this Project to such lower standard.

AZ CORP COMMISSION
DOCUMENT CONTROL

2002 JAN -8 A 7 54

RECEIVED