

ORIGINAL



0000122869

EAGLETAIL WATER CO., LLC

P.O. Box 157
Tonopah, AZ 85354
928-372-2236

RECEIVED

2011 FEB -4 P 1:04

AZ CORP COMMISSION
DOCKET CONTROL

January 25, 2011

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Arizona Corporation Commission
DOCKETED

FEB 4 2011

Re: Docket No. W-03936A-04-0840
Decision No. 67982

DOCKETED BY *RSR*

Yearly water loss report

Enclosed are copies of water loss and water sold for the calendar year 2010. We have repaired (8) major leaks in 2010. Our water loss has been greatly reduced. We have had several leaks that we had trouble determining the amount of water lost.

Our water lines consist of approximately 30 miles of pipe through rural areas and a leak is not always discovered as quickly as we would like. We will continue to monitor our lines as we work towards reaching our goal of 10% or less water loss.

Each month we have a reserve of water in our 500,000 gal storage tank before filling. This reserve averages 166,600 gal. The yearly total of this reserve is 1,999,920 gal. which when factored in equates to 11.9% water loss for the year.

If you have any questions regarding this report please call 928-372-2236 or contact us by mail at the address above.

Yours truly,

Susan Haas, Statutory Agent
Eagletail Water Co., LLC

COMPANY NAME: EagleTail Water Co. LLC. ID# 0A07032

WATER USE DATA SHEET BY MONTH FOR CALENDAR YEAR

MONTH	NUMBER OF CUSTOMERS	GALLONS SOLD	GALLON PUMPED (Thousands)
JANUARY	56	188,960	520,000
FEBRUARY	56	344,466	307,100
MARCH	56	188,140	290,300
APRIL	56	170,660	574,100
MAY	56	325,960	291,100
JUNE	56	366,110	625,000
JULY	56	413,850	587,200
AUGUST	52	420,340	1,514,400
SEPTEMBER	53	344,439	509,200
OCTOBER	53	332,409	303,400
NOVEMBER	53	302,200	551,100
DECEMBER	53	231,730	312,600
TOTAL		3,629,264	6,385,500

Is the Water Utility located in an ADWR Active Management Area (AMA)?

() Yes (/) No

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement?

() Yes (/) No

If yes, provide the GPCPD amount: _____

What is the level of arsenic for each well on your system. 0.0005 mg/l
(If more than one well, please list each separately.)

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Each month we have a reserve of water in the tank before filling. The reserve is 10' of water which amounts to 166,600 GAL. yearly amount equals 1,999,920 GAL which equates to 11.9% water loss.