

OPEN MEETING AGENDA ITEM



0000124738

ORIGINAL

BEFORE THE ARIZONA CORPORATION CC

RECEIVED

COMMISSIONERS

- GARY PIERCE, Chairman
- BOB STUMP
- SANDRA D. KENNEDY
- PAUL NEWMAN
- BRENDA BURNS

2011 APR 21 P 3:13

AZ CORP COMMISSION
DOCKET CONTROL

IN THE MATTER OF THE APPLICATION OF ABRA WATER COMPANY, INC. FOR APPROVAL OF A RATE INCREASE.

DOCKET NO. W-01782A-10-0224

IN THE MATTER OF THE APPLICATION OF ABRA WATER COMPANY, INC. FOR APPROVAL OF FINANCING.

DOCKET NO. W-01782A-10-0465

**NOTICE OF FILING
LATE-FILED EXHIBIT**

The Utilities Division ("Staff") of the Arizona Corporation Commission ("Commission") files herewith a Drinking Water Compliance Status Report dated April 20, 2011. On March 8, 2011, Staff filed the previously issued Drinking Water Compliance Report, which indicated that Abra Water Company, Inc. (AWC) was not in compliance with the Arizona Department of Environmental Quality. The Report submitted herewith indicates no major deficiencies.

RESPECTFULLY SUBMITTED this 21st day of April, 2011.

Bridget A. Humphrey
Attorney, Legal Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007
(602) 542-3402

Original and thirteen (13) copies of the foregoing were filed this 21st day of April, 2011 with:

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007

Copies of the foregoing were mailed this 21st day of April, 2011 to:

Kevin Larson, President
ABRA WATER COMPANY, INC.
P.O. Box 515
Paulden, AZ 86334

Arizona Corporation Commission
DOCKETED

APR 21 2011

DOCKETED BY

Arizona Department of Environmental Quality
Drinking Water Monitoring and Protection Unit
 Mail Code 5415B-2
 1110 West Washington Street
 Phoenix, AZ 85007

Drinking Water Compliance Status Report

System Name ABRA WATER COMPANY	System Type <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-transient Non-community <input type="checkbox"/> Transient Non-community	Is system consecutive? <input type="checkbox"/> Yes, to PWS # <input checked="" type="checkbox"/> No
System ID # 13001		

Overall compliance status	<input checked="" type="checkbox"/> No major deficiencies	<input type="checkbox"/> Major deficiencies
Monitoring and Reporting status	<input checked="" type="checkbox"/> No major deficiencies	<input type="checkbox"/> Major deficiencies
Comments: The system has arsenic treatment on EPDS002/Big Chino well and as of 3/3/11 have inactivated EPDS001/Aspen well (which had the arsenic MCL), and are now in compliance.		

Operation and Maintenance status	<input checked="" type="checkbox"/> No major deficiencies	<input type="checkbox"/> Major deficiencies
Date of last Sanitary Survey	6-26-09	Inspector Adam Klatzker, NRO
Major unresolved/ongoing operation and maintenance deficiencies:		
<input type="checkbox"/> unable to maintain 20psi	<input type="checkbox"/> inadequate storage	
<input type="checkbox"/> cross connection/backflow problems	<input type="checkbox"/> surface water treatment rule	
<input type="checkbox"/> treatment deficiencies	<input type="checkbox"/> ATC/AOC	
<input type="checkbox"/> certified operator	<input type="checkbox"/> other =	
Comments: During the last sanitary survey, recommendations were made on the distribution system (replace sample tap with a non-threaded sample tap) and finished water (resize vent screen).		

Is an ADEQ administrative order in effect?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Comments: None		

System Information	
Population Served	1512
Service Connections	630
Number of Entry Points to the Distribution System	1
Number of Sources	1
Initial Monitoring Year	1995
Monitoring Assistance Program (MAP) System	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Evaluation completed by	Donna Calderon, Manager  Drinking Water Monitoring and Protection Unit		
Phone	602-771-4641	Date	April 20, 2011
<input checked="" type="checkbox"/>	Based upon data submitted by the water system, ADEQ has determined that this system is currently delivering water that meets water quality standards required by 40 CFR 141/Arizona Administrative Code, Title 18, Chapter 4, and PWS is in compliance.		
<input type="checkbox"/>	Based upon the monitoring and reporting deficiencies noted above, ADEQ cannot determine if this system is currently delivering water that meets water quality standards required by 40 CFR 141/Arizona Administrative Code, Title 18, Chapter 4, and/or PWS is not in compliance.		
<input type="checkbox"/>	Based upon the operation and maintenance deficiencies noted above, ADEQ cannot determine if this system is currently delivering water that meets water quality standards required by 40 CFR 141/Arizona Administrative Code, Title 18, Chapter 4, and/or PWS is not in compliance.		

This compliance status report does not guarantee the water quality for this system in the future, and does not reflect the status of any other water system owned by this utility company.