ORIGINAL

0000124930

RECEIVED

2011 APR 29 P 4: 07

AZ CORP COMMISSION
DOCKET CONTROL

State Regulation

Mail Station 9708
PO Box 53999
Phoenix, Arizona 85072-3999
Tel 602-250-2709
Susan.Casady@aps.com

Arizona Corporation Commission
DOCKETED
APR 29 2011
DOCKETED BY

April 29, 2011

Docket Control
Arizona Corporation Commission
1200 W. Washington
Phoenix, AZ 85007

RE: Arizona Public Service Company 2008 Amended Rate Case
Docket No. E-01345A-08-0172

Pursuant to Decision No. 71448, dated December 30, 2009, Arizona Public Service Company ("APS") was ordered per the Settlement Agreement, Section 13.5 to:

> File a report with the Commission documenting its performance for the preceding year in relation to the Performance Measures set forth in the "Performance Measures" and "Reporting Requirements" Sections set forth above. Such annual report shall be filed not later than April 30th in the years 2011, 2012, 2013 and 2014, and shall be used for determining whether the Company has met the Performance Measures for the preceding year.

Attached, please find the APS Settlement Performance Measurements and Reporting Requirements Report containing the information set forth in Sections 13.2 and 13.4 of the Settlement Agreement, which includes information relevant to the preceding year, and includes changes from a 2007 base year. APS has met all requirements for 2010 and therefore does not seek a waiver pursuant to Section 13.3.

If you have any questions regarding this information, please contact Zac Fryer at (602)250-4167.

Sincerely,

Susan Casady

Susan Casady

SC/sl
Attachment

cc: Brian Bozzo
Steve Olea
Terri Ford
Barbara Keene
Parties of Record

Copies of the foregoing
delivered/mailed this 29th day of April,
2011, to:

Ernest G. Johnson
Executive Director, Utilities Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Maureen Scott
Legal Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Janet Wagner
Legal Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Terri Ford
Utilities Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Barbara Keene
Utilities Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Elijah Abinah
Utilities Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Daniel Pozefsky
Chief Counsel
RUCO
1110 West Washington
Suite 220
Phoenix, AZ 85007

William A. Rigsby
RUCO
1110 West Washington
Suite 220
Phoenix, AZ 85007

Tina Gamble
RUCO
1110 West Washington
Suite 220
Phoenix, AZ 85007

C. Webb Crocket
Fennemore Craig
3003 North Central
Suite 2600
Phoenix, AZ 85012

Kevin Higgins
Energy Strategies, LLC
215 South State Street
Suite 200
Salt Lake City, UT 84111

Michael L. Kurtz
Boehm, Kurt & Lowry
36 East Seventh Street
Suite 2110
Cincinnati, OH 45202

Kurt J. Boehm
Boehm, Kurt & Lowry
36 East Seventh Street
Suite 2110
Cincinnati, OH 45202

Denis George
Corporate Energy Manager (G09)
The Kroger Company
1014 Vine Street
Cincinnati, OH 45202

Stephen J. Baron
J. Kennedy & Associates
570 Colonial Park Drive
Suite 305
Roswell, GA 30075

Theodore Roberts
Law Department
Sempra Energy
101 Ash Street
H Q 13D
San Diego, CA 92101

Lawrence V. Robertson, Jr.
2247 E. Frontage Road
Tubac, AZ 85646

Michael A. Curtis
501 East Thomas Road
Phoenix, AZ 85012

William P. Sullivan
501 East Thomas Road
Phoenix, AZ 85012

Larry K. Udall
501 East Thomas Road
Phoenix, AZ 85012

Michael Grant
Gallagher & Kennedy, P.A.
2575 East Camelback Road
Phoenix, AZ 85016

Gary Yaquinto
Arizona Investment Council
2100 North Central
Suite 210
Phoenix, AZ 85004

David Berry
Western Resource Advocates
P.O. Box 1064
Scottsdale, AZ 85252

Tim Hogan
Arizona Center for Law in the Public Interest
202 East McDowell Road
Suite 153
Phoenix, AZ 85004

Jeff Schlegel
SWEEP Arizona Representatives
1167 W. Samalayuca Drive
Tucson, AZ 85704

Jay I. Moyes
Moyes, Sellers & Sims
1850 North Central Avenue
Suite 1100
Phoenix, AZ 85004

Jeffrey J. Woner
K.R. Saline & Associates, PLC
160 N. Pasadena
Suite 101
Mesa, AZ 85201

Scott Canty
General Counsel
The Hopi Tribe
P.O. Box 123
Kykotsmovi, AZ 86039

Cynthia Zwick
1940 E. Luke Avenue
Phoenix, AZ 85016

Nicholas J. Enoch
349 North 4th Avenue
Phoenix, AZ 85003

Karen S. White
Air Force Utility Litigation & Negotiation Team
AFLOA/JACL-ULT
139 Barnes Drive
Tyndall AFB, FL 32403

Douglas V. Fant
Law Offices of Douglas V. Fant
3655 W. Anthem Drive
Suite A-109 PMB 411
Anthem, AZ 85086

Barbara Wyllie-Pecora
14410 W. Gunsight Dr.
Sun City West, AZ 85375

Carlo Dal Monte
Catalyst Paper Corporation
65 Front Street
Suite 201
Nanaimo, BC 0

Steve Morrison
SCA Tissue North America
14005 West Old Hwy 66
Bellemont, AZ 86015

Arizona Public Service Company's

Settlement Section 13.2 Performance Measurements

Section 13.2 – Performance Measurements

a. APS shall initiate and implement the schools renewable program in accordance with the terms set forth in Section XV. For purposes of specific performance goals, the program shall result in 50,000 MWhs of annual energy generation or savings at Arizona schools within 36 months of program approval.

Response: In 2010, APS introduced a program for schools, municipalities and other government entities pursuant to Section 15.5 and 15.6 of the Settlement Agreement ("Schools and Government Program"). The Schools and Government Program was approved by the Commission in Decision No. 72022 (December 10, 2010) and amended by Decision No. 71274 (February 11, 2011). APS recently launched its Schools and Government Program in March 2011. APS anticipates that within 36 months of program approval, it will meet the 50,000 MWh goal required by the Settlement Agreement.

Section 13.2 – Performance Measurements

b. The Company shall comply with the terms of its Commission - approved Implementation Plan designed to meet the energy efficiency goals set forth in Section XIV.

Response: Each year on March 1st and September 1st, APS files its Demand Side Management Semi-Annual reports in Docket Control detailing APS's Compliance with the Energy Efficiency rules, Settlement Agreement, annual DSM Implementation Plan, and other DSM requirements. In 2010, APS complied with the terms of its respective DSM Implementation Plan and exceeded the Company's Energy Efficiency goals set forth in Section 14 of the Settlement Agreement. For further details regarding APS's 2010 compliance, please refer to the Demand Side Management Semi-Annual Reports docketed on March 1, 2011 and to be docketed on September 1, 2011, in Docket Nos. E-01345A-03-0437 and E-01345A-05-0526.

Section 13.2 – Performance Measurements

c. APS shall comply with the terms of its Commission-approved Implementation Plan designed to meet the goals set forth in the Renewable Energy Standard and Tariff ("REST") Rules by deriving a portion of the energy it sells from renewable technologies.

Response: Each year on April 1st, APS file a report in Docket Control detailing APS's Compliance with the RES rules, annual RES Implementation Plan, and other renewable requirements. In 2010, APS complied with the terms of its Implementation Plan and exceeded the overall RES requirement. For further details regarding 2010 compliance, please refer to APS 2010 Renewable Energy Standard Compliance Report docketed on April 1, 2011 in Docket No. E-01345A-09-0338.

Section 13.2 – Performance Measurements

d. APS shall comply with the renewable energy goals in accordance with the terms set forth in Section XV of this Agreement.

Response: Section XV specifies that APS shall make its best efforts to acquire new renewable energy resources with annual generation savings of 1,700,000 MWh to be in service by December 31, 2015. Each year, APS files its annual Implementation Plan that provides a 5-year look at APS's efforts in achieving compliance with the RES Rules and other renewable requirements including the Settlement Agreement. APS's RES Implementation Plan contains specific procurement initiatives and budgets that are designed to achieve compliance with the annual generation savings requirement of 1,700,000. APS has complied with the other provisions of Section XV through the following applications, filings, and approvals:

- Section 15.2 - Perrin Ranch Wind Project – Decision No 72058 (January 6, 2011).
- Section 15.3 – APS's Utility Scale Photovolatic ("PV") Plan ("Plan") filed April 29, 2010 in Docket No. E-01345A-08-0172. The Plan consists of 1) AZ Sun Program, 2) Procurement of 25 MW PV from Independent Power Producers, and 3) 2010 PV Request for Proposal.
- Section 15.4 - Renewable Transmission Action Plan – Decision No. 72057 (January 6, 2011).
- Sections 15.5 and 15.6 - Schools and Government Program – Decision No. 72022 (December 10, 2010) and amended by 71274 (February 11, 2011).

Section 13.2 – Performance Measurements

e. APS shall reduce its expenses by at least $30 million per year, on average, in accordance with the terms set forth in Section VII of this Agreement.

Response: Please see APS's report filed in Docket No. 01345A-08-0172 on April 29, 2011 in compliance with Section 7.3 of Settlement Agreement.

Section 13.2 – Performance Measurements

f. The Company will strive to achieve a Capital Structure with no more than 52% total debt, as calculated by the credit rating agencies, by December 31, 2012.

Response: APS provided the Commission with information in Docket No. 01345A-08-0172 on February 25, 2011 regarding the Company's capital structure as of December 31, 2010, reflecting a total debt of 54.4%, as calculated by APS's simulation of S&P's methodology. The Company's total debt as of December 31, 2009 was 56.6%. As evidenced by the decrease experienced in 2010, APS continues to move toward total debt of 52%, as calculated by the rating agencies, and will continue to follow the steps outlined in APS's Plan to Maintain Credit Ratings and Improve Financial Metrics filed with the Commission in Docket No. 01345A-08-0172 on April 29, 2010.

Section 13.2 – Performance Measurements

g. APS shall submit a plan to the Commission to maintain investment grade financial ratios and to improve its financial metrics.

Response: APS filed this plan with the Commission in Docket No. 01345A-08-0172 on April 29, 2010.

Section 13.2 – Performance Measurements

h. APS shall complete equity infusions of $700 million in accordance with the terms set forth in Section VIII.

Response: Please see the information APS provided in Section 13.4(b)(vi) of this report.

Section 13.2 – Performance Measurements

i. The Company shall comply with the Annual Reporting of Financial and Customer Service Criteria as set forth in XIII.B, following.

Response: Contained in this filing is APS's Annual Reporting of Financial and Customer Service Criteria as set forth in Section XIII.B.

Section 13.2 – Performance Measurements

j. APS shall cooperate with the Commission Staff in its conduct of the Benchmarking Study comparing APS with other similarly situated utilities.

Response: The Benchmarking Study was completed by the Liberty Consulting Group and was issued on February 28, 2011. APS provided comprehensive data and responded to all requests made by ACC Staff and their consultant, Liberty, to ensure the study's completion.

Arizona Public Service Company's

Settlement Section 13.4(a) Reporting Requirements

Section 13.4(a) - Settlement Reporting Requirements: Customer Service, Reliability and Safety Reporting

i. The frequency and duration of unplanned outages (generation, transmission and distribution) as measured by the industry-used System Average Interruption Duration Index, System Average Interruption Frequency Index, and Customer Average Interruption Duration Index.

Response: APS follows the Institute of Electrical and Electronics Engineers ("IEEE") 1366 – 2003 "Guide for Electric Power Distribution Reliability Indices" for measuring reliability. Three of the most common indicators used for measuring reliability are SAIFI (System Average Interruption Frequency Index), SAIDI (System Average Interruption Duration Index) and CAIDI (Customer Average Interruption Duration Index). These indicators are calculated with "Major Event Days" excluded, in accordance with Sections 3.13, 4.5 and Annex B.

The data provided below reflects the portion of SAIFI, SAIDI, and CAIDI due to Generation, Transmission, and Distribution causes, respectively. The total for all three is the overall reliability experienced by APS customers.

	Distribution			Transmission			Generation		
Year	**SAIFI**	**CAIDI (min.)**	**SAIDI (min.)**	**SAIFI**	**CAIDI (min.)**	**SAIDI (min.)**	**SAIFI**	**CAIDI (min.)**	**SAIDI (min.)**
2007	0.90	85	76	0.11	81	9	0	0	0
2008	0.86	87	75	0.11	77	8	0	0	0
2009	0.83	88	73	0.10	73	7	0	0	0
2010	0.80	89	72	0.09	69	7	0	0	0

Section 13.4(a) - Settlement Reporting Requirements: Customer Service, Reliability and Safety Reporting

ii. Information regarding major unplanned equipment outages or downtime for maintenance, repair and/or replacement, and distribution system outages consistent with the 1000 Hour Report currently filed with the Commission.

Response: Attached as Attachment A are the 2007 through 2010 "1000 Hour Reports" APS routinely provided to the Commission. Additionally, attached as Attachment B is a list of all generating unit outages from 2007 to 2010.

Section 13.4(a) - Settlement Reporting Requirements: Customer Service, Reliability and Safety Reporting

iii. Number of calls from customers and level of customer satisfaction (based upon feedback surveys) regarding the way calls were handled.

Response: Please see below for the above requested information.

	2007	2008	2009	2010
Number of Customer Calls into APS Call Center	5,012,173	5,172,148	5,385,642	5,238,475
Customer Experience Satisfaction Study	78%	83%	85%	85%

iv. Information regarding the levels of enrollment in DSM, Demand Response, Low-Income and RES programs.

Response:

- *Demand Side Management ("DSM") Programs*. The levels of enrollment for DSM programs were not tracked in 2007. The levels of enrollment for DSM programs from 2008 to 2010 are provided in Attachment C.

- *Demand Response ("DR") Programs*. DR programs came into effect in 2010. The level of DR enrollment in 2010 is provided in Attachment D.

- *Low Income Programs*. The level of enrollment for Low Income programs is provided in Attachment E.

- *Renewable Energy Standard ("RES") Programs*. The level of new customer enrollment for RES programs is provided in Attachment F.

Section 13.4(a) - Settlement Reporting Requirements: Customer Service, Reliability and Safety Reporting

v. Information regarding the frequency and severity of employee injuries using All Incident Injury Rate ("AIIR").

Response: Information regarding the frequency and severity of employee injuries is provided in the table below:

	2007	2008	2009	2010
Historical OSHA Recordables	177	108	97	65
All Incident Injury Rate ("AIIR")	2.49	1.48	1.38	0.95

Section 13.4(a) - Settlement Reporting Requirements: Customer Service, Reliability and Safety Reporting

vi. Information addressing changes to APS' employee counts, including changes to the counts of the employees represented by the two labor unions with whom APS has entered into collective bargaining agreements.

Response: Below is a table containing APS's employee count for 2007 through 2010:

	Regular Employees			Total		
Year	**Non- Union Employees**	**IBEW 387**	**SPEPA 820**	**Regular Employees**	**Temporary Employees**	**Total Employees**
2007	4,797	1,897	191	6,885	298	7,183
2008	4,874	1,865	215	6,954	226	7,180
2009	4,823	1,824	239	6,886	166	7,052
2010	4,747	1,698	238	6,683	150	6,833

As can be seen by the above table, from 2007 to 2010 APS has reduced its employees by 5%.

Arizona Public Service Company's

Settlement Section 13.4(b) Reporting Requirements

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

i. Information regarding the Company's earned return on equity ("ROE") for the preceding 12 months, including supporting calculation detail and identification of the major factors impacting that ROE. Such reports shall be filed within 60 days following the end of each quarter throughout the Plan Term.

Response: This information was provided to the Commission as part of APS's Quarterly Financial Reporting in Docket No. 01345A-08-0172 on the following dates:

- March 1, 2010
- May 28, 2010
- August 27, 2010
- February 25, 2011

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

ii. Information regarding the Company's Funds from Operations ("FFO") to Debt ratio, FFO/Interest ratio, and Total Debt/Capital ratio for the preceding 12 months, including supporting calculation detail and identification of the major factors impacting those metrics. Such reports shall be filed within 60 days following the end of each quarter throughout the Plan Term.

Response: This information was provided to the Commission as part of APS's Quarterly Financial Reporting in Docket No. 01345A-08-0172 on the following dates:

- March 1, 2010
- May 28, 2010
- August 27, 2010
- February 25, 2011

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

iii. Information regarding Pinnacle West Capital Corporation's ("PNW") stock price, net book value and the relationship of PNW's stock price to net book value. Such reports shall be filed within 60 days following the end of each quarter throughout the Plan Term.

Response: This information was provided to the Commission as part of APS's Quarterly Financial Reporting in Docket No. 01345A-08-0172 on the following dates:

- March 1, 2010
- May 28, 2010
- August 27, 2010
- February 25, 2011

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

iv. Information regarding the status of all shelf registrations for debt and equity issuance(s) of APS and PNW.

Response: Below please find a table describing the status of the two outstanding shelf registrations for APS and PNW.

Company	Registration Number	Name	Status
Pinnacle West Capital Corporation	333-158779 (S-3SAR)	PNW/APS Automatic Shelf Registration Statement (covering PNW Unsecured Debt Securities, Preferred Stock and Common Stock and APS Unsecured Debt Securities) (4/24/09)	This three-year shelf is effective through 4/24/2012 and registers an indeterminate amount of each identified security class. A new Automatic Shelf Registration Statement will be filed prior to 4/24/2012 to ensure there is no lapse in shelf coverage.
APS	333-158779-01 (S-3ASR)	PNW/APS Automatic Shelf Registration Statement (covering PNW Unsecured Debt Securities, Preferred Stock and Common Stock and APS Unsecured Debt Securities) (4/24/09)	This three-year shelf is effective through 4/24/2012 and registers an indeterminate amount of each identified security class. A new Automatic Shelf Registration Statement will be filed prior to 4/24/2012 to ensure there is no lapse in shelf coverage.

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

v. Information regarding any long-term debt issuances and their impact on APS' capital structure and FFO/Debt ratio within 60 days of such issuance.

Response: APS has not issued any additional long-term debt from the effective date of the Settlement Agreement. APS will report on this information as applicable.

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

vi. Information regarding any equity infusions made in accordance with the terms set forth in Section VIII herein, their impact upon APS' capital structure, the price per share at the time of issuance, any dilution to existing share, and the estimated impact upon APS' FFO/Debt ratio. Such reports shall be filed within 60 days of such infusion.

Response: Pinnacle West Capital Corporation issued 6,900,000 shares of common stock in April 2010, which resulted in net proceeds to Pinnacle West of approximately $253 million. This amount was subsequently infused into APS. APS filed this information with the Commission on May 28, 2010 in Docket No. 01345A-08-0172 and will continue to report on this information as applicable.

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

vii. Information regarding the criteria used to measure achieved performance under its Annual Cash Incentive Compensation Plan. The reporting of this information to the Commission will coincide with when it has been made publicly available and reviewed and approved by the Board of Directors for the purpose of approving Annual Cash Incentive Compensation awards.

Response: This information was provided to the Commission in Docket No. 01345A-08-0172 on February 25, 2011, as part of APS's Quarterly Financial Reporting.

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

viii. Information pertaining to Management Expenses.

Response: The evaluation of this data reflects management expenses focused on the payroll levels of management employees. The levels of management which include supervisors and above are defined by Equal Employment Opportunity ("EEO") codes A00, A01 and A02.

	$ in Millions			
	2007	**2008**	**2009**	**2010**
Total Base Salary Excluding Palo Verde	$59.0	$60.8	$60.4	$62.6
Total Palo Verde Base Salary (APS's Share)	$12.0	$14.5	$15.0	$15.4

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

ix. Information pertaining to the Company's Dividend Payout Ratio and changes from earlier years.

Response: Below please find a table containing APS's dividend payout ratio from 2007 to 2010.

Year	Dividend Payout
2007	59.9%
2008	64.8%
2009	67.7%
2010	54.3%

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

x. Information pertaining to Operation and Maintenance Expense and any significant changes from year to year.

Response: Below please find information regarding Operation and Maintenance Expense from 2007 to 2010 and explanations of year over year changes.

FERC O&M Categories (Excluding Fuel and Transmission Wheeling)[1]	$ in Millions			
	2007	**2008**	**2009**	**2010**
Steam Production[2]	$ 143.8	$ 139.7	$ 160.0	$ 160.7
Nuclear Production[3]	216.4	245.9	238.5	236.1
Other Production[4]	69.6	89.0	148.4	166.4
Distribution[5]	120.7	133.6	119.6	117.5
Transmission	27.1	30.6	33.1	36.9
Customer Service[6]	118.5	130.1	135.4	161.8
Total O&M	**$ 696.2**	**$ 768.9**	**$ 834.9**	**$ 879.3**

1: Includes functional allocations of administrative and general costs.

2: Steam production costs increased in 2009 primarily because of increased levels of planned overhauls.

3: Nuclear production costs increased in 2008 due to costs required to restore Palo Verde to operational performance and to address the NRC's Corrective Action Letter ("CAL").

4: Other production increased primarily due to the RES program cost increases of $14M in 2008 and $48.3M in 2009.

5: Distribution costs increased in 2008 and decreased in 2009 for a one-time employee severance of $9M.

6: Customer Service costs increased primarily due to DSM program cost increases of $14.4M in 2009 and $24.4M in 2010.

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

xi. Information pertaining to Customer and Sales Expense per Customer and any significant changes from year to year.

Response: Below please find a table containing APS's customer and sales expense per customer for 2007 and 2010:

	2007	2008	2009	2010
Customer and Sales Expense per Customer	$79.14	$86.42[1]	$77.34	$71.72[2]
DSM Program Costs Included in Customer and Sales Expense	$6.26	$7.42	$20.35	$41.91
Total Customer and Sales Expense per Customer	$85.40	$93.83	$97.69	$113.63

1: In 2008, the increase is due to severance and bad debt write-offs.

2: In 2010, the decrease is due to less CRCC amortization and bad debt write-offs.

Section 13.4(b) - Settlement Reporting Requirements: Financial Reporting

xii. Information regarding the Company's level of major capital expenditures, and its consideration of available alternatives in connection with such capital expenditures for generation facilities.

Response: Below please find a table containing APS's major capital expenditures from 2007, 2008, 2009 and 2010:

	Actual Capital Expenditures ($ in M)			
	2007	**2008**	**2009**	**2010**
Generation:				
Existing Generation	$ 143	$ 138	$ 144	$ 172
Nuclear Fuel	96	47	64	63
Renewables	-	-	-	6
Environmental	67	96	33	11
Yuma Peaking Plant	47	29	-	-
Distribution	372	340	246	232
Transmission	138	163	193	120
Other *	37	43	52	62
Total	**$ 900**	**$ 856**	**$ 732**	**$ 666**

* Projects included in Other are primarily related to information systems and facilities.

Other than through the AZ Sun program, APS has not made any capital investments in new generation capacity since the date of the Settlement Decision and thus did not consider any available alternatives in connection with such projects.

Attachment A

1000 HOUR CUSTOMER OUTAGE REPORT
(1/1/2007-1/7/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count
METRO	1/1/2007	ESTRELLITA	5	EQUIPMENT FAILURE - APS	08:41AM	10:53AM	10:53AM	1,322	601
METRO	1/1/2007	FILLMORE	4	EQUIPMENT FAILURE - APS	09:22PM	10:25PM	10:25PM	1,158	1,103
NORTHWEST	1/3/2007	COTTONWOOD	14	FOREIGN INTERFERENCE - VEHICLE	04:02PM	04:57PM	05:50PM	1,033	1,031
SOUTHEAST	1/5/2007	BOOTHILL	1	EQUIPMENT FAILURE	06:01PM	07:07PM	08:42PM	1,712	1,190

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

1/24/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(1/8/2007-1/14/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	1/12/2007	DIXILETA	12	EQUIPMENT FAILURE - APS	10:36AM	11:12AM	04:35PM	1,072	1,406
METRO	1/14/2007	WILDFLOWER	5	EQUIPMENT FAILURE - APS	12:29AM	01:29AM	01:29AM	1,418	1,418
NORTHEAST	1/12/2007	PREACHER CANYON	6	VEGETATION CONTACT – STORM RELATED	08:09PM	09:19PM	07:22AM	22,086	2,330
NORTHEAST	1/14/2007	ELDEN	1	EQUIPMENT FAILURE - APS	07:27AM	10:08AM	10:08AM	5,528	2,060

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

**Based on definition of "customer" in A.A.C. R-14-2-201.9

2/1/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(1/8/2007-1/14/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	1/12/2007	DIXILETA	12	EQUIPMENT FAILURE - APS	10:36AM	11:12AM	04:35PM	1,072	1,406
METRO	1/14/2007	WILDFLOWER	5	EQUIPMENT FAILURE - APS	12:29AM	01:29AM	01:29AM	1,418	1,418
NORTHEAST	1/12/2007	PREACHER CANYON	6	VEGETATION CONTACT - STORM RELATED	08:09PM	09:19PM	07:22AM	22,086	2,330
NORTHEAST	1/14/2007	ELDEN	1	EQUIPMENT FAILURE - APS	07:27AM	10:08AM	10:08AM	5,528	2,060
NORTHWEST	1/14/2007	WILHOIT	2	OVERLOAD - OTHER	08:03AM	11:26AM	04:24PM	1,111	190

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

**Based on definition of "customer" in A.A.C. R-14-2-201.9

The item in red shows the changes

3/19/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(1/8/2007-1/14/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	1/12/2007	DIXILETA	12	EQUIPMENT FAILURE - APS	10:36AM	11:12AM	04:35PM	1,072	1,406
METRO	1/14/2007	WILDFLOWER	5	EQUIPMENT FAILURE - APS	12:29AM	01:29AM	01:29AM	1,418	1,418
NORTHEAST	1/12/2007	PREACHER CANYON	6	VEGETATION CONTACT - STORM RELATED	08:09PM	09:19PM	07:22AM	22,086	2,330
NORTHEAST	1/14/2007	ELDEN	1	EQUIPMENT FAILURE - APS	07:27AM	10:08AM	10:08AM	5,528	2,060
NORTHWEST	1/14/2007	WILHOIT	2	OVERLOAD - OTHER	08:03AM	11:26AM	04:24PM	1,111	190

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

**Based on definition of "customer" in A.A.C. R-14-2-201.9

The highlighted items reflect the changes.

3/15/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(01/15/2007-01/21/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	01/19/2007	GLENDALE	6	EQIOPMENT FAILURE - APS	12:30PM	12:37PM	02:32PM	2,127	1,244
METRO	01/21/2007	COUNTRY CLUB	13	EQUIPMENT FAILURE - APS	12:56PM	01:37PM	03:00PM	1,186	1,668
NORTHEAST	01/19/2007	STRAWBERRY	2	EQUIPMENT FAILURE - APS	04:30PM	05:09PM	05:16PM	1,196	1,840
SOUTHEAST	01/15/2007	TARTESSO TEMPORARY	4	TRANSMISSION RELATED	08:27AM	02:00PM	02:00PM	2,725	491
SOUTHEAST	01/19/2007	KEARNY	6	WEATHER – STORM RELATED	03:26AM	04:37AM	05:10AM	1,622	943

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

2/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(1/22/2007-1/28/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	1/28/2007	HEARN	4	EQUIPMENT FAILURE - APS	09:15AM	09:45AM	04:37PM	2,468	1,740
NORTHWEST	1/23/2007	BALD MOUNTAIN	9	FOREIGN INTERFERENCE - VEHICLE	09:46PM	10:53PM	12:14AM	1,312	1,175

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

2/26/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(1/22/2007-1/28/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	1/28/2007	HEARN	4	EQIOPMENT FAILURE - APS	09:15AM	09:45AM	04:37PM	2,468	1,740
NORTHWEST	1/23/2007	BALD MOUNTAIN	9	FOREIGN INTERFERENCE - VEHICLE	09:46PM	10:53PM	10:53PM	1,312	1,175

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

3/12/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(1/29/2007-2/04/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t**
METRO	1/29/2007	STAGECOACH	6	UNDERGROUND CABLE	03:32AM	04:07AM	05:43AM	1,075	951
METRO	2/1/2007	COLDWATER	20	FOREIGN INTERFERENCE	09:45AM	10:28AM	10:28AM	1,023	1,427

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

2/26/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(02/05/2007-02/11/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	02/06/2007	LONE PEAK	9	SUBSTATION RELATED	07:10AM	08:22AM	08:22AM	1,829	1,524
METRO	02/06/2007	LONE PEAK	12	SUBSTATION RELATED	07:10AM	08:16AM	08:16AM	1,492	1,356
METRO	02/06/2007	LONE PEAK	13	SUBSTATION RELATED	07:10AM	08:26AM	08:26AM	2,803	2,213
METRO	02/09/2007	STAGECOACH	5	TRANSMISSON RELATED	09:57AM	10:46AM	10:46AM	1,037	1,270

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

2/27/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(2/12/2007-2/18/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t**
NORTHWEST	2/14/2007	COPPER CANYON	2	WEATHER – STORM	02:21AM	03:20AM	05:48AM	1,418	1435

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(02/19/2007-02/25/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	02/22/2007	CACTUS	25	UNDERGROUND CABLE	08:23PM	09:00PM	07:00AM (2/23)	4,929	1,142
NORTHWEST	02/19/2007	WHITE SPAR	10	WEATHER – STORM RELATED	06:50PM	01:50AM	01:50AM	1,995	285
SOUTHEAST	02/19/2007	VALLEY FARMS	6	WEATHER – STORM RELATED	03:35PM	04:35PM	04:35PM	1,661	1,661
SOUTHEAST	02/23/2007	VALLEY FARMS	6	EQUIPMENT FAILURE – APS (STORM RELATED)	01:11PM	02:59PM	02:59PM	1,089	605
SOUTHEAST	02/24/2007	VALLEY FARMS	2	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	05:44AM	11:46AM	11:46AM	6,064	1,005
SOUTHWEST	02/24/2007	ARABY	4	FOREIGN INTERFERENCE – DIG – INS CUSTOMER	07:56AM	08:57AM	08:57AM	1965	1,933

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

3/20/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(02/26/2007-03/04/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t**
METRO	03/04/2007	FORTIETH PLACE	1	EQUIPMENT FAILURE - APS	04:58AM	07:24AM	12:00PM	1,214	306
SOUTHEAST	03/04/2007	HIDDEN VALLEY	4	LOSS OF SUPPLY – OTHER UTILITY	09:53AM	11:40AM	01:15PM	1,769	956

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

3/28/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(03/05/2007-03/11/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	03/05/2007	BUFFALO	14	FOREIGN INTERFERENCE - VEHICLES	08:16AM	08:48AM	07:20PM	4,063	2,561
METRO	03/06/2007	MOUNTAIN VIEW	5	UNDERGROUND CABLE	08:54PM	09:40PM	12:22AM	1,926	1,388
METRO	03/08/2007	TWENTY – THIRD ST	20	UNDERGROUND CABLE	09:18PM	09:56PM	11:48PM	1,595	1,332
SOUTHEAST	03/06/2007	PINAL	1	EQUIPMENT FAILURE - APS	01:28AM	06:35AM	06:35AM	1,151	225

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

3/28/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(3/12/2007-3/18/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	3/15/2007	JAVELINA	13	EQUIPMENT FAILURE - APS	05:14PM	05:58PM	08:50PM	3504	3513
METRO	3/15/2007	STAGECOACH	5	EQUIPMENT FAILURE - APS	07:13PM	08:18PM	03:05AM	1654	1270
NORTHWEST	3/12/2007	HAYFIELD DRAW	2	FOREIGN INTERFERENCE – VEHICLE	09:47PM	12:40AM	12:40AM	1326	460

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

3/28/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(3/12/2007-3/18/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	3/15/2007	JAVELINA	13	EQUIPMENT FAILURE - APS	05:14PM	05:58PM	08:50PM	3504	3513
METRO	3/15/2007	STAGECOACH	5	EQUIPMENT FAILURE - APS	07:13PM	08:18PM	03:05AM	1654	1270
NORTHWEST	3/12/2007	HAYFIELD DRAW	2	FOREIGN INTERFERENCE – VEHICLE	09:47PM	12:40AM	03:58AM	2316	460

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

The highlighted item reflects the change.

5/1/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(3/19/2007-3/25/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	3/23/2007	SPANISH GARDENS	6	UNDERGROUND CABLE	04:04PM	04:29PM	06:21PM	1184	1496
NORTHWEST	3/23/2007	PAULDEN	2	TRANSMISSION RELATED	05:18AM	07:06AM	07:06AM	2461	1367
NORTHWEST	3/25/2007	SEDONA	14	EQUIPMENT FAILURE - APS	04:30AM	08:16AM	08:16AM	2072	550
SOUTHEAST	3/22/2007	BOOTHILL	1	WEATHER – LIGHTNING	02:41AM	04:09AM	04:49AM	2246	1190

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

4/5/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(03/26/2007-04/01/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	03/27/2007	HEDGEPETH HILLS	13	EQUIPMENT FAILURE - APS	07:35PM	08:29PM	10:32PM	1,316	1,222
METRO	04/01/2007	ARROWHEAD	2	TRANSMISSION RELATED	07:08AM	07:41AM	07:41AM	1,138	2,069
METRO	04/01/2007	ARROWHEAD	13	SUBSTATION RELATED	07:08AM	10:28AM	10:28AM	2,167	650
NORTHWEST	03/27/2007	PAULDEN	2	TRANSMISSION RELATED	02:46AM	03:44AM	03:44AM	1,321	1,367
NORTHWEST	03/27/2007	SEDONA	14	EQUIPMENT FAILURE – STORM RELATED	12:58PM	01:40PM	02:22PM	1,731	1,765
NORTHWEST	03/27/2007	KIRKLAND JUNCTION	12	TRANSMISSION RELATED – STORM RELATED	01:58PM	03:47PM	03:47PM	1,321	727
NORTHWEST	03/27/2007	YARNELL	4	TRANSMISSION RELATED – STORM RELATED	01:58PM	02:53PM	02:53PM	1,063	1,160
NORTHWEST	03/27/2007	SUNDOG	12	EQUIPMENT FAILURE - STORM RELATED	02:39PM	03:59PM	07:35PM	3,225	2,197

4/17/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(03/26/2007-04/01/2007)

NORTHWEST	03/28/2007	WHITE SPAR	12	EQUIPMENT FAILURE – APS	12:11PM	01:15PM	01:15PM	1,333	1,250
SOUTHEAST	04/01/2007	WINTERSBURG	12	SUBSTATION RELATED	06:29PM	08:33PM	12:39AM	2,460	613
SOUTHWEST	03/31/2007	MARINE AIR BASE	12	FOREIGN INTERFERENCE – VEHICLES	11:59PM	07:40AM	07:40AM	2,305	300

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

4/17/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(03/26/2007-04/01/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	03/27/2007	HEDGEPETH HILLS	13	EQUIPMENT FAILURE - APS	07:35PM	08:29PM	10:32PM	1,316	1,222
METRO	04/01/2007	ARROWHEAD	2	TRANSMISSION RELATED	07:08AM	07:41AM	07:41AM	1,138	2,069
METRO	04/01/2007	ARROWHEAD	13	SUBSTATION RELATED	07:08AM	10:28AM	10:28AM	2,167	650
NORTHWEST	03/27/2007	PAULDEN	2	TRANSMISSION RELATED	02:46AM	03:44AM	03:44AM	1,321	1,367
NORTHWEST	03/27/2007	SEDONA	14	EQUIPMENT FAILURE – STORM RELATED	12:58PM	01:40PM	02:22PM	1,731	1,765
NORTHWEST	03/27/2007	KIRKLAND JUNCTION	12	TRANSMISSION RELATED – STORM RELATED	01:58PM	03:47PM	03:47PM	1,321	727
NORTHWEST	03/27/2007	YARNELL	4	TRANSMISSION RELATED – STORM RELATED	01:58PM	02:53PM	02:53PM	1,063	1,160

6/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(03/26/2007-04/01/2007)

NORTHWEST	03/27/2007	SUNDOG	12	EQUIPMENT FAILURE - STORM RELATED	02:39PM	03:59PM	07:35PM	3,225	2,197
NORTHWEST	03/28/2007	WHITE SPAR	12	EQUIPMENT FAILURE – APS	12:11PM	01:15PM	01:15PM	1,333	1,250
SOUTHEAST	04/01/2007	WINTERSBURG	12	SUBSTATION RELATED	06:25PM	08:33PM	12:39AM	2,501	613
SOUTHWEST	03/31/2007	MARINE AIR BASE	12	FOREIGN INTERFERENCE – VEHICLES	11:59PM	07:40AM	07:40AM	2,305	300

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

PLEASE NOTE THE UNDERLINED ITEMS REFLECT CHANGES

6/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/02/2007-04/08/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	04/03/2007	ROADRUNNER	13	UNDERGROUND CABLE	07:37PM	08:18PM	09:09PM	1546	1323
METRO	04/03/2007	ROADRUNNER	17	FOREIGN INTERFERENCE – OTHER ACCIDENTIAL	07:37PM	08:26PM	08:26PM	1093	1338
METRO	04/07/2007	INDIANOLA	19	FOREIGN INTERFERENCE - VEHICLE	03:27AM	04:03AM	09:25AM	1159	1127
SOUTHEAST	04/02/2007	WINTERSBURG	22	SUBSTATION RELATED	02:51PM	04:48PM	06:57PM	1375	613

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

4/23/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/09/2007-04/15/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	4/9/2007	CACTUS	26	UNDERGROUND CABLE	01:30PM	02:18PM	03:27PM	1,492	1,012
METRO	4/12/2007	SURPRISE	4	FOREIGN INTERFERENCE – DIG IN CUSTOMER	08:35AM	09:25AM	09:25AM	1,733	2,080
METRO	4/12/2007	GILBERT	6	HUMAN ELEMENT – DIG IN APS	02:09PM	03:03PM	03:06PM	1,348	1,475
METRO	4/12/2007	RIO VISTA	12	EQUIPMENT FAILURE – APS STORM RELATED	03:59PM	04:29PM	05:05PM	2,724	2,619
METRO	4/12/2007	ORANGEWOOD	33	WEATHER – STORM RELATED	04:30PM	06:12PM	06:56PM	4,060	2,147
METRO	4/12/2007	JACKSON STREET	14	EQUIPMENT FAILURE – APS STORM RELATED	04:34PM	06:54PM	10:30PM	1,752	749
METRO	4/14/2007	HONEYWELL	13	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	05:34PM	06:15PM	11:46PM	3,350	3,135

5/11/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/09/2007-04/15/2007)

METRO	4/15/2007	BUFFALO	2	FOREIGN INTERFERENCE - VEHICLE	12:18PM	01:18PM	03:15PM	1,803	1,729
NORTHEAST	4/10/2007	WINSLOW	14	WEATHER – WIND	04:27PM	04:44PM	05:55PM	1,068	1,658
NORTHEAST	4/15/2007	WOODRUFF	2	WEATHER-WIND	02:09PM	03:50PM	10:22PM	1,500	270
NORTHWEST	4/10/2007	SEDONA	14	VEGETATION CONTACT	02:50PM	04:18AM	04:18AM	1,549	115
SOUTHEAST	4/12/2007	KEARNY	2	EQUIPMENT FAILURE – APS STORM RELATED	10:32PM	12:10AM	05:12AM	1,030	609
SOUTHWEST	4/12/2007	ARABY	1	EQUIPMENT FAILURE – APS STORM RELATED	04:13PM	06:02PM	06:02PM	1,363	750

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

5/11/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/09/2007-04/15/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	4/9/2007	CACTUS	26	UNDERGROUND CABLE	01:30PM	02:18PM	03:21PM	1,458	1,012
METRO	4/12/2007	SURPRISE	4	FOREIGN INTERFERENCE – DIG IN CUSTOMER	08:35AM	09:25AM	09:25AM	1,733	2,080
METRO	4/12/2007	GILBERT	6	HUMAN ELEMENT – DIG IN APS	02:09PM	03:03PM	03:06PM	1,348	1,475
METRO	4/12/2007	RIO VISTA	12	EQUIPMENT FAILURE – APS STORM RELATED	03:59PM	04:29PM	05:05PM	2,724	2,619
METRO	4/12/2007	ORANGEWOOD	33	WEATHER – STORM RELATED	04:30PM	06:12PM	06:56PM	4,060	2,147
METRO	4/12/2007	JACKSON STREET	14	EQUIPMENT FAILURE – APS STORM RELATED	04:34PM	06:54PM	10:30PM	1,752	749
METRO	4/14/2007	HONEYWELL	13	FOREIGN INTERFERENCE – OTHER	05:34PM	06:15PM	11:46PM	3,350	3,135

6/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(4/16/2007-04/22/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	04/20/2007	GREENWAY	12	FOREIGN INTERFERENCE – DIG IN CUSTOMER	12:49PM	01:44PM	02:19PM	1292	1275

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

5/15/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/23/2007-04/29/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	04/23/2007	DOVE VALLEY	4	EQUIPMENT FAILURE - APS	04:08AM	04:56AM	01:15PM	3,444	1,144
METRO	04/23/2007	EL SOL	12	FOREIGN INTERFERENCE - VEHICLES	06:30AM	07:21AM	10:52AM	1,860	1,599
METRO	04/23/2007	SURPRISE	12	UNDERGROUND CABLE	03:48PM	04:39PM	06:21PM	1,815	1,750
METRO	04/24/2007	HATFIELD	5	EQUIPMENT FAILURE - APS	05:54AM	06:47AM	10:43AM	1,708	1,663
METRO	04/27/2007	GAVILAN PEAK	44	EQUIPMENT FAILURE - APS	12:45PM	03:45PM	03:45PM	2,145	715
METRO	04/28/2007	COLTER	9	FOREIGN INTERFERENCE - VEHICLE	05:52AM	06:49AM	06:49AM	1,512	1,592
METRO	04/28/2007	GLENDALE	1	WEATHER - STORM RELATED	04:12PM	05:07PM	05:51PM	1,795	1,398
METRO	04/28/2007	ARROYO	6	EQUIPMENT FAILURE – APS (STORM RELATED)	04:13PM	05:30PM	05:30PM	2,101	1,637

5/24/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/23/2007-04/29/2007)

METRO	04/28/2007	UNION HILLS	21	EQUIPMENT FAILURE – APS (STORM RELATED)	04:14PM	06:40PM	06:40PM	3,516	1,445
METRO	04/28/2007	ORANGEWOOD	8	EQUIPMENT FAILURE – APS (STORM RELATED)	04:20PM	06:01PM	06:12PM	2,744	1,625
METRO	04/28/2007	DEADMANWASH	9	WEATHER – STORM RELATED	04:38PM	05:52PM	05:52PM	1,697	1.367
METRO	04/28/2007	DEADMANWASH	12	WEATHER – STORM RELATED	04:38PM	05:52PM	05:52PM	1,637	1,327
METRO	04/28/2007	RIO VISTA	12	WEATHER – STORM RELATED	04:50PM	05:54PM	05:54PM	3,052	2,861
METRO	04/28/2007	EL SOL	12	EQUIPMENT FAILURE – APS (STORM RELATED)	05:29PM	05:43PM	10:07PM	7,464	1,611

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

5/24/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/23/2007-04/29/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	04/23/2007	DOVE VALLEY	4	EQUIPMENT FAILURE - APS	04:08AM	04:56AM	01:15PM	3,444	1,144
METRO	04/23/2007	EL SOL	12	FOREIGN INTERFERENCE - VEHICLES	06:30AM	07:21AM	10:52AM	1,860	1,599
METRO	04/23/2007	SURPRISE	12	UNDERGROUND CABLE	03:48PM	04:39PM	06:21PM	1,815	1,750
METRO	04/24/2007	HATFIELD	5	EQUIPMENT FAILURE - APS	05:54AM	06:47AM	10:43AM	1,708	1,663
METRO	04/27/2007	GAVILAN PEAK	44	EQUIPMENT FAILURE - APS	12:45PM	03:45PM	03:45PM	2,145	715
METRO	04/28/2007	COLTER	9	FOREIGN INTERFERENCE - VEHICLE	05:52AM	06:49AM	06:49AM	1,512	1,592
METRO	04/28/2007	GLENDALE	1	WEATHER - STORM RELATED	04:12PM	05:07PM	05:51PM	1,795	1,398
METRO	04/28/2007	ARROYO	6	EQUIPMENT FAILURE – APS (STORM RELATED)	04:13PM	05:30PM	05:30PM	2,101	1,637

5/24/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/23/2007-04/29/2007)

METRO	04/28/2007	UNION HILLS	21	EQUIPMENT FAILURE – APS (STORM RELATED)	04:14PM	06:40PM	06:40PM	3,516	1,445
METRO	04/28/2007	ORANGEWOOD	8	EQUIPMENT FAILURE – APS (STORM RELATED)	04:20PM	06:01PM	06:12PM	2,744	1,625
METRO	04/28/2007	DEADMANWASH	9	WEATHER– STORM RELATED	04:38PM	05:52PM	05:52PM	1,697	1.367
METRO	04/28/2007	DEADMANWASH	12	WEATHER – STORM RELATED	04:38PM	05:52PM	05:52PM	1,637	1,327
METRO	04/28/2007	RIO VISTA	12	WEATHER – STORM RELATED	04:50PM	05:54PM	05:54PM	3,052	2,861
METRO	04/28/2007	EL SOL	12	EQUIPMENT FAILURE – APS (STORM RELATED)	05:29PM	05:43PM	10:07PM	7,464	1,611

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

5/24/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/23/2007-04/29/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	04/23/2007	DOVE VALLEY	4	EQUIPMENT FAILURE - APS	04:08AM	04:56AM	01:15PM	3,444	1,144
METRO	04/23/2007	EL SOL	12	FOREIGN INTERFERENCE - VEHICLES	06:30AM	07:21AM	10:52AM	1,865	1,599
METRO	04/23/2007	SURPRISE	12	UNDERGROUND CABLE	03:48PM	04:39PM	06:21PM	1,815	1,750
METRO	04/24/2007	HATFIELD	5	EQUIPMENT FAILURE - APS	05:54AM	06:47AM	10:43AM	1,708	1,663
METRO	04/27/2007	GAVILAN PEAK	44	EQUIPMENT FAILURE - APS	12:45PM	03:45PM	03:45PM	2,145	715
METRO	04/28/2007	COLTER	9	FOREIGN INTERFERENCE - VEHICLE	05:52AM	06:49AM	06:49AM	1,512	1,592
METRO	04/28/2007	GLENDALE	1	WEATHER - STORM RELATED	04:12PM	05:07PM	05:51PM	1,795	1,398

6/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/23/2007-04/29/2007)

METRO	04/28/2007	ARROYO	6	EQUIPMENT FAILURE – APS (STORM RELATED)	04:13PM	05:30PM	05:30PM	2,101	1,637
METRO	04/28/2007	UNION HILLS	21	EQUIPMENT FAILURE – APS (STORM RELATED)	04:14PM	06:40PM	06:40PM	3,516	1,445
METRO	04/28/2007	ORANGEWOOD	8	EQUIPMENT FAILURE – APS (STORM RELATED)	04:20PM	06:01PM	06:12PM	2,744	1,625
METRO	04/28/2007	DEADMANWASH	9	WEATHER – STORM RELATED	04:38PM	05:52PM	05:52PM	1,697	1.367
METRO	04/28/2007	DEADMANWASH	12	WEATHER – STORM RELATED	04:38PM	05:52PM	05:52PM	1,637	1,327
METRO	04/28/2007	RIO VISTA	12	WEATHER – STORM RELATED	04:50PM	05:54PM	05:54PM	3,052	2,861
METRO	04/28/2007	EL SOL	12	EQUIPMENT FAILURE – APS (STORM RELATED)	05:29PM	05:43PM	10:07PM	7,464	1,611

1000 HOUR CUSTOMER OUTAGE REPORT
(04/23/2007-04/29/2007)

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

**** Based on definition of "customer" in A.A.C. R-14-2-201. 9**

Please note the underlined item reflect the change.

6/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/30/2007-05/06/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	05/06/2007	ORANGEWOOD	8	SUBSTATION RELATED	05:31PM	08:22PM	08:22PM	4,680	1,642
METRO	05/06/2007	ORANGEWOOD	9	SUBSTATION RELATED	05:31PM	06:40PM	06:40PM	1,605	1,396
METRO	05/06/2007	ORANGEWOOD	12	SUBSTATION RELATED	05:31PM	08:19PM	08:19PM	1,680	600
METRO	05/06/2007	ORANGEWOOD	13	SUBSTATION RELATED	05:31PM	07:32PM	07:32PM	1,246	618
METRO	05/06/2007	ORANGEWOOD	14	SUBSTATION RELATED	05:31PM	07:52PM	07:52PM	2,717	1,156
NORTHEAST	05/06/2007	ORANGEWOOD	17	SUBSTATION RELATED	05:31PM	06:35PM	06:35PM	1,086	1,018
NORTHEAST	05/06/2007	ORANGEWOOD	22	SUBSTATION RELATED	05:31PM	07:32PM	07:32PM	2,660	1,319
NORTHEAST	05/06/2007	ORANGEWOOD	23	SUBSTATION RELATED	05:31PM	07:33PM	07:33PM	2,739	1,347
METRO	05/06/2007	ORANGEWOOD	29	SUBSTATION RELATED	05:31PM	08:37PM	08:37PM	5,230	1,687

5/25/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(04/30/2007-05/06/2007)

METRO	05/06/2007	ORANGEWOOD	32	SUBSTATION RELATED	05:31PM	08:16PM	08:16PM	2,481	902
METRO	05/06/2007	ORANGEWOOD	33	SUBSTATION RELATED	05:31PM	07:43PM	07:43PM	4,572	2,078
NORTHEAST	05/02/2007	TONTO	1	SUBSTATION RELATED	06:31AM	06:56AM	06:56AM	1,531	3,675
NORTHEAST	05/02/2007	TONTO	12	SUBSTATION RELATED	06:31AM	06:57AM	06:57AM	1,263	2,915
NORTHEAST	05/02/2007	TONTO	14	SUBSTATION RELATED	06:31AM	06:58AM	06:58AM	1,310	2,910
SOUTHEAST	04/30/2007	BASELINE	12	SUBSTATION RELATED	02:41PM	05:50PM	07:12PM	1,509	466

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

5/25/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(05/07/2007-05/13/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	05/08/2007	CACTUS	30	UNDERGROUND CABLE	02:12AM	02:44AM	03:05AM	1,711	2,302
METRO	05/13/2007	PARADISE	10	FOREIGN INTERFERENCE - VEHICLE	03:41AM	04:28AM	07:25AM	3,007	1,541
METRO	05/13/2007	ALTADENA	16	EQUIPMENT FAILURE	04:16AM	05:34AM	05:50AM	1,744	1,217
NORTHWEST	05/12/2007	MORRISTOWN	6	FOREIGN INTERFERENCE - VEHICLE	08:11PM	09:40PM	03:49AM (5/13)	1,553	1035
SOUTHEAST	05/10/2007	EDX (DOE)	3	LOSS OF SUPPLY – OTHER UTILITY	05:33PM	07:43PM	07:43PM	2,071	956

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

5/30/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(05/14/2007 - 05/20/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	05/19/2007	RIO VISTA	6	FOREIGN INTERFERENCE – VEHICLE	05:46AM	06:45AM	12:06PM	5,098	1,969
NORTHEAST	05/17/2007	BLUE RIDGE	12	WEATHER – STORM	01:21PM	03:36PM	03:36PM	3,049	1,355
NORTHWEST	05/18/2007	CAPITAL BUTTE	12	UNKNOWN – OTHER	08:29PM	09:54PM	09:54PM	4,760	3,360

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

6/19/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(05/21/2007 - 05/27/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	05/23/2007	BUTTE	21	FOREIGN INTERFERENCE – DIG IN CUSTOMER	01:31PM	01:59PM	12:42AM	1,672	1,392
SOUTHEAST	5/21/2007	VALENCIA	1	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	06:29AM	07:21AM	07:28AM	1,666	1,801

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

6/19/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(05/28/2007 - 06/03/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	05/30/2007	HONEYWELL	9	EQUIPMENT FAILURE – APS	04:12AM	04:58AM	05:20AM	1,270	1,617
METRO	06/03/2007	CACTUS	38	EQUIPMENT FAILURE – APS	03:01PM	03:41PM	08:22AM	3,698	1,232
NORTHWEST	06/02/2007	PRESCOTT CITY	1	FOREIGN INTERFERENCE – VEHICLE	02:44AM	03:49AM	11:42AM	3,163	2,549

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

6/19/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/04/2007 - 06/10/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
NORTHEAST	06/06/2007	LEROUX	5	EQUIPMENT FAILURE – APS STORM	03:18PM	06:19PM	06:19PM	1,810	600

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

7/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/11/2007 - 06/17/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t*
METRO	06/11/2007	CAMELBACK	10	EQUIPMENT FAILURE - APS	10:04PM	10:52PM	11:34PM	1,830	1,591
METRO	06/13/2007	BOULEVARD	1	FOREIGN INTERFERENCE – DIG-INS CUSTOMER	04:05PM	04:58PM	05:08PM	1,425	1,474
METRO	06/14/2007	PIONEER	17	SUBSTATION RELATED	04:20PM	05:30PM	01:02AM	4,564	1,550
SOUTHEAST	06/14/2007	DON LUIS	1	SUBSTATION RELATED	10:40AM	11:30AM	11:30AM	1,171	1,405
SOUTHEAST	06/14/2007	DON LUIS	3	SUBSTATION RELATED	10:40AM	11:30AM	11:30AM	1,360	1,632
SOUTHEAST	06/14/2007	FAIRVIEW	1	SUBSTATION RELATED	10:40AM	02:56PM	02:56PM	9,596	2,249
SOUTHEAST	06/14/2007	FARIVIEW	3	SUBSTATION RELATED	10:40AM	02:7PM	02:57PM	4,189	978
SOUTHEAST	06/14/2007	FAIRVIEW	14	SUBSTATION RELATED	10:40AM	02:58PM	02:58PM	12,044	2,801

7/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/11/2007 - 06/17/2007)

SOUTHEAST	06/14/2007	MURAL	1	SUBSTATION RELATED	10:40AM	11:28AM	11:28AM	1,172	1,465
SOUTHEAST	06/14/2007	MURAL	2	SUBSTATION RELATED	10:40AM	11:27AM	11:27AM	1,321	1,687

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

7/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/18/2007 - 06/24/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	06/18/2007	ESTRELLITA	5	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	25,915	1,498
METRO	06/18/2007	ESTRELLITA	9	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	11,228	649
METRO	06/18/2007	ESTRELLITA	10	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	7,526	435
METRO	06/18/2007	ESTRELLITA	12	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	20,276	1,172
METRO	06/21/2007	CACTUS	34	UNDERGROUND CABLE	08:13AM	08:47AM	10:09AM	1,809	1,708
METRO	06/21/2007	RAINTREE	13	EQUIPMENT FAILURE – APS	08:31PM	09:00PM	11:30PM	1,271	1,153
METRO	06/22/2007	WILDFLOWER	9	EQUIPMENT FAILURE – APS	05:48AM	07:07AM	11:28AM	2,908	1,500
METRO	06/22/2007	COLDWATER	18	EQUIPMENT FAILURE – APS	08:35AM	09:15AM	10:40AM	1,140	859
METRO	06/22/2007	CHAPARRAL	4	EQUIPMENT FAILURE – APS	08:17PM	08:46PM	09:08PM	1,132	1,698

1000 HOUR CUSTOMER OUTAGE REPORT
(06/18/2007 - 06/24/2007)

METRO	06/24/2007	TEMPE	14	FOREIGN INTERFERENCE – VEHICLES	01:28AM	02:48AM	05:39AM	4,179	3,070
METRO	06/24/2007	CHAPARRAL	10	EQUIPMENT FAILURE – APS	01:18PM	01:47PM	03:15PM	1,712	1,384
NORTHEAST	06/20/2007	MUNDS PARK	5	EQUIPMENT FAILURE – APS	12:35PM	12:36PM	02:42PM	2,107	2,940
SOUTHEAST	06/21/2007	DON LUIS	3	OVERLOAD – OTHER	05:25PM	06:35PM	06:35PM	1,085	930
SOUTHEAST	06/22/2007	VISTA	14	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	0646AM	07:24AM	07:27AM	1,134	1,741
SOUTHEAST	06/22/2007	PINAL	1	ENVIRONMENT – FIRE	07:38PM	08:45PM	12:46PM	1,227	240

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

7/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/18/2007 - 06/24/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	06/18/2007	ESTRELLITA	5	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	25,915	1,498
METRO	06/18/2007	ESTRELLITA	9	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	11,228	649
METRO	06/18/2007	ESTRELLITA	10	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	7,526	435
METRO	06/18/2007	ESTRELLITA	12	TRANSMISSION RELATED	12:06AM	05:24PM	05:24PM	20,276	1,172
METRO	06/21/2007	CACTUS	34	UNDERGROUND CABLE	08:13AM	08:47AM	10:09AM	1,809	1,708
METRO	06/21/2007	RAINTREE	13	EQUIPMENT FAILURE – APS	08:31PM	09:00PM	11:30PM	1,271	1,153
METRO	06/22/2007	WILDFLOWER	9	EQUIPMENT FAILURE – APS	05:48AM	07:07AM	11:28AM	2,908	1,500
METRO	06/22/2007	COLDWATER	18	EQUIPMENT FAILURE – APS	08:35AM	09:15AM	10:40AM	1,140	859
METRO	06/22/2007	CHAPARRAL	4	EQUIPMENT FAILURE – APS	08:17PM	08:46PM	09:08PM	1,132	1,698

8/7/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/18/2007 - 06/24/2007)

METRO	06/24/2007	TEMPE	14	FOREIGN INTERFERENCE – VEHICLES	01:28AM	02:48AM	05:39AM	4,179	3,070
METRO	06/24/2007	CHAPARRAL	10	EQUIPMENT FAILURE – APS	01:18PM	01:47PM	03:15PM	1,712	1,384
NORTHEAST	06/20/2007	MUNDS PARK	5	EQUIPMENT FAILURE – APS	12:35PM	12:36PM	02:42PM	2,058	980
NORTHWEST	06/18/2007	ANTELOPE	22	EQUIPMENT FAILURE – APS	05:29PM	06:13PM	09:36PM	9,253	3,475
SOUTHEAST	06/18/2007	PERRYVILLE	5	TRANSMISSION RELATED	09:59AM	10:32AM	10:32AM	2,213	595
SOUTHEAST	06/21/2007	DON LUIS	3	OVERLOAD – OTHER	05:25PM	06:35PM	06:35PM	1,085	930
SOUTHEAST	06/22/2007	VISTA	14	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	0646AM	07:24AM	07:27AM	1,134	1,741
SOUTHEAST	06/22/2007	PINAL	1	ENVIRONMENT – FIRE	07:38PM	08:45PM	12:46PM	1,227	240

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

8/7/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/18/2007 - 06/24/2007)

PLEASE NOTE: SHAED ITEMS REFLECT CHANGES

8/7/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/25/2007- 07/01/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	06/25/2007	MCMICKEN	12	EQUIPMENT FAILURE - APS	07:06PM	08:07PM	08:27PM	2,433	2,000
METRO	06/26/2007	LOOKOUT	10	EQUIPMENT FAILURE - APS	05:44AM	06:52AM	07:44AM	2,379	1,767
METRO	06/26/2007	DOUBLETREE	2	EQUIPMENT FAILURE – APS	05:37PM	10:04PM	11:45PM	1,975	442
METRO	06/28/2007	JAVELINA	13	EQUIPMENT FAILURE – APS	05:25PM	05:56PM	06:17PM	1,658	2,441
METRO	06/28/2007	BUFFALO	2	FOREIGN INTERFERENCE - VEHICLE	09:37PM	10:19PM	12:42AM	2,261	1,746
METRO	06/29/2007	ROADRUNNER	5	HUMAN ELEMENT – DIGIN APS	10:48AM	11:12AM	02:48PM	2,793	1,290
METRO	06/30/2007	WADDELL	7	OVERLOAD	03:52PM	07:31PM	07:31PM	3,734	1,023
SOUTHEAST	06/30/2007	SUPERIOR	1	EQUIPMENT FAILURE – APS	02:29AM	07:11AM	07:11AM	1,669	355

7/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(06/25/2007- 07/01/2007)

SOUTHEAST	06/30/2007	SUPERIOR	5	EQUIPMENT FAILURE – APS	02:29AM	07:11AM	07:11AM	1,640	349

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

7/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/02/2007 - 07/08/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	07/02/2007	CACTUS	34	UNDERGROUND CABLE	06:59AM	07:34AM	07:47AM	1,051	1,708
METRO	07/02/2007	DURANGO	14	ENVIROMENT – FIRE	05:20PM	06:27PM	11:12PM	1,513	1,329
METRO	07/05/2007	MCMICKEN	12	EQUIPMENT FAILURE – APS	02:10PM	02:43PM	05:22PM	1,475	2,000
METRO	07/05/2007	MOON VALLEY	10	EQUIPMENT FAILURE – APS	08:53PM	09:30PM	12:00AM	2,319	2,005
METRO	07/06/2007	DYSART	21	FOREIGN INTERFERENCE – VEHICLE	12:49AM	01:49AM	08:26AM	1,639	1,606
METRO	07/06/2007	ORANGEWOOD	23	EQUIPMENT FAILURE – STORM	07:08PM	07:11PM	10:20PM	1,551	1,347
NORTHEAST	07/06/2007	MAZATAZAL TEMP	6	WEATHER – LIGHTNING	03:28PM	04:57PM	08:20PM	5,966	1,285
NORTHEAST	07/07/2007	WINSLOW	14	UNKNOWN – OTHER	03:07PM	04:24PM	05:31PM	2,613	1,693

1000 HOUR CUSTOMER OUTAGE REPORT
(07/02/2007 - 07/08/2007)

NORTHWEST	07/05/2007	DEWEY	10	UNKNOWN – OTHER	05:58PM	11:15PM	09:10AM	18,002	2,000
SOUTHEAST	07/0/2007	FAIRVIEW	3	EQUIPMENT FAILURE – STORM	07:01PM	08:44PM	10:45PM	1,849	978

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(07/02/2007 - 07/08/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	07/02/2007	CACTUS	34	UNDERGROUND CABLE	06:59AM	07:34AM	07:47AM	1,051	1,708
METRO	07/02/2007	DURANGO	14	ENVIROMENT – FIRE	05:20PM	06:27PM	11:12PM	1,513	1,329
METRO	07/05/2007	MCMICKEN	12	EQUIPMENT FAILURE – APS	02:10PM	02:43PM	05:22PM	1,475	2,000
METRO	07/05/2007	MOON VALLEY	10	EQUIPMENT FAILURE – APS	08:53PM	09:30PM	12:00AM	2,319	2,005
METRO	07/06/2007	DYSART	21	FOREIGN INTERFERENCE – VEHICLE	12:49AM	01:49AM	08:26AM	1,639	1,606
METRO	07/06/2007	ORANGEWOOD	23	EQUIPMENT FAILURE – STORM	07:08PM	07:11PM	10:20PM	1,551	1,347
NORTHEAST	07/06/2007	MAZATAZAL TEMP	6	WEATHER – LIGHTNING	03:28PM	04:57PM	08:20PM	5,966	1,285
NORTHEAST	07/07/2007	WINSLOW	14	UNKNOWN – OTHER	03:07PM	04:24PM	05:31PM	2,613	1,693

2/5/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/02/2007 - 07/08/2007)

NORTHWEST	07/05/2007	DEWEY	10	UNKNOWN – OTHER	05:58PM	11:15PM	09:10AM	18,002	2,000
SOUTHEAST	07/0/2007	FAIRVIEW	3	EQUIPMENT FAILURE – STORM	07:01PM	08:44PM	10:45PM	1,849	978
NORTHWEST	07/07/2007	QUAIL SPRINGS	2	WEATHER – STORM RELATED	03:06PM	05:20PM	05:20PM	1,139	510

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(07/09/2007-07/15/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	7/10/2007	BOULEVARD	13	SUBSTATION RELATED	09:47PM	10:45PM	10:45PM	1,408	1,457
METRO	7/11/2007	BOULEVARD	13	FOREIGN INTERFERENCE – DIG INS CUSTOMER	02:09PM	02:51PM	02:59PM	1,122	1,457
NORTHEAST	7/9/2007	TONTO	14	TRANSMISSION RELATED – STORM RELATED	01:43PM	05:15PM	05:15PM	10,406	2,945
NORTHEAST	7/9/2007	STRAWBERRY	2	TRANSMISSION RELATED – STORM RELATED	03:29PM	05:15PM	05:15PM	6,784	3,840
NORTHEAST	7/12/2007	COCONINO	12	WEATHER – LIGHTNING	06:11PM	04:38AM	04:38AM	3,417	327
NORTHWEST	7/9/2007	QUAIL SPRINGS	6	TRANSMISSION RELATED – STORM RELATED	03:33PM	04:15PM	04:15PM	2,010	2,872
NORTHWEST	7/9/2007	MCGUIREVILLE	10	TRANSMISSION RELATED - STORM RELATED	03:35PM	05:20PM	05:20PM	2,979	1,702
NORTHWEST	7/9/2007	COPPER CANYON	6	TRANSMISSION RELATED – STORM RELATED	04:14PM	05:28PM	05:28PM	2,313	1,875

7/23/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/09/2007-07/15/2007)

NORTHWEST	7/11/2007	LONESOME VALLEY	14	WEATHER - LIGHTNING	02:07PM	02:49PM	05:59PM	3,344	3,602

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

7/23/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/09/2007-07/15/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	7/10/2007	BOULEVARD	13	SUBSTATION RELATED	09:47PM	10:45PM	10:45PM	1,408	1,457
METRO	7/11/2007	BOULEVARD	13	FOREIGN INTERFERENCE – DIG INS CUSTOMER	02:09PM	02:51PM	02:59PM	1,122	1,457
NORTHEAST	7/9/2007	TONTO	14	TRANSMISSION RELATED – STORM RELATED	01:43PM	05:15PM	05:15PM	10,406	2,945
NORTHEAST	7/9/2007	STRAWBERRY	2	TRANSMISSION RELATED – STORM RELATED	03:29PM	05:15PM	05:15PM	6,784	3,840
NORTHEAST	7/12/2007	COCONINO	12	WEATHER – LIGHTNING	06:11PM	04:38AM	04:38AM	3,417	327
NORTHWEST	7/9/2007	QUAIL SPRINGS	6	TRANSMISSION RELATED – STORM RELATED	03:33PM	04:15PM	04:15PM	2,010	2,872
NORTHWEST	7/9/2007	MCGUIREVILLE	10	TRANSMISSION RELATED - STORM RELATED	03:35PM	05:20PM	05:20PM	2,979	1,702
NORTHWEST	7/9/2007	COPPER CANYON	6	TRANSMISSION RELATED – STORM RELATED	04:14PM	05:28PM	05:28PM	2,313	1,875

2/5/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/09/2007-07/15/2007)

NORTHWEST	**7/11/2007**	**LONESOME VALLEY**	**14**	**WEATHER - LIGHTNING**	**02:07PM**	**02:49PM**	**05:59PM**	**3,344**	**3,602**
SOUTHWEST	**07/15/2007**	**COCOPAH**	**5**	**FOREIGN INTERFERENCE – VEHICLES**	**09:20AM**	**09:56AM**	**09:56AM**	**1,079**	**1,798**

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(07/16/2007-07/22/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	07/16/2007	SHERMAN STREET	18	WEATHER – STORM RELATED	10:00PM	11:41PM	12:23AM	1,409	701
METRO	07/17/2007	DALE	4	EQUIPMENT FAILURE - APS	04:27PM	05:17PM	05:24PM	1,016	1,130
METRO	07/19/2007	ORANGEWOOD	23	WEATHER - WIND	10:35PM	11:24PM	11:24PM	1,100	1,347
METRO	07/19/2007	SUNNYSLOPE	18	WEATHER – STORM RELATED	10:39PM	11:35PM	11:35PM	1,488	1,594
METRO	07/19/2007	UNION HILLS	21	EQUIPMENT FAILURE – APS(STORM RELATED)	10:42PM	11:21PM	05:06AM	1,676	1,462
METRO	07/19/2007	ARROYO	6	EQUIPMENT FAILURE – APS(STORM RELATED)	10:43PM	11:46PM	06:49AM	2,019	1,654
NORTHEAST	07/16/2007	SHOWLOW	13	WEATHER – STORM RELATED	01:21PM	01:53PM	02:59PM	4,909	3,236
NORTHEAST	07/19/2007	WINSLOW	14	WEATHER – STORM RELATED	05:59PM	07:08PM	11:52PM	2,284	1,693

8/3/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/16/2007-07/22/2007)

NORTHWEST	07/16/2007	DELANO	10	WEATHER – LIGHTNING	04:23PM	01:00AM	01:00AM	7,109	825
NORTHWEST	07/16/2007	DEWEY	14	WEATHER – STORM RELATED	10:10PM	11:01PM	03:22AM	1,901	2,190
NORTHWEST	07/17/2007	CHINO VALLEY	6	WEATHER – STORM RELATED	12:44AM	01:35AM	01:35AM	1,551	1,825
NORTHWEST	07/21/2007	PRESCOTT CITY	3	UNKNOWN – OTHER	03:49AM	04:58AM	04:58AM	1,265	1,100
NORTHWEST	07/21/2007	CHINO VALLEY	10	WEATHER – LIGHTNING	06:19PM	11:24PM	11:24PM	3,863	760
SOUTHEAST	07/21/2007	HIDDEN VALLEY	4	LOSS OF SUPPLY – OTHER UTILITY(STORM RELATED)	03:50AM	05:39AM	05:39AM	1,662	915

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

8/3/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/16/2007-07/22/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	07/17/2007	DALE	4	EQUIPMENT FAILURE - APS	04:27PM	05:17PM	05:24PM	1,016	1,130
METRO	07/19/2007	ORANGEWOOD	23	WEATHER - WIND	10:35PM	11:24PM	11:24PM	1,100	1,347
METRO	07/19/2007	SUNNYSLOPE	18	WEATHER – STORM RELATED	10:39PM	11:35PM	11:35PM	1,488	1,594
METRO	07/19/2007	UNION HILLS	21	EQUIPMENT FAILURE – APS(STORM RELATED)	10:42PM	11:21PM	05:06AM	1,676	1,462
METRO	07/19/2007	ARROYO	6	EQUIPMENT FAILURE – APS(STORM RELATED)	10:43PM	11:46PM	06:49AM	2,019	1,654
NORTHEAST	07/16/2007	SHOWLOW	13	WEATHER – STORM RELATED	01:21PM	01:53PM	02:59PM	4,909	3,236
NORTHEAST	07/19/2007	WINSLOW	14	WEATHER – STORM RELATED	05:59PM	07:08PM	11:52PM	2,284	1,693
NORTHWEST	07/16/2007	DELANO	10	WEATHER – LIGHTNING	04:23PM	01:00AM	01:00AM	6,678	775

1000 HOUR CUSTOMER OUTAGE REPORT
(07/16/2007-07/22/2007)

NORTHWEST	07/16/2007	DEWEY	14	WEATHER – STORM RELATED	10:10PM	11:01PM	03:22AM	1,901	2,190
NORTHWEST	07/17/2007	CHINO VALLEY	6	WEATHER – STORM RELATED	12:44AM	01:35AM	01:35AM	1,551	1,825
NORTHWEST	07/21/2007	PRESCOTT CITY	3	UNKNOWN – OTHER	03:49AM	04:58AM	04:58AM	1,265	1,100
NORTHWEST	07/21/2007	CHINO VALLEY	10	WEATHER – LIGHTNING	06:19PM	11:24PM	11:24PM	3,863	760
SOUTHEAST	07/21/2007	HIDDEN VALLEY	4	LOSS OF SUPPLY – OTHER UTILITY(STORM RELATED)	03:50AM	05:39AM	05:39AM	1,662	915

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(07/23/2007 - 07/29/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	07/23/2007	ORANGEWOOD	23	VEGETATION CONTACT – STORM	05:16PM	05:36PM	08:52AM	1,589	1,325
NORTHEAST	07/26/2007	CHOLLA	33	EQUIPMENT FAILURE – STORM	10:48PM	02:56AM	06:01AM	5,248	925
NORTHEAST	07/29/2007	COCONINO	14	EQUIPMENT FAILURE – STORM	07:33AM	08:30AM	02:05PM	15,089	3,070
NORTHWEST	07/24/2007	KIRKLAND JUNCTION	12	WEATHER – LIGHTNING	12:52PM	01:58PM	08:17PM	1,238	235
NORTHWEST	07/28/2007	KIRKLAND JUNCTION	12	WEATHER – STORM	08:30PM	08:30PM	08:30PM	19,560	815
SOUTHEAST	07/24/2007	COOLIDGE	3	FOREIGN INTERFERENCE – BIRDS	03:36PM	04:56PM	05:35PM	2,554	1,362
SOUTHEAST	07/25/2007	VALLEY FARMS	2	FOREIGN INTERFERENCE – BIRDS	02:22AM	03:21AM	07:12AM	1,122	1,025
SOUTHEAST	07/25/2007	HIDDEN VALLEY	2	WEATHER – STORM	03:58PM	05:07PM	11:42PM	1,489	481

8/8/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/23/2007 - 07/29/2007)

SOUTHWEST	07/23/2007	BLUEWATER	2	WEATHER – STORM	08:30PM	10:56PM	10:56PM	5,232	2,150
SOUTHWEST	07/24/2007	ARABY	4	WEATHER – STORM	08:57AM	12:07PM	12:07PM	3,822	1,207
SOUTHWEST	07/25/2007	IVALON	12	WEATHER – STORM	11:40AM	02:18PM	02:18PM	3,734	1,418

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

8/8/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/23/2007 - 07/29/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	07/23/2007	ORANGEWOOD	23	VEGETATION CONTACT – STORM	05:16PM	05:36PM	08:52AM	1,589	1,325
NORTHEAST	07/26/2007	CHOLLA	33	EQUIPMENT FAILURE – STORM	10:48PM	02:56AM	06:01AM	5,248	925
NORTHEAST	07/29/2007	COCONINO	14	EQUIPMENT FAILURE – STORM	07:33AM	08:30AM	02:05PM	15,089	3,070
NORTHWEST	07/24/2007	KIRKLAND JUNCTION	12	WEATHER – LIGHTNING	12:52PM	01:58PM	08:17PM	1,238	235
NORTHWEST	07/28/2007	KIRKLAND JUNCTION	12	WEATHER – STORM	08:30PM	08:30PM	08:30PM	19,560	815
SOUTHEAST	07/24/2007	COOLIDGE	3	FOREIGN INTERFERENCE – BIRDS	03:36PM	04:56PM	05:35PM	2,554	1,362
SOUTHEAST	07/25/2007	VALLEY FARMS	2	FOREIGN INTERFERENCE – BIRDS	02:22AM	03:21AM	07:12AM	1,122	1,025
SOUTHEAST	07/25/2007	HIDDEN VALLEY	2	WEATHER – STORM	03:58PM	05:07PM	11:42PM	1,489	481

1000 HOUR CUSTOMER OUTAGE REPORT
(07/23/2007 - 07/29/2007)

SOUTHWEST	07/23/2007	BLUEWATER	2	WEATHER – STORM	08:30PM	11:07PM	11:07PM	1,823	729
SOUTHWEST	07/24/2007	ARABY	4	WEATHER – STORM	08:57AM	12:07PM	12:07PM	3,822	1,207
SOUTHWEST	07/25/2007	IVALON	12	WEATHER – STORM	11:40AM	02:18PM	02:18PM	3,734	1,418
SOUTHWEST	07/23/2007	CROSSROADS	4	LOSS OF SUPPLY – OTHER UTILITY	08:37PM	10:54PM	10:54PM	2,028	888

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(07/30/2007 - 08/05/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	07/30/2007	ORANGEWOOD	23	VEGETATION CONTACT – STORM	03:29PM	04:10PM	05:08PM	1,202	1,347
METRO	07/30/2007	INDIAN BEND	5	EQUIPMENT FAILURE – APS	03:31PM	04:52PM	02:34AM	1,725	1,216
METRO	07/30/2007	PIMA	6	EQUIPMENT FAILURE – STORM	03:47PM	06:42PM	07:14PM	2,147	637
METRO	07/30/2007	CAMELBACK	12	STORM RELATED	04:10PM	05:13PM	03:25AM	2,259	1,092
METRO	07/30/2007	CAMELBACK	22	EQUIPMENT FAILURE – STORM	04:11PM	05:52PM	05:52PM	1,096	651
METRO	07/30/2007	BUTTE	21	WEATHER – STORM RELATED	04:49PM	07:14PM	07:36PM	3,619	1,392
METRO	07/31/2007	STAGECOACH	6	EQUIPMENT FAILURE – STORM RELATED	06:33PM	09:00PM	10:38PM	4,797	1,522
METRO	07/31/2007	ORANGEWOOD	23	VEGETATION CONTACT – STORM RELATED	06:52PM	07:18PM	12:41AM	2,081	1,347

8/21/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/30/2007 - 08/05/2007)

NORTHEAST	07/31/2007	LEROUX	5	WEATHER – STORM RELATED	07:39PM	09:07PM	09:07PM	2,706	1,845
NORTHEAST	07/31/2007	LEROUX	3	WEATHER – STORM RELATED	07:49PM	09:18PM	09:18PM	1,595	1,075
NORTHWEST	07/30/2007	COTTONWOOD	14	WEATHER – LIGHTNING	03:09PM	08:07PM	08:07PM	2,235	450
SOUTHEAST	07/31/2007	PINAL	2	EQUIPMENT FAILURE – STORM RELATED	03:22PM	04:18PM	05:30PM	1,518	1,109

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

8/21/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/06/2007-08/12/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	08/06/2007	WESTBROOK	11	UNDERGROUND CABLE	10:11PM	10:40PM	10:40PM	1,293	2,676
METRO	08/08/2007	CACTUS	30	UNDERGROUND CABLE	12:36AM	01:26AM	02:02AM	2,617	2,302
METRO	08/09/2007	EL SOL	14	UNDERGROUND CABLE	06:30AM	07:09AM	07:29AM	1,486	1,905
METRO	08/09/2007	GLENDALE	4	EQUIPMENT FAILURE - APS	06:42AM	08:37AM	11:17AM	3,975	1,442
METRO	08/10/2007	STAGECOACH	13	FOREIGN INTERFERENCE - ANIMALS	06:18AM	07:29AM	08:18AM	1,289	931
METRO	08/12/2007	MEADOWBROOK	18	FOREIGN INTERFERENCE - VEHICLES	10:12AM	11:03AM	04:30PM	1,615	1,791
NORTHEAST	08/06/2007	SNOWFLAKE	2	WEATHER - STORM RELATED	03:39PM	04:36PM	05:25PM	2,207	2,315
NORTHEAST	08/12/2007	WINSLOW	14	WEATHER - STOWM RELATED	11:23PM	11:59PM	11:59PM	1,016	1,693

8/23/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/06/2007-08/12/2007)

SOUTHEAST	08/07/2007	COOLIDGE	1	LOSS OF SUPPLY – OTHER UTILITY	06:36PM	08:35PM	08:35PM	3,741	1,886
SOUTHEAST	08/07/2007	COOLIDGE	2	LOSS OF SUPPLY – OTHER UTILITY	06:36PM	08:35PM	08:35PM	1,164	587
SOUTHEAST	08/07/2007	COOLIDGE	3	LOSS OF SUPPLY – OTHER UTILITY	06:36PM	08:35PM	08:35PM	2,724	1,362

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

8/23/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	08/14/2007	MCDOWELL	18	WEATHER – LIGHTNING	02:45AM	06:30AM	06:30AM	1,103	294
METRO	08/14/2007	ORANGEWOOD	33	EQUIPMENT FAILURE – STORM RELATED	02:45AM	03:45AM	05:19AM	4,243	2,078
METRO	08/14/2007	CACTUS	34	UNDERGROUND CABLE	09:48AM	10:32AM	10:54AM	1,323	1,708
METRO	08/16/2007	TWENTY-THIRD ST	20	EQUIPMENT FAILURE	02:50PM	04:17PM	04:17PM	1,640	1,131
METRO	08/16/2007	TWENTY-THIRD ST	21	EQUIPMENT FAILURE	02:50PM	04:08PM	04:08PM	1,873	1,441
METRO	08/16/2007	TWENTY-THIRD ST	22	EQUIPMENT FAILURE	02:50PM	05:06PM	05:06PM	5,773	2,547
METRO	08/16/2007	FILLMORE	19	EQUIPMENT FAILURE	03:26PM	04:11PM	01:10AM	1,729	1,272
METRO	08/17/2007	WILDFLOWER	5	UNDERGROUND CABLE	03:38PM	04:54PM	04:54PM	1,462	1,154

9/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

NORTHEAST	08/13/2007	ELDEN	1	SUBSTATION RELATED – STORM RELATED	12:45PM	01:26PM	01:26PM	2,012	2,945
NORTHEAST	08/13/2007	ELDEN	2	SUBSTATION RELATED – STORM RELATED	12:45PM	01:26PM	01:26PM	2,149	3,145
NORTHEAST	08/13/2007	SANDVIG	4	SUBSTATION RELATED – STORM RELATED	12:45PM	01:24PM	01:24PM	1,518	2,335
NORTHEAST	08/13/2007	SANDVIG	10	SUBSTATION RELATED – STORM RELATED	12:45PM	01:24PM	01:24PM	1,586	2,440
NORTHEAST	08/13/2007	SANDVIG	14	SUBSTATION RELATED – STORM RELATED	12:45PM	01:24PM	01:24PM	1,976	3,040
NORTHEAST	08/13/2007	SWITZER CANYON	13	SUBSTATION RELATED – STORM RELATED	12:45PM	01:22PM	01:22PM	3,401	5,515
NORTHEAST	08/13/2007	TUBA CITY	3	SUBSTATION RELATED – STORM RELATED	12:45PM	01:25PM	01:25PM	1,213	1,820
NORTHEAST	08/13/2007	WOODY MOUNTAIN	14	SUBSTATION RELATED – STORM RELATED	01:14PM	01:43PM	01:43PM	1,206	2,495

9/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

NORTHEAST	08/13/2007	WINSLOW	14	EQUIPMENT FAILURE – STORM RELATED	06:57PM	08:31PM	01:10AM	2,680	1,693
NORTHEAST	08/16/2007	MAZATZAL TEMPORARY	6	FOREIGN INTERFERENCE – VANDALISM	10:51AM	11:24AM	01:39PM	3,250	1,285
NORTHWEST	08/13/2007	WHITE SPAR	10	EQUIPMENT FAILURE – STORM RELATED	11:04AM	05:05PM	05:05PM	1,715	285
NORTHWEST	08/14/2007	CHINO VALLEY	14	FOREIGN INTEFERENCE – BIRDS	08:52AM	09:52AM	09:52AM	1,216	1,216
NORTHWEST	08/15/2007	CHINO VALLEY	10	WEATHER- STORM RELATED	02:32PM	03:04PM	03:04PM	1,538	2,884
SOUTHEAST	08/13/2007	EASTGATE	2	WEATHER – STORM RELATED	10:02PM	10:05PM	05:52PM	9,394	1,248
SOUTHEAST	08/13/2007	MILLIGAN TEMP	2	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	10,181	1,308
SOUTHEAST	08/13/2007	MILLIGAN TEMP	4	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	3,160	406
SOUTHEAST	08/13/2007	TOLTEC	1	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	4,398	565

9/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

SOUTHEAST	08/13/2007	TOLTEC	5	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	15,100	1,940
SOUTHEAST	08/13/2007	TOLTEC	6	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	17,287	2,221
SOUTHEAST	08/16/2007	PINAL	3	FOREIGN INTERFERENCE – VEHICLES	07:30AM	07:51AM	02:15PM	5,607	1,941
SOUTHEAST	08/16/2007	VALLEY FARMS	4	EQUIPMENT FAILURE – STORM RELATED	05:14PM	06:09PM	06:09PM	1,143	1,247

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

9/10/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	08/14/2007	MCDOWELL	18	WEATHER – LIGHTNING	02:45AM	06:30AM	06:30AM	1,103	294
METRO	08/14/2007	ORANGEWOOD	33	EQUIPMENT FAILURE – STORM RELATED	02:45AM	03:45AM	05:19AM	4,243	2,078
METRO	08/14/2007	CACTUS	34	UNDERGROUND CABLE	09:48AM	10:32AM	10:54AM	1,323	1,708
METRO	08/16/2007	TWENTY-THIRD ST	20	EQUIPMENT FAILURE	02:50PM	04:17PM	04:17PM	1,640	1,131
METRO	08/16/2007	TWENTY-THIRD ST	21	EQUIPMENT FAILURE	02:50PM	04:08PM	04:08PM	1,873	1,441
METRO	08/16/2007	TWENTY-THIRD ST	22	EQUIPMENT FAILURE	02:50PM	05:06PM	05:06PM	5,773	2,547
METRO	08/16/2007	FILLMORE	19	EQUIPMENT FAILURE	03:26PM	04:11PM	01:10AM	1,729	1,272
METRO	08/17/2007	WILDFLOWER	5	UNDERGROUND CABLE	03:38PM	04:54PM	04:54PM	1,462	1,154

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

NORTHEAST	08/13/2007	ELDEN	1	SUBSTATION RELATED – STORM RELATED	12:45PM	01:26PM	01:26PM	2,012	2,945
NORTHEAST	08/13/2007	ELDEN	2	SUBSTATION RELATED – STORM RELATED	12:45PM	01:26PM	01:26PM	2,149	3,145
NORTHEAST	08/13/2007	SANDVIG	4	SUBSTATION RELATED – STORM RELATED	12:45PM	01:24PM	01:24PM	1,518	2,335
NORTHEAST	08/13/2007	SANDVIG	10	SUBSTATION RELATED – STORM RELATED	12:45PM	01:24PM	01:24PM	1,586	2,440
NORTHEAST	08/13/2007	SANDVIG	14	SUBSTATION RELATED – STORM RELATED	12:45PM	01:24PM	01:24PM	1,976	3,040
NORTHEAST	08/13/2007	SWITZER CANYON	13	SUBSTATION RELATED – STORM RELATED	12:45PM	01:22PM	01:22PM	3,401	5,515
NORTHEAST	08/13/2007	TUBA CITY	3	SUBSTATION RELATED – STORM RELATED	12:45PM	01:25PM	01:25PM	1,213	1,820
NORTHEAST	08/13/2007	WOODY MOUNTAIN	14	SUBSTATION RELATED – STORM RELATED	01:14PM	01:43PM	01:43PM	1,206	2,495

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

NORTHEAST	08/13/2007	WINSLOW	14	EQUIPMENT FAILURE – STORM RELATED	06:57PM	08:31PM	01:10AM	2,680	1,693
NORTHEAST	08/16/2007	MAZATZAL TEMPORARY	6	FOREIGN INTERFERENCE – VANDALISM	10:51AM	11:24AM	01:39PM	3,250	1,285
NORTHWEST	08/13/2007	WHITE SPAR	10	EQUIPMENT FAILURE – STORM RELATED	11:04AM	05:05PM	05:05PM	1,715	285
NORTHWEST	08/14/2007	CHINO VALLEY	14	FOREIGN INTEFERENCE – BIRDS	08:52AM	09:52AM	09:52AM	1,216	1,216
NORTHWEST	08/15/2007	CHINO VALLEY	10	WEATHER- STORM RELATED	02:32PM	03:04PM	03:04PM	1,538	2,884
SOUTHEAST	08/13/2007	EASTGATE	2	WEATHER – STORM RELATED	10:02PM	10:05PM	10:39PM 8/15	10,618	1,248
SOUTHEAST	08/13/2007	MILLIGAN TEMP	2	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	10,181	1,308
SOUTHEAST	08/13/2007	MILLIGAN TEMP	4	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	3,160	406

1000 HOUR CUSTOMER OUTAGE REPORT
(08/13/2007-08/19/2007)

SOUTHEAST	08/13/2007	TOLTEC	1	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	4,398	565
SOUTHEAST	08/13/2007	TOLTEC	5	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	15,100	1,940
SOUTHEAST	08/13/2007	TOLTEC	6	TRANSMISSION RELATED – STORM RELATED	10:02PM	05:49AM	05:49AM	17,287	2,221
SOUTHEAST	08/16/2007	PINAL	3	FOREIGN INTERFERENCE – VEHICLES	07:30AM	07:51AM	02:15PM	5,607	1,941
SOUTHEAST	08/16/2007	VALLEY FARMS	4	EQUIPMENT FAILURE – STORM RELATED	05:14PM	06:09PM	06:09PM	1,143	1,247

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(08/20/2007-08/26/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	08/22/2007	CACTUS	25	UNDERGROUND CABLE	03:32PM	04:15PM	04:43PM	1,180	1,155
METRO	08/24/2007	CACTUS	30	UNDERGROUND CABLE	08:20AM	09:09AM	09:46AM	2,263	2,302
METRO	08/25/2007	GLENDALE	17	FOREIGN INTERFERENCE – VEHICLES	07:37AM	08:06AM	02:35PM	1,993	1,120

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

9/4/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/20/2007 - 08/26/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	08/22/2007	CACTUS	25	UNDERGROUND CABLE	03:32PM	04:15PM	04:43PM	1,180	1,115
METRO	08/24/2007	CACTUS	30	UNDERGROUND CABLE	08:20AM	09:09AM	09:46AM	2,263	2,302
METRO	08/25/2007	GLENDALE	17	FOREIGN INTERFERENCE – VEHICLES	07:37AM	08:06AM	02:35PM	1,993	1,120

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

9/12/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/27/2007 - 09/02/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	08/29/2007	DYSART	20	FOREIGN INTERFERENCE – VEHICLE	02:58AM	03:34AM	03:54AM	1,588	1,985
METRO	08/29/2007	ORANGEWOOD	23	EQUIPMENT FAILURE – STORM	06:59PM	07:30PM	09:32PM	1,879	1,347
METRO	08/30/2007	CACTUS	30	UNDERGROUND CABLE	05:58PM	06:36PM	06:54PM	1,872	2,302
METRO	08/31/2007	TURF	10	UNDERGROUND CABLE	12:25AM	02:58AM	02:58AM	1,030	404
METRO	09/02/2007	INDIAN BEND	1	UNKNOWN / OTHER	05:25AM	06:07AM	07:16AM	1,272	1,274
METRO	09/02/2007	PYRAMID PEAK	2	FOREIGN INTERFERENCE – VEHICLE	06:53PM	07:41PM	07:41PM	1,119	1,399
NORTHEAST	08/28/2007	WINSLOW	14	EQUIPMENT FAILURE – APS	01:31PM	01:53PM	03:37PM	1,418	1,693
NORTHEAST	08/31/2007	COCONINO	12	VEGETATION CONTACT	11:20AM	12:17PM	04:32PM	1,178	300

9/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/27/2007 - 09/02/2007)

NORTHWEST	08/30/2007	KIRKLAND JUNCTION	12	EQUIPMENT FAILURE – STORM	03:20PM	04:57PM	11:20PM	1,682	815
SOUTHEAST	08/29/2007	COOLIDGE	1	WEATHER – STORM	07:10PM	02:45PM	04:40PM 8/31	79,050	1,846
SOUTHEAST	08/29/2007	COOLIDGE	3	WEATHER – STORM	07:10PM	09:40PM	07:26PM 8/30	12,306	1,362
SOUTHEAST	08/29/2007	FARRELL	6	LOSS OF SUPPLY – OTHER UTILITY STORM	08:11PM	08:35PM	01:20AM	2,893	821
SOUTHEAST	09/01/2007	AJO	1	TRANSMISSION RELATED – STORM	01:31PM	02:35PM	02:35PM	1,004	941
SOUTHEAST	09/01/2007	WHY	1	TRANSMISSION RELATED – STORM	01:31PM	05:55PM	06:33PM	1,270	284
SOUTHWEST	09/01/2007	ARABY	4	EQUIPMENT FAILURE – STORM	11:52PM	01:06AM	01:06AM	1,626	1,318
SOUTHWEST	09/02/2007	IVALON	12	EQUIPMENT FAILURE – STORM	12:20AM	03:17AM	03:17AM	3,224	1,093
SOUTHWEST	09/02/2007	QUECHAN	30	EQUIPMENT FAILUE – STORM	12:23AM	02:25AM	02:25AM	3,379	1,662

9/13/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/27/2007 - 09/02/2007)

SOUTHWEST	09/02/2007	IVALON	5	EQUIPMENT FAILURE – STORM	12:24AM	01:45AM	01:45AM	2,153	1,595
SOUTHWEST	09/02/2007	THIRTY-SECOND ST	12	EQUIPMENT FAILURE – STORM	12:24AM	04:33AM	04:33AM	5,889	1,419
SOUTHWEST	09/02/2007	THIRTY-SECOND	2	EQUIPMENT FAILURE – STORM	12:28AM	02:17AM	02:17AM	2,476	1,363

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(08/27/2007 - 09/02/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	08/29/2007	DYSART	20	FOREIGN INTERFERENCE – VEHICLE	02:58AM	03:34AM	03:54AM	1,588	1,985
METRO	08/29/2007	ORANGEWOOD	23	EQUIPMENT FAILURE – STORM	06:59PM	07:30PM	08:35PM	1,425	1,347
METRO	08/30/2007	CACTUS	30	UNDERGROUND CABLE	05:58PM	06:36PM	06:54PM	1,872	2,302
METRO	08/31/2007	TURF	10	UNDERGROUND CABLE	12:25AM	02:58AM	02:58AM	1,030	404
METRO	09/02/2007	INDIAN BEND	1	UNKNOWN / OTHER	05:25AM	06:07AM	07:16AM	1,272	1,274
METRO	09/02/2007	PYRAMID PEAK	2	FOREIGN INTERFERENCE – VEHICLE	06:53PM	07:41PM	07:41PM	1,119	1,399
NORTHEAST	08/28/2007	WINSLOW	14	EQUIPMENT FAILURE – APS	01:31PM	01:53PM	03:37PM	1,418	1,693
NORTHEAST	08/31/2007	COCONINO	12	VEGETATION CONTACT	11:20AM	12:17PM	04:32PM	1,178	300

1000 HOUR CUSTOMER OUTAGE REPORT
(08/27/2007 - 09/02/2007)

REVISED

NORTHWEST	08/30/2007	KIRKLAND JUNCTION	12	EQUIPMENT FAILURE – STORM	03:20PM	04:57PM	11:20PM	1,682	815
SOUTHEAST	08/29/2007	COOLIDGE	1	WEATHER – STORM	07:10PM	02:45PM	04:40PM 8/31	79,050	1,846
SOUTHEAST	08/29/2007	COOLIDGE	3	WEATHER – STORM	07:10PM	09:40PM	07:26PM 8/30	12,306	1,362
SOUTHEAST	08/29/2007	FARRELL	6	LOSS OF SUPPLY – OTHER UTILITY STORM	08:11PM	08:35PM	01:20AM	2,893	821
SOUTHWEST	09/01/2007	ARABY	4	EQUIPMENT FAILURE – STORM	11:52PM	01:06AM	01:06AM	1,626	1,318
SOUTHWEST	09/02/2007	IVALON	12	EQUIPMENT FAILURE – STORM	12:20AM	03:17AM	03:17AM	3,224	1,093
SOUTHWEST	09/02/2007	QUECHAN	30	EQUIPMENT FAILUE – STORM	12:23AM	02:25AM	02:25AM	3,379	1,662
SOUTHWEST	09/02/2007	IVALON	5	EQUIPMENT FAILURE – STORM	12:24AM	01:45AM	01:45AM	2,153	1,595
SOUTHWEST	09/02/2007	THIRTY-SECOND ST	12	EQUIPMENT FAILURE – STORM	12:24AM	04:33AM	04:33AM	5,889	1,419

1000 HOUR CUSTOMER OUTAGE REPORT
(08/27/2007 - 09/02/2007)

REVISED

SOUTHWEST	**09/02/2007**	**THIRTY-SECOND**	**2**	**EQUIPMENT FAILURE – STORM**	**12:28AM**	**02:17AM**	**02:17AM**	**2,476**	**1,363**

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

2/5/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(09/03/2007-09/09/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	09/03/2007	DYSART	14	UNDERGROUND CABLE	04:47PM	05:01PM	08:24PM	1,539	2,308
NORTHEAST	09/08/2007	SHOWLOW	9	FOREIGN INTERFERENCE - VEHICLES	07:59AM	10:23AM	01:13PM	4,109	1,225
SOUTHEAST	09/03/2007	VISTA	6	UNDERGROUND CABLE	12:00AM	03:58AM	06:25PM	29,674	1,099

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

9/24/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(09/10/2007-09/16/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	09/10/2007	MEADOWBROOK	21	FOREIGN INTERFERENCE - VEHICLES	04:58PM	06:08PM	09:11PM	1,020	734
SOUTHEAST	09/15/2007	GILA BEND	10	WEATHER – STORM RELATED	01:25PM	02:54PM	02:54PM	1,093	737
SOUTHEAST	09/15/2007	GILLESPIE	1	EQUIPMENT FAILURE – APS STORM RELATED	02:13PM	07:36PM	06:04AM	1,048	189
SOUTHEAST	09/15/2007	BASELINE	1	EQUIPMENT FAILURE – APS STORM RELATED	03:02PM	05:11PM	03:00AM	1,125	387

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

10/11/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(09/17/2007-09/23/2007)

NORTHEAST	09/23/2007	COCONINO	12	EQUIPMENT FAILURE – APS (STORM RELATED)	07:02AM	05:29PM	05:29PM	1,150	110
SOUTHEAST	09/17/2007	VALENCIA	1	FOREIGN INTERFERENCE – VEHICLES	09:28AM	10:11AM	01:15PM	1,337	1,801
SOUTHEAST	09/21/2007	PINAL	4	EQUIPMENT FAILURE – APS (STORM RELATED)	02:45AM	05:11AM	05:11AM	1,095	450
SOUTHEAST	09/21/2007	CASA GRANDE	2	FOREIGN INTERFERENCE – VEHICLE	08:28PM	08:30PM	08:24AM	2,801	728

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

10/11/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(09/17/2007-09/23/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	09/21/2007	ARROWHEAD	5	EQUIPMENT FAILURE – APS (STORM RELATED)	05:41PM	06:24PM	06:57PM	1,358	1,644
METRO	09/22/2007	ESTRELLITA	5	TRANSMISSION RELATED - STORM	03:10PM	05:33PM	05:33PM	3,570	1,498
METRO	09/22/2007	ESTRELLITA	9	TRANSMISSION RELATED - STORM	03:10PM	05:33PM	05133PM	1,547	649
METRO	09/22/2007	ESTRELLITA	10	TRANSMISSION RELATED - STORM	03:10PM	05:33PM	05:33PM	1,037	435
METRO	09/22/2007	ESTRELLITA	12	TRANSMISSION RELATED - STORM	03:10PM	05:33PM	05:33PM	2,793	1,172
NORTHEAST	09/22/2007	ASHFORK	10	STORM RELATED	08:45AM	09:44AM	09:44AM	1,022	1,039
NORTHEAST	09/22/2007	BLUE RIDGE	12	WEATHER - STORM RELATED	06:04PM	10:27 PM	02:00AM	6,506	1,355

10/11/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(09/24/2007-09/30/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	09/29/2007	LONE PEAK	12	UNDERGROUND CABLE	11:10PM	12:04AM	12:22AM	1,668	1,766

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

10/11/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(10/01/2007 - 10/07/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	10/02/2007	ALTADENA	4	UNDERGROUND CABLE	11:33PM	12:20AM	03:27AM	1,756	1,042
SOUTHEAST	10/04/2007	KEARNY	6	SUBSTATION RELATED	08:05PM	09:07PM	02:11AM	4,146	947
SOUTHEAST	10/04/2007	KEARNY	2	SUBSTATION RELATED	08:05PM	02:11AM	02:11AM	3,715	609

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

10/18/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(10/08/2007-10/14/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	10/09/2007	MOON VALLEY	5	UNDERGROUND CABLE	12:14PM	12:42PM	01:43PM	1,509	1,844

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

10/23/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(10/15/2007 - 10/21/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	10/17/2007	GREENWAY	6	UNDERGROUND CABLE	08:00AM	08:37AM	12:07PM	1,428	1,608
NORTHEAST	10/16/2007	SWITZER CANYON	13	UNDERGROUND CABLE	01:00AM	03:51AM	09:50AM	4,904	700
NORTHWEST	10/16/2007	BALD MOUNTAIN	1	FOREIGN INTERFERENCE	04:44PM	05:54PM	09:45PM	3,218	1,450
NORTHWEST	10/19/2007	ANTELOPE	18	UNDERGROUND CABLE	02:04AM	03:46AM	03:46AM	6,698	3,940
SOUTHWEST	10/21/2007	HAVASU	2	WEATHER – WIND	12:27AM	02:15AM	02:15AM	1,881	1,045
SOUTHWEST	10/21/2007	HAVASU	1	WEATHER – WIND	12:51AM	03:41AM	03:41AM	2,754	972

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

11/1/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(10/22/2007-10/28/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	10/23/2007	MCCORMICK	5	EQUIPMENT FAILURE – APS	08:25PM	08:58PM	12:08AM	1,487	1,438
SOUTHEAST	10/22/2007	TOLTEC	5	EQUIPMENT FAILURE – APS	01:17PM	02:04PM	03:35PM	1,523	1,940
SOUTHWEST	10/23/2007	SAN LUIS	10	FOREIGN INTERFERENCE-VEHICLES	08:34PM	09:45PM	09:45PM	1,877	1,586

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

11/14/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(11/05/2007-11/11/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	11/08/2007	CHAPARRAL	10	FOREIGN INTERFERENCE - BIRDS	01:05PM	01:36PM	09:22PM	1,270	1,384
METRO	11/09/2007	BOULEVARD	13	EQUIPMENT FAILURE - APS	06:47PM	07:19PM	10:50PM	1,736	1,457
NORTHEAST	11/10/2007	SHOWLOW	13	FOREIGN INTERFERENCE – VEHICLES	11:48PM	04:08AM	08:23AM	14,027	3,236

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

11/27/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(11/12/2007-11/18/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	11/13/2007	LOOKOUT	6	FOREIGN INTERFERENCE-DIG-INS	02:55PM	03:46PM	06:08PM	2,429	2,743
METRO	11/18/2007	EL SOL	18	EQUIPMENT FAILURE - APS	01:48AM	03:04AM	08:30AM	2,226	1,719
NORTHEAST	11/17/2007	SWITZER CANYON	13	UNDERGROUND CABLE	11:21PM	11:21PM	11:21PM (11/18/07)	1,536	64

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

12/21/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(11/12/2007-11/18/2007)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	11/13/2007	LOOKOUT	6	FOREIGN INTERFERENCE-DIG-INS	02:55PM	03:46PM	06:08PM	2,429	2,743
METRO	11/18/2007	EL SOL	18	EQUIPMENT FAILURE - APS	01:48AM	03:04AM	08:30AM	2,226	1,719

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(11/19/2007-11/25/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	11/23/2007	OBERLIN TEMPORARY	12	TRANSMISSION RELATED	07:09AM	09:11AM	09:11AM	2,651	1,304
NORTHEAST	11/22/2007	SANDVIG	10	EQUIPMENT FAILURE - APS	04:48AM	07:27AM	07:27AM	1,458	550
NORTHEAST	11/24/2007	PREACHER CANYON	6	VEGETATION CONTACT	07:34AM	01:32PM	01:32PM	1,492	250
NORTHEAST	11/24/2007	PREACHER CANYON	6	VEGETATION CONTACT	08:08AM	09:04AM	04:32PM	1,759	250
NORTHEAST	11/24/2007	MUNDS PARK	5	EQUIPMENT FAILURE - APS	10:13AM	05:25PM	05:25PM	21,168	2,940
NORTHEAST	11/24/2007	MUNDS PARK	5	EQUIPMENT FAILURE - APS	05:28PM	09:00PM	11:42PM	11,835	2,940
SOUTHEAST	11/24/2007	MURAL	2	EQUIPMENT FAILURE – APS	08:57AM	09:56AM	09:56AM	1,659	1,687

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

12/31/2007

1000 HOUR CUSTOMER OUTAGE REPORT
(11/19/2007-11/25/2007)

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(11/26/2007 - 12/02/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t**
METRO	11/30/2007	COLDWATER	22	EQUIPMENT FAILURE – APS STORM	01:38PM	02:26PM	06:40PM	3,641	2,117
METRO	11/30/2007	MCMICKEN	9	EQUIPMENT FAILURE – APS STORM	03:37PM	05:05PM	05:05PM	1,879	1,281
METRO	11/30/2007	GRISWOLD	4	EQUIPMENT FAILUE – APS STORM	03:57PM	05:03PM	10:57PM	1,787	1,544
METRO	11/30/2007	ESTRELLITA	5	EQUIPMENT FAILURE – APS STORM	04:36PM	06:40PM	02:02PM	2,329	500
METRO	11/30/2007	ENCANTO	4	EQUIPMENT FAILURE – APS STORM	11:18PM	11:19PM	04:07AM	7,349	292
METRO	11/30/2007	INDIAN BEND	12	WEATHER – STORM	11:58PM	01:40AM	03:30AM	1,370	613
NORTHEAST	12/01/2007	BLUE RIDGE	12	WEATHER – STORM	12:41AM	03:03AM	05:57AM	5,307	1,355
NORTHEAST	12/01/2007	BLUE RIDGE	12	WEATHER – STORM	06:13AM	06:51AM	03:18PM	2,548	1,355
NORTHWEST	11/30/2007	COTTONWOOD	22	TRANSMISSION RELATED – STORM	12:01PM	12:30PM	12:30PM	1,157	2,393

1/8/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(11/26/2007 - 12/02/2007)

NORTHWEST	11/30/2007	WICKENBURG	14	EQUIPMENT FAILURE – APS STORM	01:01PM	02:54PM	02:54PM	1,313	697
NORTHWEST	11/30/2007	KIRKLAND JUNCTION	10	VEGETATION CONTACT – STORM	11:21PM	09:36AM	09:36AM	6,868	670
NORTHWEST	11/30/2007	BAGDAD TOWNSITE	10	EQUIPMENT FAILURE – APS STORM	11:47PM	04:58AM	06:03PM	1,388	225
NORTHWEST	12/01/2007	COPPER CANYON	6	EQUIPMENT FAILURE – APS STORM	12:29AM	05:27AM	02:58PM	1,786	235
NORTHWEST	12/01/2007	MINGUS	2	TRANSMISSION RELATED – STORM	11:42AM	02:43PM	02:43PM	2,269	84
NORTHWEST	12/01/2007	CORDES	2	VEGETATION CONTACT – STORM	02:12PM	04:06PM	04:06PM	1,062	41
SOUTHEAST	11/29/2007	KEARNY	6	EQUIPMENT FAILURE – APS STORM	03:41PM	04:43PM	07:01PM	3,051	947
SOUTHEAST	11/30/2007	KEARNY	6	EQUIPMENT FAILURE – APS STORM	03:33AM	06:06AM	09:34AM	4,055	947
SOUTHEAST	12/01/2007	HAYES GULCH	2	WEATHER – STORM	12:26AM	01:21AM	04:16PM	4,362	1,303

1000 HOUR CUSTOMER OUTAGE REPORT
(11/26/2007 - 12/02/2007)

SOUTHWEST	11/30/2007	COCOPAH	14	WEATHER – STORM	04:40PM	08:10PM	08:10PM	2,006	573
SOUTHWEST	11/30/2007	THIRTY-SECOND ST	9	WEATHER – STORM	07:19PM	08:09PM	08:09PM	1,289	1,547
SOUTHWEST	11/30/2007	QUECHAN	18	WEATHER – STORM	08:47PM	09:51PM	09:51PM	1,731	1,623
SOUTHWEST	11/30/2007	TENTH STREET	9	WEATEHR – STORM	09:14PM	10:55PM	10:55PM	2,532	1,504

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(12/03/2007 - 12/09/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t**
METRO	12/05/2007	HONEYWELL	9	UNDERGROUND CABLE	05:00PM	05:37PM	06:52PM	1,789	1,617
METRO	12/07/2007	CAVE CREEK	10	EQUIPMENT FAILURE – APS STORM	06:43PM	08:30PM	09:41PM	3,752	1,805
NORTHEAST	12/08/2007	BLUE RIDGE	12	EQUIPMENT FAILURE – APS STORM	11:20AM	01:48PM	08:56PM	4,769	1,355
NORTHEAST	12/09/2007	SNOWFLAKE	2	TRANSMISSION RELATED – STORM	10:22PM	10:55PM	10:55PM	1,273	2,315
NORTHEAST	12/09/2007	WOODRUFF	2	TRANSMISSION RELATED – STORM	11:31PM	07:35AM	07:35AM	1,638	203
NORTHWEST	12/03/2007	COTTONWOOD	18	FOREIGN INTERFERENCE – VEHICLE	01:12PM	01:43PM	01:43PM	1,343	2,600

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1/8/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/10/2007 – 12/16/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t**
METRO	12/12/2007	RAINTREE	1	EQUIPMENT FAILURE – APS	12:39PM	01:12PM	01:29PM	1,357	1,830
METRO	12/12/2007	ALTADENA	13	EQUIPMENT FAILURE – APS	03:28PM	07:53PM	07:53PM	1,577	357
METRO	12/16/2007	RAINTREE	1	EQUIPMENT FAILURE – APS	01:54AM	02:35AM	02:54AM	2,500	1,830
METRO	12/16/2007	DESERT SPRINGS	1	SUBSTATION RELATED	03:20AM	04:29AM	04:29AM	2,512	2,184
METRO	12/16/2007	DESERT SPRINGS	4	SUBSTATION RELATED	03:20AM	04:29AM	04:29AM	1,486	1,292
METRO	12/16/2007	DESERT SPRINGS	5	SUBSTATION RELATED	03:20AM	04:30AM	04:30AM	1,789	1,533
METRO	12/16/2007	DESERT SPRINGS	9	SUBSTATION RELATED	03:20AM	04:34AM	04:34AM	1,305	1,058
METRO	12/16/2007	DESERT SPRINGS	12	SUBSTATION RELATED	03:20AM	04:34AM	04:34AM	1,772	1,437

1/11/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/10/2007 – 12/16/2007)

METRO	12/16/2007	DESERT SPRINGS	13	SUBSTATION RELATED	03:20AM	04:36AM	04:36AM	1,302	1,028
METRO	12/16/2007	DESERT SPRINGS	14	SUBSTATION RELATED	03:20AM	04:32AM	04:32AM	1,637	1,364
NORTHEAST	12/11/2007	STRAWBERRY	2	WEATHER – STORM	08:52AM	09:28AM	09:28AM	2,304	3,840
NORTHEAST	12/11/2007	STRAWBERRY	2	WEATHER – STORM	09:40AM	09:53AM	11:12AM	3,579	3,840

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

**** Based on definition of "customer" in A.A.C. R-14-2-201. 9**

1/11/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/17/2007 - 12/23/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count t**
METRO	12/20/2007	HEDGEPETH HILLS	13	FOREIGN INTERFERENCE – VEHICLE	03:21AM	03:52AM	01:04PM	1,571	1,276
METRO	12/21/2007	NORTH VALLEY	10	UNDERGROUND CABLE	03:44AM	04:36AM	04:46AM	1,722	1,779
METRO	12/21/2007	SHEA	10	FOREIGN INTERFERENCE – ANIMALS	06:19AM	07:09AM	08:00AM	1,082	833
NORTHEAST	12/22/2007	PREACHER CANYON	6	FOREIGN INTERFERENCE – VEHICLE	08:52PM	10:13PM	10:29PM	3,026	1,925

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1/14/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/24/2007-12/30/2007)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
NORTHEAST	12/25/2007	TONTO	12	UNDERGROUND CABLE	03:46AM	05:10AM	06:08AM	4,333	2,950
NORTHEAST	12/27/2007	TONTO	12	UNDERGROUND CABLE	10:48PM	12:06AM	01:05AM	3,914	2,950
NORTHEAST	12/28/2007	PREACHER CANYON	6	EQUIPMENT FAILURE – APS	07:35AM	07:40AM	10:14AM	6,242	2,365
NORTHEAST	12/30/2007	ASHFORK	10	EQUIPMENT FAILURE – APS	06:55AM	11:59AM	02:02PM	1,602	290
NORTHWEST	12/29/2007	SEDONA	6	EQUIPMENT FAILURE – APS	01:32PM	02:45PM	08:44PM	3,774	1,461
NORTHWEST	12/30/2007	SEDONA	6	EQUIPMENT FAILURE – APS	05:37AM	08:38AM	08:38AM	1,810	600
SOUTHEAST	12/26/2007	WINGFIELD	5	LOSS OF SUPPLY – OTHER UTILITY	04:52AM	05:54AM	09:28AM	1,152	404
SOUTHEAST	12/27/2007	FAIRVIEW	3	EQUIPMENT FAILURE – APS	10:51PM	11:39PM	12:20AM	1,288	978

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outag
additional information is received. Any revision resulting in a change greater than 10% in customer hours

1/14/200

1000 HOUR CUSTOMER OUTAGE REPORT
(12/24/2007-12/30/2007)

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1/14/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/31/2007-01/06/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	01/01/2008	ENCANTO	5	FOREIGN INTERFERENCE – VANDALISM	12:00AM	01:08AM	07:00AM	1,113	618
SOUTHEAST	01/06/2008	COOLIDGE	1	WEATHER – STORM RELATED	08:32AM	09:21AM	10:37AM	3,820	1,886

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1/23/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(01/07/2008-01/13/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
NORTHEAST	01/07/2008	BLUE RIDGE	12	WEATHER – STORM RELATED	08:03AM	02:04PM	02:04PM	1,655	275
NORTHEAST	01/07/2008	BLUE RIDGE	12	WEATHER – STORM RELATED	08:03AM	03:11PM	03:11PM	2,497	350
NORTHEAST	01/07/2008	KEAMS CANYON	5	WEATHER – STORM RELATED	09:33AM	04:09PM	04:09PM	1,848	280
NORTHEAST	01/07/2008	BLUE RIDGE	12	WEATHER – STORM RELATED	11:01AM	12:17PM	12:17PM	1,716	1,355
NORTHWEST	01/07/2008	WHITE SPAR	12	VEGETATION CONTACT (STORM RELATED)	07:15AM	05:01PM	06:26PM	13,883	1,250
NORTHWEST	01/07/2008	WHITE SPAR	12	EQUIPMENT FAILURE – APS (STORM RELATED)	07:50AM	07:23PM	07:23PM	4,620	400
SOUTHEAST	01/07/2008	PINAL	4	EQUIPMENT FAILURE – APS (STORM RELATED)	10:47PM	12:15AM	03:31AM	2,384	1,300

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1/24/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(01/14/2008-01/21/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	01/19/2008	BUFFALO	2	FOREIGN INTERFERENCE – VEHICLES	07:01PM	07:45PM	08:36PM	1,348	1,746

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(01/21/2008-01/27/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	01/22/2008	JAVELINA	13	UNDERGROUND CABLE	05:40 PM	06:27 PM	07:27 PM	2,949	2,441
METRO	01/24/2008	GLENDALE	17	EQUIPMENT FAILURE – APS (STORM RELATED)	06:22 PM	07:35 PM	12:13 AM	1,558	1,120
METRO	01/26/2008	SPANISH GARDENS	12	UNDERGROUND CABLE	08:23 AM	09:05 AM	10:08 AM	2,125	1,824
METRO	01/27/2008	GLENDALE	2	ENVIRONMENT - FIRE	10:22 AM	10:45 AM	05:45 PM	1,217	2,089
SOUTHEAST	01/27/2008	PINAL	1	EQUIPMENT FAILURE – APS (STORM RELATED)	06:49 PM	08:19 PM	10:53 AM	1,773	1,143

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

2/13/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(01/21/2008-01/27/2008)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	01/22/2008	JAVELINA	13	UNDERGROUND CABLE	05:40 PM	06:27 PM	07:27 PM	2,949	2,441
METRO	01/24/2008	GLENDALE	17	EQUIPMENT FAILURE – APS (STORM RELATED)	06:22 PM	07:35 PM	12:13 AM	1,558	1,120
METRO	01/26/2008	SPANISH GARDENS	12	UNDERGROUND CABLE	08:23 AM	09:05 AM	10:08 AM	2,125	1,824
METRO	01/27/2008	GLENDALE	2	ENVIRONMENT - FIRE	10:22 AM	10:45 AM	05:45 PM	1,217	2,089
SOUTHEAST	01/27/2008	PINAL	1	EQUIPMENT FAILURE – APS (STORM RELATED)	06:49 PM	08:19 PM	10:53 AM	1,773	1,143
SOUTHWEST	01/27/2008	LAGUNA	1	WEATHER – STORM RELATED	12:25AM	05:02AM	05:02AM	6,925	1,500
SOUTHWEST	01/27/2008	COCOPAH	1	WEATHER – STORM RELATED	01:27AM	05:16AM	05:16AM	2,672	700
SOUTHWEST	01/27/2008	MITTRY	1	WEATHER – STORM RELATED	01:12PM	05:04PM	05:04PM	6,589	1,704

2/21/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(01/21/2008-01/27/2008)

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

Highlighted items reflect changes

2/21/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(01/28/2008 - 02/03/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	01/30/2008	MOUNTAIN VIEW	6	EQUIPMENT FAILURE – APS	05:14AM	06:43AM	07:09AM	4,018	1,962
METRO	01/31/2008	DOUBLETREE	2	EQUIPMENT FAILURE –APS	05:36AM	08:15AM	08:15AM	1,150	434
NORTHEAST	01/28/2008	BLUE RIDGE	12	WEATHER – STORM RELATED	08:54AM	10:18AM	10:18AM	1,897	1,355
NORTHEAST	01/28/2008	MAZATZAL TEMP	6	EQUIPMENT FAILURE – APS STORM	09:49AM	06:19PM	06:32PM	7,826	900
NORTHEAST	01/28/2008	BLUE RIDGE	12	WEATHER – STORM	10:33AM	12:48PM	01:10PM	3,379	1,355
NORTHEAST	02/03/2008	WINSLOW	2	WEATHER – STORM	02:03PM	03:07PM	10:22PM	2,068	1,925
NORTHWEST	02/03/2008	YARNELL	4	WEATHER – STORM	08:03PM	02:17PM	02:17PM	4,522	248
SOUTHEAST	02/02/2008	HIDDEN VALLEY	2	LOSS OF SUPPLY – OTHER UTILITY	05:54AM	06:42AM	11:12AM	1,195	481

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

2/20/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(02/04/2008 – 02/10/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	02/09/2008	DURANGO	14	EQUIPMENT FAILURE - APS	09:44PM	10:34PM	12:13AM	1,501	1,329
NORTHEAST	02/04/2008	SHOWLOW	13	EQUIPMENT FAILURE – APS STORM RELATED	01:33AM	07:50AM	07:50AM	1,571	250
NORTHEAST	02/04/2008	SHOWLOW	9	EQUIPMENT FAILURE – APS STORM RELATED	04:51AM	05:33AM	07:51AM	1,426	1,225
NORTHEAST	02/05/2008	WOODRUFF	2	EQUIPMENT FAILURE – APS STORM RELATED	09:29PM	09:32AM	09:32AM	1,506	125
SOUTHEAST	02/09/2008	PINAL	3	FOREIGN INTERFERENCE - BIRDS	07:45AM	08:44AM	10:46AM	1,925	1,941

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

2/20/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(02/11/2008-2/17/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	02/13/2008	COLTER	4	FOREIGN INTERFERENCE-DIG INS CUSTOMER	12:39PM	01:26PM	01:28PM	1,047	1,332
METRO	02/15/2008	WILDFLOWER	10	FOREIGN INTERFERENCE-VANDALISM	07:38PM	08:52PM	08:52PM	1,788	1,450
METRO	02/17/2008	ROSE GARDEN	1	SUBSTATION RELATED	07:24AM	08:35AM	09:05AM	1,051	798
SOUTHWEST	02/14/2008	THIRTY-SECOND ST	5	UNKNOWN OTHER	01:02PM	01:50PM	01:50PM	1,157	1,446

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(02/18/2008-02/24/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count **
METRO	02/20/2008	STAGECOACH	6	EQUIPMENT FAILURE – APS STORM RELATED	09:24PM	10:52PM	04:30AM	3,611	1,190
METRO	02/20/2008	SARIVAL	14	WEATHER – LIGHTNING	10:43PM	06:21AM	11:54AM	1,225	159
NORTHEAST	02/21/2008	SANDVIG	10	EQUIPMENT FAILURE – APS STORM RELATED	09:40AM	10:11AM	04:15PM	6,626	1,200
SOUTHEAST	02/21/2008	EASTGATE	2	SUBSTATION RELATED	08:17AM	10:36AM	10:36AM	2,891	1,248
SOUTHEAST	02/21/2008	EASTGATE	4	SUBSTATION RELATED	08:17AM	07:29AM	08:18AM	1,289	931
SOUTHEAST	02/21/2008	EASTGATE	6	SUBSTATION RELATED	08:17AM	10:30AM	10:30AM	1,977	892
SOUTHEAST	02/21/2008	TOLTEC	5	SUBSTATION RELATED	09:22AM	10:07AM	10:07AM	1,455	1,940
SOUTHEAST	02/21/2008	TOLTEC	6	SUBSTATION RELATED	09:22AM	10:18AM	10:18AM	2,073	2,221

3/6/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(02/18/2008-02/24/2008)

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(02/25/2008 - 03/02/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	02/29/2008	ENCANTO	12	FOREIGN INTERFERENCE – VEHICLES	02:07AM	03:22AM	12:20PM	1,299	887
METRO	03/01/2008	PARADISE	9	FOREIGN INTERFERENCE – VEHICLES	01:32AM	03:15AM	01:06PM	4,842	1,651
METRO	03/01/2008	SHAW	15	FOREIGN INTERFERENCE – VEHICLES	12:33PM	01:04PM	02:53PM	1,740	3,364
METRO	03/02/2008	ROADRUNNER	18	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	08:04AM	09:22AM	12:19PM	1,834	1,406
MORTHEAST	02/26/2008	PREACER CANYON	6	WEATHER – STORM RELATED	07:04AM	10:47AM	10:47AM	6,318	1,700
NORTHWEST	02/26/2008	WHITE SPAR	12	WEATHER – STORM RELATED	05:08AM	07:27AM	07:27AM	1,263	545
SOUTHEAST	03/01/2008	FARELL	6	LOSS OF SUPPLY – OTHER	08:34PM	09:56PM	09:56PM	1,122	821

3/12/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(02/25/2008 - 03/02/2008)

SOUTHWEST	03/02/2008	LAGUNA	5	UNKNOWN OTHER	12:52PM	01:44PM	01:44PM	1,816	2,095

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(03/03/2008 - 03/09/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	03/04/2008	MCCORMICK	5	HUMAN ELEMENT – SWITCHING ERROR	09:08AM	09:41AM	10:31AM	1,103	1,438
METRO	03/05/2008	PEBBLE CREEK	5	EQUIPMENT FAILURE – APS	11:20AM	11:35AM	06:54PM	1,337	877
METRO	03/06/2008	WILDFLOWER	9	EQUIPMENT FAILUE – APS	03:02AM	03:35AM	06:30AM	1,335	1,500
SOUTHWEST	03/08/2008	HAVASU	2	UNKNOWN-OTHER	10:33PM	11:34PM	11:34PM	1,071	1,053

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

3/20/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(03/10/2008 – 03/16/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	03/16/2008	DOVE VALLEY	10	FOREIGN INTERFERENCE – VEHICLES	09:36PM	10:33PM	04:08AM	1,507	1,227

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(03/17/2008-03/23/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

There are no outages to report for this timeframe.

4/14/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(03/24/2008-03/31/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	03/24/2008	PALM VALLEY	2	SUBSTATION RELATED	07:07 PM	08:11 PM	08:11 PM	1,797	1,685
METRO	03/25/2008	ROSE GARDEN	4	FOREIGN INTERFERENCE – DIG-INS CUSTOMER	07:26 AM	08:08 AM	08:10 AM	1,122	1,601
METRO	03/28/2008	GLENDALE	2	FOREIGN INTERFERENCE – VEHICLES	09:48 PM	10:21 PM	04:21 AM	1,587	2,089
METRO	3/30/2008	SHAW	15	FOREGIN INTERFERENCE – VEHICLES	08:41 PM	09:20 PM	03:20 AM	2,307	3,364
NORTHEAST	03/26/2008	KEAMS CANYON	5	UNKNOWN – OTHER	02:00 PM	09:36 PM	09:36 PM	2,128	280
SOUTHEAST	03/29/2008	EASTGATE	4	UNDERGROUND CABLE	06:26 AM	07:03 AM	07:53 AM	1,246	1,227

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

4/14/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(03/31/2008-04/06/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Restoration	Customer Hours off *	Customer Count**
METRO	04/03/2008	STAGECOACH	13	UNKNOWN	09:04PM	09:56PM	11:52PM	1,527	931
METRO	04/05/2008	MEADOWBROOK	22	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	01:58PM	02:00PM	11:28PM	1,443	973

*Individual customer hours may vary as portions of the feeder may be brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on definition of "customer" in A.A.C. R-14-2-201. 9

4/25/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(04/07/2008 - 04/13/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of final Restoration	Customer Hours off *	Customer Count**
METRO	04/07/2008	MEADOWBROOK	6	EQUIPMENT FAILURE – APS	03:15AM	04:14AM	04:14AM	2,098	2,134
METRO	04/11/2008	DYSART	9	FOREIGN INTERFERENCE – DIG-INS CUSTOMER	01:50PM	02:35PM	03:14PM	1,593	1,643
METRO	04/12/2008	GLENDALE	2	EQUIPMENT FAILURE – APS	02:46PM	04:05PM	09:20PM	1,493	1,038
SOUTHEAST	04/12/2008	PICKET	2	EQUIPMENT FAILURE – APS STORM RELATED	06:55AM	08:39AM	09:39PM	1,325	500

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201.9

4/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(04/07/2008 - 04/13/2008)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/07/2008	MEADOWBROOK	6	EQUIPMENT FAILURE – APS	03:15AM	04:14AM	09:47AM	4,816	2,134
METRO	04/11/2008	DYSART	9	FOREIGN INTERFERENCE – DIG-INS CUSTOMER	01:50PM	02:35PM	03:14PM	1,593	1,643
METRO	04/12/2008	GLENDALE	2	EQUIPMENT FAILURE – APS	02:46PM	04:05PM	09:20PM	1,493	1,038
SOUTHEAST	04/12/2008	PICKET	2	EQUIPMETN FAILURE – APS STORM RELATED	06:55AM	08:39AM	09:39PM	1,325	500

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

5/20/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(04/14/2008 - 04/20/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/16/2008	ROADRUNNER	9	WEATHER – WIND	01:17PM	01:48PM	08:29PM	2,218	1,480
METRO	04/16/2008	BUCKEYE	4	EQUIPMENT FAILURE – APS	08:42PM	10:41PM	10:41PM	1,085	547
METRO	04/18/2008	SHERMAN STREET	14	EQUIPMENT FAILURE – APS	02:31AM	3:53AM	03:53AM	1,356	992
METRO	04/19/2008	PARADISE	6	UNDERGROUND CABLE	09:13PM	09:40PM	10:20PM	1,290	1,776

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

5/5/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(04/21/2008 - 04/27/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/24/2008	VALENCIA	1	SUBSTATION RELATED	05:30AM	07:32AM	07:32AM	3,469	1,706
METRO	04/24/2008	VALENCIA	5	SUBSTATION RELATED	05:30AM	08:33AM	08:33AM	5,673	1,860
METRO	04/24/2008	SHAW	13	UNDERGROUND CABLE	03:20AM	04:14AM	04:14AM	2,441	2,712
METRO	04/24/2008	GILA BEND	10	FOREIGN INTERFERENCE – VEHICLES	06:44PM	07:40PM	05:19AM	1,098	606
METRO	04/25/2008	EL SOL	18	UNKNOWN / OTHER	07:36PM	08:27PM	01:45PM	1,236	1,321
SOUTHEAST	04/25/2008	VISTA	6	OVERLOAD – DUE TO SWITCHING	10:10AM	11:49AM	12:07PM	3,054	1,800
SOUTHWEST	04/27/2008	SALOME	3	FOREIGN INTERFERENCE – VEHICLES	09:30AM	02:41PM	02:41PM	2,172	419

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

5/12/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(04/28/2008 - 05/04/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**

There are no outages to report for this timeframe.

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

5/16/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(05/05/2008 - 05/11/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	05/05/2008	TUBA CITY	3	WEATHER – WIND	01:18PM	04:06PM	06:06PM	1,060	250
NORTHEAST	05/06/2008	MOUNT FLOYD	1	SUBSTATION RELATED – STORM	08:07PM	11:08PM	11:08PM	1,991	660
NORTHWEST	05/06/2008	CHINO VALLEY	6	UNKNOWN – OTHER	07:05AM	07:39AM	09:01AM	1,106	1,825

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

5/28/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(05/19/2008-05/25/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/19/2008	SHAW	13	EQUIPMENT FAILURE - APS	12:28PM	12:45PM	01:57PM	2,329	2,712
METRO	05/19/2008	MOON VALLEY	10	OVERLOAD – DUE TO SWITCHING	04:28PM	04:51PM	06:27PM	1,524	2,115
METRO	05/22/2008	STOUT	4	FOREIGN INTERFERENCE – VANDALISM	12:21AM	03:20AM	03:20AM	1,492	500
METRO	05/22/2008	CIELO GRANDE	21	FOREIGN INTERFERENCE – VANDALISM	10:13PM	11:26PM	11:31PM	2,206	1,806
METRO	05/23/2008	GILA BEND	10	EQUIPMENT FAILURE – APS (STORM RELATED)	12:27AM	02:27AM	02:27AM	1,212	606
METRO	05/23/2008	MEADOWBROOK	2	ENVIRONMENT – FIRE	12:41AM	01:18AM	08:00AM	1,463	1,300
METRO	05/23/2008	GRISWOLD	4	ENVIRONMENT – FIRE	02:27AM	02:55AM	11:25AM	1,019	1,546

6/20/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(05/19/2008-05/25/2008)

METRO	05/23/2008	ARROYO	6	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	05:31PM	06:04PM	06:09PM	1,085	1,737
METRO	05/24/2008	CENTURY	17	EQUIPMENT FAILURE – APS	12:24PM	01:18PM	01:18PM	1,046	1,162
METRO	05/24/2008	PEORIA	12	FOREIGN INTERFERENCE – VEHICLES	10:53PM	11:55PM	01:10AM	1,175	855
METRO	05/25/2008	COLDWATER	18	EQUIPMENT FAILURE – APS	08:31PM	02:00AM	02:00AM	1,645	300
NORTHEAST	05/22/2008	PREACHER CANYON	6	VEGETATION CONTACT (STORM RELATED)	12:21PM	03:53PM	03:53PM	1,413	400
NORTHEAST	05/23/2008	MUNDS PARK	5	WEATHER – STORM RELATED	05:06PM	05:50PM	07:45PM	2,787	2,955
NORTHEAST	05/23/2008	MUNDS PARK	5	WEATHER – STORM RELATED	08:20PM	09:08PM	09:08PM	2,364	2,955
NORTHEAST	05/23/2008	MUNDS PARK	5	WEATHER – STORM RELATED	09:09PM	10:18PM	11:48PM	4,519	2,955
NORTHWEST	05/24/2008	YARNELL	4	WEATHER – LIGHTNING	12:03AM	02:41AM	02:41AM	3,160	1,200

1000 HOUR CUSTOMER OUTAGE REPORT
(05/19/2008-05/25/2008)

SOUTHEAST	05/22/2008	FAIRVIEW	4	EQUIPMENT FAILURE – APS (STORM RELATED)	01:15PM	01:26PM	03:58PM	1,717	632
SOUTHEAST	05/22/2008	VISTA	6	EQUIPMENT FAILURE – APS (STORM RELATED)	04:05PM	07:22PM	07:22PM	1,379	420

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(05/26/2008-06/02/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/26/2008	DALE	13	UNDERGROUND CABLE	03:40AM	04:22AM	06:32AM	2,018	1,283
METRO	05/31/2008	COUNTRY CLUB	13	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	02:38PM	03:07PM	03:07PM	1,023	2,117
METRO	06/02/2008	CAVE CREEK	10	FOREIGN INTERFERENCE – VEHICLES	07:17AM	08:41AM	01:15PM	1,525	822
SOUTHEAST	05/30/2008	VISTA	6	FOREIGN INTERFERENCE – VEHICLES	07:47PM	02:14AM	02:14AM	1,290	200

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

6/17/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(06/02/2008-06/08/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/02/2008	CAVE CREEK	10	FOREIGN INTERFERENCE – VEHICLES	07:17AM	08:41AM	01:15PM	1,525	822
METRO	06/03/2008	MEADOWBROOK	9	FOREIGN INTERFERENCE - BIRDS	01:45AM	03:25AM	07:30AM	1,171	671
METRO	06/04/2008	ALTADENA	13	UNDERGROUND CABLE	06:36AM	07:18AM	08:27AM	1,571	1,622
METRO	06/04/2008	INDIAN BEND	9	UNDERGROUND CABLE	07:20AM	07:58AM	07:58AM	1,158	1,828
METRO	06/05/2008	WADDELL TEMPORARY	12	FOREIGN INTERFERENCE – VEHICLES	02:20PM	03:03PM	03:03PM	1,076	1,501
NORTHWEST	06/04/2008	CAPITAL BUTTE	2	UNDERGROUND CABLE	05:01AM	05:57AM	05:57AM	1,249	1,338
SOUTHWEST	06/06/2008	COLORADO	4	UNDERGROUND CABLE	05:52PM	07:19PM	07:19PM	1,169	806

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

6/30/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(06/09/2008 - 06/15/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/09/2008	SURPRISE	4	EQUIPMENT FAILURE – APS	08:13PM	09:20PM	03:46AM	3,310	1,559
METRO	06/11/2008	DESERT SPRINGS	14	UNDERGROUND CABLE	06:09PM	06:59PM	08:03PM	1,837	1,670
METRO	06/11/2008	NORTH VALLEY	10	UNDERGROUND CABLE	09:08PM	11:45PM	11:45PM	1,062	406
METRO	06/14/2008	WESTBROOK	11	UNDERGROUND CABLE	04:46AM	05:33AM	06:22AM	1,889	1,794
SOUTHEAST	06/10/2008	PINAL	4	VEGETATION CONTACT	02:50PM	03:07PM	10:23PM	4,468	2,101
SOUTHWEST	06/14/2008	QUECHAN	18	FOREIGN INTERFERENCE – BIRDS	06:28PM	07:56PM	07:56PM	2,077	1,416

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

7/3/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(06/16/2008 - 06/22/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/19/2008	RIO VISTA	13	EQUIPMENT FAILURE – APS	01:54PM	02:29PM	05:35PM	2,353	2,238
METRO	06/19/2008	GILBERT	6	EQUIPMENT FAILURE – APS	05:36PM	06:35PM	00:23AM	2,596	2,581
METRO	06/20/2008	CACTUS	34	UNDERGROUND CABLE	10:41PM	11:49PM	12:57AM	3,528	2,147
METRO	06/22/2008	STARDUST	4	EQUIPMENT FAILURE – APS	03:14AM	04:19AM	05:29AM	2,056	1,276
NORTHEAST	06/20/2008	PREACHER CANYON	2	SUBSTATION RELATED	05:53AM	06:33AM	06:33AM	1,653	2,480
NORTHEAST	06/20/2008	PREACHER CANYON	6	SUBSTATION RELATED	05:53AM	06:33AM	06:33AM	1,593	2,390
NORTHEAST	06/21/2008	LEROUX	3	WEATHER – LIGHTNING	03:08PM	03:58PM	04:20PM	1,047	1,080
NORTHWEST	06/20/2008	CAPITAL BUTTE	2	UNDERGROUND CABLE	05:29AM	06:20AM	06:20AM	1,615	1,900
SOUTHEAST	06/22/2008	FAIRVIEW	1	LOSS OF SUPPLY – SYS.	02:01PM	06:07PM	06:07PM	1,845	450

7/15/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(06/16/2008 - 06/22/2008)

				DISTURBANCE (STORM)					
SOUTHEAST	06/22/2008	FAIRVIEW	4	LOSS OF SUPPLY – SYS. DISTURBANCE (STORM)	04:43PM	10:16PM	10:16PM	1,665	300

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

7/15/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(06/23/2008-06/29/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/23/2008	GILBERT	6	UNDERGROUND CABLE	04:07PM	05:15PM	08:00PM	4,810	2,581
METRO	06/25/2008	ROADRUNNER	6	EQUIPMENT FAILURE - APS	08:47AM	09:22AM	12:33PM	1,179	935
METRO	06/26/2008	CACTUS	34	UNDERGROUND CABLE	11:38PM	12:07AM	01:47AM	1,945	2,147
METRO	06/29/2008	MEADOWBROOK	2	FOREIGN INTERFERENCE – VEHICLES	04:15AM	05:07AM	10:55AM	1,158	1,828
NORTHWEST	06/26/2008	CHINO VALLEY	6	UNDERGROUND CABLE	10:06PM	06:22AM	06:22AM	1,620	196
SOUTHEAST	06/24/2008	MILLIGAN TEMP	2	UNKNOWN - OTHER	02:46PM	03:23PM	03:58PM	1,346	1,682
SOUTHEAST	06/25/2008	MILLIGAN TEMP	2	WEATHER – STORM RELATED	03:29PM	04:25PM	08:14PM	1,635	1,682

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

7/16/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(06/30/2008 - 07/06/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/01/2008	MCMICKEN	9	EQUIPMENT FAILURE – APS STORM	05:20PM	06:47PM	07:42PM	1,968	1,172
METRO	07/02/2008	FORTIETH PLACE	1	UNDERGROUND CABLE	03:37AM	04:15AM	05:21AM	1,604	1,399
METRO	07/02/2008	STARDUST	6	EQUIMENT FAILURE – APS STORM	08:10PM	09:06PM	10:17PM	1,925	1,555
METRO	07/03/2008	TWENTY-THIRD ST	22	EQUIPMENT FAILURE – APS STORM	10:27PM	12:08AM	12:08AM	4,281	2,543
NORTHEAST	07/03/2008	KACHINA	4	WEATHER – LIGHTNING	12:05PM	01:12PM	04:48PM	1,410	500
NORTHEAST	07/02/2008	KEAMS CANYON	3	EQUIPMENT FAILURE – APS	07:31AM	10:47AM	10:47AM	1,960	600
NORTHEAST	07/06/2008	WOODY MOUNTAIN	10	EQUIPMENT FAILURE – APS STORM	09:37PM	09:40PM	06:10AM	1,778	525

8/5/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(06/30/2008 - 07/06/2008)

SOUTHWEST	06/30/2008	FOOTHILLS	10	UNDERGROUND CABLE	06:43AM	07:43AM	07:43AM	1,511	1,511

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

8/5/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/07/2008 - 07/13/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/02/2008	ORANGEWOOD	22	EQUIPMENT FAILURE – APS STORM	12:23AM	01:05AM	05:35AM	1,495	1,402
METRO	07/09/2008	RAWHIDE	6	FOREIGN INTERFERENCE – BIRDS	03:49AM	04:54AM	07:17AM	2,293	1,632
METRO	07/10/2008	ROADRUNNER	17	EQUIPMENT FAILURE – APS STORM	08:22PM	09:04PM	10:10PM	1,328	1,736
METRO	07/10/2008	MCDOWELL	18	EQUIPMENT FAILURE – APS STORM	09:05PM	12:06AM	12:06AM	1,674	555
METRO	07/10/2008	GREENWAY	2	EQUIPMENT FAILURE – STORM	09:05PM	09:52PM	03:01AM	1,871	1,073
METRO	07/12/2008	TWENTY-THIRD ST	22	EQUIPMENT FAILURE – APS	03:52AM	06:12AM	06:12AM	4,433	1,900
METRO	07/12/2008	SHAW	13	EQUIPMENT FAILURE – APS STORM	11:30AM	11:41AM	06:50PM	1,610	2,712

8/6/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/07/2008 - 07/13/2008)

METRO	07/13/2008	MCCORMICK	10	EQUIPMENT FAILURE – APS	02:09PM	02:36PM	09:33PM	7,168	2,168
METRO	07/13/2008	MARINETTE	21	EQUIPMENT FAILURE – APS STORM	04:02PM	04:37PM	08:29PM	1,475	1,402
METRO	07/13/2008	SHERMAN STREET	17	EQUIPMENT FAILURE – APS STORM	06:29PM	06:47PM	12:15AM	1.464	1.235
NORTHEAST	07/10/2008	MAZATZAL TEMPORARY	6	EQUIPMENT FAILURE – APS STORM	11:17PM	02:46AM	05:58AM	5,951	900
NORTHEAST	07/11/2008	SNOWFLAKE	2	WEATHER – LIGHTNING	10:34PM	05:29AM	05:29AM	6,917	1,000
NORTHEAST	07/11/2008	SHUMWAY	6	EQUIPMENT FAILURE – APS STORM	10:53PM	06:40AM	08:53AM	5,086	544
NORTHWEST	07/08/2008	PRESCOTT CITY	1	UNDERGROUND CABLE	05:59PM	06:54PM	07:22PM	2,306	1,781
NORTHWEST	07/10/2008	KIRKLAND JUNCTION	10	VEGETATION CONTACT – STORM	02:32PM	06:08AM	06:08AM	3,666	235
NORTHWEST	07/10/2008	WHITE SPAR	12	EQUIPMENT FAILURE – APS STORM	05:29PM	04:10AM	04:10AM	13,354	1,250

1000 HOUR CUSTOMER OUTAGE REPORT
(07/07/2008 - 07/13/2008)

NORTHWEST	07/11/2008	WHITE SPAR	12	WEATHER – STORM	11:50AM	02:46PM	02:46PM	3,667	1,250
SOUTHEAST	07/09/2008	BOOTHILL	1	TRANSMISSION RELATED	08:26PM	11:20PM	11:20PM	3,434	1,184
SOUTHWEST	07/07/2008	QUARTSITE	2	WEATHER – STORM	03:15PM	03:57PM	03:57PM	1,156	1,652

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

8/6/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/07/2008 - 07/13/2008)

CORRECTION

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/07/2008	ORANGEWOOD	22	EQUIPMENT FAILURE – APS STORM	12:23AM	01:05AM	05:35AM	1,495	1,402
METRO	07/09/2008	RAWHIDE	6	FOREIGN INTERFERENCE – BIRDS	03:49AM	04:54AM	07:17AM	2,293	1,632
METRO	07/10/2008	ROADRUNNER	17	EQUIPMENT FAILURE – APS STORM	08:22PM	09:04PM	10:10PM	1,328	1,736
METRO	07/10/2008	MCDOWELL	18	EQUIPMENT FAILURE – APS STORM	09:05PM	12:06AM	12:06AM	1,674	555
METRO	07/10/2008	GREENWAY	2	EQUIPMENT FAILURE – STORM	09:05PM	09:52PM	03:01AM	1,871	1,073
METRO	07/12/2008	TWENTY-THIRD ST	22	EQUIPMENT FAILURE – APS	03:52AM	06:12AM	06:12AM	4,433	1,900
METRO	07/12/2008	SHAW	13	EQUIPMENT FAILURE – APS STORM	11:30AM	11:41AM	06:50PM	1,610	2,712

8/21/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/07/2008 - 07/13/2008)

METRO	07/13/2008	MCCORMICK	10	EQUIPMENT FAILURE – APS	02:09PM	02:36PM	09:33PM	7,168	2,168
METRO	07/13/2008	MARINETTE	21	EQUIPMENT FAILURE – APS STORM	04:02PM	04:37PM	08:29PM	1,475	1,402
METRO	07/13/2008	SHERMAN STREET	17	EQUIPMENT FAILURE – APS STORM	06:29PM	06:47PM	12:15AM	1.464	1.235
NORTHEAST	07/10/2008	MAZATZAL TEMPORARY	6	EQUIPMENT FAILURE – APS STORM	11:17PM	02:46AM	05:58AM	5,951	900
NORTHEAST	07/11/2008	SNOWFLAKE	2	WEATHER – LIGHTNING	10:34PM	05:29AM	05:29AM	6,917	1,000
NORTHEAST	07/11/2008	SHUMWAY	6	EQUIPMENT FAILURE – APS STORM	10:53PM	06:40AM	08:53AM	5,086	544
NORTHWEST	07/08/2008	PRESCOTT CITY	1	UNDERGROUND CABLE	05:59PM	06:54PM	07:22PM	2,306	1,781
NORTHWEST	07/10/2008	KIRKLAND JUNCTION	10	VEGETATION CONTACT – STORM	02:32PM	06:08AM	06:08AM	3,666	235
NORTHWEST	07/10/2008	WHITE SPAR	12	EQUIPMENT FAILURE – APS STORM	05:29PM	04:10AM	04:10AM	13,354	1,250

1000 HOUR CUSTOMER OUTAGE REPORT
(07/07/2008 - 07/13/2008)

NORTHWEST	07/11/2008	WHITE SPAR	12	WEATHER – STORM	11:50AM	02:46PM	02:46PM	3,667	1,250
SOUTHEAST	07/09/2008	BOOTHILL	1	TRANSMISSION RELATED	08:26PM	11:20PM	11:20PM	3,434	1,184
SOUTHWEST	07/07/2008	QUARTSITE	2	WEATHER – STORM	03:15PM	03:57PM	03:57PM	1,156	1,652

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

Please note the highlighted section(s) reflect the change(s).

8/21/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/14/2008-07/20/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/14/2008	MCMICKEN	2	WEATHER – STORM RELATED	09:01AM	09:42AM	01:55PM	1,760	1,651
METRO	07/18/2008	WINTERSBURG	12	TRANSMISSION RELATED	06:53PM	08:51PM	08:51PM	2,513	1,278
METRO	07/18/2008	CACTUS	25	UNDERGROUND CABLE	08:05PM	09:21PM	11:05PM	2,466	1,408
METRO	07/20/2008	AJO	1	TRANSMISSION RELATED – (STORM RELATED)	12:35AM	08:29AM	08:29AM	9,559	1,210
METRO	07/20/2008	WHY	1	TRANSMISSION RELATED – (STORM RELATED)	12:35AM	08:29AM	08:29AM	1,059	134
METRO	07/20/2008	INDIAN BEND	1	EQUIPMENT FAILURE – APS (STORM RELATED)	02:30AM	03:05AM	04:00AM	1,367	1,885
METRO	07/20/2008	DEER VALLEY	17	WEATHER – STORM RELATED	02:30AM	03:24AM	03:35AM	1,082	1,042

8/19/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/14/2008-07/20/2008)

METRO	07/20/2008	DEL RIO	1	TRANSMISSION RELATED- (STORM RELATED)	02:53AM	06:29AM	06:29AM	4,043	1,123
METRO	07/20/2008	DEL RIO	2	TRANSMISSION RELATED – (STORM RELATED)	02:53AM	06:29AM	06:29AM	3,262	906
METRO	07/20/2008	PEORIA	10	EQUIPMENT FAILURE – APS (STORM RELATED)	02:53AM	03:50AM	03:50AM	1,221	1,285
METRO	07/20/2008	MARINETTE	10	EQUIPMENT FAILURE – APS (STORM RELATED)	03:18AM	04:32AM	08:30AM	2,231	1,760
NORTHWEST	07/19/2008	QUAIL SPRINGS	2	WEATHER – WIND	06:37PM	07:57PM	08:24AM	63,427	2,873
SOUTHEAST	07/19/2008	SEXTON	8	LOSS OF SUPPLY – OTHER UTILITY	04:10AM	10:10AM	10:10AM	1,350	45
SOUTHEAST	07/19/2008	SAN MANUEL	29	WEATHER – LIGHTNING	06:18PM	07:14PM	08:52PM	2,375	1,478

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

8/19/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/14/2008-07/20/2008)

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

8/19/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/14/2008-07/20/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/14/2008	MCMICKEN	2	WEATHER – STORM RELATED	09:01AM	09:42AM	01:55PM	1,760	1,651
METRO	07/18/2008	WINTERSBURG	12	TRANSMISSION RELATED	06:53PM	08:51PM	08:51PM	2,513	1,278
METRO	07/18/2008	CACTUS	25	UNDERGROUND CABLE	08:05PM	09:21PM	11:05PM	2,466	1,408
METRO	07/20/2008	AJO	1	TRANSMISSION RELATED – (STORM RELATED)	12:35AM	08:29AM	08:29AM	9,559	1,210
METRO	07/20/2008	WHY	1	TRANSMISSION RELATED – (STORM RELATED)	12:35AM	08:29AM	08:29AM	1,059	134
METRO	07/20/2008	INDIAN BEND	1	EQUIPMENT FAILURE – APS (STORM RELATED)	02:30AM	03:05AM	04:00AM	1,367	1,885
METRO	07/20/2008	DEER VALLEY	17	WEATHER – STORM RELATED	02:30AM	03:24AM	03:35AM	1,082	1,042

1000 HOUR CUSTOMER OUTAGE REPORT
(07/14/2008-07/20/2008)
REVISED

METRO	07/20/2008	DEL RIO	1	TRANSMISSION RELATED-(STORM RELATED)	02:53AM	06:29AM	06:29AM	4,043	1,123
METRO	07/20/2008	DEL RIO	2	TRANSMISSION RELATED – (STORM RELATED)	02:53AM	06:29AM	06:29AM	3,262	906
METRO	07/20/2008	PEORIA	10	EQUIPMENT FAILURE – APS (STORM RELATED)	02:53AM	03:50AM	03:50AM	1,221	1,285
METRO	07/20/2008	MARINETTE	10	EQUIPMENT FAILURE – APS (STORM RELATED)	03:18AM	04:32AM	08:30AM	2,231	1,760
NORTHWEST	07/19/2008	QUAIL SPRINGS	2	WEATHER – WIND	06:37PM	07:57PM	08:24AM	63,427	2,873
SOUTHEAST	07/19/2008	SEXTON	8	LOSS OF SUPPLY – OTHER UTILITY	04:10AM	10:10AM	10:10AM	1,350	45
SOUTHEAST	07/19/2008	SAN MANUEL	29	WEATHER – LIGHTNING	06:18PM	07:14PM	08:52PM	2,375	1,478

1000 HOUR CUSTOMER OUTAGE REPORT
(07/14/2008-07/20/2008)
REVISED

SOUTHEAST	07/19/2008	SAGUARO	13	WEATHER - LIGHTNING	08:55PM	10:31PM	11:28PM	1,181	549

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

The highlighted item(s) reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(07/21/2008-07/27/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/24/2008	ROCK SPRINGS	3	EQUIPMENT FAILURE - APS	01:33PM	02:46PM	04:25PM	1,862	1,524
NORTHEAST	07/22/2008	SANDVIG	10	WEATHER – LIGHTNING	04:04PM	06:14PM	06:14PM	1,192	550
NORTHEAST	07/23/2008	SNOWFLAKE	14	WEATHER – STORM RELATED	06:37PM	07:18PM	07:18PM	1,052	1,540
NORTHEAST	07/26/2008	LEROUX	3	WEATHER- STORM RELATED	04:02PM	04:30PM	10:20PM	2,837	1,080

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

8/19/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(07/28/2008 - 08/03/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/30/2008	PEORIA	2	FOREIGN INTERFERENCE – VEHICLES	12:58PM	01:37PM	07:27PM	3,839	1,113
METRO	08/01/2008	HAPPY VALLEY TEMPORARY	4	EQUIPMENT FAILURE – APS	08:14PM	08:54PM	09:29PM	1,306	1,147
NORTHWEST	07/31/2008	CORDES	2	EQUIPMENT FAILURE – APS STORM	10:07AM	05:25PM	05:25PM	2,336	320
NORTHWEST	08/03/2008	WHITE SPAR	2	WEATHER – STORM	04:00PM	09:28PM	09:28PM	8,747	1,600
SOUTHEAST	08/03/2008	FAIRVIEW	1	EQUIPMENT FAILURE – APS STORM	05:21PM	05:40PM	10:07PM	1,171	2,249

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

8/22/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/05/08	SUNNYSLOPE	21	EQUIPMENT FAILURE-APS (STORM RELATED)	08:42PM	12:18AM	03:39AM	7,759	1,876
METRO	08/05/08	SUNNYSLOPE	9	EQUIPMENT FAILURE-APS (STORM RELATED)	08:52PM	06:30AM	06:30AM	1,474	153
METRO	08/05/08	TWENTY-THIRD ST	21	WEATHER-STORM RELATED	09:29PM	11:52PM	11:52PM	3,451	1,448
METRO	08/05/08	MEADOWBROOK	6	EQUIPMENT FAILURE-APS (STORM RELATED)	09:45PM	11:13PM	03:02AM	5,371	2,189
METRO	08/05/08	INDIAN BEND	1	WEATHER-STORM RELATED	11:01PM	11:52PM	07:00AM	2,012	1,885
METRO	08/06/08	TONOPAH	1	EQUIPMENT FAILURE-APS (STORM RELATED)	07:07PM	08:26PM	08:08AM	1.276	583
METRO	08/07/08	ARLINGTON	3	TRANSMISSION RELATED (STORM	07:59PM	11:28PM	11:28PM	1,658	476

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)

				RELATED)					
METRO	08/07/08	GILLESPIE	2	WEATHER-STORM RELATED	08:00PM	06:14PM	06:14PM	2,358	51
METRO	08/07/08	JACKSON STREET	13	WEATHER-STORM RELATED	08:27PM	12:39AM	12:39AM	1,033	246
METRO	08/07/08	BASELINE	12	WEATHER-STORM RELATED	08:28PM	11:38AM	11:38AM	8,691	573
METRO	08/07/08	BASELINE	1	EQUIPMENT FAILURE–APS (STORM RELATED)	08:34PM	03:58AM	04:47PM	2,852	336
METRO	08/07/08	BASELINE	3	TRANSMISSION RELATED (STORM RELATED)	08:34PM	01:16PM	01:16PM	11,905	184
METRO	08/07/08	PERRYVILLE	5	TRANSMISSION RELATED (STORM RELATED)	08:34PM	10:36PM	10:36PM	1,104	543
METRO	08/07/08	VALENCIA	1	TRANSMISSION RELATED (STORM RELATED)	08:34PM	11:16PM	11:16PM	4,606	1,706

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)

METRO	08/07/08	VALENCIA	5	TRANSMISSION RELATED (STORM RELATED)	08:34PM	11:16PM	11:16PM	5,022	1,860
METRO	08/07/08	VALENCIA	12	TRANSMISSION RELATED (STORM RELATED)	08:34PM	11:16PM	11:16PM	1,593	590
METRO	08/07/08	FILLMORE	4	WEATHER-STORM RELATED	08:35PM	11:45PM	11:45PM	4,133	1,305
METRO	08/07/08	PERRYVILLE	5	WEATHER-STORM RELATED	08:38PM	10:38PM	10:38PM	1,086	543
METRO	08/07/08	VALENCIA	12	WEATHER-STORM RELATED	08:38PM	11:23PM	11:23PM	1,623	590
METRO	08/07/08	TEMPE	22	WEATHER-STORM RELATED	08:39PM	10:53PM	10:53PM	1,664	745
METRO	08/07/08	GRISWOLD	4	WEATHER-STORM RELATED	08:40PM	12:03AM	12:03AM	5,231	1,546
METRO	08/07/08	MCDOWELL	18	WEATHER-STORM RELATED	08:42PM	10:44PM	10:44PM	1,129	555
METRO	08/07/08	SHAW	15	WEATHER-STORM RELATED	08:47PM	09:09PM	09:09PM	1,274	3,475

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)

METRO	08/07/08	BUTTE	22	WEATHER-STORM RELATED	08:52PM	09:52PM	09:52PM	2,069	2,069
METRO	08/07/08	LOMA VISTA	22	WEATHER-STORM RELATED	08:54PM	10:29PM	10:29PM	1,688	1,066
METRO	08/07/08	RIO VITSA	13	WEATHER-STORM RELATED	08:58PM	10:14PM	11:16PM	3,445	2,238
METRO	08/07/08	ORANGEWOOD	12	WEATHER-STORM RELATED	09:10PM	12:58AM	12:58AM	2,356	620
METRO	08/07/08	ORANGEWOOD	14	WEATHER-STORM RELATED	09:17PM	10:25PM	10:25PM	1,384	1,221
METRO	08/07/08	ORANGEWOOD	13	WEATHER-STORM RELATED	09:19PM	01:37AM	01:37AM	2,778	646
METRO	08/07/08	ORANGEWOOD	33	WEATHER-STORM RELATED	09:29PM	02:31AM	02:31AM	10,857	2,157
METRO	08/07/08	GLENDALE	17	WEATHER-STORM RELATED	09:37PM	07:15AM	07:15AM	1,445	150
METRO	08/07/08	BUTTE	22	WEATHER-STORM RELATED	10:08PM	06:33AM	06:33AM	17,414	2,069
METRO	08/07/08	SUNNYSLOPE	18	WEATHER-STORM RELATED	10:10PM	12:46AM	12:46AM	4,378	1,684

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)

METRO	08/07/08	COUNTRY CLUB	13	WEATHER-STORM RELATED	10:13PM	02:54AM	02:54AM	9,915	2,117
METRO	08/07/08	ORANGEWOOD	32	WEATHER-STORM RELATED	11:43PM	03:19AM	03:19AM	4,561	1,267
METRO	08/09/08	AZTEC	10	TRANSMISSION RELATED (STORM RELATED)	07:13PM	10:17AM	10:17AM	3,164	210
METRO	08/09/08	HYDER	1	TRANSMISSION RELATED (STORM RELATED)	07:13PM	07:17PM	07:17PM	1,059	44
METRO	08/09/08	HYDER	3	TRANSMISSION RELATED (STORM RELATED)	07:13PM	07:17PM	07:17PM	2,262	94
NORTHEAST	08/05/08	SANDVIG	10	WEATHER-LIGHTNING	01:38PM	03:03PM	03:58PM	1,237	550
NORTHEAST	08/05/08	LEROUX	3	WEATHER-LIGHTNING	10:27PM	12:06AM	12:06AM	1,782	1,080
NORTHEAST	08/07/08	WINSLOW	2	WEATHER-STORM RELATED	02:41PM	05:10PM	07:37PM	4,990	1,960

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)

NORTHWEST	08/05/08	DEWEY	14	WEATHER-LIGHTNING	03:55PM	07:14PM	07:14PM	1,111	335
NORTHWEST	08/09/08	CORDES	2	EQUIPMENT FAILURE-APS (STORM RELATED)	11:25AM	12:37PM	02:08PM	1,495	1,175
NORTHWEST	08/09/08	BALD MOUNTAIN	1	EQUIPMENT FAILURE-APS (STORM RELATED)	01:4.3PM	3:20PM	03:20PM	2,344	1,450
SOUTHWEST	08/07/08	SAN LUIS	10	TRANSMISSION RELATED (STORM RELATED)	04:22PM	11:36PM	11:36PM	9,859	1,363
SOUTHWEST	08/07/08	SAN LUIS	2	WEATHER-STORM RELATED	04:28PM	09:04PM	09:04PM	11,905	2,588
SOUTHWEST	08/07/08	SAN LUIS	14	WEATHER-STORM RELATED	05:04PM	12:58AM	12:58AM	7,552	956
SOUTHWEST	08/07/08	SAN LUIS	2	TRANSMISSION RELATED (STORM RELATED)	09:08PM	10:18PM	10:18PM	3,019	2,588
SOUTHWEST	08/08/08	SAN LUIS	14	TRANSMISSION RELATED (STORM RELATED)	01:10AM	08:01AM	08:01AM	6,549	956

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)

SOUTHWEST	08/08/08	LAGUNA	9	WEATHER-STORM RELATED	07:39AM	09:03AM	09:03AM	1,751	1,251

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

9/12/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/05/08	SUNNYSLOPE	21	EQUIPMENT FAILURE-APS STORM RELATE	08:42PM	12:18AM	03:39AM	7,759	1,876
METRO	08/05/08	SUNNYSLOPE	9	EQUIPMENT FAILURE-APS STORM RELATED	08:52PM	06:30AM	06:30AM	1,474	153
METRO	08/05/08	TWENTY-THIRD ST	21	EQUIPMENT FAILURE-APS STORM RELATED	09:29PM	11:39PM	11:52PM	3,294	1,448
METRO	08/05/08	MEADOWBROOK	6	EQUIPMENT FAILURE-APS STORM RELATED	09:45PM	11:13PM	03:02AM	5,371	2,189
METRO	08/05/08	INDIAN BEND	1	WEATHER - LIGHTNING	11:01PM	11:52PM	07:00AM	2,012	1,885
METRO	08/06/08	TONOPAH	1	EQUIPMENT FAILURE-APS STORM RELATED	07:07PM	08:26PM	08:08AM	1.276	583
METRO	08/07/08	ARLINGTON	3	TRANSMISSION RELATED STORM RELATED	07:59PM	11:28PM	11:28PM	1,658	476

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)
REVISED

METRO	08/07/08	GILLESPIE	2	TRANSMISSION RELATED-STORM RELATED	08:00PM	06:14PM	06:14PM	2,358	51
METRO	08/07/08	JACKSON STREET	13	WEATHER-STORM RELATED	08:27PM	12:39AM	01:12AM	1,081	246
METRO	08/07/08	BASELINE	12	TRANSMISSION RELATED-STORM RELATED	08:28PM	11:38AM	11:38AM	8,691	573
METRO	08/07/08	BASELINE	1	TRANSMISSION RELATED–APS STORM RELATED	08:34PM	03:58AM	04:47PM	2,852	336
METRO	08/07/08	BASELINE	3	TRANSMISSION RELATED STORM RELATED	08:34PM	01:16PM	01:16PM	11,905	184
METRO	08/07/08	PERRYVILLE	5	TRANSMISSION RELATED STORM RELATED	08:34PM	10:36PM	10:36PM	1,104	543
METRO	08/07/08	VALENCIA	1	TRANSMISSION RELATED STORM RELATED	08:34PM	11:16PM	11:16PM	4,606	1,706
METRO	08/07/08	VALENCIA	5	TRANSMISSION RELATED STORM RELATED	08:34PM	11:16PM	11:16PM	5,022	1,860
METRO	08/07/08	PERRYVILLE	5	WEATHER-STORM RELATED	08:38PM	10:38PM	10:38PM	1,086	543

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)
REVISED

METRO	08/07/08	VALENCIA	12	WEATHER-STORM RELATED	08:38PM	11:23PM	11:23PM	1,623	590
METRO	08/07/08	TEMPE	22	FOREIGN INTERFERENCE – VANDALISM	08:39PM	10:53PM	06:31AM	3,084	745
METRO	08/07/08	GRISWOLD	4	EQUIPMENT FAILURE – APS STORM RELATED	08:40PM	12:03AM	12:03AM	5,231	1,546
METRO	08/07/08	MCDOWELL	18	WEATHER-STORM RELATED	08:42PM	10:44PM	11:01PM	1,192	555
METRO	08/07/08	SHAW	15	WEATHER-STORM RELATED	08:47PM	09:09PM	06:09AM	1,321	3,475
METRO	08/07/08	RIO VITSA	13	WEATHER-STORM RELATED	08:58PM	10:14PM	11:16PM	3,445	2,238
METRO	08/07/08	CHAPARRAL	6	VEGETATION CONTACT STORM RELATED	08:59PM	03:19AM	03:19AM	1,609	254
METRO	08/07/08	ORANGEWOOD	12	EQUIPMENT FAILURE – APS STORM RELATED	09:10PM	12:58AM	12:58AM	2,356	620
METRO	08/07/08	ORANGEWOOD	13	WEATHER-STORM RELATED	09:19PM	00:35AM	04:20AM	3,311	646

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)
REVISED

METRO	08/07/08	ORANGEWOOD	33	EQUIPMENT FAILURE – APS STORM RELATED	09:29PM	02:31AM	02:31AM	10,857	2,157
METRO	08/07/08	GLENDALE	17	EQUIPMENT FAILURE – APS STORM RELATED	09:37PM	07:15AM	07:15AM	1,445	150
METRO	08/07/08	BUTTE	22	EQUIPMENT FAILURE – APS STORM RELATED	10:08PM	11:54PM	02:45AM	7,139	2,069
METRO	08/07/08	BUTTE	22	EQUIPMENT FAILURE – APS STORM RELATED	10:08PM	11:54PM	02:45AM	7,139	1,858
METRO	08/07/08	SUNNYSLOPE	18	VEGETATION CONTACT – STORM RELATED	10:10PM	12:46AM	02:22AM	6,316	1,684
METRO	08/07/08	COUNTRY CLUB	13	EQUIPMENT FAILURE – APS STORM RELATED	10:13PM	02:04AM	02:54AM	8,459	2,117
METRO	08/07/08	ORANGEWOOD	32	EQUIPMENT FAILURE – APS STORM RELATED	11:43PM	03:19AM	06:09AM	4,595	1,267
METRO	08/09/08	AZTEC	10	TRANSMISSION RELATED STORM RELATED	07:13PM	10:17AM	10:17AM	3,164	210

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)
REVISED

METRO	08/09/08	HYDER	1	TRANSMISSION RELATED STORM RELATED	07:13PM	07:17PM	07:17PM	1,059	44
METRO	08/09/08	HYDER	3	TRANSMISSION RELATED STORM RELATED	07:13PM	07:17PM	07:17PM	2,262	94
NORTHEAST	08/05/08	SANDVIG	10	EQUIPMENT FAILURE-APS STORM RELATED	01:38PM	03:03PM	03:58PM	1,237	550
NORTHEAST	08/05/08	LEROUX	3	EQUIPMENT FAILURE-APS STORM RELATED	10:27PM	12:06AM	12:06AM	1,782	1,080
NORTHEAST	08/07/08	WINSLOW	2	WEATHER-STORM RELATED	02:41PM	05:10PM	07:37PM	4,990	1,960
NORTHWEST	08/05/08	DEWEY	14	EQUIPMENT FAILURE-APS STORM RELATED	03:55PM	07:14PM	07:14PM	1,111	335
NORTHWEST	08/09/08	CORDES	2	EQUIPMENT FAILURE-APS STORM RELATED	11:25AM	12:37PM	02:08PM	1,495	1,175
NORTHWEST	08/09/08	BALD MOUNTAIN	1	VEGETATION CONTACT – STORM RELATED	01:4.3PM	3:20PM	03:20PM	2,344	1,450

1000 HOUR CUSTOMER OUTAGE REPORT
(08/04/2008 - 08/10/2008)
REVISED

SOUTHWEST	08/07/08	SAN LUIS	10	TRANSMISSION RELATED STORM RELATED	04:22PM	11:36PM	11:36PM	9,859	1,363
SOUTHWEST	08/07/08	SAN LUIS	2	WEATHER-STORM RELATED	04:28PM	09:04PM	09:04PM	11,905	2,588
SOUTHWEST	08/07/08	SAN LUIS	14	TRANSMISSION RELATED STORM RELATED	05:04PM	12:58AM	12:58AM	7,552	956
SOUTHWEST	08/07/08	SAN LUIS	2	TRANSMISSION RELATED STORM RELATED	09:08PM	10:18PM	10:18PM	3,019	2,588
SOUTHWEST	08/08/08	SAN LUIS	14	TRANSMISSION RELATED STORM RELATED	01:10AM	08:01AM	08:01AM	6,549	956
SOUTHWEST	08/08/08	LAGUNA	9	WEATHER-STORM RELATED	07:39AM	09:03AM	09:03AM	1,751	1,251

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

The highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(08/11/2008 - 08/17/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/14/2008	COLDWATER	21	EQUIPMENT FAILURE – APS STORM	08:25PM	02:07AM	08:05AM	1,531	232
METRO	08/17/2008	ORANGEWOOD	32	UNDERGROUND CABLE	02:51AM	03:33AM	04:59AM	1,330	1,267
METRO	08/17/2008	DESERT SPRINGS	5	UNDERGROUND CABLE	06:16AM	06:50AM	07:19AM	1,345	1,867
METRO	08/17/2008	COLDWATER	18	EQUIPMENT FAILURE – APS	07:24AM	12:50PM	12:50PM	1,299	239
NORTHEAST	08/13/2008	RED LAKE	2	TRANSMISSION RELATED	06:13PM	08:06PM	08:06PM	1,111	590
NORTHWEST	08/14/2008	CHINO VALLEY	14	WEATHER – STORM RELATED	03:50PM	09:13PM	09:13PM	1,346	250
SOUTHEAST	08/12/2008	PINAL	4	EQUIPMENT FAILURE – APS	09:59AM	01:17PM	05:29PM	1,423	421
SOUTHEAST	08/16/2008	TOLTEC	4	EQUIPMENT FAILURE – APS STORM	09:15PM	12:02AM	12:02AM	1,506	541

9/23/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(08/11/2008 - 08/17/2008)

SOUTHEAST	08/16/2008	MURAL	2	WEATHER – STORM	10:44PM	11:54PM	11:54PM	1,944	1,666
SOUTHEAST	08/17/2008	MURAL	2	EQUIPMENT FAILURE – APS STORM	12:12AM	12:34AM	10:45AM	4,019	1,666

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(08/18/2008 - 08/24/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/22/2008	MCDOWELL	20	EQUIPMENT FAILURE – APS	07:07PM	08:05PM	08:53PM	1,923	1,888
METRO	08/23/2008	TWENTY-THIRD ST	22	FOREIGN INTERFERENCE – BIRDS	09:46AM	10:10AM	11:48AM	1,058	2,543
METRO	08/24/2008	WESTWING	17	EQUIPMENT FAILURE – APS	01:28AM	02:42AM	05:46AM	1,674	1,255
METRO	08/24/2008	STARDUST	6	EQUIPMENT FAILURE – APS	01:28AM	02:29AM	02:29AM	1,581	1,555
NORTHEAST	08/20/2008	ASHFORK	10	EQUIPMENT FAILURE – APS STORM	01:22PM	02:38PM	03:12PM	1,899	1,410
NORTHEAST	08/23/2008	SWITZER CANYON	13	UNDERGROUND CABLE	01:07AM	02:36AM	03:57AM	13,148	5,535
NORTHWEST	08/18/2008	COPPER CANYON	6	EQUIPMENT FAILURE – APS STORM	05:10PM	09:02PM	09:02PM	1,029	266
SOUTHEAST	08/21/2008	SAN MANUEL	29	EQUIPMENT FAILURE – APS	02:51PM	04:42PM	05:28PM	3,525	1,460

9/23/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(08/18/2008 - 08/24/2008)

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

9/23/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/25/2008	GLENDALE	6	EQUIPMENT FAILURE- APS	04:25PM	05:05PM	09:50PM	1,758	1,029
METRO	08/25/2008	WINTERSBURG	12	WEATHER-STORM RELATED	06:36PM	08:05PM	08:05PM	1,896	1,278
METRO	08/25/2008	SUNNYSLOPE	12	EQUIPMENT FAILURE – APS	08:43PM	09:09PM	10:11PM	2,279	1,876
METRO	08/26/2008	ALTADENA	13	EQUIPMENT FAILURE- APS	12:16AM	01:18AM	02:13AM	2,378	1,622
METRO	08/26/2008	MOON VALLEY	6	WEATHER-STORM RELATED	12:27AM	01:18AM	02:13AM	2,086	1,784
METRO	08/26/2008	DALE	5	WEATHER-STORM RELATED	05:31AM	06:34AM	07:42AM	1,899	1,240
METRO	08/27/2008	CANAL	13	UNDERGROUND CABLE	10:56PM	02:45AM	03:55AM	1,027	269
METRO	08/28/2008	JAVELINA	13	EQUIPMENT FAILURE- APS	07:49AM	08:14AM	09:09AM	1,680	1,983

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/28/2008	RAINBOW VALLEY	5	EQUIPMENT FAILURE- APS	09:32PM	08:50PM	08:50PM	6,004	63
METRO	08/28/2008	BUTTE	17	WEATHER- STORM RELATED	09:34PM	02:25AM	02:25AM	5,854	1,207
METRO	08/28/2008	CAMELBACK	12	WEATHER- STORM RELATED	09:35PM	12:05AM	12:05AM	1,605	642
METRO	08/28/2008	TEMPE	18	EQUIPMNT FAILURE- APS	09:36PM	01:03AM	01:03AM	7,835	2,271
METRO	08/28/2008	TEMPE	14	EQUIPMENT FAILURE- APS	09:37PM	01:11AM	01:11AM	10,579	2,966
METRO	08/28/2008	TWENTY-THIRD ST	21	EQUIPMENT FAILURE- APS	09:38PM	05:16AM	05:16AM	11,053	1,448
METRO	08/28/2008	TWENTY-THIRD ST	22	EQUIPMENT FAILURE-APS	09:39PM	04:07AM	05:10PM	16,552	2,543
METRO	08/28/2008	JACKSON STREET	22	WEATHER- STORM RELATED	09:39PM	11:58AM	11:58AM	6,629	463
METRO	08/28/2008	TWENTY-THIRD ST	14	WEATHER- STORM RELATED	09:40PM	06:03AM	06:03AM	14,386	1,716
METRO	08/28/2008	METRO	5	WEATHER- STORM RELATED	09:41PM	06:38AM	06:38AM	1,414	158

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/28/2008	LINCOLN STREET WEST	17	EQUIPMENT FAILURE- APS	09:41PM	06:56AM	06:56AM	3,349	362
METRO	08/28/2008	MEADOWBROOK	14	EQUIPMENT FAILURE- APS	09:42PM	03:35AM	3:50PM 8/29	8,863	1,077
METRO	08/28/2008	TEMPE	22	WEATHER- STORM RELATED	09:43PM	01:22AM	01:22AM	2,719	745
METRO	08/28/2008	ORANGEWOOD	9	WEATHER- STORM RELATED	09:43PM	09:50PM	09:50PM	35,861	1,487
METRO	08/28/2008	SHERMAN STREET	14	EQUIPMENT FAILURE- APS	09:43PM	04:20AM	04:28AM	6,583	992
METRO	08/28/2008	INDIANOLA	15	WEATHER- STORM RELATED	09:43PM	04:28AM	04:28AM	4,752	704
METRO	08/28/2008	ORANGEWOOD	17	WEATHER- STORM RELATED	09:44PM	11:02AM	11:02AM	14,032	1,055
METRO	08/28/2008	ENCANTO	10	EQUIPMENT FAILURE-APS	09:44PM	01:59AM	09:47AM	3,261	749
METRO	08/28/2008	ENCANTO	5	WEATHER- STORM RELATED	09:45PM	07:31AM	07:31AM	6,182	633
METRO	08/28/2008	ENCANTO	4	EQUIPMENT FAILURE-APS	09:45PM	03:55AM	04:34AM	1,985	295

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/28/2008	SHAW	15	WEATHER-STORM RELATED	09:47PM	09:56AM	09:56AM	42,221	3,475
METRO	08/28/2008	TURF	10	WEATHER-STORM RELATED	09:52PM	07:09AM	07:09AM	6,433	693
METRO	08/28/2008	COUNTRY CLUB	30	WEATHER-STORM REALTED	09:55PM	05:32AM	06:25AM	1,777	225
METRO	08/28/2008	MEADOWBROOK	13	EQUIPMENT FAILURE-APS	09:56PM	12:23AM	12:52AM	2,916	1,043
METRO	08/28/2008	COUNTY CLUB	13	WEATHER-STORM RELATED	09:57PM	01:21AM	02:36AM 8/29	7,259	2,117
METRO	08/28/2008	COUNTY CLUB	18	WEATHER-STORM RELATED	09:57PM	06:45PM	06:45PM 8/30	12,634	282
METRO	08/28/2008	COUNTY CLUB	27	WEATHER STORM RELATED	09:57PM	11:57AM	11:57AM	2,520	180
METRO	08/28/2008	COU NTRY CLUB	29	WEATHER STORM RELATED	09:57PM	09:21AM	09:21AM	5,791	508
METRO	08/28/2008	COUNTRY CLUB	21	WEATHER STORM RELATED	09:57PM	01:11PM	01:11PM	21,220	1,393
METRO	08/28/2008	COUNTRY CLUB	22	WEATHER-STORM RELATED	09:58PM	09:24AM	09:24AM 9/01	53,815	645

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/28/2008	GARFIELD	3	WEATHER-STORM RELATED	09:58PM	06:58AM	06:58AM	2,628	292
METRO	08/28/2008	FILLMORE	4	EQUIPMENT FAILURE-APS	09:58PM	07:54AM	07:54AM	12,963	1,305
METRO	08/28/2008	ENCANTO	9	EQUIPMENT FAILURE-APS	09:58PM	10:21AM	07:40AM 8/30	15,654	1,178
METRO	08/28/2008	MCDOWELL	9	EQUIPMENT FAILURE-APS	10:00PM	06:41AM	01:52PM 8/30	2,648	252
METRO	08/28/2008	FILLMORE	19	EQUIPMENT FAILURE-APS	10:03PM	08:46AM	02:17PM 8/29	15,181	1,363
METRO	08/28/2008	LITCHFIELD	10	WEATHER-STORM RELATED	10:03PM	12:01AM	12:01AM	1,674	851
METRO	08/28/2008	COLDWATER	18	WEATHER-STORM RELATED	10:03PM	12:22AM	06:10AM	5,444	1,860
METRO	08/28/2008	MEADOWBROOK	5	EQUIPMENT FAILURE-APS	10:03PM	03:36AM	07:12PM 8/30	3,195	326
METRO	08/28/2008	ORANGEWOOD	12	WEATHER-STORM RELATED	10:05PM	02:21PM	02:21PM	10,085	620
METRO	08/28/2008	TUTHILL	4	WEATHER-STORM RELATED	10:17PM	12:48AM	12:48AM	2,534	1,007

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/28/2008	PALOMA	1	EQUIPMENT FAILURE-APS	10:27PM	01:20AM	02:37PM 8/31	1,731	69
METRO	08/28/2008	MUMMY MOUNTAIN	8	WEATHER-STORM RELATED	11:16PM	01:47AM	01:47PM 8/30	1,405	53
METRO	08/28/2008	VARNEY	1	EQUIPMENT FAILURE-APS	11:23PM	04:43AM	04:43AM	4,619	866
METRO	08/28/2008	ROADRUNNER	9	EQUIPMENT FAILURE-APS	11:29PM	02:49AM	06:51PM	12,094	1,480
METRO	08/28/2008	ROADRUNNER	18	EQUIPMENT FAILURE-APS	11:29PM	02:02AM	05:41PM	5,535	1,654
METRO	08/28/2008	INDIAN BEND	9	EQUIPMENT FAILURE-APS	11:29PM	02:12AM	02:30AM 8/30	10,750	1,828
METRO	08/28/2008	ROADRUNNER	17	EQUIPMENT FAILURE-APS	11:29PM	04:40AM	01:10PM 8/30	10,023	1,736
METRO	08/28/2008	ROADRUNNER	6	EQUIPMENT FAILURE-APS	11:05PM	04:49AM	12:02PM 8/29	9,821	935
METRO	08/28/2008	ORANGEWOOD	22	VEGETATION CONTACT	11:35PM	03:21AM	10:00PM	20,201	1,402
METRO	08/28/2008	SUNNYSLOPE	21	EQUIPMENT FAILURE-APS STORM RELATED	11:36PM	04:06AM	04:06AM	8,442	1,876

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/28/2008	SUNNYSLOPE	9	EQUIPMENT FAILURE-APS STORM RELATED	11:37PM	02:56AM	09:10PM	8,004	2,202
METRO	08/28/2008	MEADOWBROOK	21	WEATHER-STORM RELATED	11:39PM	01:31PM	06:45PM	12,687	772
METRO	08/28/2008	GRISWOLD	4	EQUIPMENT FAILURE-APS	11:40PM	03:56PM	01:29PM 8/30	25,579	1,546
METRO	08/28/2008	ORANGEWOOD	8	EQUIPMENT FAILURE-APS STORM RELATED	11:40PM	01:23AM	10:10AM	12,436	1,758
METRO	08/28/2008	MEADOWBROOK	2	WEATHER-STORM RELATED	11:41PM	01:38AM	01:38AM	2,527	1,296
METRO	08/28/2008	ORANGEWOOD	13	WEATHER-STORM RELATED	11:42PM	02:19PM	02:19PM	9,442	646
METRO	08/28/2008	MEADOWBROOK	1	WEATHER-STORM RELATED	11:42PM	04:09PM	05:13PM	26,559	1,558
METRO	08/28/2008	INDIANOLA	32	WEATHER-STORM RELATED	11:46PM	03:38AM	03:38AM	1,365	353
METRO	08/28/2008	ENCANTO	12	WEATHER-STORM RELATED	11:48PM	07:18AM	07:18AM	7,005	934
METRO	08/29/2008	PALM VALLEY	1	WEATHER-STORM RELATED	12:23AM	01:20AM	12:00PM	2,454	1,104

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/29/2008	CAVE CREEK	14	EQUIPMENT FAILURE-APS	01:01AM	01:32PM	01:32PM	2,793	75
METRO	08/29/2008	FORTIETH PLACE	1	EQUIPMENT FAILURE-APS	01:46AM	02:02AM	05:50PM	3,119	1,399
METRO	08/29/2008	ROADRUNNER	18	EQUIPMENT FAILURE-APS	11:29AM	02:02AM	05:41PM	6,417	1,040
METRO	08/29/2008	ORANGEWOOD	17	EQUIPMENT FAILURE-APS	03:00AM	05:45PM	05:45PM	1,705	44
METRO	08/29/2008	MEADOWBROOK	13	EQUIPMENT FAILURE-APS	03:22AM	04:22AM	08:30AM	2,534	1,043
METRO	08/29/2008	SUNNYSLOPE	21	EQUIPMENT FAILURE-APS	03:57AM	09:53AM	09:53AM	4,490	150
METRO	08/28/2008	MEADOWBROOK	14	WEATHER-STORM RELATED	09:42PM	03:35AM	03:50PM	8,835	380
METRO	08/29/2008	ORANGEWOOD	23	WEATHER-STORM RELATED	07:03AM	07:08AM	11:14AM	1,561	1,410
METRO	08/28/2008	SHAW	15	WEATHER STORM RELATED	09:47PM	09:59AM	09:56AM	42,221	3,475
METRO	08/29/2008	SHAW	15	UNKNOWN / OTHER	09:57AM	11:46AM	11:46AM	6,313	3,475

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/29/2008	SHAW	15	WEATHER-STORM RELATED	11:48AM	12:27PM	12:27PM	2,259	3,475
METRO	08/29/2008	ROSE GARDEN	2	WEATHER-STORM RELATED	12:22PM	07:48PM	07:48PM	3,494	470
METRO	08/28/2008	GRISWOLD	4	EQUIPMENT FAILURE-APS	11:40PM	03:56PM	01:29PM 8/30	25,689	1,546
METRO	08/29/2008	WHY	1	EQUIPMENT FAILURE-APS	08:07PM	04:57AM	04:57AM	1,184	134
METRO	08/29/2008	GAVILAN PEAK	41	EQUIPMENT FAILURE-APS	10:53PM	11:31PM	07:38AM	1,022	1,340
METRO	08/29/2008	NEW RIVER	12	WEATHER-STORM RELATED	10:55PM	12:15AM	12:20AM	1,573	1,127
METRO	08/29/2008	UNION HILLS	17	EQUIPMENT FAILURE-APS	11:06PM	11:51PM	01:11AM	2,582	1,463
METRO	08/29/2008	HEDGEPETH HILLS	13	WEATHER-STORM RELATED	11:13PM	01:09AM	01:09AM	1,899	982
METRO	08/29/2008	ADOBE	10	EQUIPMENT FAILURE-APS	11:15PM	12:27AM	12:48AM	2,535	1,969
METRO	08/29/2008	CAVE CREEK	14	FOREIGN INTERFERENCE-VEHICLES	11:19PM	01:01AM	01:01AM	1,450	853

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

METRO	08/29/2008	METRO	13	WEATHER-STORM RELATED	12:47PM	05:14PM	05:14PM	1,423	50
METRO	08/29/2008	ORANGEWOOD	17	EQUIPMENT FAILURE-APS	01:56PM	05:25PM	05:25PM	3,675	1,055
METRO	08/30/2008	MEADOWBROOK	1	WEATHER-STORM RELATED	02:20PM	04:31AM	04:31AM	1,120	79
NORTHWEST	08/25/2008	MORRISTOWN	2	EQUIPMENT FAILURE-APS	06:07PM	10:40PM	03:26AM	3,878	511
NORTHWEST	08/25/2008	YARNELL	4	WEATHER-STORM RELATED	10:38PM	12:35AM	12:35AM	2,340	1,200
NORTHWEST	08/26/2008	YARNELL	4	UNDERGROUND CABLE	12:13AM	02:04PM	08:21AM	6,653	38
NORTHWEST	08/26/2008	08/30/2008	3	EQUIPMENT FAILURE-APS	12:45AM	03:17AM	03:17AM	1,079	426
SOUTHEAST	08/25/2008	PINAL	4	EQUIPMENT FAILURE-APS	09:45PM	09:57PM	01:31AM	1,537	1,208
SOUTHEAST	08/26/2008	KEARNY	6	EQUIPMENT FAILURE-APS	12:23AM	04:36AM	11:44AM	4,540	947
SOUTHEAST	08/28/2008	COOLIDGE	1	WEATHER-STORM RELATED	01:13AM	02:22AM	04:08AM	4,596	1,846

1000 HOUR CUSTOMER OUTAGE REPORT
(08/25/2008 – 08/31/2008)

SOUTHEAST	08/28/2008	HIDDEN VALLEY	4	EQUIPEMT FAILURE-APS	08:13PM	11:50PM	06:59AM	2,360	360
SOUTHWEST	08/25/2008	QUARTZSITE	2	EQUIPMENT FAILURE-APS	11:00PM	02:39AM	02:39AM	3,577	980
SOUTHWEST	08/29/2008	QUECHAN	22	WEATHER-STORM RELATED	12:45AM	02:47AM	02:47AM	1,761	866
SOUTHWEST	08/29/2008	LAGUNA	9	EQUIPMENT FAILURE-APS	01:22AM	02:42AM	02:42AM	1,668	1,251
SOUTHWEST	08/30/2008	QUECHAN	22	EQUIPMENT FAILURE-APS	12:45AM	02:47AM	02:47AM	1,761	866

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(09/01/2008 - 09/07/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/03/2008	TUTHILL	4	EQUIPMENT FAILURE	04:48AM	05:24AM	06:18AM	1,057	1,007
METRO	09/06/2008	CACTUS	22	UNKNOWN/ OTHER	04:15PM	04:45PM	05:36PM	1,392	1,724
METRO	09/06/2008	DALE	2	UNDERGROUND CABLE	08:30PM	10:01PM	11:02PM	2,002	920

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

10/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(09/08/2008-09/14/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/10/2008	TONOPAH	1	TRANSMISSION RELATED (STORM RELATED)	05:44PM	08:08PM	01:06PM	2,741	583
METRO	09/11/2008	BUNYAN	1	TRANSMISSION RELATED (STORM RELATED)	04:30PM	02:27PM	02:27PM	1,976	90
METRO	09/11/2008	GILA BEND	10	EQUIPMENT FAILURE – (STORM RELATED)	04:40PM	06:53PM	04:53PM	3,416	606
METRO	09/11/2008	ARLINGTON	3	EQUIPMENT FAILURE – (STORM RELATED)	05:25PM	09:50PM	09:50PM	1,563	55
METRO	09/11/2008	AZTEC	10	TRANSMISSION RELATED (STORM RELATED)	05:25PM	12:52PM	12:52PM	4,085	210
METRO	09/11/2008	HORN	2	TRANSMISSION RELATED (STORM RELATED)	05:25PM	12:52PM	12:52PM	1,011	52

1000 HOUR CUSTOMER OUTAGE REPORT
(09/08/2008-09/14/2008)

METRO	09/11/2008	HYDER	3	TRANSMISSION RELATED (STORM RELATED)	05:25PM	12:52PM	12:52PM	1,828	94
METRO	09/11/2008	SADDLE MOUNTAIN	6	TRANSMISSION RELATED (STORM RELATED)	05:25PM	12:52PM	12:52PM	1,323	68
METRO	09/11/2008	TARTESSO TEMPORARY	4	TRANSMISSION RELATED (STORM RELATED)	05:25PM	08:06AM	08:06AM	5,139	350
METRO	09/11/2008	TONOPAH	1	TRANSMISSION RELATED (STORM RELATED)	05:25PM	12:08PM	12:08PM	10,912	583
METRO	09/11/2008	WINTERSBURG	12	TRANSMISSION RELATED (STORM RELATED)	05:25PM	08:19PM	08:19PM	3,706	1,278
METRO	09/11/2008	GILLESPIE	4	WEATHER – STORM RELATED	05:30PM	04:10PM	04:10PM	1,167	25
METRO	09/11/2008	PIMA	3	EQUIPMENT FAILURE – (STORM RELATED)	05:46PM	10:48PM	10:48PM	1,284	255

1000 HOUR CUSTOMER OUTAGE REPORT
(09/08/2008-09/14/2008)

METRO	09/11/2008	METRO	13	WEATHER – STORM RELATED	05:56PM	06:38PM	01:40AM	1,150	1,140
METRO	09/11/2008	AJO	1	WEATHER – STORM RELATED	05:57PM	07:23PM	09:49PM	1,880	1,210
METRO	09/13/2008	AZTEC	10	EQUIPMENT FAILURE – (STORM RELATED)	04:05PM	01:00PM	01:00PM	2,849	10***
METRO	09/13/2008	TONOPAH	1	TRANSMISSION RELATED (STORM RELATED)	06:08PM	10:00PM	10:00PM	2,254	583
METRO	09/13/2008	TONOPAH	3	TRANSMISSION RELATED (STORM RELATED)	06:08PM	10:00PM	10:00PM	1,210	313
METRO	09/13/2008	GILA BEND	10	FOREIGN INTERFERENCE – VEHICLES	08:11PM	10:25PM	11:05PM	1,393	606
METRO	09/13/2008	GILA BEND	10	UNKNOWN / OTHER	07:31AM	09:18AM	09:18AM	1,081	606
NORTHEAST	9/10/2008	LEROUX	5	WEATHER – STORM RELATED	04:41PM	06:02PM	06:02PM	2,525	1,870

1000 HOUR CUSTOMER OUTAGE REPORT
(09/08/2008-09/14/2008)

SOUTHEAST	09/10/2008	VISTA	6	EQUIPMENT FAILURE – (STORM RELATED)	09:28PM	10:39PM	08:06AM	5,032	1,798
SOUTHWEST	09/09/2008	QUARTZSITE	2	TRANSMISSION RELATED (STORM RELATED)	09:03PM	12:41PM	12:41PM	25,826	1,652
SOUTHWEST	09/09/2008	QUARTZSITE	6	TRANSMISSION RELATED (STORM RELATED)	09:03PM	12:42PM	12:42PM	3,881	248
SOUTHWEST	09/09/2008	UTTING	1	EQUIPMENT FAILURE – (STORM RELATED)	10:46PM	02:47AM	02:47AM	2,828	704
SOUTHWEST	09/09/2008	UTTING	1	TRANSMISSION RELATED (STORM RELATED)	03:57PM	06:12PM	06:12PM	1,584	704
SOUTHWEST	09/11/2008	COCOPAH	12	WEATHER – STORM RELATED	01:28PM	02:14PM	02:14PM	1,274	1,662
SOUTHWEST	09/11/2008	LAGUNA	1	SUBSTATION RELATED (STORM RELATED)	04:20PM	09:25PM	09:25PM	4,885	961

1000 HOUR CUSTOMER OUTAGE REPORT
(09/08/2008-09/14/2008)

SOUTHWEST	09/12/2008	COCOPAH	12	FOREIGN INTERFERENCE – VEHICLES	01:19AM	02:04AM	02:04PM	1,419	1,892
SOUTHWEST	09/12/2008	LAGUNA	5	WEATHER – STORM RELATED	01:30AM	03:08AM	03:08AM	3,064	1,876

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

*** These 10 customers reflect well banks only. owner ok with length of outage

1000 HOUR CUSTOMER OUTAGE REPORT
(09/15/2008 - 09/21/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/19/2008	COLDWAER	18	EQUIPMENT FAILURE – APS	10:59AM	02:32PM	02:32PM	2,893	815
METRO	09/21/2008	COLDWATER	18	EQUIPMENT FAILURE – APS	12:36AM	05:05AM	05:05AM	3,654	815
SOUTHWEST	09/20/2008	SAN LUIS	10	ENVIRONMENT – FIRE	06:27AM	09:23AM	09:23AM	3,998	1,363

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

10/27/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(09/22/2008 - 09/28/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/23/2008	DIXILETA	10	EQUIPMENT FAILURE – APS	02:04AM	03:35AM	06:37AM	2,516	1,404
METRO	09/23/2008	DIXILETA	13	OTHER – ACCIDENTAL	02:04AM	03:33AM	03:33AM	1,955	1,318
NORTHEAST	09/25/2008	TUBA CITY	2	TRANSMISSION RELATED – STORM	06:22PM	08:12PM	08:12PM	1,934	1,055
NORTHEAST	09/28/2008	TUBA CITY	3	TRANSMISSION RELATED – STORM	06:22PM	08:12PM	08:12PM	3,346	1,825
SOUTHEAST	09/26/2008	SAN MANUEL	29	EQUIPMENT FAILURE – APS STORM	12:46PM	01:29PM	02:09PM	1,363	1,460

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

10/27/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(09/29/2008 - 10/05/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/02/2008	DOUBLETREE	3	VEGETATION CONTACT	11:54PM	01:20AM	01:20AM	1,283	895

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

10/30/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(10/06/2008-10/12/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	10/11/2008	BLUE RIDGE	12	VEGETATION CONTACT (STORM RELATED)	06:03AM	09:50AM	09:50AM	1,207	319
NORTHEAST	10/11/2008	LEROUX	3	WEATHER – WIND	11:52AM	01:09PM	01:09PM	1,386	1,080
NORTHEAST	10/11/2008	SNOWFLAKE	2	WEATHER – WIND	12:11PM	12:58PM	12:58PM	1,853	2,365
NORTHEAST	10/11/2008	LEROUX	3	WEATHER – STORM RELATED	02:24PM	04:58PM	04:58PM	2,772	1,080
SOUTHEAST	10/10/2008	PALOMINAS	4	EQUIPMENT FAILURE – STORM RELATED	06:58PM	09:44PM	12:12PM	7,476	438

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

11/13/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(10/13/2008 - 10/19/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/13/2008	COLDWATER	21	FOREIGN INTERFERENCE - VEHICLES	05:18 PM	05:57 PM	05:57 PM	1,137	1,749
METRO	10/19/2008	STAGECOACH	9	UNKNOWN	06:20 AM	07:57 AM	07:57 AM	1,631	1,009
METRO	10/19/2008	BUTTE	17	EQUIPMENT FAILURE	08:32 AM	09:38 AM	09:38 AM	1,328	1,207

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(10/13/2008 - 10/19/2008)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/13/2008	COLDWATER	21	FOREIGN INTERFERENCE - VEHICLES	05:18 PM	05:57 PM	05:57 PM	1,137	1,749
METRO	10/19/2008	STAGECOACH	9	UNKNOWN	06:20 AM	07:57 AM	07:57 AM	1,631	1,009
METRO	10/19/2008	BUTTE	17	EQUIPMENT FAILURE - APS	08:32 AM	09:38 AM	09:38 AM	1,48[illegible]	1,207

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

The highlighted item(s) reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(10/20/2008 - 10/26/2008)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/22/2008	SURPRISE	21	UNDERGROUND CABLE	04:06PM	04:40PM	05:11PM	1,020	2,103

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

The highlighted item(s) reflect changess

12/17/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(10/27/2008 - 11/02/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
SOUTHWEST	10/30/2008	FOOTHILLS	20	ENVIRONMENT – FIRE	12:27PM	07:00PM	07:00PM	3,897	595

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

11/13/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(10/27/2008 - 11/02/2008)

REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
SOUTHWEST	10/30/2008	FOOTHILLS	20	ENVIRONMENT – FIRE	12:27PM	12:56PM	07:00PM	6,450	4,204

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

The highlighted item(s) reflect changes.

12/17/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(11/03/2008 - 11/09/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHWEST	11/09/2008	SNOWFLAKE	14	WEATHER – WIND	07:52PM	08:49PM	08:49PM	1,463	1,540
NORTHWEST	11/09/2008	CORNVILLE	2	TRANSMISSION RELATED (STORM RELATED)	11:24PM	03:41AM	03:41AM	5,179	1,209
NORTHWEST	11/09/2008	CORNVILLE	4	TRANSMISSION RELATED (STORM RELATED)	11:24PM	03:41AM	03:41AM	3,131	731
NORTHWEST	11/09/2008	MCGUIREVILLE	10	TRANSMISSION RELATED (STORM RELATED)	11:24PM	11:55PM	11:55PM	1,183	2,289
SOUTHWEST	11/09/2008	TENTH STREET	7	WEATHER - WIND	02:14PM	02:42PM	02:42PM	1,062	2,275

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(11/03/2008 - 11/09/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHWEST	11/09/2008	SNOWFLAKE	14	WEATHER – WIND	07:52PM	08:49PM	08:49PM	1,463	1,540
NORTHWEST	11/09/2008	CORNVILLE	2	TRANSMISSION RELATED (STORM RELATED)	11:24PM	03:41AM	03:41AM	5,179	1,209
NORTHWEST	11/09/2008	CORNVILLE	4	TRANSMISSION RELATED (STORM RELATED)	11:24PM	03:41AM	03:41AM	5,305	731
NORTHWEST	11/09/2008	MCGUIREVILLE	10	TRANSMISSION RELATED (STORM RELATED)	11:24PM	11:55PM	11:55PM	1,183	2,289
SOUTHWEST	11/09/2008	TENTH STREET	7	WEATHER - WIND	02:14PM	02:42PM	02:42PM	1,062	2,275

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9
The highlighted item(s) reflect changes

1/12/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(11/03/2008 - 11/09/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	11/09/2008	SNOWFLAKE	14	WEATHER – WIND	07:52PM	08:49PM	08:49PM	1,463	1,540
NORTHWEST	11/09/2008	CORNVILLE	2	TRANSMISSION RELATED (STORM RELATED)	11:24PM	03:41AM	03:41AM	5,179	1,209
NORTHWEST	11/09/2008	CORNVILLE	4	TRANSMISSION RELATED (STORM RELATED)	11:24PM	03:41AM	07:46AM	5,305	731
NORTHWEST	11/09/2008	MCGUIREVILLE	10	TRANSMISSION RELATED (STORM RELATED)	11:24PM	11:55PM	11:55PM	1,183	2,289
SOUTHWEST	11/09/2008	TENTH STREET	7	WEATHER - WIND	02:14PM	02:42PM	02:42PM	1,062	2,275

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9
The highlighted item(s) reflect changes.

1/21/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(11/10/2008 - 11/16/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/10/2008	MOON VALLEY	5	UNKNOWN/ OTHER	11:15AM	12:03PM	12:03PM	1,562	1,952
METRO	11/10/2008	MOON VALLEY	6	UNKOWN/ OTHER	11:15AM	12:08PM	12:08PM	1,576	1,784
METRO	11/12/2008	ORANGEWOOD	8	UNKNOWN/ OTHER	07:10AM	07:45AM	08:17AM	1,618	1,758

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

12/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(11/10/2008 - 11/16/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/10/2008	MOON VALLEY	5	UNKNOWN/ OTHER	11:15AM	12:03PM	12:03PM	1,562	1,952
METRO	11/10/2008	MOON VALLEY	6	UNKOWN/ OTHER	11:15AM	12:08PM	03:01PM	2,205	1,784
METRO	11/12/2008	ORANGEWOOD	8	UNKNOWN/ OTHER	07:10AM	07:45AM	08:17AM	1,618	1,758

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

The highlighted item(s) reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(11/17/2008-11/23/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/26/2008	OBERLIN TEMPORARY	12	FOREIGN INTERFERENCE - VEHICLES	10:12PM	12:16AM	12:16AM	2,038	986

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

12/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(11/24/2008-11/30/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/26/2008	TEMPE	18	FOREIGN INTERFERENCE – VEHICLES	09:51AM	10:37AM	04:23PM	4,128	2,271
METRO	11/27/2008	BUCKEYE	2	EQUIPMENT FAILURE – (STORM RELATED)	01:14AM	06:54AM	06:54AM	1,133	200
METRO	11/27/2008	PEORIA	2	EQUIPMENT FAILURE – (STORM RELATED)	01:20AM	02:21AM	05:01AM	2,247	1,113
METRO	11/27/2008	MEADOWBROOK	6	EQUIPMENT FAILURE – (STORM RELATED)	06:07AM	06:44AM	11:41AM	1,644	2,189
METRO	11/27/2008	VALENCIA	5	EQUIPMENT FAILURE – (STORM RELATED)	09:17AM	09:45AM	11:24AM	1,021	1,860
METRO	11/29/2008	SURPRISE	10	FOREIGN INTERFERENCE – VEHICLES	04:29PM	05:30PM	09:51PM	1,132	1,053

12/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(11/24/2008-11/30/2008)

NORTHWEST	11/26/2008	CORNVILLE	2	TRANSMISSION RELATED (STORM RELATED)	11:08AM	03:14PM	03:14PM	4,957	1,209
NORTHWEST	11/26/2008	MCGUIREVILLE	10	TRANSMISSION RELATED (STORM RELATED)	11:08AM	11:35AM	11:35AM	1,030	2,289
NORTHWEST	11/27/2008	CHINO VALLEY	10	EQUIPMENT FAILURE – (STORM RELATED)	02:02AM	06:01AM	09:28AM	10,766	2,636
SOUTHWEST	11/26/2008	SALOME	3	TRANSMISSION RELATED – (STORM RELATED)	12:01PM	01:18PM	01:18PM	1,115	869
SOUTHWEST	11/26/2008	ARABY	1	WEATHER – STORM RELATED	08:26PM	10:41PM	10:41PM	1,814	806

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

12/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/01/2008 – 12/07/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/05/2008	GLENDALE	18	EQUIPMENT FAILURE – APS	01:22AM	03:16AM	09:04AM	1,731	621
METRO	12/06/2008	DIXILETA	13	EQUIPMENT FAILURE – APS	01:28PM	03:30PM	10:04PM	1,213	593
METRO	12/07/2008	ESTRELLITA	5	FOREIGN INTERFERENCE – VEHICLE	11:55PM	01:15AM	01:15AM	1,219	914
METRO	12/07/2008	ORANGEWOOD	9	EQUIPMENT FAILURE – APS	09:36AM	10:39AM	02:45PM	2,003	1,487

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

12/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/08/2008 – 12/14/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/08/2008	CACTUS	36	UNDERGROUND CABLE	01:13AM	02:24AM	03:17AM	1,879	1,333
NORTHEAST	12/13/2008	TUBA CITY	3	EQUIPMENT FAILURE – APS	11:38PM	03:39AM	06:36	7,478	1,825
NORTHEAST	12/14/2008	SHOWLOW	15	WEATHER-STORM RELATED	04:26AM	06:25AM	06:56AM	1,243	535
SOUTHEAST	12/13/2008	PINAL	4	WEATHER – STORM RELATED	10:21PM	10:51PM	01:09AM	1,988	2,206

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

12/29/2008

1000 HOUR CUSTOMER OUTAGE REPORT
(12/08/2008 – 12/14/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/08/2008	CACTUS	36	UNDERGROUND CABLE	01:13AM	02:24AM	03:17AM	1,879	1,333
METRO	12/0820/08	MOON VALLEY	14	UNDERGROUND CABLE	10:32PM	11:03PM	11:45PM	1,273	1,469
NORTHEAST	12/13/2008	TUBA CITY	3	EQUIPMENT FAILURE STORM RELATED	11:38PM	03:39AM	06:36AM	11,128	1,825
NORTHEAST	12/14/2008	SHOWLOW	15	WEATHER-STORM RELATED	04:26AM	06:25AM	06:56AM	1,243	535
NORTHWEST	12/11/2008	PRESCOTT CITY	1	FOREIGN INTERFERENCE – VEHICLES	01:47AM	08:06AM	08:06AM	2,400	380
SOUTHEAST	12/13/2008	PINAL	4	WEATHER – STORM RELATED	10:21PM	10:51PM	01:09AM	1,988	2,206
SOUTHWEST	12/13/2008	QUECHAN	18	WEATHER – STORM RELATED	11:56PM	01:19AM	01:19AM	2,508	1,813

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

2/16/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(12/15/2008 – 12/21/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/16/2008	GLENDALE	2	EQUIPMENT FAILURE – STORM RELATED	09:00AM	09:37AM	11:45AM	1,582	1,551
METRO	12/16/2008	EL SOL	9	EQUIPMENT FAILURE – STORM RELATED	09:10AM	09:28AM	12:31PM	1,057	1,668
NORTHEAST	12/16/2008	MUNDS PARK	5	VEGETATION CONTACT – STORM RELATED	11:24PM	12:44AM	10:43AM	8,617	2,955
NORTHEAST	12/18/2008	ELDEN	1	WEATHER – STORM RELATED	02:46AM	02:48AM	07:00AM	4,405	2,965
SOUTHEAST	12/17/2008	TOLTEC	2	WEATHER – STORM RELATED	12:47AM	02:54AM	06:16AM	3,293	1,099
SOUTHEAST	12/19/2008	FAIRVIEW	14	EQUIPMENT FAILURE	06:25PM	09:59PM	09:59PM	1,598	448

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1/13/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(12/22/2008 - 12/28/2008)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/27/2008	ORANGEWOOD	32	EQUIPMENT FAILURE	09:56AM	11:09AM	06:50PM	1,920	1,267
NORTHEAST	12/26/2008	SWITZER CANYON	22	WEATHER – STORM RELATED	12:33AM	06:02AM	06:15PM	1,038	185
NORTHEAST	12/26/2008	ASHFORK	6	WEATHER – STORM RELATED	12;53AM	06:00AM	06:00AM	1,627	318
NORTHEAST	12/26/2008	COCONINO	14	WEATHER – STORM RELATED	01:11AM	02:25PM	02:25PM	4,235	320
NORTHEAST	12/26/2008	PREACHER CANYON	6	EQUIPMENT FAILURE – STORM RELATED	01:23AM	07:09AM	11:50AM	5,094	509
NORTHEAST	12/26/2008	SHUMWAY	6	EQUIPMENT FAILURE – APS STORM RELATED	04:56AM	09:45AM	09:45AM	7,538	1,325
NORTHEAST	12/26/2008	SHUMWAY	6	WEATHER – STORM RELATED	10:53AM	01:04PM	01:54PM	1,270	426
NORTHEAST	12/27/2008	STRAWBERRY	2	WEATHER – STORM RELATED	09:06AM	09:42AM	09:42AM	2,310	3.850
NORTHWEST	12/25/2008	PRESCOTT CITY	1	WEATHER – STORM RELATED	07:17PM	07:58PM	07:58PM	1,217	1,781

1000 HOUR CUSTOMER OUTAGE REPORT
(12/22/2008 - 12/28/2008)

NORTHWEST	12/25/2008	CHINO VALLEY	10	WEATHER – STORM RELATED	09:05PM	11:50PM	11:50PM	15,494	5,634
NORTHWEST	12/25/2008	CHINO VALLEY	6	VEGETATION CONTACT – STORM RELATED	09:09PM	11:50PM	11:50PM	3,440	1,282
NORTHWEST	12/26/2008	CHINO VALLEY	10	WEATHER – STORM RELATED	01:53AM	12:36PM	12:36PM	1,522	142
SOUTHEAST	12/26/2008	PINAL	4	VEGETATION CONTACT – STORM RELATED	03:23AM	07:12AM	07:12AM	8,397	2,200

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(12/15/2008 – 12/21/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/16/2008	GLENDALE	2	EQUIPMENT FAILURE STORM RELATED	09:00AM	09:37AM	11:45AM	1,582	1,551
METRO	12/16/2008	EL SOL	9	EQUIPMENT FAILURE STORM RELATED	09:10AM	09:28AM	12:31PM	1,057	1,668
NORTHEAST	12/16/2008	MUNDS PARK	5	VEGETATION CONTACT – STORM RELATED	11:24PM	12:44AM	10:43AM	8,617	2,955
NORTHEAST	12/18/2008	ELDEN	1	WEATHER – STORM RELATED	02:46AM	02:48AM	07:00AM	4,405	2,965
SOUTHEAST	12/17/2008	TOLTEC	2	WEATHER – STORM RELATED	12:47AM	02:54AM	06:16AM	3,293	1,099
SOUTHEAST	12/19/2008	FAIRVIEW	14	EQUIPMENT FAILURE	06:25PM	09:59PM	09:59PM	1,598	448
NORTHWEST	12/17/2008	YARNELL	4	OVERLOAD – FUSE OVERLOAD COLD LOAD PICKUP	11:11PM	09:37AM	09:37AM	1,221	117

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

2/13/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(12/15/2008 – 12/21/2008)
REVISED

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

Items in RED reflect change

2/13/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(12/22/2008 - 12/28/2008)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/27/2008	ORANGEWOOD	32	EQUIPMENT FAILURE	09:56AM	11:09AM	06:50PM	1,920	1,267
NORTHEAST	12/26/2008	SWITZER CANYON	22	WEATHER – STORM RELATED	12:33AM	06:02AM	06:15PM	1,038	185
NORTHEAST	12/26/2008	ASHFORK	6	WEATHER – STORM RELATED	12;53AM	06:00AM	06:00AM	1,627	318
NORTHEAST	12/26/2008	COCONINO	14	WEATHER – STORM RELATED	01:11AM	02:25PM	02:25PM	4,235	320
NORTHEAST	12/26/2008	PREACHER CANYON	6	EQUIPMENT FAILURE STORM RELATED	01:23AM	07:09AM	11:50AM	5,094	509
NORTHEAST	12/26/2008	SHUMWAY	6	EQUIPMENT FAILURE STORM RELATED	04:56AM	09:45AM	10:51AM	8,864	1,325
NORTHEAST	12/26/2008	SHUMWAY	6	WEATHER – STORM RELATED	10:53AM	01:04PM	01:54PM	1,270	426
NORTHEAST	12/27/2008	STRAWBERRY	2	WEATHER – STORM RELATED	09:06AM	09:42AM	09:42AM	2,310	3.850

2/13/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(12/22/2008 - 12/28/2008)
REVISED

NORTHWEST	12/25/2008	PRESCOTT CITY	1	WEATHER – STORM RELATED	07:17PM	07:58PM	07:58PM	1,217	1,781
NORTHWEST	12/25/2008	CHINO VALLEY	10	WEATHER – STORM RELATED	09:05PM	11:50PM	11:50PM	15,494	5,634
NORTHWEST	12/25/2008	CHINO VALLEY	6	VEGETATION CONTACT – STORM RELATED	09:09PM	11:50PM	11:50PM	3,440	1,282
NORTHWEST	12/25/2008	PRESCOTT CITY	1	WEATHER – STORM RELATED	07:23PM	09:47PM	09:47PM	1,714	714
NORTHWEST	12/26/2008	CHINO VALLEY	10	WEATHER – STORM RELATED	01:53AM	12:36PM	12:36PM	1,522	142
SOUTHEAST	12/26/2008	PINAL	4	VEGETATION CONTACT – STORM RELATED	03:23AM	07:12AM	07:12AM	8,397	2,200

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

Highlighted items reflect changes.

2/13/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(12/29/2008 - 01/04/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/29/2008	AJO	1	EQUIPMENT FAILURE	12:40PM	03:12PM	11:00PM	3,741	1,210
METRO	01/02/2009	CACTUS	30	FOREIGN INTERFERENCE – DIG-INS CUSTOMER	09:57AM	10:40AM	01:13PM	3,737	2,868
SOUTHEAST	01/02/2009	DON LUIS	1	FOREIGN INTERFERENCE – VEHICLE	01:28AM	02:01AM	06:45AM	4,581	867

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

2/2/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(01/05/2009-01/11/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	01/11/2009	TWENTY-THIRD ST	20	FOREIGN INTERFERENCE – VEHICLES	10:24AM	11:06AM	03:21PM	1,450	1,296
METRO	01/11/2009	PEORIA	4	UNKNOWN / OTHER	05:04PM	05:38PM	06:02PM	1,298	1,715
NORTHEAST	01/05/2009	KEAMS CANYON	3	WEATHER – STORM RELATED	07:51PM	09:40PM	09:40PM	1,034	569
NORTHEAST	01/07/2009	SHOWLOW	13	EQUIPMENT FAILURE	12:10PM	01:16PM	01:30PM	3,630	2,723

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

2/13/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(01/12/2009-01/18/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	01/12/2009	MOUNTAIN VIEW	4	FOREIGN INTERFERENCE – ANIMALS	10:12PM	10:59PM	12:08AM	1,222	1,152
NORTHEAST	01/14/2009	STRAWBERRY	2	FOREIGN INTERFERENCE – VEHICLES	05:33PM	07:23PM	11:45PM	3,088	1,540
NORTHEAST	01/15/2009	KEAMS CANYON	3	WIRE DOWN	04:41PM	01:03AM	01:03AM	15,813	1,890

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(01/19/2009 - 01/25/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	01/21/2009	DALE	5	FOREIGN INTERFERENCE – ANIMALS	03:32 AM	04:34AM	05:02AM	1,848	1,240
METRO	01/21/2009	DALE	10	FOREIGN INTERFERENCE – ANIMALS	03:32 AM	04:49 AM	04:49 AM	1,685	1,313
METRO	01/23/2009	DESERT SPRINGS	9	UNDERGROUND CABLE	03:43 PM	04:18 PM	07:40 PM	2,607	2,156
METRO	01/25/2009	UNION HILLS	20	FOREIGN INTERFERENCE – VANDALISM	04:58 AM	05:52 AM	05:52 AM	1,221	1,357
NORTHEAST	01/20/2009	PREACHER CANYON	6	UNDERGROUND CABLE	01:45 AM	06:09 AM	12:44 PM	5,773	525
SOUTHEAST	01/19/2009	VISTA	10	EQUIPMENT FAILURE	06:14 AM	07:45 AM	09:16 AM	2,765	1,666
SOUTHEAST	01/23/2009	FAIRVIEW	14	EQUIPMENT FAILURE	12:07 AM	01:20 AM	01:20 AM	2,600	2,137
SOUTHEAST	01/25/2009	HIDDEN VALLEY	4	LOSS OF SUPPLY – OTHER UTILITY	05:01 AM	06:59 AM	08:15 AM	2,536	998

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

2/26/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(01/19/2009 - 01/25/2009)

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

2/26/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(01/26/2009 - 02/01/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

There are no outages to report for this timeframe.

2/17/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(02/02/2009 - 02/08/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/07/2009	ORANGEWOOD	32	UNDERGROUND CABLE	09:26PM	10:00PM	11:37PM	1,129	1,267
METRO	02/08/2009	ENCANTO	2	VEGETATION CONTACT	06:12AM	06:43AM	07:38AM	1,220	2,007
NORTHEAST	02/08/2009	PREACHER CANYON	6	EQUIPMENT FAILURE STORM RELATED	10:13AM	10:41AM	11:29AM	3,177	3,103
NORTHEAST	02/08/2009	PREACHER CANYON	6	EQUIPMENT FAILURE STORM RELATED	11:29AM	11:32AM	02:35PM	6,745	3,103

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

2/27/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(02/09/2009 - 02/15/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/09/2009	MCDOWELL	20	EQUIPMENT FAILURE – STORM	08:36PM	09:22PM	01:45AM	1,637	1,826
NORTHEAST	02/09/2009	TONTO	14	EQUIPMENT FAILURE – STORM	05:04PM	05:06PM	11:07PM	1,234	434
NORTHEAST	02/09/2009	TONTO	14	EQUIPMENT FAILURE – STORM	11:25PM	12:09AM	10:07PM	3,174	434
NORTHEAST	02/10/2009	PREACHER CANYON	6	WEATHER – STORM	06:59AM	07:58AM	07:58AM	3,051	3,103
NORTHEAST	02/10/2009	PREACHER CANYON	6	WEATHER – STORM	08:22AM	11:02AM	11:02AM	8,275	3,103
NORTHEAST	02/15/2009	SWITZER CANYON	13	EQUIPMENT FAILURE – DIG-IN	06:04PM	07:34PM	10:06PM	15,513	5,776
NORTHEAST	02/15/2009	ELDEN	2	EQUIPMENT FAILURE	10:16PM	10:49PM	01:46AM	4,668	3,093
NORTHWEST	02/09/2009	WHITE SPAR	10	WEATHER – STORM	07:33PM	09:30PM	09:30PM	3,062	1,570

3/19/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(02/09/2009 - 02/15/2009)

NORTHWEST	02/09/2009	SEDONA	14	EQUIPMENT FAILURE – STORM	08:44PM	03:06AM	03:50AM	2,781	271
NORTHWEST	02/09/2009	WHITE SPAR	10	WEATHER – STORM	09:37PM	12:00AM	12:00AM	3,742	1,570
NORTHWEST	02/10/2009	WHITE SPAR	10	EQUIPMENT FAILURE – STORM	12:09AM	03:00PM	03:00PM	4,232	285
SOUTHEAST	02/11/2009	MURAL	2	EQUIPMENT FAILURE – STORM	06:06PM	07:05PM	09:51PM	2,781	1,595
SOUTHEAST	02/12/2009	BOOTHILL	1	FOREIGN INTERFERENCE – VEHICLES	03:48PM	04:24PM	03:20PM	1,205	1,105
SOUTHWEST	02/13/2009	COLORADO	4	LOSS OF SUPPLY – OTHER UTILITY	09:09AM	10:43AM	10:43AM	1,466	936

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

1000 HOUR CUSTOMER OUTAGE REPORT
(02/09/2009 - 02/15/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/09/2009	MCDOWELL	20	EQUIPMENT FAILURE – STORM	08:36PM	09:22PM	01:45AM	1,637	1,826
NORTHEAST	02/09/2009	TONTO	14	EQUIPMENT FAILURE – STORM	02:26PM	04:14PM	11:07PM	2,182	434
NORTHEAST	02/09/2009	TONTO	14	EQUIPMENT FAILURE – STORM	11:25PM	12:09AM	10:07PM	3,174	434
NORTHEAST	02/10/2009	PREACHER CANYON	6	WEATHER – STORM	06:59AM	07:58AM	07:58AM	3,051	3,103
NORTHEAST	02/10/2009	PREACHER CANYON	6	WEATHER – STORM	08:22AM	11:02AM	11:02AM	8,275	3,103
NORTHEAST	02/15/2009	SWITZER CANYON	13	EQUIPMENT FAILURE – DIG-IN	06:04PM	07:34PM	10:06PM	15,513	5,776
NORTHEAST	02/15/2009	ELDEN	2	EQUIPMENT FAILURE	10:16PM	10:49PM	11:46PM	3,242	3,093
NORTHWEST	02/09/2009	WHITE SPAR	10	WEATHER – STORM	07:33PM	09:30PM	09:30PM	3,062	1,570

4/7/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(02/09/2009 - 02/15/2009)
REVISED

NORTHWEST	02/09/2009	SEDONA	14	EQUIPMENT FAILURE – STORM	08:44PM	03:06AM	03:50PM	2,395	271
NORTHWEST	02/09/2009	WHITE SPAR	10	WEATHER – STORM	09:37PM	12:00AM	12:00AM	3,742	1,570
NORTHWEST	02/10/2009	WHITE SPAR	10	EQUIPMENT FAILURE – STORM	12:09AM	03:00PM	03:00PM	4,232	285
SOUTHEAST	02/11/2009	MURAL	2	EQUIPMENT FAILURE – STORM	06:06PM	07:05PM	09:51PM	2,781	1,595
SOUTHEAST	02/12/2009	BOOTHILL	1	FOREIGN INTERFERENCE – VEHICLES	03:48PM	04:24PM	03:20PM	1,205	1,105
SOUTHWEST	02/13/2009	COLORADO	4	LOSS OF SUPPLY – OTHER UTILITY	09:09AM	10:43AM	10:43AM	1,466	936

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

The highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(02/16/2009 - 02/22/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/19/2009	CACTUS	30	UNDERGROUND CABLE	03:59AM	05:22AM	07:59AM	4,846	2,718
METRO	02/19/2009	TEMPE	14	SUBSTATION RELATED	05:05PM	06:08PM	06:08PM	3,492	3,326
METRO	02/19/2009	TEMPE	18	SUBSTATION RELATED	05:05PM	06:08PM	06:08PM	2,079	1,980
NORTHWEST	02/17/2009	CHINO VALLEY	10	EQUIPMENT FAILURE – STORM	01:48AM	05:07AM	05:07AM	1,051	317

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

3/11/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(02/23/2009 - 03/01/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	02/27/2009	KEAMS CANYON	3	FOREIGN INTERFERENCE – VANDALISM	11:41AM	12:33PM	05:27PM	8,668	1,583

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

1000 HOUR CUSTOMER OUTAGE REPORT
(03/02/2009 - 03/08/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	03/04/2009	TUBA CITY	3	EQUIPMENT FAILURE	03:19PM	04:23PM	04:23PM	2,046	1,918

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

4/22/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(03/09/2009 - 03/15/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201. 9

There are no outages to report for this timeframe.

1000 HOUR CUSTOMER OUTAGE REPORT
(03/16/2009-03/22/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	03/22/2009	MOUNT FLOYD	1	WEATHER–WIND	01:52PM	05:28PM	05:28PM	2,214	615
NORTHEAST	03/22/2009	BLUE RIDGE	12	VEGETATION CONTACT (STORM RELATED)	05:08PM	06:19PM	10:55PM	1,142	430
NORTHWEST	03/16/2009	WHITE SPAR	12	EQUIPMENT FAILURE	08:10AM	07:35AM	07:35AM	5,175	221
NORTHWEST	03/22/2009	PRESCOTT CITY	1	EQUIPMENT FAILURE (STORM RELATED)	01:09PM	01:51PM	03:05PM	1,089	718
NORTHWEST	03/22/2009	DEWEY	10	EQUIPMENT FAILURE (STORM RELATED)	02:58PM	03:29PM	04:27PM	1,226	2,214
NORTHWEST	03/22/2009	QUAIL SPRINGS	10	VEGETATION CONTACT (STORM RELATED)	04:00PM	06:18PM	08:40PM	1,999	735
SOUTHWEST	03/17/2009	COLORADO	4	LOSS OF SUPPLY-OTHER UTILITY	01:30PM	04:06PM	04:06PM	2,434	936

4/22/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(03/16/2009-03/22/2009)

SOUTHWEST	03/22/2009	QUECHAN	18	WEATHER – WIND	01:02PM	02:25PM	02:25PM	2,534	1,832

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

1000 HOUR CUSTOMER OUTAGE REPORT
(03/23/2009-03/29/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	03/23/2009	TURF	6	UNDERGROUND CABLE	02:54AM	03:31AM	04:28AM	1,022	615
METRO	03/26/2009	HATFIELD	5	UNDERGROUND CABLE	04:21AM	06:07AM	08:53AM	2,062	976
METRO	03/26/2009	COUNTRY CLUB	21	WEATHER-WIND	07:36PM	09:16PM	12:43AM	4,882	1,284
METRO	03/26/2009	SUNNYSLOPE	13	WEATHER-WIND	07:41PM	01:18AM	01:18AM	1,517	270
METRO	03/26/2009	ARROYO	6	WEATHER-WIND	08:12PM	09:29PM	09:29PM	2,162	1,685
METRO	03/26/2009	NEW RIVER	12	EQUIPMENT FAILURE (STORM RELATED)	08:27PM	07:00AM	07:00AM	1,372	130
METRO	03/26/2009	SHAW	15	WEATHER-WIND	09:11PM	11:16PM	11:28PM	7,303	3,376
METRO	03/26/2009	MEADOWBROOK	1	WEATHER-WIND	09:34PM	12:25AM	12:25AM	4,358	1,529

4/22/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(03/23/2009-03/29/2009)

METRO	03/26/2009	COUNTRY CLUB	13	WEATHER-WIND	09:45PM	11:09PM	11:27PM	4,440	2,965
METRO	03/26/2009	FLYING E	2	WEATHER-WIND	07:05PM	07:38PM	09:51PM	1,118	675
NORTHEAST	03/26/2009	WINSLOW	14	WEATHER-WIND	02:37PM	03:56PM	03:56PM	2,394	1,818
NORTHEAST	03/26/2009	KEAMS CANYON	3	EQUIPMENT FAILURE(STORM RELATED)	11:55PM	12:31AM	11:20AM	11,280	1,583
NORTHEAST	03/29/2009	WINSLOW	14	EQUIPMENT FAILURE(STORM RELATED)	02:19PM	04:50PM	04:50PM	2,174	864
NORTHWEST	03/26/2009	COPPER CANYON	2	WEATHER-WIND	04:59PM	06:11PM	06:11PM	1,457	1,214
SOUTHEAST	03/26/2009	COOLIDGE	1	VEGETATION CONTACT (STORM RELATED)	09:13PM	10:17PM	10:17PM	1,012	949

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

4/22/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(03/30/2009-04/05/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/04/2009	LOOKOUT	12	EQUIPMENT FAILURE	03:18PM	03:54PM	05:33PM	2,272	2,000
NORTHEAST	04/03/2009	GRAND CANYON	1	SUBSTATION RELATED	09:19AM	02:33PM	02:33PM	2,198	420
NORTHEAST	04/03/2009	GRAND CANYON	3	SUBSTATION RELATED	09:19AM	02:33PM	02:33PM	2,857	546
NORTHEAST	04/03/2009	CHOLLA	33	TRANSMISSION RELATED (STORM RELATED)	11:26AM	03:05PM	03:05PM	2,504	686
NORTHEAST	04/03/2009	SHOWLOW	9	LOSS OF SUPPLY-SYSTEM DISTURBANCE (STORM)	11:34AM	12:44PM	12:44PM	1,628	1,395
NORTHEAST	04/03/2009	SHUMWAY	6	LOSS OF SUPPLY-SYSTEM DISTURBANCE (STORM)	11:34AM	12:45PM	12:45PM	2,102	1,776
NORTHEAST	04/03/2009	SNOWFLAKE	2	LOSS OF SUPPLY-SYSTEM DISTURBANCE (STORM)	11:34AM	12:43PM	12:43PM	2,448	2,129

5/7/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(03/30/2009-04/05/2009)

NORTHEAST	04/03/2009	WOODY MOUNTAIN	14	WEATHER-WIND	05:54PM	07:07PM	07:07PM	3,566	2,931

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(04/06/2009-04/12/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/07/2009	DALE	2	UNDERGROUND CABLE	02:37AM	04:05AM	05:02AM	2,073	859
METRO	04/10/2008	TURF	6	UNDERGROUND CABLE	12:50AM	01:25AM	02:06AM	1.496	1,450
METRO	04/11/2009	GLENDALE	2	VEGETATION CONTACT (STORM RELATED)	01:17AM	02:18AM	02:55AM	1,228	1,003
METRO	04/11/2009	COUNTRY CLUB	26	WEATHER-WIND	01:19AM	07:00AM	07:00AM	1,273	224
METRO	04/11/2009	ENCANTO	10	EQUIPMENT FAILURE (STORM RELATED)	01:22AM	02:38AM	03:20AM	1,026	775
METRO	04/11/2009	STAGECOACH	5	UNKNOWN / OTHER	08:43AM	10:14AM	10:14AM	2,619	1,727
METRO	04/11/2009	STAGECOACH	5	EQUIPMENT FAILURE (STORM RELATED)	05:13PM	05:58PM	10:25PM	2,261	1,727
METRO	04/12/2009	LONE PEAK	13	FOREIGN INTERFERENCE – VANDALISM	01:39AM	03:10AM	03:10AM	1,389	916

5/19/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(04/06/2009-04/12/2009)

METRO	04/12/2009	UNION HILLS	9	FOREIGN INTERFERENCE – VANDALISM	02:16AM	03:07AM	03:07AM	1,145	1,347
METRO	04/12/2009	MOUNTAIN VIEW	6	EQUIPMENT FAILURE	05:19PM	05:47PM	06:09PM	1,044	1,542
NORTHEAST	04/07/2009	COCONINO	12	VEGETATION CONTACT (STORM RELATED)	01:50PM	12:20AM	12:32AM	4,551	426
SOUTHEAST	04/11/2009	PINAL	4	UNDERGROUND CABLE	05:38AM	07:10AM	07:10AM	1,993	1,300
SOUTHEAST	04/11/2009	PINAL	4	WEATHER – STORM RELATED	12:36PM	03:16PM	03:16PM	1,200	450

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(04/13/2009-04/19/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
SOUTHWEST	04/14/2009	COLORADO	4	LOSS OF SUPPLY-OTHER UTILITY (STORM RELATED)	12:26PM	01:35PM	01:35PM	1,076	936

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

5/7/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(04/13/2009-04/19/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/14/2009	DURANGO	1	EQUIPMENT FAILURE – STORM RELATED	08:17PM	08:49PM	09:56PM	1,251	1,025
SOUTHWEST	04/14/2009	COLORADO	4	LOSS OF SUPPLY-OTHER UTILITY (STORM RELATED)	12:26PM	01:35PM	01:35PM	1,076	936

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The highlighted items reflect changes.

1000 HOUR CUSTOMER OUTAGE REPORT
(04/20/2009-04/26/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/20/2009	GILBERT	10	SUBSTATION RELATED	04:10PM	04:58PM	04:58PM	1,440	1,800
METRO	04/20/2009	GILBERT	12	UNKNOWN - OTHER	04:10PM	05:18PM	06:36PM	3,666	2,239
NORTHEAST	04/23/2009	COCONINO	12	FOREIGN INTERFERENCE	12:03PM	01:24PM	03:29PM	2,934	900
SOUTHEAST	04/23/2009	PICKET	2	EQUIPMENT FAILURE	07:37AM	08:59AM	11:32AM	5,979	1,559

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

5/28/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(04/27/2009 - 05/03/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/01/2009	MARINETTE	22	EQUIPMENT FAILURE	04:18AM	05:06AM	09:40AM	1,001	1,158

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

5/26/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(05/11/2009-05/17/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/11/2009	PEORIA	4	UNDERGROUND CABLE	07:05AM	07:52AM	09:41AM	1,339	1,327
METRO	05/11/2009	CIELO GRANDE	9	FOREIGN INTERFERENCE	10:27AM	11:39AM	12:03PM	2,747	2,265
NORTHEAST	05/13/2009	SANDVIG	10	FOREIGN INTERFERENCE - VEHICLES	04:11PM	09:10PM	09:10PM	2,686	539
NORTHEAST	05/16/2009	PREACHER CANYON	6	EQUIPMENT FAILURE	04:45AM	07:05AM	10:36AM	11,092	2,175
SOUTHEAST	05/16/2009	PINAL	4	EQUIPMENT FAILURE	12:27AM	02:30AM	03:16AM	3,194	1,318
SOUTHEAST	05/16/2009	PINAL	4	EQUIPMENT FAILURE	04:04PM	05:10PM	05:10PM	2,318	2,107
SOUTHEAST	05/17/2009	SAN MANUEL	29	FOREIGN INTERFERENCE – VEHICLES	05:37PM	09:23PM	04:24AM	1,106	111

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

6/15/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(05/04/2009-05/10/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
SOUTHEAST	05/05/2009	TOLTEC	2	EQUIPMENT FAILURE	12:32AM	03:20AM	04:33AM	1,988	574
SOUTHEAST	05/05/2009	TOLTEC	5	EQUIPMENT FAILURE	05:41AM	06:48AM	06:48AM	1,028	921
SOUTHEAST	05/05/2009	TOLTEC	2	EQUIPMENT FAILURE	10:46AM	02:49PM	02:55PM	2,356	574
SOUTHWEST	05/08/2009	LAGUNA	5	UNKNOWN/ OTHER	03:59PM	04:43PM	09:05PM	1,219	1,370

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(05/11/2009-05/17/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/11/2009	PEORIA	4	UNDERGROUND CABLE	07:05AM	07:52AM	09:41AM	1,339	1,327
METRO	05/11/2009	CIELO GRANDE	9	FOREIGN INTERFERENCE	10:27AM	11:39AM	12:03PM	2,747	2,265
NORTHEAST	05/13/2009	SANDVIG	10	FOREIGN INTERFERENCE - VEHICLES	04:11PM	09:10PM	09:10PM	2,686	539
NORTHEAST	05/16/2009	PREACHER CANYON	6	EQUIPMENT FAILURE	04:45AM	07:05AM	10:36AM	11,092	2,175
SOUTHEAST	05/16/2009	PINAL	4	EQUIPMENT FAILURE	12:27AM	02:30AM	03:16AM	3,194	1,318
SOUTHEAST	05/16/2009	PINAL	4	EQUIPMENT FAILURE	04:04PM	05:10PM	05:10PM	2,318	2,107
SOUTHEAST	05/17/2009	SAN MANUEL	29	FOREIGN INTERFERENCE – VEHICLES	05:37PM	09:23PM	04:24AM	1,106	111

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(05/18/2009-05/24/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/18/2009	BUTTE	22	WEATHER – WIND	09:37PM	10:22PM	11:36PM	2,426	2,591
METRO	05/18/2009	ROADRUNNER	13	EQUIPMENT FAILURE (STORM RELATED)	10:07PM	11:11PM	04:09AM	1,303	998
METRO	05/19/2009	TEMPE	14	SWITCHING ERROR	04:59AM	05:27AM	05:29AM	1,655	3,326
METRO	05/19/2009	COLDWATER	18	EQUIPMENT FAILURE (STORM RELATED)	10:53PM	12:44AM	05:20AM	2,706	1,348
METRO	05/20/2009	CAMELBACK	26	FOREIGN INTERFERENCE – DIG IN CUSTOMER	02:21PM	02:51PM	04:08PM	2,709	2,610
METRO	05/22/2009	JAVELINA	4	FOREIGN INTERFERENCE – VEHICLES	01:23AM	03:23AM	04:37AM	3,280	1,228
METRO	05/22/2009	BUCKEYE	2	EQUIPMENT FAILURE (STORM RELATED)	01:35AM	03:24AM	12:40PM	4,946	1,830

1000 HOUR CUSTOMER OUTAGE REPORT
(05/18/2009-05/24/2009)

NORTHEAST	5/22/2009	COCONINO	12	WEATHER – STORM RELATED	05:04AM	06:37AM	06:37AM	1,229	793
NORTHWEST	05/18/2009	CORDES	2	WEATHER – LIGHTNING	11:30PM	03:28AM	02:48PM	1,665	344
NORTHWEST	05/23/2009	COTTONWOOD	18	WEATHER – WIND	03:57PM	04:28PM	04:28PM	1,225	2,371
SOUTHEAST	05/21/2009	PINAL	1	FOREIGN INTERFERENCE – OTHER ACCIDENTAL CAUSE	04:24PM	05:29PM	05:29PM	1,214	1,121

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

6/24/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(05/25/2009-05/31/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHWEST	05/25/2009	BALD MOUNTAIN	9	UNDERGROUND CABLE	09:01PM	10:21PM	10:21PM	1,700	1,275

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

6/24/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(06/01/2009 - 06/07/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/01/2009	SURPRISE	21	FOREIGN INTERFERENCE – VEHICLES	08:55AM	10:45AM	10:45AM	1,511	824
METRO	06/05/2009	CAVE CREEK	10	FOREIGN INTERFERENCE – BIRDS	11:39PM	07:39AM	07:39AM	1,048	131
SOUTHEAST	06/03/2009	CASA GRANDE	6	FOREIGN INTERFERENCE – VEHICLES	04:48PM	05:55PM	01:46PM 06/04/09	1,010	486

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(06/01/2009 - 06/07/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/01/2009	SURPRISE	21	FOREIGN INTERFERENCE – VEHICLES	08:55AM	10:45AM	10:45AM	1,511	824
METRO	06/05/2009	CAVE CREEK	10	FOREIGN INTERFERENCE – BIRDS	11:39PM	07:39AM	07:39AM	1,048	131
SOUTHEAST	06/03/2009	CASA GRANDE	6	FOREIGN INTERFERENCE – VEHICLES	04:48PM	05:55PM	01:46PM (06/04/09)	1,010	486
SOUTHWEST	06/04/2009	IVALON	5	SUBSTATION RELATED	06:35 AM	11:16 AM	11:16 AM	4,875	1,041
SOUTHWEST	06/04/2009	REDONDO	2	SUBSTATION RELATED	06:35 AM	08:02 AM	08:02 AM	1,054	727

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

The highlighted items reflect change(s).

8/6/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(06/08/2009 - 06/14/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	06/10/2009	LEROUX	3	FOREIGN INTERFERENCE – BIRDS	02:38AM	05:10AM	05:10AM	2,749	1,085
NORTHWEST	06/11/2009	SEDONA	6	FOREIGN INTERFERENCE – CRANE CONTACT	11:06PM	01:03AM	01:03AM	3,001	1,539
SOUTHEAST	06/08/2009	FAIRVIEW	14	WEATHER – WIND	09:28PM	12:36AM	02:34AM	6,320	748

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

7/2/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(06/08/2009 - 06/14/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/14/2009	PARADISE	9	SUBSTATION RELATED – CAT IN SUBSTATION	09:29 PM	10:17 PM	10:17 PM	1,855	2,319
METRO	06/14/2009	PARADISE	10	SUBSTATION RELATED – CAT IN SUBSTATION	09:29 PM	10:22 PM	10:22 PM	1,530	1,732
METRO	06/14/2009	PARADISE	14	SUBSTATION RELATED – CAT IN SUBSTATION	09:29 PM	10:23 PM	10:23 PM	1,733	1,926
NORTHEAST	06/10/2009	LEROUX	3	FOREIGN INTERFERENCE – BIRDS	02:38AM	05:10AM	05:10AM	2,749	1,085
NORTHWEST	06/11/2009	SEDONA	6	FOREIGN INTERFERENCE – CRANE CONTACT	11:06PM	01:03AM	01:03AM	3,001	1,539
SOUTHEAST	06/08/2009	FAIRVIEW	14	WEATHER – WIND	09:28PM	12:36AM	02:34AM	8,348	2209

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

The highlighted items reflect change(s).

8/6/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(06/15/2009 - 06/21/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	06/15/2009	TONTO	1	FOREIGN INTERFERENCE – VEHICLES	11:46AM	12:13PM	03:38PM	1,305	2,862
NORTHWEST	06/21/2009	COPPER CANYON	6	EQUIPMENT FAILURE	09:42PM	11:04PM	12:03AM	2,797	1,964
SOUTHEAST	06/18/2009	SAN MANUEL	29	EQUIPMENT FAILURE STORM RELATED	01:24PM	01:39PM	11:32PM	2,866	1,462

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

7/27/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(06/22/2009-06/28/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHWEST	06/24/2009	COTTONWOOD	14	FOREIGN INTERFERENCE - OTHER ACCIDENTIAL CAUSE	11:38AM	12:23PM	02:19PM	3,663	2,104
NORTHWEST	06/24/2009	PRESCOTT CITY	7	FOREIGN INTERFERENCE - VEHICLE	04:05PM	05:16PM	05:16PM	1,244	1,051
NORTHWEST	06/24/2009	DELANO	10	FOREIGN INTERFERENCE - VEHICLE	05:35PM	07:40PM	07:40PM	4,185	2,009
SOUTHEAST	06/26/2009	DON LUIS	1	EQUIPMENT FAILURE	03:26PM	04:14PM	05:04PM	1,101	884

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

7/24/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(06/29/2009 - 07/05/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/01/2009	CAMELBACK	18	FOREIGN INTERFERENCE – VEHICLES	11:50AM	12:38PM	05:45PM	3,388	1,382
METRO	07/02/2009	AJO	1	TRANSMISSION RELATED – STORM	03:18PM	11:40PM	11:40PM	8,877	1,061
METRO	07/02/2009	AZTEC	10	TRANSMISSION RELATED – STORM	04:45PM	10:48PM	10:48PM	1,192	197
NORTHEAST	07/04/2009	BLUE RIDGE	12	WEATHER – STORM	07:45AM	09:56AM	11:32AM	1,728	456
SOUTHEAST	06/30/2009	VALLEY FARMS	4	EQUIPMENT FAILURE – STORM	01:17PM	02:07PM	02:07PM	1,378	1,654
SOUTHEAST	07/03/2009	PINAL	4	EQUIPMENT FAILURE – STORM	05:20PM	07:03PM	09:38PM	2,094	550
SOUTHEAST	07/03/2009	VALLEY FARMS	4	EQUIPMENT FAILURE – STORM	07:19PM	09:08PM	09:41PM	4,086	1,785

7/24/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(06/29/2009 - 07/05/2009)

SOUTHEAST	07/03/2009	FARRELL	6	LOSS OF SUPPLY – OTHER UTILITY	08:04PM	10:45PM	12:47AM	2,329	846
SOUTHEAST	07/05/2009	DON LUIS	1	FOREIGN INTERFERENCE – VEHICLES	05:08PM	06:09PM	07:41PM	2,209	866

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(07/06/2009-07/12/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/07/2009	EASTERN OFFICE	9	UNKNOWN/ OTHER	06:46AM	07:27AM	08:39AM	2,619	2,772
NORTHEAST	07/06/2009	SHOWLOW	13	EQUIPMENT FAILURE	10:07PM	12:16AM	03:26AM	6,016	1,599
NORTHEAST	07/08/2009	SHOWLOW	13	EQUIPMENT FAILURE	03:58PM	07:16PM	07:16PM	2,016	611
NORTHEAST	07/12/2009	SHOWLOW	13	EQUIPMENT FAILURE	10:54AM	11:29AM	12:44PM	1,196	1,509
NORTHWEST	07/07/2009	STRUM RUGER	12	EQUIPMENT FAILURE	02:05AM	05:35AM	05:35AM	2,100	600
NORTHWEST	07/11/2009	QUAIL SPRINGS	2	WEATHER-STORM RELATED	01:07PM	02:16PM	02:16PM	1,662	1,445
SOUTHEAST	07/08/2009	SAN MANUEL	29	WEATHER-STORM RELATED	07:01PM	07:08AM	07:08AM	1,575	130
SOUTHEAST	07/12/2009	VALLEY FARMS	4	UNKNOWN/ OTHER	09:08PM	10:09PM	04:20AM	1,571	1,365

8/11/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/06/2009-07/12/2009)

SOUTHWEST	07/12/2009	QUECHAN	18	SUBSTATION RELATED	03:18AM	03:51AM	03:51AM	1,008	1,832

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(07/06/2009-07/12/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/07/2009	EASTERN OFFICE	9	UNKNOWN/ OTHER	06:46AM	07:27AM	08:39AM	2,619	2,772
NORTHEAST	07/06/2009	SHOWLOW	13	EQUIPMENT FAILURE	10:07PM	12:16AM	03:26AM	6,016	1,599
NORTHEAST	07/08/2009	SHOWLOW	13	EQUIPMENT FAILURE	03:58PM	07:16PM	07:16PM	2,016	611
NORTHEAST	07/12/2009	SHOWLOW	13	EQUIPMENT FAILURE	10:54AM	11:29AM	12:44PM	1,196	1,509
NORTHWEST	07/07/2009	STRUM RUGER	12	EQUIPMENT FAILURE	02:05AM	05:35AM	05:35AM	2,100	600
NORTHWEST	07/11/2009	QUAIL SPRINGS	2	WEATHER-STORM RELATED	01:07PM	02:16PM	02:16PM	1,662	1,445
SOUTHEAST	07/08/2009	SAN MANUEL	29	WESTHER-STORM RELATED	07:01PM	07:08AM	07:08AM	1,575	130
SOUTHEAST	07/12/2009	VALLEY FARMS	4	UNKNOWN/ OTHER	09:08PM	10:09PM	[redacted]	[redacted]	1,365

9/3/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/06/2009-07/12/2009)
REVISED

SOUTHWEST	07/12/2009	QUECHAN	18	SUBSTATION RELATED	03:18AM	03:51AM	03:51AM	1,008	1,832

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/14/2009	MOON VALLEY	6	EQUIPMENT FAILURE	02:38AM	03:12AM	03:47AM	1,134	1,545
METRO	07/14/2009	GREENWAY	1	EQUIPMENT FAILURE	10:37AM	11:57AM	11:57AM	1,064	798
METRO	07/16/2009	ALTADENA	3	UNDERGROUND CABLE	12:45PM	01:58PM	03:51PM	2,980	1,722
METRO	07/17/2009	PATTERSON	12	WEATHER – STORM RELATED	07:32PM	05:19AM	05:19AM 7/21/09	2,944	36
METRO	07/19/2009	LOOKOUT	12	EQUIPMENT FAILURE	05:44PM	06:30PM	07:30PM	2,012	2,000
METRO	07/19/2009	GILA BEND	10	EQUIPMENT FAILURE	06:12PM	09:36AM	09:36AM 7/21/09	21.946	557
METRO	07/19/2009	GILA BEND	22	TRANSMISSION RELATED – STORM RELATED	06:29PM	12:00AM	12:00AM 7/22/09	23,494	439
METRO	07/19/2009	AJO	1	TRANSMISSION RELATED – STORM RELATED	06:30PM	07:20AM	07:20AM 7/21/09	39,080	1,061
METRO	07/19/2009	PIMA	6	EQUIPMENT FAILURE – STORM RELATED	08:04PM	12:32AM	12:32AM	2,381	533

8/31/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)

METRO	07/19/2009	BASELINE	1	EQUIPMENT FAILURE – STORM RELATED	08:19PM	10:45PM	01:54AM	1,251	321
METRO	07/19/2009	DOVE VALLEY	13	WEATHER – STORM RELATED	08:49PM	09:31PM	10:26PM	1,357	1,416
NORTHEAST	07/16/2009	WINSLOW	2	FOREIGN INTERFERENCE – VEHICLES	10:31AM	11:13AM	11:13AM	1,501	2,144
NORTHEAST	07/18/2009	SNOWFLAKE	2	EQUIPMENT FAILURE	02:21PM	07:46PM	07:46PM	1,609	297
NORTHEAST	07/18/2009	SNOWFLAKE	2	WEATHER – STORM RELATED	05:13PM	07:27PM	07:27PM	4,755	2,129
NORTHEAST	07/18/2009	SNOWFLAKE	2	WEATHER – STORM RELATED	06:07PM	07:34PM	07:34PM	1,021	704
NORTHWEST	07/17/2009	QUAIL SPRINGS	10	OVERLOAD DUE TO SWITCHING	02:43PM	03:46PM	04:51PM	1,180	775
NORTHWEST	07/17/2009	BAGDAD TOWN	4	EQUIPMENT FAILURE – STORM RELATED	08:30PM	10:43PM	10:43PM	2,252	1,016

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)

SOUTHEAST	07/16/2009	HAYES GULCH	1	EQUIPMENT FAILURE – STORM RELATED	06:24PM	06:57PM	07:49PM	6,691	1.767
SOUTHEAST	07/17/2009	COOLIDGE	2	WEATHER – STORM RELATED	07:19PM	08:29PM	08:29PM	1,093	937
SOUTHWEST	07/13/2009	COCOPAH	1	UNKNOWN / OTHER	08:48PM	11:20PM	01:40AM	2,440	908
SOUTHWEST	07/18/2009	ARABY	1	WEATHER – STORM RELATED	04:00PM	05:26PM	05:26PM	2,440	1,702
SOUTHWEST	07/18/2009	COCOPAH	13	WEATHER – STORM RELATED	04:28PM	06:01PM	06:01PM	2,695	1,739
SOUTHWEST	07/18/2009	THIRTY-SECOND ST	9	WEATHER – STORM RELATED	04:28PM	07:09PM	07:09PM	2,436	908
SOUTHWEST	07/18/2009	QUECHAN	30	WEATHER – STORM RELATED	04:39PM	07:49PM	07:49PM	3,873	1,223
SOUTHWEST	07/19/2009	COCOPAH	10	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	07:57PM	07:57PM	3,504	1,569
SOUTHWEST	07/19/2009	COCOPAH	12	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	07:59PM	07:59PM	3,801	1,677

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)

SOUTHWEST	07/19/2009	COCOPAH	13	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	07:05PM	07:05PM	2,377	1,739
SOUTHWEST	07/19/2009	COCOPAH	14	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	08:52PM	08:52PM	4,933	1,566
SOUTHWEST	07/19/2009	ARABY	1	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:47PM	09:10PM	09:10PM	4,277	1,264
SOUTHWEST	07/19/2009	COCOPAH	2	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:47PM	07:07PM	07:07PM	2,475	1,856
SOUTHWEST	07/19/2009	COCOPAH	5	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:48PM	07:57PM	07:57PM	4,463	2,076
SOUTHWEST	07/19/2009	FOOTHILLS	9	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:50PM	09:29PM	09:29PM	7,198	1,972

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

8/31/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/14/2009	MOON VALLEY	6	EQUIPMENT FAILURE	02:38AM	03:12AM	03:47AM	1,134	1,545
METRO	07/14/2009	GREENWAY	1	EQUIPMENT FAILURE	10:37AM	11:57AM	11:57AM	1,064	798
METRO	07/14/2009	GREENWAY	9	EQUIPMENT FAILURE	10:37AM	11:12AM	11:57AM	1,000	826
METRO	07/16/2009	ALTADENA	3	UNDERGROUND CABLE	12:45PM	01:58PM	03:51PM	2,980	1,722
METRO	07/17/2009	PATTERSON	12	WEATHER – STORM RELATED	07:32PM	05:19AM	05:19AM 7/21/09	2,944	36
METRO	07/19/2009	LOOKOUT	12	EQUIPMENT FAILURE	05:44PM	06:30PM	07:30PM	2,012	2,000
METRO	07/19/2009	GILA BEND	10	EQUIPMENT FAILURE	06:12PM	09:36AM	09:36AM 7/21/09	21.946	557
METRO	07/19/2009	GILA BEND	22	TRANSMISSION RELATED – STORM RELATED	06:29PM	12:00AM	12:00AM 7/22/09	23,494	439
METRO	07/19/2009	AJO	1	TRANSMISSION RELATED – STORM RELATED	06:30PM	07:20AM	07:20AM 7/21/09	39,080	1,061

9/3/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)
REVISED

METRO	07/19/2009	PIMA	6	EQUIPMENT FAILURE – STORM RELATED	08:04PM	12:32AM	12:32AM	2,381	533
METRO	07/19/2009	BASELINE	1	EQUIPMENT FAILURE – STORM RELATED	08:19PM	10:45PM	01:54AM	1,251	321
METRO	07/19/2009	DOVE VALLEY	13	WEATHER – STORM RELATED	08:49PM	09:31PM	10:26PM	1,357	1,416
NORTHEAST	07/16/2009	WINSLOW	2	FOREIGN INTERFERENCE – VEHICLES	10:31AM	11:13AM	11:13AM	1,501	2,144
NORTHEAST	07/18/2009	SNOWFLAKE	2	EQUIPMENT FAILURE	02:21PM	07:46PM	07:46PM	1,609	297
NORTHEAST	07/18/2009	SNOWFLAKE	2	WEATHER – STORM RELATED	05:13PM	07:27PM	07:27PM	4,755	2,129
NORTHEAST	07/18/2009	SNOWFLAKE	2	WEATHER – STORM RELATED	06:07PM	07:34PM	07:34PM	1,021	704
NORTHWEST	07/17/2009	QUAIL SPRINGS	10	OVERLOAD DUE TO SWITCHING	02:43PM	03:46PM	04:51PM	1,180	775
NORTHWEST	07/17/2009	BAGDAD TOWN	4	EQUIPMENT FAILURE – STORM RELATED	08:30PM	10:43PM	10:43PM	2,252	1,016

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)
REVISED

SOUTHEAST	07/16/2009	HAYES GULCH	1	EQUIPMENT FAILURE – STORM RELATED	06:24PM	06:57PM	07:49PM	6,691	1.767
SOUTHEAST	07/17/2009	COOLIDGE	2	WEATHER – STORM RELATED	07:19PM	08:29PM	08:29PM	1,093	937
SOUTHWEST	07/13/2009	COCOPAH	1	UNKNOWN / OTHER	08:48PM	11:20PM	01:40AM	2,440	908
SOUTHWEST	07/18/2009	ARABY	1	WEATHER – STORM RELATED	04:00PM	05:26PM	05:26PM	2,440	1,702
SOUTHWEST	07/18/2009	COCOPAH	13	WEATHER – STORM RELATED	04:28PM	06:01PM	06:01PM	2,695	1,739
SOUTHWEST	07/18/2009	THIRTY-SECOND ST	9	WEATHER – STORM RELATED	04:28PM	07:09PM	07:09PM	2,436	908
SOUTHWEST	07/18/2009	QUECHAN	30	WEATHER – STORM RELATED	04:39PM	07:49PM	07:49PM	3,873	1,223
SOUTHWEST	07/19/2009	COCOPAH	10	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	07:57PM	07:57PM	3,504	1,569
SOUTHWEST	07/19/2009	COCOPAH	12	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	07:59PM	07:59PM	3,801	1,677

9/3/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)
REVISED

SOUTHWEST	07/19/2009	COCOPAH	13	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	07:05PM	07:05PM	2,377	1,739
SOUTHWEST	07/19/2009	COCOPAH	14	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:43PM	08:52PM	08:52PM	4,933	1,566
SOUTHWEST	07/19/2009	ARABY	1	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:47PM	09:10PM	09:10PM	4,277	1,264
SOUTHWEST	07/19/2009	COCOPAH	2	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:47PM	07:07PM	07:07PM	2,475	1,856
SOUTHWEST	07/19/2009	COCOPAH	5	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:48PM	07:57PM	07:57PM	4,463	2,076
SOUTHWEST	07/19/2009	FOOTHILLS	9	LOSS OF SUPPLY – SYSTEM DISTURBANCE / CURTAILMENT	05:50PM	09:29PM	09:29PM	7,198	1,972

1000 HOUR CUSTOMER OUTAGE REPORT
(07/13/2009-07/19/2009)
REVISED

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/3/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/20/09	SADDLE MOUNTAIN	6	WEATHER – STORM RELATED	17:57 PM	03:15 AM 07/22/09	14:49 PM 07/22/09	2,200	61
METRO	07/20/09	GLENDALE	18	WEATHER – STORM RELATED	18:32 PM	12:52 AM	12:52 AM	5,162	815
METRO	07/20/09	ENCANTO	13	WEATHER – STORM RELATED	18:43 PM	20:38 PM	22:30 PM	1,094	413
METRO	07/20/09	MCDOWELL	20	WEATHER – STORM RELATED	19:16 PM	22:44 PM	02:25 AM	6,746	1,826
METRO	07/20/09	SHAW	15	WEATHER – STORM RELATED	19:40 PM	20:30 PM	21:56 PM	2,816	3,376
METRO	07/20/09	ESTRELLITA	5	WEATHER – STORM RELATED	21:16 PM	00:59 AM	05:30 AM	4,070	1,069
METRO	07/21/09	ORANGEWOOD	33	SUBSTATION RELATED	07:09 AM	07:56 AM	07:56 AM	1,715	2,189
METRO	07/21/09	VALENCIA	1	WEATHER – STORM RELATED	20:47 PM	21:35 PM	22:40 PM	1,742	1,727

8/31/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)

METRO	07/22/09	SHAW	9	VEHICLE HIT POLE	23:21 PM	00:01 AM	00:15 AM	1,017	1,524
METRO	07/24/09	PERRYVILLE	4	WEATHER – STORM RELATED	00:41 AM	03:40 AM	13:52 PM	2,940	271
METRO	07/24/09	PERRYVILLE	5	TRANSMISSION RELATED – STORM RELATED	00:50 AM	03:15 AM	03:48 AM	1,247	463
METRO	07/24/09	PERRYVILLE	1	TRANSMISSION RELATED – STORM RELATED	00:52 AM	04:11 AM	08:05 AM	2,047	288
METRO	07/24/09	ALTADENA	3	WEATHER – STORM RELATED	00:53 AM	02:56 AM	09:23 AM	3,938	1,722
METRO	07/24/09	ALTADENA	7	WEATHER – STORM RELATED	00:53 AM	02:16 AM	02:16 AM	1,912	1,382
METRO	07/24/09	INDIANOLA	19	EQUIPMENT FAILURE	20:57 PM	21:28 PM	22:25 PM	1,038	1,209
METRO	07/25/09	WINTERSBURG	12	WEATHER – STORM RELATED	21:13 PM	17:13 PM	17:13 PM	1,500	75
NORTHEAST	07/20/09	SWITZER CANYON	13	UNDERGROUND CABLE	03:37 AM	06:15 AM	08:41 AM	6,107	2,007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)

NORTHEAST	07/20/09	KEAMS CANYON	3	TRANSMISSION RELATED – STORM RELATED	13:53 PM	06:53 AM	06:53 AM	26,911	1,583
NORTHEAST	07/20/09	KEAMS CANYON	5	TRANSMISSION RELATED – STORM RELATED	13:53 PM	06:54 PM	06:54 PM	3,012	177
NORTHEAST	07/24/09	WOODY MOUNTAIN	14	WEATHER – STORM RELATED	12:12 PM	14:48 PM	14:48 PM	2,259	869
NORTHEAST	07/25/09	WINSLOW	14	WEATHER – STORM RELATED	15:06 PM	16:46 PM	20:28 PM	1,540	882
NORTHWEST	07/25/09	AGUILA	3	WEATHER – STORM RELATED	18:17 PM	20:54 PM	22:00 PM	1,382	479
NORTHWEST	07/25/09	WICKENBURG	14	WEATHER – STORM RELATED	18:30 PM	08:05 AM	08:21 AM	1,262	92
NORTHWEST	07/25/09	FLYING E	2	WEATHER – STORM RELATED	19:51 PM	20:31 PM	06:18 AM	1,802	675
SOUTHEAST	07/20/2009	SAGUARO	13	WEATHER – STORM RELATED	20:25 PM	22:06 PM	22:55 PM	1,264	528
SOUTHEAST	07/20/2009	SAGUARO	13	WEATHER – STORM RELATED	22:55 PM	22:59 PM	03:25 AM	2,070	528

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)

SOUTHEAST	07/21/2009	SAGUARO	13	WEATHER – LIGHTNING	03:24 AM	03:27 AM	14:45 PM	5,145	528
SOUTHEAST	07/21/2009	FARRELL	6	LOSS OF SUPPLY – OTHER UTILITY (STORM RELATED)	20:30 PM	01:00 AM	07:48 AM	7,707	827
SOUTHEAST	07/25/2009	PALOMINAS	4	WEATHER - LIGHTNING	13:37 PM	14:53 PM	14:58 PM	1,780	1,348

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/20/09	SADDLE MOUNTAIN	6	WEATHER – STORM RELATED	05:57 PM	03:15 AM 07/22/09	02:49 PM 07/22/09	2,200	61
METRO	07/20/09	GLENDALE	18	WEATHER – STORM RELATED	06:32 PM	12:52 AM	12:52 AM	5,162	815
METRO	07/20/09	ENCANTO	13	WEATHER – STORM RELATED	06:43 PM	08:38 PM	10:30 PM	1,094	413
METRO	07/20/09	MCDOWELL	20	WEATHER – STORM RELATED	07:16 PM	10:44 PM	02:25 AM	6,746	1,826
METRO	07/20/09	SHAW	15	WEATHER – STORM RELATED	07:40 PM	08:30 PM	09:56 PM	2,816	3,376
METRO	07/20/09	ESTRELLITA	5	WEATHER – STORM RELATED	09:16 PM	12:59 AM	05:30 AM	4,070	1,069
METRO	07/21/09	ORANGEWOOD	33	SUBSTATION RELATED	07:09 AM	07:56 AM	07:56 AM	1,715	2,189
METRO	07/21/09	VALENCIA	1	WEATHER – STORM RELATED	08:47 PM	09:35 PM	10:40 PM	1,742	1,727

9/3/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)
REVISED

METRO	07/22/09	SHAW	9	VEHICLE HIT POLE	11:21 PM	12:01 AM	12:15 AM	1,017	1,524
METRO	07/24/09	PERRYVILLE	4	WEATHER – STORM RELATED	12:41 AM	03:40 AM	01:52 PM	2,940	271
METRO	07/24/09	PERRYVILLE	5	TRANSMISSION RELATED – STORM RELATED	12:50 AM	03:15 AM	03:48 AM	1,247	463
METRO	07/24/09	PERRYVILLE	1	TRANSMISSION RELATED – STORM RELATED	12:52 AM	04:11 AM	08:05 AM	2,047	288
METRO	07/24/09	ALTADENA	3	WEATHER – STORM RELATED	12:53 AM	02:56 AM	09:23 AM	3,938	1,722
METRO	07/24/09	ALTADENA	7	WEATHER – STORM RELATED	12:53 AM	02:16 AM	02:16 AM	1,912	1,382
METRO	07/24/09	INDIANOLA	19	EQUIPMENT FAILURE	08:57 PM	09:28 PM	10:25 PM	1,038	1,209
METRO	07/25/09	WINTERSBURG	12	WEATHER – STORM RELATED	09:13 PM	05:13 PM	05:13 PM	1,500	75
NORTHEAST	07/20/09	SWITZER CANYON	13	UNDERGROUND CABLE	03:37 AM	06:15 AM	08:41 AM	6,107	2,007

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)
REVISED

NORTHEAST	07/20/09	KEAMS CANYON	3	TRANSMISSION RELATED – STORM RELATED	01:53 PM	06:53 AM	06:53 AM	26,911	1,583
NORTHEAST	07/20/09	KEAMS CANYON	5	TRANSMISSION RELATED – STORM RELATED	01:53 PM	06:54 PM	06:54 PM	3,012	177
NORTHEAST	07/24/09	WOODY MOUNTAIN	14	WEATHER – STORM RELATED	12:12 PM	02:48 PM	02:48 PM	2,259	869
NORTHEAST	07/25/09	WINSLOW	14	WEATHER – STORM RELATED	03:06 PM	04:46 PM	08:28 PM	1,540	882
NORTHWEST	07/25/09	AGUILA	3	WEATHER – STORM RELATED	06:17 PM	08:54 PM	10:00 PM	1,382	479
NORTHWEST	07/25/09	WICKENBURG	14	WEATHER – STORM RELATED	06:30 PM	08:05 AM	08:21 AM	1,262	92
NORTHWEST	07/25/09	FLYING E	2	WEATHER – STORM RELATED	07:51 PM	08:31 PM	06:18 AM	1,802	675
SOUTHEAST	07/20/2009	SAGUARO	13	WEATHER – STORM RELATED	08:25 PM	10:06 PM	02:45 PM	8,531	528
SOUTHEAST	07/21/2009	FARRELL	6	LOSS OF SUPPLY – OTHER UTILITY (STORM RELATED)	08:30 PM	01:00 AM	07:48 AM	7,707	827

1000 HOUR CUSTOMER OUTAGE REPORT
(07/20/2009-07/26/2009)
REVISED

SOUTHEAST	07/25/2009	PALOMINAS	4	WEATHER - LIGHTNING	01:37 PM	02:53 PM	02:58 PM	1,780	1,348

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/3/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(07/27/2009-08/02/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/27/2009	DESERT SPRINGS	14	EQUIPMENT FAILURE	03:15AM	04:13AM	05:34AM	2,010	1,674
METRO	08/01/2009	SURPRISE	21	EQUIPMENT FAILURE	06:10AM	07:59AM	07:59AM	1,310	721

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

8/31/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/03/2009 - 08/09/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/03/2009	SPANISH GARDENS	12	UNDERGROUND CABLE	02:58AM	03:36AM	04:26AM	1,270	1,134
METRO	08/03/2009	SPANISH GARDENS	5	UNDERGROUND CABLE	08:24PM	08:57PM	09:33PM	1,135	1,594
NORTHEAST	08/05/2009	LEROUX	3	EQUIPMENT FAILURE - STORM RELATED	02:06PM	06:05PM	09:40PM	5,659	755
NORTHEAST	08/08/2009	KEAMS CANYON	3	EQUIPMENT FAILURE	09:35PM	01:39AM	01:39AM	2,098	516
NORTHEAST	08/09/2009	SWITZER CANYON	13	UNDERGROUND CABLE	10:19PM	10:51PM	12:26AM	4,410	5,681
NORTHWEST	08/03/2009	SEDONA	14	FOREIGN INTERFERENCE – BIRDS	11:41AM	12:56PM	12:56PM	2,116	1,693

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/3/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/10/2009 - 08/16/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/12/2009	MOUNTAIN VIEW	9	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	11:02PM	12:46AM	01:20AM	2,570	1,307
METRO	08/13/2009	ROADRUNNER	17	EQUIPMENT FAILURE	04:10PM	04:49PM	09:51PM	1,527	1,699
METRO	08/16/2009	MCCORMICK	13	UNKNOWN / OTHER	06:13AM	06:48AM	07:46AM	1,567	1,968
METRO	08/16/2009	EL SOL	18	EQUIPMENT FAILURE	07:35PM	08:49PM	12:55AM	1,723	1,310
NORTHWEST	08/12/2009	QUAIL SPRINGS	6	WEATHER – STORM RELATED	07:04PM	08:34PM	08:34PM	2,462	1,641
NORTHWEST	08/15/2009	COPPER CANYON	6	FOREIGN INTERFERENCE – BIRDS	11:54AM	02:29PM	04:59PM	3,798	1,083

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

9/18/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/17/2009-08/23/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/17/2009	DEER VALLEY	30	UNDERGROUND CABLE	09:58PM	11:03PM	01:06AM	3,207	1,122
METRO	08/21/2009	ENCANTO	12	FOREIGN INTERFERENCE – VEHICLES	03:48PM	03:58PM	06:00AM	2,076	919
METRO	08/21/2009	EASTERN OFFICE	9	EQUIPMENT FAILURE – STORM RELATED	07:55PM	08:17PM	10:44PM	1,484	2,772
METRO	08/21/2009	PERRYVILLE	5	WEATHER – WIND	08:30PM	11:49PM	11:49PM	1,536	463
METRO	08/21/2009	WADDEL	13	VEGETATION CONTACT – STORM	08:50PM	10:12PM	10:12PM	1,764	1,291
METRO	08/21/2009	PALM VALLEY	2	EQUIPMENT FAILURE – STORM RELATED	08:53PM	10:56PM	09:40AM	2,410	573
METRO	08/21/2009	PEBBLE CREEK	5	WEATHER – WIND	05:47AM	07:49AM	09:39AM	1,420	518
NORTHWEST	08/21/2009	WICKENBURG	14	WEATHER – STORM RELATED	08:01PM	10:00PM	10:00PM	2,277	1,148

9/22/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/17/2009-08/23/2009)

SOUTHEAST	08/19/2009	TOLTEC	5	EQUIPMENT FAILURE	03:23AM	05:31AM	06:31AM	1,590	693
SOUTHEAST	08/21/2009	HIDDEN VALLEY	2	EQUIPMENT FAILURE STORM RELATED	09:52PM	12:05AM	07:45AM	2,357	489

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(08/17/2009-08/23/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/17/2009	DEER VALLEY	30	UNDERGROUND CABLE	09:58PM	11:03PM	12:34AM	2,705	1,122
METRO	08/21/2009	ENCANTO	12	FOREIGN INTERFERENCE – VEHICLES	03:48PM	03:58PM	06:00AM	2,076	919
METRO	08/21/2009	EASTERN OFFICE	9	EQUIPMENT FAILURE – STORM RELATED	07:55PM	08:17PM	10:44PM	1,484	2,772
METRO	08/21/2009	PERRYVILLE	5	WEATHER – WIND	08:30PM	11:49PM	11:49PM	1,536	463
METRO	08/21/2009	WADDELL	13	VEGETATION CONTACT – STORM	08:50PM	10:12PM	10:12PM	1,764	1,291
METRO	08/21/2009	PALM VALLEY	2	EQUIPMENT FAILURE – STORM RELATED	08:53PM	10:56PM	09:40AM	2,410	573
METRO	08/21/2009	EL SOL	14	WEATHER – STORM RELATED	10:23PM	11:23PM	11:23PM	1,464	1,464

10/16/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/17/2009-08/23/2009)
REVISED

METRO	08/21/2009	PEBBLE CREEK	5	WEATHER – WIND	05:47AM	07:49AM	09:39AM	1,420	518
NORTHWEST	08/21/2009	WICKENBURG	14	WEATHER – STORM RELATED	08:01PM	10:00PM	10:00PM	2,277	1,148
SOUTHEAST	08/19/2009	TOLTEC	5	EQUIPMENT FAILURE	03:23AM	05:31AM	06:31AM	1,590	693
SOUTHEAST	08/21/2009	HIDDEN VALLEY	2	EQUIPMENT FAILURE STORM RELATED	09:52PM	12:05AM	07:45AM	2,357	489

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

10/16/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/24/2009-08/30/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/27/2009	JAVELINA	1	EQUIPMENT FAILURE	03:42PM	04:41PM	05:12PM	1,029	882
METRO	08/30/2009	DALE	13	EQUIPMENT FAILURE	06:00AM	06:49AM	07:57AM	1,915	1,097
NORTHEAST	08/25/2009	WINSLOW	2	FOREIGN INTERFERENCE - VEHICLES	12:27AM	04:11AM	12:15PM	9,855	2,144
NORTHEAST	08/26/2009	KEAMS CANYON	3	SUBSTATION RELATED	12:26PM	02:25PM	02:25PM	3,140	1,583
SOUTHEAST	08/28/2009	PINAL	1	SUBSTATION RELATED	07:31AM	09:55AM	09:55AM	2,393	997
SOUTHEAST	08/28/2009	PINAL	2	SUBSTATION RELATED	07:31AM	09:56AM	09:56AM	2,221	919
SOUTHEAST	08/28/2009	PINAL	3	SUBSTATION RELATED	07:31AM	09:57AM	09:57AM	3,550	1,459

10/13/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/24/2009-08/30/2009)

SOUTHEAST	08/28/2009	PINAL	4	SUBSTATION RELATED	07:31AM	09:57AM	09:57AM	5,127	2,107
SOUTHEAST	08/28/2009	PINAL	5	SUBSTATION RELATED	07:31AM	09:59AM	09:59AM	1,339	543

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(08/31/2009-09/06/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/31/2009	AJO	1	EQUIPMENT FAILURE - STORM RELATED	08:15PM	10:14PM	10:14PM	2,104	1,061
METRO	09/01/2009	DIXILETA	12	FOREIGN INTERFERENCE - ANIMALS	08:41AM	09:18AM	10:49AM	1,802	2,317
METRO	09/03/2009	STAGECOACH	5	WEATHER-WIND	11:39PM	01:22AM	02:38AM	3,082	1,727
METRO	09/05/2009	GREENWAY	1	EQUIPMENT FAILURE - STORM RELATED	09:22AM	10:15AM	10:15AM	1,481	1,677
METRO	09/05/2009	ROCK SPRINGS	3	EQUIPMENT FAILURE - STORM RELATED	01:56PM	02:50PM	07:10PM	2,091	1,515
NORTHWEST	09/05/2009	CHINO VALLEY	10	EQUIPMENT FAILURE - STORM RELATED	12:57PM	01:36PM	01:36PM	1,723	2,650
SOUTHWEST	09/01/2009	QUARTZSITE	2	WEATHER-WIND	01:47AM	03:02AM	03:02AM	1,004	803
SOUTHWEST	09/01/2009	QUARTZSITE	6	WEATHER-WIND	03:45AM	05:36AM	06:07AM	2,234	1,070

10/9/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(08/31/2009-09/06/2009)

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

10/9/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(09/07/2009-09/13/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off*	Customer Count**
METRO	09/07/2009	DIXILETA	2	FOREIGN INTERFERENCE	07:33AM	08:42AM	09:27AM	1,299	1,032
METRO	09/12/2009	TWENTY-THIRD ST	22	FOREIGN INTERFERENCE	01:01AM	02:44AM	09:57AM	4,544	2030
NORTHEAST	09/08/2009	TONTO	14	WEATHER – LIGHTNING	06:58PM	12:38AM	01:49AM	2,632	433
NORTHEAST	09/10/2009	SNOWFLAKE	02	EQUIPMENT FAILURE	02:07AM	03:30AM	06:14AM	4,200	2,129
NORTHWEST	09/8/2009	WHITE SPAR	12	FOREIGN INTERFERENCE	04:00AM	06:24AM	06:24AM	1,152	480

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/29/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(09/14/2009-09/20/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/14/2009	CACTUS	25	UNKNOWN/ OTHER	06:34AM	07:14AM	08:18AM	1,773	1,404
METRO	09/15/2009	CANAL	13	FOREIGN INTERFERENCE - VEHICLE	02:06AM	02:41AM	12:46PM	1,923	634
METRO	09/20/2009	RIO VISTA	2	FOREIGN INTERFERENCE - VEHICLE	02:35AM	03:40AM	09:47AM	2,148	1,620

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(09/21/2009-09/27/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/21/2009	MARINETTE	10	FOREIGN INTERFERENCE	04:50AM	05:52AM	05:52AM	1,473	1,425
NORTHWEST	09/22/2009	GLASSFORD HILL TEMPORARY	2	TRANSMISSION RELATED	06:40AM	07:34AM	07:34AM	1,623	1,803
NORTHWEST	09/22/2009	GLASSFORD HILL TEMPORARY	4	TRANSMISSION RELATED	06:40AM	07:35AM	07:35AM	1,141	1,245
NORTHWEST	09/24/2009	BALD MOUNTAIN	1	FOREIGN INTERFERENCE	03:04PM	03:38PM	06:43PM	1,726	2,751

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(09/28/2009-10/04/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHWEST	10/03/2009	CHINO VALLEY	6	FOREIGN INTERERENCE	07:52AM	08:37AM	09:19AM	2,238	33
SOUTHEAST	09/29/2009	VALLEY FARMS	4	EQUIPMENT FAILURE	10:26AM	12:22PM	07:50PM	7,193	1,677

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

10/15/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(09/28/2009-10/04/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/04/2009	MEADOWBROOK	22	FOREIGN INTERFERENCE - VEHICLES	02:52AM	03:42AM	12:10PM	1,657	940
NORTHWEST	10/03/2009	CHINO VALLEY	6	FOREIGN INTERFERENCE - VEHICLES	08:37AM	09:19AM	09:19AM	2,190	3,128
SOUTHEAST	09/29/2009	VALLEY FARMS	4	EQUIPMENT FAILURE	10:26AM	12:22PM	07:50PM	7,193	1,677
SOUTHWEST	10/03/2009	LAGUNA	1	TRANSMISSION RELATED	11:53AM	12:55AM	12:55AM	1,666	1,612
SOUTHWEST	10/03/2009	LAGUNA	5	TRANSMISSION RELATED	11:53AM	12:55AM	12:55AM	1,873	1,813
SOUTHWEST	10/03/2009	LAGUNA	9	TRANSMISSION RELATED	11:53AM	12:56AM	12:56AM	1,730	1,648
SOUTHWEST	10/03/2009	LAGUNA	13	TRANSMISSION RELATED	11:53AM	12:56AM	12:56AM	1,607	1,530

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(10/05/2009-10/11/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/06/2009	CACTUS	34	EQUIPMENT FAILURE	10:11AM	10:49AM	11:11AM	1,785	2,086
SOUTHEAST	10/08/2009	BOOTHILL	1	FOREIGN INTERFERENCE - VANDALISM	05:39AM	10:55AM	11:02AM	5,835	1,104

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

10/23/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(10/12/2009-10/18/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/16/2009	ROADRUNNER	22	FOREIGN INTERFERENCE-BIRDS	08:43AM	10:02AM	12:00PM	2,258	1,248
METRO	10/16/2009	TURF	13	EQUIPMENT FAILURE	11:47AM	12:15PM	12:48PM	1,009	1,728
METRO	10/17/2009	LOMA VISTA	14	UNDERGROUND CABLE	09:27AM	10:19AM	11:37AM	1,883	1,441
NORTHEAST	10/14/2009	MAZATZAL TEMPORARY	6	FOREIGN INTERFERENCE-VANDALISM	06:04PM	06:59PM	08:02PM	2,568	1,535

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(10/19/2009-10/25/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/21/2009	ORANGEWOOD	32	EQUIPMENT FAILURE - APS	07:42AM	08:40AM	08:40AM	1,206	1,248
METRO	10/21/2009	ORANGEWOOD	33	SUBSTATION RELATED	07:42AM	08:40AM	08:40AM	2,116	2,189
METRO	10/22/2009	DOVE VALLEY	2	EQUIPMENT FAILURE - APS	05:22AM	06:09AM	09:09AM	1,755	1,589
NORTHEAST	10/20/2009	SWITZER CANYON	13	FOREIGN INTERFERENCE - ANIMALS	09:35PM	11:06PM	12:58AM	4,699	1,948

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

11/19/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(10/26/2009 – 11/01/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/28/2009	TURF	14	FOREIGN INTERFERENCE - VANDALISM	08:33PM	09:03PM	01:30AM	1,623	1,729
METRO	10/30/2009	BUCKEYE	2	SUBSTATION RELATED	09:40PM	11:05PM	11:05PM	2,593	1,830
METRO	10/30/2009	BUCKEYE	4	SUBSTATION RELATED	09:40PM	11:05PM	11:05PM	1,563	1,103
NORTHEAST	10/26/2009	SWITZER CANYON	13	UNDERGROUND CABLE	06:14AM	07:25AM	10:14AM	5,166	2,010
NORTHEAST	10/27/2009	SNOWFLAKE	2	WEATHER – STORM RELATED	10:27PM	12:19AM	01:40AM	1,964	680
NORTHWEST	11/1/2009	MCGUIREVILLE	10	FOREIGN INTERFERENCE - VEHICLE	02:08AM	05:01AM	05:01AM	2,898	1,005
SOUTHWEST	10/27/2009	LAGUNA	1	TRANSMISSION RELATED	04:08PM	06:00PM	06:00PM	1,002	537
SOUTHWEST	10/27/2009	LAGUNA	5	TRANSMISSION RELATED	04:08PM	06:00PM	06:00PM	1,127	604
SOUTHWEST	10/27/2009	LAGUNA	9	TRANSMISSION RELATED	04:08PM	06:00PM	06:00PM	1,025	549

12/7/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(10/26/2009 – 11/01/2009)

SOUTHWEST	10/27/2009	LAGUNA	1	TRANSMISSION RELATED	04:29PM	06:00PM	06:00PM	1,630	1,075
SOUTHWEST	10/27/2009	LAGUNA	5	TRANSMISSION RELATED	04:29PM	06:00PM	06:00PM	1,834	1,209
SOUTHWEST	10/27/2009	LAGUNA	9	TRANSMISSION RELATED	04:29PM	06:00PM	06:00PM	1,667	1,099
SOUTHWEST	10/27/2009	LAGUNA	13	TRANSMISSION RELATED	04:29PM	06:00PM	06:00PM	1,547	1,020

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(11/01/2009 – 11/08/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/03/2009	CACTUS	30	UNDERGROUND CABLE	10:38AM	11:01AM	11:44AM	1,603	2,718
METRO	11/07/2009	CAMELBACK	26	UNDERGROUND CABLE	06:48PM	08:04PM	08:35PM	3,406	2,610
SOUTHWEST	11/04/2009	FOOTHILLS	12	FOREIGN INTERFERENCE - BIRDS	01:44PM	03:24PM	03:24PM	3,448	2,069

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(11/09/2009-11/15/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/11/2009	UNION HILLS	22	UNDERGROUND CABLE	09:33PM	10:03PM	12:07AM	1,278	1,348
NORTHEAST	11/14/2009	KEAMS CANYON	3	SUBSTAION RELATED	07:14AM	01:47PM	01:47PM	10,369	1,583
NORTHEAST	11/14/2009	KEAMS CANYON	5	SUBSTATION RELATED	07:14AM	01:47PM	01:47PM	1,159	177
NORTHEAST	11/15/2009	SNOWFLAKE	2	EQUIPMENT FAILURE	05:30AM	06:23PM	06:23PM	3,929	305

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

12/15/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(11/17/2009 – 11/22/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/17/2009	MOON VALLEY	1	EQUIPMENT FAILURE	03:11AM	03:50AM	04:14AM	1,960	1,832
METRO	11/19/2009	RAINTREE	5	FOREIGN INTERFERENCE – DIG-INS CUSTOMER	11:11AM	12:04PM	07:42PM	3,533	2,851
METRO	11/19/2009	RAINTREE	1	EQUIPMENT FAILURE	02:22PM	02:38PM	07:04PM	1,317	1,659
NORTHEAST	11/19/2009	COCONINO	24	SUBSTATION RELATED	08:00PM	09:06PM	09:06PM	1,825	1,659

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

12/10/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(11/16/2009 – 11/22/2009)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/17/2009	MOON VALLEY	1	EQUIPMENT FAILURE	03:11AM	03:50AM	04:41AM	1,965	1,832
METRO	11/19/2009	RAINTREE	5	FOREIGN INTERFERENCE – DIG-INS CUSTOMER	11:11AM	12:04PM	07:42PM	5,403	2,851
METRO	11/19/2009	RAINTREE	1	EQUIPMENT FAILURE	02:22PM	02:38PM	07:04PM	1,214	2,060
NORTHEAST	11/19/2009	COCONINO	24	SUBSTATION RELATED	08:00PM	09:06PM	09:06PM	1,825	1,659

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The highlighted items reflect changes.

12/30/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(11/23/2009-11/29/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/25/2009	SKUNK CREEK	2	FOREIGN INTERFERENCE	09:09PM	09:46PM	01:54AM	2,658	942
NORTHWEST	11/29/2009	CORNVILLE	2	EQUIPMENT FAILURE	07:06AM	08:57AM	08:57AM	1,249	675

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(11/30/2009-12/06/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/30/2009	ORANGEWOOD	32	SUBSTATION RELATED	09:18AM	10:14AM	10:14AM	1165	1248
METRO	11/30/2009	ORANGEWOOD	33	SUBSTATION RELATED	09:18AM	10:15AM	10:15AM	2080	2189
METRO	12/03/2009	MOUNTAIN VIEW	5	UNDERGROUND CABLE	06:29PM	07:19PM	08:05PM	1588	1470
METRO	12/04/2009	TONOPAH	1	EQUIPMENT FAILURE	08:29PM	09:46PM	03:10AM	1001	532
NORTHEAST	12/06/2009	SANDVIG	10	WEATHER – WIND	07:03PM	10:34PM	10:34PM	1811	515
SOUTHEAST	12/04/2009	CASA GRANDE	6	HUMAN CONTACT – PUBLIC	09:32PM	12:33AM	06:05AM	3676	430

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

12/30/2009

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

The filing of this report was delayed due to the high volume of outages experienced during the severe winter storms that moved across the State on December 7, 2010 and December 8, 2010. The December storms were the worst that Arizona has seen in many years and all but 10 of the outages included in this report were directly related to the storm.

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/07/2009	BUFFALO	1	WEATHER-STORM RELATED	07:38AM	09:36AM	09:36AM	68,500	2,638
METRO	12/07/2009	ARROYO	2	SUBSTATION RELATED – STORM RELATED	12:25PM	12:59PM	12:59PM	1,004	1,771
METRO	12/07/2009	ARROYO	4	SUBSTATION RELATED – STORM RELATED	12:25PM	01:00PM	01:00PM	1,104	1,892
METRO	12/07/2009	ROCK SPRINGS	3	WEATHER – STORM RELATED	05:48PM	09:53PM	09:53PM	6,186	1,515
METRO	12/07/2009	BASELINE	1	EQUIPMENT FAILURE -STORM RELATED	09:33PM	08:58AM	08:58AM	3,665	321
METRO	12/07/2009	TONOPAH	1	EQUIPMENT FAILURE - STORM RELATED	09:42PM	10:42AM	10:42AM	6,916	532

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/07/2009	BASELINE	1	WEATHER – STORM RELATED	09:58PM	09:21AM	12:37PM	4,423	321
METRO	12/07/2009	WADDELL	13	WEATHER – STORM RELATED	10:10PM	04:31AM	04:31AM	8,198	1,291
METRO	12/07/2009	COLDWATER	18	WEATHER – STORM RELATED	10:20PM	05:00PM	05:00PM	3,080	165
METRO	12/07/2009	EL SOL	14	WEATHER – STORM RELATED	10:22PM	04:03AM	04:03AM	8,320	1,464
METRO	12/07/2009	TARTESSO TEMPORARY	4	TRANSMISSION RELATED – STORM RELATED	10:27PM	01:56PM	01:56PM	14,059	908
METRO	12/07/2009	TONOPAH	3	TRANSMISSION RELATED – STORM RELATED	10:27PM	03:16AM	03:16AM	1,455	302
METRO	12/072009	VARNEY	4	EQUIPMENT FAILURE - STORM RELATED	10:35PM	08:20AM	07:30PM	7,666	759
METRO	12/07/2009	BASELINE	12	EQUIPMENT FAILURE - STORM RELATED	10:41PM	07:35PM	07:35PM	1,609	77
METRO	12/07/2009	BUCKEYE	2	EQUIPMENT FAILURE – STORM RELATED	10:41PM	04:49AM	05:03AM	11,333	1,830

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/07/2009	BUCKEYE	4	EQUIPMENT FAILURE – STORM RELATED	10:47PM	03:07AM	06:28PM	6,823	1,103
METRO	12/07/2009	WATSON	4	WEATHER – STORM RELATED	10:53PM	07:38AM	07:43AM	10,385	1,184
METRO	12/07/2009	PERRYVILLE	5	WEATHER – STORM RELATED	10:54PM	06:50AM	07:06AM	3,776	463
METRO	12/07/2009	ROCK SPRINGS	3	TRANSMISSION RELATED – STORM RELATED	10:58PM	01:14AM	01:14AM	3,434	1,515
METRO	12/07/2009	PIMA	3	WEATHER – STORM RELATED	10:58PM	05:27AM	05:27AM	2,807	433
METRO	12/07/2009	COUNTRY CLUB	13	EQUIPMENT FAILURE – STORM RELATED	10:58PM	11:11AM	12:10PM	32,328	2,965
METRO	12/07/2009	SARIVAL	14	EQUIPMENT FAILURE – STORM RELATED	10:59PM	08:16AM	08:16AM	2,228	240
METRO	12/07/2009	EL SOL	12	WEATHER – STORM RELATED	10:59PM	04:01AM	04:01AM	6,302	1,252
METRO	12/07/2009	GLENDALE	17	EQUIPMENT FAILURE – STORM RELATED	11:03PM	01:46AM	02:02AM	2,374	828

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/07/2009	DEER VALLEY	14	WEATHER – STORM RELATED	11:08PM	04:49AM	04:59AM	11,337	1,938
METRO	12/07/2009	HONEYWELL	14	EQUIPMENT FAILURE – STORM RELATED	11:08PM	07:40AM	08:35PM	18,784	2,083
METRO	12/07/2009	TURF	13	EQUIPMENT FAILURE – STORM RELATED	11:11PM	06:49AM	07:05AM	13,514	1,728
METRO	12/07/2009	WEST PHOENIX	1	WEATHER – STORM RELATED	11:13PM	04:34AM	04:34AM	5,468	1,022
METRO	12/07/2009	INDIANOLA	15	WEATHER – STORM RELATED	11:14PM	04:28AM	04:28AM	4,998	955
METRO	12/07/5009	MEADOWBROOK	18	EQUIPMENT FAILURE – STORM RELATED	11:14PM	01:32AM	12:45AM	8,553	1,799
METRO	12/07/2009	ENCANTO	12	WEATHER- STORM RELATED	11:14PM	02:26AM	02:26AM	2,941	919
METRO	12/07/2009	MCDOWELL	20	WEATHER – STORM RELATED	11:14PM	01:47AM	01:47AM	4,656	1,826
METRO	12/07/2009	SUNNYSLOPE	21	WEATHER – STORM RELATED	11:15PM	08:08AM	08:08AM	15,590	1,755

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/07/2009	SHAW	14	WEATHER – STORM RELATED	11:16PM	03:46AM	03:46AM	2,795	621
METRO	12/07/2009	DURANGO	1	EQUIPMENT FAILURE – STORM RELATED	11:16PM	04:40AM	04:40AM	5,535	1,025
METRO	12/07/2009	SUNNYSLOPE	18	WEATHER – STORM RELATED	11:17PM	02:20AM	04:18AM	6,088	1,653
METRO	12/07/2009	MEADOWBROOK	6	WEATHER – STORM RELATED	11:18PM	01:11AM	01:58AM	5,619	2,195
METRO	12/07/2009	BUFFALO	2	EQUIPMENT FAILURE – STORM RELATED	11:18PM	02:12AM	11:38AM	14,004	2,939
METRO	12/07/2009	ENCANTO	5	WEATHER – STORM RELATED	11:18PM	02:26AM	02:26AM	1,946	621
METRO	12/07/2009	SUNNYSLOPE	9	WEATHER – STORM RELATED	11:18PM	01:57AM	01:57AM	5,764	2,175
METRO	12/07/2009	LINCOLN STREET WEST	10	WEATHER – STORM RELATED	11:19PM	03:23AM	03:23AM	2,102	517
METRO	12/07/2009	ENCANTO	4	EQUIPMENT FAILURE – STORM RELATED	11:19PM	08:54AM	05:15PM	3,692	291

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/072009	ENCANTO	13	EQUIPMENT FAILURE – STORM RELATED	11:19PM	06:23AM	08:30AM	3,105	413
METRO	12/07/2009	DURANGO	14	WEATHER – STORM RELATED	11:20PM	11:15PM	11:15PM	1,913	80
METRO	12/07/2009	MCDOWELL	9	EQUIPMENT FAILURE – STORM RELATED	11:20PM	12:03AM	08:13PM	1,227	165
METRO	12/07/2009	TWENTY-THIRD ST	20	WEATHER – STORM RELATED	11:20PM	03:19AM	03:19AM	4,222	1,060
METRO	12/07/2009	BUFFALO	10	WEATHER – STORM RELATED	11:20PM	01:08AM	01:08AM	4,315	2,397
METRO	12/07/2009	DOVE VALLEY	13	WEATHER – STORM RELATED	11:20PM	01:30AM	01:30AM	3,068	1,416
METRO	12/07/2009	ENCANTO	2	WEATHER – STORM RELATED	11:21PM	02:24AM	02:24AM	5,289	1,734
METRO	12/07/2009	DURANGO	14	WEATHER – STORM RELATED	11:21PM	03:18AM	03:18AM	5,329	1,349
METRO	12/07/2009	COUNTRY CLUB	21	WEATHER – STORM RELATED	11:21PM	11:03AM	11:03AM	15,023	1,284
METRO	12/07/2009	SHERMAN STREET	13	WEATHER – STORM RELATED	11:21PM	04:32AM	04:32AM	3,421	660

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/07/2009	INDIANOLA	26	EQUIPMENT FAILURE – STORM RELATED	11:21PM	05:05AM	07:38AM	6,953	1,096
METRO	12/07/2009	GRISWOLD	6	WEATHER – STORM RELATED	11:22PM	08:07AM	08:07AM	15,225	1,740
METRO	12/07/2009	ORANGEWOOD	33	WEATHER – STORM RELATED	11:23PM	03:25AM	03:25AM	8,829	2,189
METRO	12/07/2009	ROADRUNNER	6	EQUIPMENT FAILURE – STORM RELATED	11:23PM	03:10AM	02:40PM	3,587	942
METRO	12/07/2009	EVANS CHURCHILL	7	EQUIPMENT FAILURE – STORM RELATED	11:23PM	10:22AM	10:22AM	4,459	406
METRO	12/07/2009	ROADRUNNER	22	EQUIPMENT FAILURE – STORM RELATED	11:23PM	12:57AM	07:45AM	2,159	1,248
METRO	12/07/2009	ROADRUNNER	9	EQUIPMENT FAILURE – STORM RELATED	11:23PM	01:25AM	01:25AM	3,005	1,478
METRO	12/07/2009	ORANGEWOOD	23	EQUIPMENT FAILURE – STORM RELATED	11:24PM	03:37AM	07:55AM	8,701	1,385
METRO	12/07/2009	TWENTY-THIRD ST	22	EQUIPMENT FAILURE – STORM RELATED	11:24PM	04:45AM	06:20AM	12,915	2,030

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/07/2009	HARBOR	13	UNDERGROUND CABLE	11:25PM	09:37AM	10:18AM	1,686	161
METRO	12/07/2009	TWENTY-THIRD ST	21	WEATHER – STORM RELATED	11:26PM	02:12AM	02:12AM	3,915	1,415
METRO	12/07/2009	JACKSON STREET	22	WEATHER – STORM RELATED	11:36PM	01:49AM	01:49AM	1,009	455
METRO	12/07/2009	MCDOWELL	18	WEATHER – STORM RELATED	11:41PM	05:10PM	05:10PM	2,623	150
METRO	12/08/2009	VALENCIA	5	EQUIPMENT FAILURE – STORM RELATED	12:15AM	10:56AM	10:56AM	18,087	1,693
METRO	12/08/2009	ALTADENA	17	UNDERGROUND CABLE	12:35AM	03:30AM	06:25AM	7,397	1,539
METRO	12/08/2009	WADDELL	13	EQUIPMENT FAILURE – STORM RELATED	12:59AM	04:31AM	04:31AM	4,562	1,291
METRO	12/08/2009	ENCANTO	2	WEATHER – STORM RELATED	04:18AM	08:35AM	03:15PM	8,200	1,734
METRO	12/07/2009	BUCKEYE	2	EQUIPMENT FAILURE – STORM RELATED	10:41PM	04:49AM	07:02PM	12,494	1,830
METRO	12/08/2009	BUFFALO	1	WEATHER – STORM RELATED	10:52AM	08:40AM	08:40AM	57,508	2,638

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

METRO	12/08/2009	GILBERT	12	UNDERGROUND CABLE	11:45AM	12:24PM	07:04PM	2,131	2,239
METRO	12/08/2009	TARTESSO TEMPORARY	4	WEATHER – STORM RELATED	01:57PM	03:12PM	03:12PM	1,135	908
METRO	12/08/2009	MCMICKEN	9	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	10:53PM	02:00PM	02:00PM	1,527	101
METRO	12/09/2009	PIMA	3	UNKNOWN / OTHER	07:25PM	11:05PM	11:05PM	1,588	433
NORTHEAST	12/07/2009	STRAWBERRY	2	EQUIPMENT FAILURE – STORM RELATED	03:58PM	11:15AM	11:15AM	6,885	124
NORTHEAST	12/07/2009	STRAWBERRY	2	WEATHER – STORM RELATED	05:35PM	07:09AM	07:09AM	53,536	3,949
NORTHEAST	12/07/2009	PREACHER CANYON	6	WEATHER – STORM RELATED	06:28PM	06:42PM	08:15PM	48,640	2,199
NORTHEAST	12/07/2009	TONTO	14	WEATHER – STORM RELATED	06:58PM	06:45AM	10:04AM	5,672	450
NORTHEAST	12/07/2009	KACHINA	4	WEATHER – STORM RELATED	07:20PM	08:48PM	03:14AM	6,119	2,795

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHEAST	12/07/2009	BLUE RIDGE	12	VEGETATION CONTACT – STORM RELATED	07:49PM	09:03PM	05:51PM	18,672	1480
NORTHEAST	12/07/2009	SHOWLOW	13	WEATHER – STORM RELATED	09:04PM	01:03AM	02:32AM	14,258	2,769
NORTHEAST	12/07/2009	STRAWBERRY	2	TRANSMISSION RELATED – STORM RELATED	09:57PM	07:09AM	09:10AM	42,699	3,949
NORTHEAST	12/07/2009	MUNDS PARK	5	WEATHER – STORM RELATED	10:01PM	10:26PM	10:26PM	1,269	3,046
NORTHEAST	12/07/2009	ASHFORK	6	WEATHER – STORM RELATED	10:28PM	03:52AM	08:40PM	6,213	617
NORTHEAST	12/07/2009	ELDEN	12	SUBSTATION RELATED – STORM	11:28PM	01:59AM	01:59AM	4,840	1,923
NORTHEAST	12/07/2009	SWITZER CANYON	13	WEATHER – STORM RELATED	11:29PM	04:44AM	04:44AM	8,726	1,662
NORTHEAST	12/07/2009	ELDEN	2	WEATHER – STORM RELATED	11:36PM	02:01AM	08:25PM	16,871	3,093
NORTHEAST	12/07/2009	WELCH	1	TRANSMISSION RELATED – STORM RELATED	11:38PM	01:45PM	01:45PM	1,443	7
NORTHEAST	12/07/2009	SHOWLOW	9	WEATHER – STORM RELATED	11:43PM	03:45AM	03:45AM	5,627	1,395

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHEAST	12/07/2009	CAMERON	3	TRANSMISSION RELATED – STORM RELATED	11:44PM	09:57AM	09:57AM	1M512	148
NORTHEAST	12/07/2009	TUBA CITY	2	TRANSMISSION RELATED – STORM RELATED	11:44PM	09:57AM	09:57AM	8,980	879
NORTHEAST	12/07/2009	TUBA CITY	3	TRANSMISSION RELATED – STORM RELATED	11:44PM	09:57AM	09:57AM	19,596	1,918
NORTHEAST	12/07/2009	SANDVIG	14	WEATHER – STORM RELATED	11:59PM	04:53AM	04:53AM	14,372	2,933
NORTHEAST	12/08/2009	PREACHER CANYON	2	WEATHER – STORM RELATED	12:15AM	02:30AM	04:08AM	7,587	2,545
NORTHEAST	12/08/2009	SWITZER CANYON	13	EQUIPMENT FAILURE – STORM RELATED	12:23AM	04:44AM	04:44AM	7,230	1,662
NORTHEAST	12/08/2009	SHOWLOW	9	WEATHER – STORM RELATED	12:32AM	03:45AM	02:20PM	4,593	1,387
NORTHEAST	12/08/2009	KEAMS CANYON	3	TRANSMISSION RELATED – STORM RELATED	12:41AM	01:19AM	01:19AM	1,003	1,583
NORTHEAST	12/08/2009	MOUNT FLOYD	1	WEATHER – STORM RELATED	12:56AM	05:29AM	01:04PM	6,585	615

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHEAST	12/08/2009	WINSLOW	2	SUBSTATION RELATED – STORM RELATED	01:09AM	11:44AM	11:44AM	22,691	2,144
NORTHEAST	12/08/2009	KEAMS CANYON	5	WEATHER – STORM RELATED	01:19AM	08:30PM	08:30PM	3,395	177
NORTHEAST	12/08/2009	COCONINO	14	WEATHER – STORM RELATED	01:22AM	05:56AM	05:56AM	1,411	309
NORTHEAST	12/08/2009	LEROUX	5	WEATHER – STORM RELATED	01:46AM	03:54AM	03:54AM	3,501	1,641
NORTHEAST	12/08/2009	KEAMS CANYON	3	TRANSMISSION RELATED – STORM RELATED	02:26AM	08:30PM	08:30PM	28,600	1,583
NORTHEAST	12/08/2009	LEROUX	3	TRANSMISSION RELATED – STORM RELATED	02:26AM	03:51AM	03:51AM	1,537	1,085
NORTHEAST	12/08/2009	SHOWLOW	13	WEATHER – STORM RELATED	02:34AM	03:48AM	03:48AM	3,415	2,769
NORTHEAST	12/08/2009	SHOWLOW	13	WEATHER – STORM RELATED	03:49AM	04:35AM	07:00AM	3,784	2,769
NORTHEAST	12/08/2009	WOODY MOUNTAIN	14	WEATHER – STORM RELATED	07:08AM	09:37PM	09:37PM	3,983	275
NORTHEAST	12/08/2009	WOODY MOUNTAIN	14	WEATHER – STORM RELATED	07:40AM	09:45PM	09:45PM	1,070	76

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHEAST	12/08/2009	COCONINO	12	WEATHER – STORM RELATED	11:53AM	04:38PM	04:38PM	1,183	249
NORTHEAST	12/08/2009	PREACHER CANYON	2	WEATHER – STORM RELATED	06:41PM	05:22AM	05:22AM	4,273	400
NORTHEAST	12/08/2009	KEAMS CANYON	3	UNKNOWN / OTHER	10:16AM	03:49PM	03:49PM	8,786	1,583
NORTHEAST	12/08/2009	MUNDS PARK	5	WEATHER – STORM RELATED	02:30PM	06:35PM	06:35PM	4,116	1,008
NORTHWEST	12/07/2009	WHITE SPAR	10	EQUIPMENT FAILURE – STORM RELATED	04:54AM	03:56PM	03:56PM	25,325	305
NORTHWEST	12/07/2009	WHITE SPAR	12	VEGETATION CONTACT STORM RELATED	03:23PM	01:27PM	01:27PM	1,191	17
NORTHWEST	12/07/2009	WHITE SPAR	12	EQUIPMENT FAILURE – STORM RELATED	03:23PM	03:17PM	03:17PM	1,080	5
NORTHWEST	12/07/2009	WHITE SPAR	12	EQUIPMENT FAILURE – STORM RELATED	03:23PM	09:59PM	09:59PM	2,979	15
NORTHWEST	12/07/2009	WHITE SPAR	12	EQUIPMENT FAILURE – STORM RELATED	04:54PM	04:13PM	04:13PM	46,276	978

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHWEST	12/07/2009	WHITE SPAR	12	VEGETATION CONTACT – STORM RELATED	06:03PM	09:16PM	09:16PM	1,232	383
NORTHWEST	12/07/2009	DEWEY	14	EQUIPMENT FAILURE – STORM RELATED	06:30PM	11:50PM	11:50PM	1,621	304
NORTHWEST	12/07/2009	PRESCOTT-CHINO WELLS	4	EQUIPMENT FAILURE – STORM RELATED	08:56PM	05:31PM	05:31PM	1,461	71
NORTHWEST	12/07/2009	YARNELL	4	WEATHER – WIND	09:04PM	01:41PM	01:41PM	2,659	160
NORTHWEST	12/07/2009	MINGUS	1	TRANSMISSION RELATED – STORM RELATED	09:34PM	02:24AM	02:24AM	1,057	20
NORTHWEST	12/07/2009	CHINO VALLEY	14	EQUIPMENT FAILURE – STORM RELATED	09:48PM	11:49PM	11:49PM	3,705	1,837
NORTHWEST	12/07/2009	CORDES	4	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	10:09PM	03:00AM	03:00AM	6,809	1,404
NORTHWEST	12/07/2009	WICKENBURG	10	WEATHER – STORM RELATED	10:22PM	12:58AM	12:58AM	1,349	519
NORTHWEST	12/07/2009	WILHOIT	2	WEATHER – STORM RELATED	10:23PM	09:22PM	09:22PM	6,343	276

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHWEST	12/07/2009	PATTON	1	WEATHER – STORM RELATED	10:25PM	03:40AM	03:40AM	1,667	57
NORTHWEST	12/07/2009	PRESCOTT CITY	5	WEATHER – STORM RELATED	10:27PM	12:45AM	12:45AM	7,123	3,097
NORTHWEST	12/07/2009	CHINO VALLEY	10	EQUIPMENT FAILURE – STORM RELATED	10:30PM	12:58AM	02:57AM	5,503	2,650
NORTHWEST	12/07/2009	DEWEY	14	EQUIPMENT FAILURE – STORM RELATED	10:45PM	08:26AM	08:26AM	3,176	328
NORTHWEST	12/07/2009	PRESCOTT CITY	1	WEATHER – STORM RELATED	10:52PM	01:20AM	01:20AM	1,771	718
NORTHWEST	12/07/2009	WICKENBURG	10	WEATHER – STORM RELATED	10:53PM	12:58AM	12:58AM	1,081	519
NORTHWEST	12/07/2009	HAYFIELD DRAW	2	WEATHER – STORM RELATED	10:53PM	01:48AM	01:48AM	2,896	993
NORTHWEST	12/07/2009	COPPER CANYON	2	TRANSMISSION RELATED – STORM RELATED	10:56PM	03:35AM	03:35AM	3,217	1,214
NORTHWEST	12/07/2009	COPPER CANYON	6	TRANSMISSION RELATED – STORM RELATED	10:56PM	01:35AM	03:35AM	5,205	1,964
NORTHWEST	12/07/2009	COPPER CANYON	10	TRANSMISSION RELATED – STORM RELATED	10:56PM	01:35AM	03:35AM	3,893	1,469

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHWEST	12/07/2009	HAYFIELD DRAW	2	TRANSMISSION RELATED - STORM RELATED	10:56PM	03:35AM	03:35AM	2,631	993
NORTHWEST	12/07/2009	PRESCOTT CITY	1	SUBSTATION RELATED – STORM RELATED	11:01PM	03:31AM	03:31AM	8,028	1,784
NORTHWEST	12/07/2009	KIRKLAND JUNCTION	10	TRANSMISSION RELATED – STORM RELATED	11:27PM	04:15AM	04:15AM	1,517	316
NORTHWEST	12/07/2009	WILHOIT	2	TRANSMISSION RELATED – STORM RELATED	11:27PM	04:15AM	04:15AM	1,325	276
NORTHWEST	12/07/2009	YARNELL	4	TRANSMISSION RELATED – STORM RELATED	11:27PM	04:15AM	04:15AM	4,882	1,017
NORTHWEST	12/07/2009	KIRKLAND JUNCTION	10	WEATHER – STORM RELATED	11:31PM	09:20PM	09:20PM	6,894	316
NORTHWEST	12/07/2009	KIRKLAND JUNCTION	12	WEATHER – STORM RELATED	11:31PM	09:21PM	09:21PM	1,179	54
NORTHWEST	12/07/2009	PRESCOTT CITY	5	WEATHER – STORM RELATED	11:37PM	04:46AM	08:10AM	24,630	3,097
NORTHWEST	12/07/2009	COTTONWOOD	18	WEATHER – STORM RELATED	11:38PM	12:38AM	02:21AM	3,774	2,371
NORTHWEST	12/08/2009	PRESCOTT CITY	5	EQUIPMENT FAILURE – STORM RELATED	03:00AM	12:32PM	13:32PM	1,144	120

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHWEST	12/08/2009	KIRKLAND JUNCTION	10	TRANSMISSION RELATED – STORM RELATED	04:16AM	09:14PM	09:14PM	5,256	316
NORTHWEST	12/08/2009	WILHOIT	2	TRANSMISSION RELATED – STORM RELATED	04:16AM	09:14PM	09:14PM	4,591	276
NORTHWEST	12/08/2009	YARNELL	4	TRANSMISSION RELATED – STORM RELATED	04:16AM	10:46AM	10:46AM	6,611	1,017
NORTHWEST	12/08/2009	PRESCOTT CITY	5	WEATHER – STORM RELATED	04:42AM	04:47AM	08:10AM	15,537	3,097
NORTHWEST	12/08/2009	DELANO	10	EQUIPMENT FAILURE – STORM RELATED	05:00AM	07:01AM	07:01AM	2,184	1,083
NORTHWEST	12/08/2009	HAYFIELD DRAW	2	EQUIPMENT FAILURE – STORM RELATED	05:24AM	12:02PM	12:02PM	1,606	216
NORTHWEST	12/08/2009	PAULDEN	4	WEATHER – WIND	05:26AM	06:25PM	06:25PM	1,136	82
NORTHWEST	12/08/2009	WHITE SPAR	10	FOREIGN INTERFERENCE – VEHICLES	06:00AM	10:00AM	05:50PM	2,741	256

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

NORTHWEST	12/07/2009	WHITE SPAR	12	EQUIPMENT FAILURE – STORM RELATED	04:54PM	04:13PM	04:07PM	50,029	978
NORTHWEST	12/08/2009	CORDES	2	EQUIPMENT FAILURE – STORM RELATED	11:08AM	11:37AM	02:30PM	8,058	368
NORTHWEST	12/08/2009	DELANO	10	VEGETATION CONTACT STORM RELATED	11:24AM	09:45PM	10:32PM	1,778	138
NORTHWEST	12/08/2009	PAULDEN	2	EQUIPMENT FAILURE – STORM RELATED	09:000PM	10:07PM	10:07PM	1,130	45
NORTHWEST	12/08/2009	DELANO	10	EQUIPMENT FAILURE – STORM RELATED	01:30AM	04:32AM	04:32AM	1,458	52
SOUTHEAST	12/07/2009	MURAL	1	EQUIPMENT FAILURE – STORM RELATED	09:44PM	07:39PM	07:39PM	1,410	63
SOUTHEAST	12/07/2009	HIDDEN VALLEY	2	EQUIPMENT FAILURE – STORM RELATED	10:17PM	02:37AM	02:16PM	4,663	489
SOUTHEAST	12/08/2009	PINAL	1	EQUIPMENT FAILURE – STORM RELATED	12:02AM	01:11AM	03:21AM	1,913	995

1000 HOUR CUSTOMER OUTAGE REPORT
(12/07/2009 - 12/13/2009)

SOUTHEAST	12/08/2009	TOLTEC	2	EQUIPMENT FAILURE – STORM RELATED	12:57AM	06:20AM	06:20AM	8,004	1,099
SOUTHEAST	12/08/2009	HAYES GULCH	2	FOREIGN INTERFERENCE – VEHICLES	03:23AM	05:40AM	02:49PM	3,561	487
SOUTHWEST	12/07/2009	UTTING	1	TRANSMISSION RELATED – STORM RELATED	10:02AM	11:26AM	11:26AM	1,082	738
SOUTHWEST	12/07/2009	COCOPAH	13	WEATHER – STORM RELATED	07:36PM	08:13PM	08:13PM	3,159	1,739
SOUTHWEST	12/09/2009	ARABY	12	EQUIPMENT FAILURE	04:24AM	11:20AM	11:20AM	5,777	747

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(12/14/2009 - 12/20/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	12/18/2009	SANDVIG	4	SUBSTATION RELATED	02:21PM	03:05PM	03:05PM	2,321	3,165
NORTHEAST	12/18/2009	SANDVIG	4	SUBSTATION RELATED	04:06PM	10:06AM	10:06AM	56,970	3,165
NORTHEAST	12/19/2009	SANDVIG	4	UNKNOWN / OTHER	10:29AM	10:55AM	10:55AM	1,372	3,165
NORTHWEST	12/15/2009	DELANO	10	OVERLOAD DUE TO SWITCHING	05:33PM	06:10PM	06:10PM	2,142	3,474
SOUTHWEST	12/19/2009	THIRTHY-SECOND ST	1	FOREIGN INTERFERENCE – VEHICLES	10:33PM	11:17PM	11:17PM	1,005	1,370

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(12/21/2009-12/27/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/21/2009	GREENWAY	18	EQUIPMENT FAILURE	12:15PM	01:17PM	02:18PM	1,769	1,248
NORTHEAST	12/23/2009	PARKS	14	WEATHER - WIND	01:48AM	03:13AM	04:49AM	1,267	855
NORTHWEST	12/21/2009	YARNELL	4	FOREIGN INTERFERENCE – VEHICLES	04:16PM	05:30PM	05:30PM	1,216	986
SOUTHEAST	12/22/2009	KEARNY	2	EQUIPMENT FAILURE (STORM RELATED)	05:50PM	06:57PM	12:10PM 12/23/2009	1,685	1,004

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/28/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(12/28/2009-01/03/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/28/2009	WESTBROOK	11	UNDERGROUND CABLE	10:26PM	11:04PM	12:22AM	1,738	1,614
NORTHWEST	01/02/2010	SUNDOG	5	UNKNOWN/ OTHER	12:07PM	02:47PM	02:47PM	1,341	503

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/28/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(01/04/2010-01/10/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
There are no outages to report for this timeframe.									

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

2/9/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(01/11/2010 - 01/17/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
SOUTHEAST	01/12/2010	SAGUARO	13	UNKNOWN / OTHER	09:25AM	11:31AM	12:29PM	2,316	813

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

2/11/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

The filing of this report was delayed due to the high volume of outages experienced during the severe winter storms that moved across the State in late January. All but 6 of the outages included in this report were directly related to the storm.

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	01/19/2010	SHERMAN STREET	18	EQUIPMENT FAILURE – STORM RELATED	06:06PM	06:50PM	09:45PM	1,137	685
METRO	01/19/2010	ENCANTO	9	EQUIPMENT FAILURE – STORM RELATED	06:22PM	07:53PM	07:53PM	1,744	1,150
METRO	01/19/2010	RAINBOW VALLEY	1	TRANSMISSION RELATED – STORM RELATED	09:55PM	08:25AM	08:25AM	1,239	118
METRO	01/21/2010	TONOPAH	1	EQUIPMENT FAILURE – STORM RELATED	04:48AM	06:30AM	09:01AM	1,312	532
METRO	01/21/2010	ESTRELLITA	5	EQUIPMENT FAILURE – STORM RELATED	11:01AM	01:25PM	01:25PM	2,275	948
METRO	01/21/2010	PARADISE	9	EQUIPMENT FAILURE – STORM RELATED	12:44PM	01:17PM	03:04PM	1,556	2,319
METRO	01/21/2010	GILLESPIE	2	WEATHER – STORM RELATED	03:30PM	04:49PM	04:49PM	1,114	44

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

METRO	01/21/2010	BUTTE	21	EQUIPMENT FAILURE – STORM RELATED	03:47PM	04:25PM	06:56PM	1,853	1,276
METRO	01/21/2010	PARADISE	19	VEGETATION CONTACT – STORM RELATED	05:22PM	06:10PM	06:10PM	2,039	2,549
METRO	01/21/2010	TEMPE	18	VEGETATION CONTACT – STORM RELATED	05:23PM	06:51PM	05:08AM	3,476	1,980
METRO	01/21/2010	GILA BEND	10	EQUIPMENT FAILURE – STORM RELATED	05:25PM	07:21PM	12:11AM	1,449	557
METRO	01/21/2010	DESERT SPRINGS	4	VEGETATION CONTACT – STORM RELATED	06:14PM	07:00PM	07:00PM	1,380	1,800
METRO	01/21/2010	JACKSON STREET	22	EQUIPMENT FAILURE – STORM RELATED	06:18PM	09:23AM	09:23AM	1,508	100
METRO	01/21/2010	DOVE VALLEY	13	EQUIPMENT FAILURE – STORM RELATED	06:24PM	07:30PM	08:14PM	1,744	1,416
METRO	01/21/2010	ROADRUNNER	13	EQUIPMENT FAILURE – STORM RELATED	06:26PM	07:12PM	12:14AM	1,515	998
METRO	01/21/2010	AZTEC	10	TRANSMISSION RELATED – STORM RELATED	07:07PM	08:01AM	08:01AM	2,541	197

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

METRO	01/21/2010	NEW RIVER	10	WEATHER – STORM RELATED	08:10PM	08:52PM	09:21PM	1,139	1,375
METRO	01/21/2010	GLENDALE	6	EQUIPMENT FAILURE – STORM RELATED	08:14PM	09:49PM	05:00AM	1,802	1,027
METRO	01/21/2010	HEDGEPETH HILLS	5	WEATHER – STORM RELATED	08:18PM	09:55PM	10:13PM	1,798	952
METRO	01/21/2010	ORANGEWOOD	33	EQUIPMENT FALIURE – STORM RELATED	08:28PM	09:29PM	01:12AM	4,980	2,189
METRO	01/21/2010	CIELO GRANDE	10	EQUIPMENT FAILURE – STORM RELATED	08:37PM	10:31PM	04:55AM	2,185	1,096
METRO	01/21/2010	CHAPARRAL	6	WEATHER – STORM RELATED	08:39PM	09:59PM	09:59PM	1,087	815
METRO	01/21/2010	MEADOWBROOK	10	WEATHER – STORM RELATED	08:41PM	10:52PM	10:52PM	2,249	1,030
METRO	01/21/2010	WADDELL	13	WEATHER – STORM RELATED	08:49PM	11:11PM	12:00AM	3,885	1,291
METRO	01/21/2010	ROADRUNNER	18	EQUIPMENT FAILURE – STORM RELATED	09:04PM	10:48PM	03:06AM	3,686	1,651

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

METRO	01/21/2010	ORANGEWOOD	33	EQUIPMENT FAILURE – STORM RELATED	09:28PM	09:29PM	01:00AM	7,471	1,519
METRO	01/21/2010	PALM VALLEY	2	EQUIPMENT FAILURE – STORM RELATED	11:19PM	01:16AM	01:16AM	1,119	574
METRO	01/22/2010	WINTERSBURG	12	EQUIPMENT FAILURE – STORM RELATED	01:11AM	12:36PM	12:36PM	3,174	278
METRO	01/22/2010	CACTUS	25	FOREIGN INTERFERENCE – VEHICLES	11:07AM	11:51AM	03:50PM	1,142	1,404
METRO	01/23/2010	EAST END	5	EQUIPMENT FAILURE	01:27PM	02:10PM	03:27PM	1,110	1,387
NORTHEAST	01/19/2010	PREACHER CANYON	6	WEATHER – STORM RELATED	09:22AM	09:37AM	11:07AM	5,056	3,103
NORTHEAST	01/19/2010	PREACHER CANYON	6	EQUIPMENT FAILURE – STORM RELATED	05:18PM	06:50PM	06:50PM	1,722	1,123
NORTHEAST	01/19/2010	MUNDS PARK	5	WEATHER – STORM RELATED	06:58PM	08:52PM	08:52PM	5,787	3,046
NORTHEAST	01/19/2010	MUNDS PARK	5	WEATHER – STORM RELATED	10:04PM	10:22PM	05:37AM	2,581	3,046

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

NORTHEAST	01/19/2010	BLUE RIDGE	12	WEATHER – STORM RELATED	10:34PM	01:34AM	04:02AM	6,318	1,251
NORTHEAST	01/19/2010	STRAWBERRY	2	WEATHER – STORM RELATED	11:50PM	02:04AM	02:37AM	10,287	3,949
NORTHEAST	01/20/2010	ELDEN	12	SUBSTATION RELATED – STORM RELATED	01:19AM	02:28AM	02:28AM	2,211	1,923
NORTHEAST	01/21/2010	PREACHER CANYON	6	WEATHER – STORM RELATED	06:45AM	10:55AM	10:55AM	2,138	513
NORTHEAST	01/21/2010	PREACHER CANYON	6	WEATHER – STORM RELATED	08:09AM	08:48AM	07:45PM	3,232	2,590
NORTHEAST	01/21/2010	SHOWLOW	15	WEATHER – STORM RELATED	09:31AM	11:11AM	11:11AM	7,007	273
NORTHEAST	01/21/2010	ASHFORK	6	WEATHER – STORM RELATED	10:19AM	12:00PM	12:00PM	1,039	617
NORTHEAST	01/21/2010	COCONINO	12	EQUIPMENT FAILURE – STORM RELATED	10:59AM	07:53PM	07:53PM	4,147	466
NORTHEAST	01/21/2010	KEAMS CANYON	3	WEATHER – STORM RELATED	11:49AM	01:38PM	06:38PM	3,261	1,583
NORTHEAST	01/21/2010	ELDEN	12	WEATHER – STORM RELATED	12:57PM	05:25PM	05:25PM	7,928	1,775

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

NORTHEAST	01/21/2010	ELDEN	12	WEATHER – STORM RELATED	01:11PM	05:25PM	06:22PM	7,139	1,628
NORTHEAST	01/21/2010	STRAWBERRY	2	TRANSMISSION RELATED – STORM RELATED	06:08PM	08:53PM	08:53PM	10,860	3,949
NORTHEAST	01/21/2010	ELDEN	12	WEATHER – STORM RELATED	06:53PM	09:40PM	09:40PM	1,052	378
NORTHEAST	01/21/2010	MUNDS PARK	5	TRANSMISSION RELATED – STORM RELATED	07:32PM	02:01AM	02:01AM	19,748	3,046
NORTHEAST	01/21/2010	BLUE RIDGE	12	WEATHER – STORM RELATED	08:36PM	08:36AM	08:36AM	1,488	124
NORTHEAST	01/21/2010	STRAWBERRY	2	WEATHER – STORM RELATED	09:07PM	10:44PM	10:44PM	2,423	1,499
NORTHEAST	01/21/2010	SANDVIG	4	WEATHER – STORM RELATED	09:58PM	01:42AM	01:42AM	1,183	317
NORTHEAST	01/21/2010	BLUE RIDGE	12	WEATHER – STORM RELATED	02:17AM	11:21AM	11:21AM	2,212	244
NORHTEAST	01/21/2010	TONTO	14	WEATHER – STORM RELATED	02:33AM	11:55AM	11:55AM	9,929	1,060
NORTHEAST	01/22/2010	STRAWBERRY	2	WEATHER – STORM RELATED	05:12AM	09:57AM	09:57AM	18,758	3,949

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

NORTHEAST	01/22/2010	COCONINO	12	WEATHER – STORM RELATED	05:21AM	08:11AM	02:02PM	4,996	801
NORTHEAST	01/22/2010	STRAWBERRY	2	WEATHER – STORM RELATED	07:06AM	09:00PM	09:00PM	20,836	1,499
NORTHEAST	01/22/2010	PREACHER CANYON	6	WEATHER – STORM RELATED	07:49AM	03:26PM	03:26PM	4,326	568
NORTHEAST	01/22/2010	PREACHER CANYON	6	WEATHER – STORM RELATED	09:23AM	09:36AM	03:27PM	15,095	3,103
NORTHEAST	01/22/2010	KACHINA	4	WEATHER – STORM RELATED	09:45AM	09:17PM	09:17PM	1,349	117
NORTHEAST	01/22/2010	STRAWBERRY	2	WEATHER – STORM RELATED	12:56PM	06:14PM	06:14PM	20,930	3,949
NORTHEAST	01/22/2010	STRAWBERRY	2	WEATHER – STORM RELATED	10:48PM	12:05AM	12:05AM	5,068	3,949
NORTHEAST	01/22/2010	SHOWLOW	15	WEATHER – STORM RELATED	11:27PM	04:39AM	04:39AM	1,420	273
NORTHEAST	01/22/2010	STRAWBERRY	2	WEATHER – STORM RELATED	02:53AM	08:59AM	04:40PM	34,341	3,494
NORTHEAST	01/22/2010	COCONINO	12	WEATHER – STORM RELATED	06:48AM	03:03PM	03:03PM	1,658	201

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

NORTHEAST	01/23/2010	STRAWBERRY	2	VEGETATION CONTACT	04:32PM	04:41PM	11:27PM	3,200	125
NORTHEAST	01/24/2010	COCONINO	12	EQUIPMENT FAILURE	01:59PM	02:10PM	06:12PM	1,652	430
NORTHWEST	01/20/2010	AGUILA	1	WEATHER – STORM RELATED	08:59PM	12:42AM	12:42AM	1,780	479
NORTHWEST	01/21/2010	COTTONWOOD	14	EQUIPMENT FAILURE – STORM RELATED	07:46AM	04:04PM	04:04PM	4,324	521
NORTHWEST	01/21/2010	SEDONA	14	EQUIPMENT FAILURE – STORM RELATED	07:53AM	04:00PM	10:59AM	26,737	257
NORTHWEST	01/21/2010	DELANO	10	EQUIPMENT FAILURE – STORM RELATED	08:03AM	09:40PM	09:40PM	1,843	49
NORTHWEST	01/21/2010	PRESCOTT CITY	5	VEGETATION CONTACT – STORM RELATED	08:24AM	11:26PM	11:26PM	13,274	883
NORTHWEST	01/21/2010	WHITE SPAR	2	EQUIPMENT FAILURE – STORM RELATED	08:25AM	09:41PM	06:33AM	23,836	1,782
NORTHWEST	01/21/2010	DELANO	10	WEATHER – STORM RELATED	08:28AM	01:35PM	01:35PM	9,548	1,866

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

NORTHWEST	01/21/2010	DELANO	10	EQUIPMENT FAILURE – STORM RELATED	08:34AM	01:35PM	01:35PM	10,105	2,021
NORTHWEST	01/21/2010	PRESCOTT CITY	5	WEATHER – STORM RELATED	09:29AM	08:18PM	09:18PM	2,328	65
NORTHWEST	01/21/2010	DELANO	10	VEGETATION CONTACT – STORM RELATED	01:35PM	04:50PM	06:40PM	19,649	903
NORHTWEST	01/21/2010	CHINO VALLEY	10	VEGETATION CONTACT – STORM RELATED	01:44PM	07:43AM	07:43AM	2,680	149
NORHTWEST	01/21/2010	CORDES	4	EQUIPMENT FAILURE – STORM RELATED	03:59PM	04:13AM	04:13AM	1,321	108
NORTHWEST	01/21/2010	WHITE SPAR	10	VEGETATION CONTACT – STORM RELATED	04:03PM	12:57PM	12:57PM	2,290	51
NORHTWEST	01/21/2010	WHITE SPAR	12	WEATHER – STORM RELATED	05:36PM	06:54PM	06:54PM	1,456	1,120
NORHTWEST	01/21/2010	KIRKLAND JUNCTION	10	EQUIPMENT FAILURE – STORM RELATED	06:44PM	04:11AM	04:11AM	2,684	284
NORTHWEST	01/21/2010	SUNDOG	1	WEATHER – STORM RELATED	08:07PM	03:47PM	03:47PM	3,575	39

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

NORTHWEST	01/21/2010	WILHOIT	2	TRANSMISSION RELATED – STORM RELATED	08:28PM	12:50AM	12:50AM	1,205	276
NORTHWEST	01/21/2010	YARNELL	4	TRANSMISSION RELATED – STORM RELATED	08:28PM	12:50AM	12:50AM	4,441	1,017
NORTHWEST	01/21/2010	WILHOIT	2	WEATHER – STORM RELATED	08:31PM	01:00AM	01:00AM	1,237	276
NORTHWEST	01/21/2010	WHITE SPAR	10	VEGETATION CONTACT – STORM RELATED	10:50PM	11:17PM	04:40PM	1,644	368
NORTHWEST	01/21/2010	KIRKLAND JUNCTION	10	EQUIPMENT FAILURE – STORM RELATED	04:36AM	04:41AM	08:27AM	3,803	284
NORTHWEST	01/23/2010	WHITE SPAR	12	WEATHER – STORM RELATED	02:04AM	03:51AM	07:07PM	13,599	1,120
SOUTHEAST	01/20/2010	MERRILL	2	SUBSTATION RELATED	12:01AM	03:25AM	03:25AM	2,081	612
SOUTHEAST	01/20/2010	MERRILL	6	SUBSTATION RELATED	12:01AM	03:25AM	03:25AM	2,771	815
SOUTHEAST	01/20/2010	DON LUIS	1	EQUIPMENT FAILURE – STORM RELATED	04:17AM	05:50AM	07:41AM	1,581	682

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

SOUTHEAST	01/20/2010	FAIRVIEW	1	TRANSMISSION RELATED – STORM RELATED	04:51AM	06:08AM	06:08AM	3,505	2,731
SOUTHEAST	01/20/2010	FAIRVIEW	6	TRANSMISSION RELATED – STORM RELATED	04:51AM	06:13AM	06:13AM	1,584	1,159
SOUTHEAST	01/20/2010	FAIRVIEW	14	TRANSMISSION RELATED – STORM RELATED	04:51AM	06:09AM	06:09AM	3,188	2,452
SOUTHEAST	01/20/2010	HAYES GULCH	2	EQUIPMENT FAILURE – STORM RELATED	02:20AM	06:17AM	08:58AM	1,470	364
SOUTHEAST	01/21/2010	VISTA	12	EQUIPMENT FAILURE – STORM RELATED	03:48AM	04:40AM	04:40AM	6,888	277
SOUTHEAST	01/21/2010	PINAL	4	WEATHER – WIND	07:43PM	08:50PM	08:52PM	1,508	1,338
SOUTHEAST	01/22/2010	DON LUIS	3	EQUIPMENT FAILURE – STORM RELATED	01:53AM	03:05AM	03:43PM	1,997	723
SOUTHEAST	01/22/2010	HAYES GULCH	2	WEATHER – WIND	03:51AM	02:20PM	02:20PM	2,002	191
SOUTHEAST	01/22/2010	PINAL	1	EQUIPMENT FAILURE – STORM RELATED	09:59AM	01:10PM	01:10PM	3,174	997

1000 HOUR CUSTOMER OUTAGE REPORT
(01/18/2010 - 01/24/2010)

SOUTHEAST	01/22/2010	PINAL	1	EQUIPMENT FAILURE – STORM RELATED	10:17AM	10:17AM	04:39PM	7,613	124
SOUTHEAST	01/22/2010	PINAL	1	EQUIPMENT FAILURE – STORM RELATED	03:57PM	04:39PM	07:44PM	1,062	486
SOUTHWEST	01/19/2010	COCOPAH	14	EQUIPMENT FAILURE – STORM RELATED	02:09PM	09:45AM	09:45AM	2,450	125
SOUTHWEST	01/19/2010	IVALON	12	EQUIPMENT FAILURE – STORM RELATED	02:59PM	03:57PM	08:25PM	1,653	1,682
SOUTHWEST	01/21/2010	EHRENBERG	4	WEATHER – STORM RELATED	04:26PM	12:08AM	12:08AM	4,859	631

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(01/25/2010 - 01/31/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	01/25/2010	DYSART	9	EQUIPMENT FAILURE – STORM RELATED	10:40AM	12:28AM	11:31AM	1,064	1,282
METRO	01/25/2010	SURPRISE	12	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	12:37PM	01:09PM	06:39PM	1,206	1,115
METRO	01/28/2010	ROSE GARDEN	10	WEATHER – STORM RELATED	08:40AM	09:20AM	11:51PM	1,495	740
NORTHEAST	01/29/2010	KEAMS CANYON	3	WEATHER – STORM RELATED	05:01PM	06:26PM	06:26PM	2,243	1,583

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(02/01/2010-02/07/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	02/06/2010	KACHINA	4	WEATHER – STORM RELATED	10:39PM	03:20AM	03:20AM	1,091	233
NORTHEAST	02/07/2010	KACHINA	4	WEATHER – STORM RELATED	01:57AM	03:20AM	03:20AM	3,866	2,795
NORTHEAST	02/07/2010	COCONINO	12	EQUIPMENT FAILURE – STORM RELATED	05:15AM	09:34AM	09:34AM	2,029	470
NORTHEAST	02/07/2010	COCONINO	12	WEATHER – STORM RELATED	09:15AM	09:16AM	01:56PM	2,040	300
NORTHWEST	02/05/2010	WHITE SPAR	12	VEGETATION CONTACT (STORM RELATED)	07:03PM	07:03PM	07:03PM 02/06/2010	2,736	114
NORTHWEST	02/07/2010	WHITE SPAR	12	WEATHER – STORM RELATED	04:30AM	09:30P M	09:30PM	2,057	121
NORTHWEST	02/07/2010	SEDONA	14	WEATHER – STORM RELATED	07:18AM	11:20AM	05:17PM	1,107	143

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

3/9/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(02/01/2010-02/07/2010)

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(02/01/2010-02/07/2010)

[redacted]

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	02/06/2010	KACHINA	4	WEATHER – STORM RELATED	10:39PM	03:20AM	03:20AM	1,091	233
NORTHEAST	02/07/2010	KACHINA	4	WEATHER – STORM RELATED	01:57AM	03:20AM	03:20AM	[redacted]	[redacted]
NORTHEAST	02/07/2010	COCONINO	12	EQUIPMENT FAILURE – STORM RELATED	05:15AM	09:34AM	09:34AM	2,029	470
NORTHEAST	02/07/2010	COCONINO	12	WEATHER – STORM RELATED	09:15AM	09:16AM	01:56PM	2,040	300
NORTHWEST	02/05/2010	WHITE SPAR	12	VEGETATION CONTACT (STORM RELATED)	07:03PM	07:03PM	07:03PM 02/06/2010	2,736	114
NORTHWEST	02/07/2010	WHITE SPAR	12	WEATHER – STORM RELATED	04:30AM	09:30P M	09:30PM	2,057	121

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

4/13/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(02/08/2010-02/14/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
There are no outages to report for this timeframe.									

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

3/8/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(02/15/2010-02/21/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/16/2010	SURPRISE	21	FOREIGN INTERFERENCE - VEHICLE	12:41PM	01:10PM	01:20PM	1,303	2,034
METRO	02/21/2010	GRISWOLD	6	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	04:33PM	05:10PM	12:20AM	1,181	1,740
SOUTHEAST	02/16/2010	HIDDEN VALLEY	4	LOSS OF SUPPLY – OTHER UTILITY	01:44AM	03:17AM	03:17AM	1,547	998

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

3/15/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(02/15/2010-02/21/2010)
[redacted]

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/16/2010	SURPRISE	21	FOREIGN INTERFERENCE - VEHICLE	12:41PM	01:10PM	01:20PM	[redacted]	[redacted]
METRO	02/21/2010	GRISWOLD	6	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	04:33PM	05:10PM	00:20AM	[redacted]	[redacted]
SOUTHEAST	02/16/2010	HIDDEN VALLEY	4	LOSS OF SUPPLY – OTHER UTILITY	01:44AM	03:17AM	03:17AM	1,547	998

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

4/13/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(02/22/2010 - 02/28/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/28/2010	FILLMORE	4	EQUIPMENT FAILURE – STORM RELATED	12:16AM	02:05AM	10:26AM	2,735	1,234
METRO	02/28/2010	ENCANTO	9	EQUIPMENT FAILURE – STORM RELATED	01:15PM	02:17PM	02:17PM	1,188	1,150
NORTHWEST	02/22/2010	FLYING E	4	EQUIPMENT FAILURE – STORM RELATED	04:09PM	04:48PM	06:11PM	1,390	1,000

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(02/22/2010 - 02/28/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	02/28/2010	FILLMORE	4	EQUIPMENT FAILURE – STORM RELATED	12:16AM	02:05AM	10:26AM	1,945	799
METRO	02/28/2010	ENCANTO	9	EQUIPMENT FAILURE – STORM RELATED	01:15PM	02:17PM	02:17PM	1,167	1,129
NORTHWEST	02/22/2010	FLYING E	4	EQUIPMENT FAILURE – STORM RELATED	04:09PM	04:48PM	06:11PM	1,483	1,143

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(03/01/2010-03/07/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	03/07/2010	UNION HILLS	21	EQUIPMENT FAILURE	10:52AM	11:32AM	01:06PM	1,007	1,408

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

4/13/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(03/08/2010-03/14/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	03/09/2010	GLENDALE	2	VEGETATION CONTACT	03:01PM	04:02PM	04:02PM	1,076	1058
METRO	03/09/2010	VALENCIA	5	UNKNOWN/ OTHER	06:30PM	09:40PM	09:40PM	4,842	1529
METRO	03/13/2010	JAVELINA	4	EQUIPMENT FAILURE	10:13AM	10:54AM	11:51AM	1,406	1548
NORTHEAST	03/11/2011	WOODY MOUNTAIN	14	EQUIPMENT FAILURE	03:19PM	04:41PM	06:38PM	7,235	3228
NORTHWEST	03/10/2010	LONESOME VALLEY	14	FOREIGN INTERFERENCE/ VEHICLE	08:08AM	08:48AM	08:48AM	1423	2134
NORTHWEST	03/13/2010	CORDES	2	FOREIGN INTERFERENCE/ VANDALISM	02:30PM	05:20PM	05:20PM	1014	358
SOUTHWEST	03/13/2010	COCOPAH	1	EQUIPMENT FAILURE	05:52PM	07:38PM	07:38PM	1564	885

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9)

1000 HOUR CUSTOMER OUTAGE REPORT
(03/08/2010-03/14/2010)
REVISED

The Valencia 5 outage that occurred on 03/09/2010 was removed from this report. Upon further review, it was discovered that customers experienced voltage fluctuations rather than an interruption of service.

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	03/09/2010	GLENDALE	2	VEGETATION CONTACT	03:01PM	04:02PM	04:02PM	1,076	1058
METRO	03/13/2010	JAVELINA	4	EQUIPMENT FAILURE	10:13AM	10:54AM	11:51AM	1,406	1548
NORTHEAST	03/11/2011	WOODY MOUNTAIN	14	EQUIPMENT FAILURE	03:19PM	04:41PM	06:38PM	7,235	3228
NORTHWEST	03/10/2010	LONESOME VALLEY	14	FOREIGN INTERFERENCE/ VEHICLE	08:08AM	08:48AM	08:48AM	1423	2134
NORTHWEST	03/13/2010	CORDES	2	FOREIGN INTERFERENCE/ VANDALISM	02:30PM	05:20PM	05:20PM	1014	358
SOUTHWEST	03/13/2010	COCOPAH	1	EQUIPMENT FAILURE	05:52PM	07:38PM	07:38PM	1564	885

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

5/13/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(03/15/2009-03/21/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	03/17/2010	PEORIA	12	UNDERGROUND CABLE	12:54AM	02:04AM	02:36PM	1,423	1,083
METRO	03/19/2010	MARINETTE	9	UNDERGROUND CABLE	07:21AM	08:14AM	12:09PM	2,043	1,545
METRO	03/20/2010	FILLMORE	19	FOREIGN INTERFERENCE	12:26PM	01:03PM	02:22PM	1,138	1,308

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

4/22/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(03/15/2010-03/21/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	03/17/2010	PEORIA	12	UNDERGROUND CABLE	12:54AM	02:04AM	02:36PM	1,423	1,083
METRO	03/19/2010	MARINETTE	9	UNDERGROUND CABLE	07:21AM	08:14AM	12:09PM	2,043	1,545
METRO	03/20/2010	FILLMORE	19	FOREIGN INTERFERENCE	12:26PM	01:03PM	02:22PM	1,138	1,308

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

5/6/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(03/22/2010-03/29/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	03/27/2010	ARROYO	6	FOREIGN INTERFERENCE - VEHICLES	05:27AM	05:44AM	10:52AM	1,371	690
NORTHEAST	03/24/2010	MAZATZAL TEMPORARY	6	UNKNOWN	01:00PM	02:11PM	02:11PM	1,186	1,002

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

4/29/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(04/05/2010-04/11/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/05/2010	PALM VALLEY	1	EQUIPMENT FAILURE	12:00PM	12:41PM	01:27PM	1,271	1,209
METRO	04/11/2010	MOUNTAIN VIEW	5	UNDERGROUND CABLE	12:30AM	01:25AM	02:38AM	2,465	2,059
METRO	04/11/2010	TURF	13	SUBSTATION RELATED	01:45PM	02:26PM	02:26PM	1,083	1,585
METRO	04/11/2010	TURF	14	SUBSTATION RELATED	01:45PM	02:47PM	02:47PM	2,217	2,145
NORTHEAST	04/05/2010	WOODY MOUNTAIN	14	TRANSMISSION RELATED (STORM RELATED)	11:58AM	12:34PM	12:34PM	1,937	3,228
NORTHEAST	04/05/2010	SWITZER CANYON	13	VEGETATION CONTACT (STORM RELATED)	12:57PM	12:59PM	06:46PM	1,204	5,861
NORTHWEST	04/05/2010	WHITE SPAR	12	VEGETATION CONTACT	02:36PM	04:48PM	06:19PM	1,128	375
SOUTHEAST	04/07/2010	HAYES GULCH	1	SUBSTATION RELATED	03:26AM	04:45AM	04:45AM	2,230	1,694

1000 HOUR CUSTOMER OUTAGE REPORT
(04/05/2010-04/11/2010)

SOUTHEAST	04/07/2010	HAYES GULCH	2	SUBSTATION RELATED	03:26AM	04:45AM	04:45AM	1,618	1,229

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(04/12/2010-04/18/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/12/2010	MARINETTE	22	EQUIPMENT FAILURE	04:34AM	05:42AM	06:01AM	2,060	1,471
METRO	04/13/2010	MUMMY MOUNTAIN	8	UNKNOWN/ OTHER	11:11AM	02:06PM	02:06PM	2,969	1,018

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

5/21/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(04/19/2009-04/25/2009)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/23/2009	RIO VISTA	6	UNDERGROUND CABLE	07:05PM	07:54PM	08:50PM	1,396	1,358
METRO	04/25/2009	INDIAN BEND	10	UNKNOWN / OTHER	07:25PM	07:56PM	08:17PM	1,586	2,341
NORTHWEST	04/19/2009	PAULDEN	2	FOREIGN INTERFERENCE - BIRDS	06:04AM	07:51AM	12:57PM	3,053	1,449

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

6/11/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(04/19/2010-04/25/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/23/2010	RIO VISTA	6	UNDERGROUND CABLE	07:05PM	07:54PM	08:50PM	1,396	1,358
METRO	04/25/2010	INDIAN BEND	10	UNKNOWN / OTHER	07:25PM	07:56PM	08:17PM	1,586	2,341
NORTHWEST	04/19/2010	PAULDEN	2	FOREIGN INTERFERENCE - BIRDS	06:04AM	07:51AM	12:57PM	3,062	1,449

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The underlined items reflect change(s).

1000 HOUR CUSTOMER OUTAGE REPORT
(04/26/2010 - 05/02/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/27/2010	COLTER	9	HUMAN ELEMENT – SWITCHING ERROR - NON FIELD PERSONNEL	10:09AM	11:10AM	11:10AM	1,242	1,222
METRO	05/1/2010	WINTERSBURG	12	UNKNOWN	12:50PM	14:04PM	14:04PM	1,591	1,290
METRO	05/02/2010	COLDWATER	18	UNKNOWN	03:27AM	04:11AM	04:11AM	1,302	1,776
NORTHEAST	04/26/2010	MAZATZAL TEMPORARY	2	SUBSTATION RELATED	05:29AM	01:42PM	01:42PM	3,560	435
NORTHEAST	04/26/2010	MAZATZAL TEMPORARY	6	SUBSTATION RELATED	05:29AM	07:29AM	07:36PM	3,336	1,580
NORTHEAST	04/28/2010	BLUE RIDGE	12	VEGETATION CONTACT	08:43AM	09:25AM	09:25AM	3,557	144
NORTHEAST	04/28/2010	BLUE RIDGE	12	VEGETATION CONTACT	11:37AM	01:14PM	06:45PM	1,271	302
NORTHEAST	04/28/2010	WINSLOW	2	SUBSTATION RELATED	05:14PM	06:48PM	06:48PM	3,353	2,140

6/11/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(04/26/2010 - 05/02/2010)

NORTHEAST	04/28/2010	WINSLOW	14	WEATHER – WIND	05:23PM	05:24PM	06:21PM	1,714	1,804
NORTHEAST	04/28/2010	WINSLOW	14	WEATHER – WIND	06:21PM	07:04PM	07:24PM	1,598	1,804
NORTHEAST	05/2/2010	SNOWFLAKE	2	EQUIPMENT FAILURE	11:28AM	12:53PM	03:31PM	2,590	757
NORTHWEST	05/2/2010	COPPER CANYON	2	UNKNOWN	01:57PM	03:57PM	03:57PM	2,338	1,169
NORTHWEST	05/02/2010	COPPER CANYON	2	WEATHER – WIND	01:57PM	03:09PM	03:09PM	1,628	1,357

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(04/26/2010 - 05/02/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/27/2010	COLTER	9	HUMAN ELEMENT	10:09AM	11:10AM	11:10AM	1,242	1,222
METRO	05/1/2010	WINTERSBURG	12	UNKNOWN	12:50PM	14:04PM	14:04PM	1,591	1,290
METRO	05/02/2010	COLDWATER	18	UNKNOWN	03:27AM	04:11AM	04:11AM	1,302	1,776
NORTHEAST	04/26/2010	MAZATZAL TEMPORARY	2	SUBSTATION RELATED	05:29AM	01:42PM	01:42PM	3,574	435
NORTHEAST	04/26/2010	MAZATZAL TEMPORARY	6	SUBSTATION RELATED	05:29AM	07:29AM	07:36PM	3,336	1,580
NORTHEAST	04/28/2010	BLUE RIDGE	12	VEGETATION CONTACT	08:43AM	09:25AM	09:25AM	3,557	144
NORTHEAST	04/28/2010	BLUE RIDGE	12	VEGETATION CONTACT	11:37AM	01:14PM	06:45PM	1,271	302
NORTHEAST	04/28/2010	WINSLOW	2	SUBSTATION RELATED	05:14PM	06:48PM	06:48PM	3,353	2,140

6/24/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(04/26/2010 - 05/02/2010)
REVISED

NORTHEAST	04/28/2010	WINSLOW	14	WEATHER – WIND	05:23PM	05:24PM	06:21PM	1,714	1,804
NORTHEAST	04/28/2010	WINSLOW	14	WEATHER – WIND	06:21PM	07:04PM	07:24PM	1,598	1,804
NORTHEAST	05/2/2010	SNOWFLAKE	2	EQUIPMENT FAILURE	11:28AM	12:53PM	03:31PM	2,590	757
NORTHWEST	05/2/2010	COPPER CANYON	2	UNKNOWN	01:57PM	03:57PM	03:57PM	2,338	1,169
NORTHWEST	05/02/2010	COPPER CANYON	2	WEATHER – WIND	01:57PM	03:09PM	03:09PM	1,628	1,357

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The underlined items reflect change(s).

6/24/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(04/26/2010 - 05/02/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	04/27/2010	COLTER	9	HUMAN ELEMENT	10:09AM	11:10AM	11:10AM	1,242	1,222
METRO	05/1/2010	WINTERSBURG	12	UNKNOWN	12:50PM	14:04PM	14:39PM	1,886	1,290
METRO	05/02/2010	COLDWATER	18	WEATHER - WIND	03:27PM	04:11PM	04:47PM	1,800	1,776
NORTHEAST	04/26/2010	MAZATZAL TEMPORARY	2	SUBSTATION RELATED	05:29AM	01:42PM	01:42PM	3,574	435
NORTHEAST	04/26/2010	MAZATZAL TEMPORARY	6	SUBSTATION RELATED	05:29AM	07:29AM	07:36PM	3,336	1,580
NORTHEAST	04/28/2010	BLUE RIDGE	12	VEGETATION CONTACT	08:43AM	09:25AM	09:25AM	3,557	144
NORTHEAST	04/28/2010	BLUE RIDGE	12	VEGETATION CONTACT	11:37AM	01:14PM	06:45PM	1,271	302
NORTHEAST	04/28/2010	WINSLOW	2	SUBSTATION RELATED	05:14PM	06:48PM	06:48PM	3,353	2,140

7/19/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(04/26/2010 - 05/02/2010)
REVISED

NORTHEAST	04/28/2010	WINSLOW	14	WEATHER – WIND	05:23PM	05:24PM	06:21PM	1,714	1,804
NORTHEAST	04/28/2010	WINSLOW	14	WEATHER – WIND	06:21PM	07:04PM	07:24PM	1,598	1,804
NORTHEAST	05/2/2010	SNOWFLAKE	2	STORM RELATED	11:28AM	12:56PM	03:31PM	2,562	757
NORTHWEST	05/02/2010	COPPER CANYON	2	WEATHER – WIND	01:57PM	03:09PM	03:09PM	1,628	1,357

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The underlined items reflect change(s).

7/19/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(05/03/2010-05/09/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/08/2010	WADDELL	12	SUBSTATION RELATED	10:22AM	11:24AM	11:24AM	1,341	1,298
METRO	05/08/2010	WADDELL	13	SUBSTATION RELATED	10:22AM	11:26AM	11:26AM	1,973	1,850
METRO	05/08/2010	WADDELL	10	SUBSTATION RELATED	10:22AM	11:25AM	11:25AM	1,140	1,086
NORTHWEST	05/04/2010	CAPITAL BUTTE	2	FOREIGN INTERFERENCE – ANIMALS	03:01PM	04:01PM	06:08PM	1,337	429

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

6/11/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(05/03/2010-05/09/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/08/2010	WADDEL	12	SUBSTATION RELATED	10:22AM	11:24AM	11:24AM	1,341	1,298
METRO	05/08/2010	WADDELL	13	SUBSTATION RELATED	10:22AM	11:26AM	11:26AM	1,973	1,850
METRO	05/08/2010	WADDELL	18	SUBSTATION RELATED	10:22AM	11:25AM	11:25AM	1,140	1,086
NORTHWEST	05/04/2010	CAPITAL BUTTE	2	FOREIGN INTERFERENCE – ANIMALS	03:01PM	06:08PM	06:08PM	1,337	429

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The underlined items reflect change(s).

7/19/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(05/10/2010-05/16/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	05/14/2010	PREACHER CANYON	6	EQUIPMENT FAILURE	10:04AM	10:30AM	10:30AM	1,325	3,057
NORTHWEST	05/13/2010	CHINO VALLEY	6	EQUIPMENT FAILURE	07:57AM	08:19AM	08:19AM	1,118	3,048

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

6/11/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(05/17/2010 - 05/23/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	05/22/2010	COCONINO	12	VEGETATION CONTACT – STORM RELATED	01:00PM	07:55PM	07:55PM	2,843	411
NORTHWEST	05/22/2010	WHITE SPAR	12	UNDERGROUND CABLE	12:55AM	09:30AM	09:30AM	1,571	183
SOUTHEAST	05/22/2010	PALOMINAS	4	ENVIRONMENT – FIRE	06:48AM	08:29AM	12:17PM	3,829	1,315

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(05/24/2010 - 05/30/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/26/2010	DALE	9	UNKNOWN / OTHER	12:12AM	01:32AM	01:32AM	1,501	1,126
METRO	05/26/2010	MONTE CRISTO	14	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	03:29AM	04:43AM	04:43AM	1,170	1,596
METRO	05/26/2010	DYSART	17	UNKNOWN / OTHER	10:31PM	11:15PM	11:15PM	1,131	1,542
METRO	05/29/2010	ORANGEWOOD	22	UNKNOWN / OTHER	01:58AM	02:51AM	10:46AM	2,194	1,337

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

6/24/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(05/24/2010 - 05/30/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	05/26/2010	DALE	9	UNKNOWN / OTHER	12:12AM	01:25AM	03:30AM	1,556	1,126
METRO	05/26/2010	MONTE CRISTO	14	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	03:59AM	04:43AM	04:43AM	1,170	1,596
METRO	05/26/2010	DYSART	17	UNDERGROUND CABLE	10:31PM	11:15PM	00:09AM	1,271	1,542
METRO	05/29/2010	ORANGEWOOD	22	FOREIGN INTERFERENCE - VEHICLES	01:58AM	02:51AM	10:46AM	2,194	1,337

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The underlined items reflect change(s).

7/19/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(05/31/2010 - 06/06/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/05/2010	DEER VALLEY	21	UNDERGROUND CABLE	08:10AM	08:40AM	09:28AM	1,037	1,581
METRO	06/06/2010	BUFFALO	4	EQUIPMENT FAILURE	12:53PM	01:22PM	02:21PM	1,345	1,460
NORTHWEST	06/05/2010	WHITE SPAR	12	UNDERGROUND CABLE	11:14AM	07:06PM	07:06PM	1,243	158

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

7/19/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/07/2010 - 06/13/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/10/2010	ALTADENA	13	UNDERGROUND CABLE	02:34PM	03:03PM	03:59PM	1,892	1,488
METRO	06/12/2010	WADDELL	18	EQUIPMENT FAILURE	10:44AM	11:16AM	04:30PM	1,437	1,086
METRO	06/12/2010	BUTTE	21	FOREIGN INTERFERENCE – OTHER	05:17PM	05:50PM	00:31AM	1,637	1,859
METRO	06/13/2010	DIXILETA	13	SUBSTATION RELATED	05:16AM	06:21AM	06:21AM	1,225	1,131
SOUTHEAST	06/08/2010	CASA GRANDE	2	WIRE DOWN	04:57PM	05:51PM	04:41PM 06/09/10	2,927	1,526

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

7/8/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/14/2010 - 06/20/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/18/2010	DURANGO	14	UNKNOWN / OTHER	10:21AM	12:00PM	12:00PM	2158	1308
NORTHEAST	06/20/2010	SANDVIG	4	ENVIRONMENT - FIRE	03:36PM	10:36AM (6/22)	10:36AM (6/22)	1118	26
NORTHWEST	06/15/2010	SEDONA	2	UNDERGROUND CABLE	07:11PM	02:06AM (6/16)	02:06AM (6/16)	2947	426
SOUTHEAST	06/16/2010	FAIRVIEW	1	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	05:00PM	05:42PM	05:42PM	1898	2712
SOUTHEAST	06/19/2010	MURAL	1	FOREIGN INTERFERENCE – VEHICLES	09:04PM	11:33PM	01:32AM (6/20)	4783	1308
SOUTHWEST	06/17/2010	TENTH STREET	9	EQUIPMENT FAILURE	12:33AM	02:15AM	02:15AM	1586	981

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

7/23/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/14/2010 - 06/20/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/18/2010	DURANGO	14	UNKNOWN / OTHER	10:21AM	10:49AM	12:00PM	1058	1308
METRO	06/18/2010	ALTADENA	13	FOREIGN INTERFERENCE – ANIMALS	07:53AM	08:21AM	12:15PM	1326	1488
NORTHEAST	06/20/2010	SANDVIG	4	ENVIRONMENT – FIRE	03:36PM	10:36AM (6/22)	10:36AM (6/22)	1118	26
NORTHWEST	06/15/2010	SEDONA	2	UNDERGROUND CABLE	07:11PM	02:06AM (6/16)	02:06AM (6/16)	2947	426
SOUTHEAST	06/16/2010	FAIRVIEW	1	FOREIGN INTERFERENCE – OTHER ACCIDENTAL	05:00PM	05:42PM	05:42PM	1898	2712
SOUTHEAST	06/19/2010	MURAL	1	FOREIGN INTERFERENCE – VEHICLES	09:04PM	11:33PM	01:32AM (6/20)	4783	1308
SOUTHWEST	06/17/2010	TENTH STREET	9	EQUIPMENT FAILURE	12:38AM	02:15AM	02:15AM	1586	981

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/2/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/14/2010 - 06/20/2010)
REVISED

The underlined items reflect changes.

9/2/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/21/2010 - 06/27/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/23/2010	DESERT RIDGE	1	SUBSTATION RELATED	08:19PM	12:10AM	12:10AM	4,805	1,248
METRO	06/23/2010	DESERT RIDGE	4	SUBSTATION RELATED	08:19PM	11:34PM	11:34PM	2,249	692
METRO	06/23/2010	DESERT RIDGE	13	SUBSTATION RELATED	08:19PM	11:52PM	11:52PM	2,723	767
METRO	06/23/2010	DESERT RIDGE	20	SUBSTATION RELATED	08:19PM	12:13AM	12:13AM	3,822	980
METRO	06/25/2010	MEADOWBROOK	6	FOREIGN INTERFERENCE - BIRDS	07:32AM	08:38AM	04:30PM	2,222	2,013

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

7/29/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/21/2010 - 06/27/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/23/2010	DESERT RIDGE	1	SUBSTATION RELATED	08:19PM	12:10AM (6/24)	12:10AM (6/24)	4,805	1,248
METRO	06/23/2010	DESERT RIDGE	4	SUBSTATION RELATED	08:19PM	11:34PM	11:34PM	2,249	692
METRO	06/23/2010	DESERT RIDGE	13	SUBSTATION RELATED	08:19PM	11:52PM	11:52PM	2,723	767
METRO	06/23/2010	DESERT RIDGE	20	SUBSTATION RELATED	08:19PM	12:13AM (6/24)	12:13AM (6/24)	3,822	980
METRO	06/25/2010	MEADOWBROOK	6	FOREIGN INTERFERENCE - BIRDS	07:32AM	08:37AM	04:30PM	2,189	2,013

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

The underlined items reflect changes.

9/2/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/28/2010 - 07/04/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	06/28/2010	BUFFALO	10	UNDERGROUND CABLE	08:11PM	08:48PM	10:09PM	2,219	1,728
METRO	06/30/2010	DESERT SPRINGS	13	UNDERGROUND CABLE	08:28AM	09:31AM	09:31AM	1,050	1,000
METRO	06/30/2010	TEMPE	14	UNDERGROUND CABLE	02:23PM	02:57PM	04:22PM	3,250	2,509
METRO	07/01/2010	EL SOL	18	FOREIGN INTERFERENCE	07:59PM	08:55PM	03:09AM	4,846	1,778
METRO	07/01/2010	SPANISH GARDEN	12	UNDERGROUND CABLE	10:36PM	11:53PM	01:02AM	3,370	1,419
NORTHEAST	06/28/2010	TUBA CITY	3	TRANSMISSION RELATED-STORM	06:51PM	07:44PM	07:44PM	1,412	1,599
NORTHEAST	7/3/2010	SWITZER CANYON	14	UNDERGROUND CABLE	07:00AM	08:36AM	01:50PM	1,310	577
NORTHEAST	07/04/2010	KEAMS CANYON	3	SUBSTATION RELATED	12:10PM	02:00PM	02:00PM	2,748	1,499

8/18/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(06/28/2010 - 07/04/2010)

NORTHWEST	06/28/2010	COTTONWOOD	18	EQUIPMENT FAILURE	11:17AM	12:05PM	12:05PM	1,926	2,408
NORTHWEST	07/01/2010	CAPITAL BUTTE	12	UNDERGROUND CABLE	10:16PM	11:54PM	12:58AM	5,311	2,152
SOUTHEAST	07/01/2010	SAN MANUEL	29	WEATHER-STORM RELATED	05:39PM	06:21PM	06:21PM	1,494	1,750

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

8/18/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(07/05/2010 - 07/11/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/06/2010	TWENTY-THIRD ST	22	EQUIPMENT FAILURE	06:24PM	07:00PM	07:48PM	1,910	1,913
METRO	07/08/2010	DESERT SPRINGS	12	UNDERGROUND CABLE	08:35PM	09:18PM	09:42PM	1,231	1,311
METRO	07/09/2010	ALTADENA	4	FOREIGN INTERFERENCE - ANIMALS	05:44AM	06:24AM	01:59PM	1,655	1,109
NORTHEAST	0710/2010	BLUE RIDGE	12	UNDERGROUND CABLE	12:39PM	07:31PM	06:16AM	1,257	72
NORTHWEST	07/06/2010	WICKENBURG	10	HUMAN ELEMENT – DIG IN	08:59AM	10:06AM	11:42AM	1,505	560
NORTHWEST	07/10/2010	KIRKLAND JUNCTION	10	TRANSMISSION RELATED – STORM RELATED	03:52AM	07:34AM	07:34AM	1,765	477
NORTHWEST	07/10/2010	WILHOIT	2	TRANSMISSION RELATED – STORM RELATED	03:52AM	06:13AM	06:13AM	1,055	449
NORTHWEST	07/10/2010	YARNELL	4	TRANSMISSION RELATED – STORM RELATED	03:52AM	06:18AM	06:18AM	1,460	600

8/18/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(07/05/2010 - 07/11/2010)

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

8/18/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(07/12/2010 – 07/18/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/12/2010	DESERT SPRINGS	13	UNDERGROUND CABLE	06:53PM	07:57PM	10:10PM	1,576	1,002
METRO	07/16/2010	NEW RIVER	10	EQUIPMENT FAILURE	05:16PM	06:17PM	06:17PM	1,412	1,389
NORTHEAST	07/16/2010	COCONINO	24	WEATHER-LIGHTNING	11:47AM	12:15PM	03:07PM	4,964	1,768
NORTHEAST	07/18/2010	SNOWFLAKE	14	SUBSTATION REALTED	07:18PM	08:26PM	09:23PM	2,044	1,661
NORTHWEST	07/15/2010	PAULDEN	2	SUBSTATION REALTED	02:00PM	06:46PM	07:02PM	6,862	1,421
NORTHWEST	07/16/2010	LONESOME VALLEY	10	FOREIGN INTERFERENCE	02:13PM	03:09PM	07:28PM	2,584	1,790
NORTHWEST	07/16/2010	COPPER CANYON	6	WEATHER-STORM RELATED	03:40PM	04:54PM	04:54PM	2,390	1,938
NORTHWEST	07/18/2010	OAK CREEK	10	UNDERGROUND CABLE	10:18PM	12:19AM (7/19)	12:19AM (7/19)	3,487	1.729
SOUTHEAST	07/13/2010	FAIRVIEW	4	EQUIPMENT FAILURE	06:30PM	08:02PM	11:48PM	1,957	866

1000 HOUR CUSTOMER OUTAGE REPORT
(07/12/2010 – 07/18/2010)

SOUTHEAST	07/15/2010	KEARNEY	2	EQUIPMENT FAILURE	04:07PM	08:23PM	08:23PM	4,075	955
SOUTHEAST	07/15/2010	PINAL	1	EQUIPMENT FAILURE	05:28PM	08:58PM	09:24PM	3,611	974
SOUTHEAST	07/15/2010	PINAL	2	EQUIPMENT FAILURE	05:36PM	06:38PM	11:07PM	4,888	895
SOUTHEAST	07/15/2010	PINAL	4	EQUIPMENT FAILURE	05:57PM	06:26PM	06:26PM	1,029	2,129
SOUTHEAST	07/16/2010	CASA GRANDE	6	FOREIGN INTERFERENCE	02:09PM	02:10PM	09:15PM	2,431	956
SOUTHWEST	07/13/2010	QUARTZSITE	2	SUBSTATION RELATED	01:38PM	03:04PM	03:04PM	1,203	839
SOUTHWEST	07/13/2010	QUARZSITE	6	SUBSTATION RELATED	01:38PM	03:05PM	03:05PM	1,699	1,172

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/2/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(07/19/2010 – 07/25/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/21/2010	DEADMAN WASH	10	UNKNOWN/OTHER	08:38AM	09:17AM	09:17AM	1,287	1,980
METRO	07/23/2010	WESTBROOK	11	UNDERGROUND CABLE	12:16AM	01:31AM	01:40AM	2,700	2,038
METRO	07/24/2010	SPANISH GARDENS	12	UNDERGROUND CABLE	08:25PM	08:55PM	09:30PM	1,191	1,409
METRO	07/24/2010	EASTERN OFFICE	13	EQUIPMENT FAILURE	10:57PM	11:48PM	12:34AM (7/25)	1,382	1,490
METRO	07/25/2010	DEER VALLEY	28	EQUIPMENT FAILURE	03:45AM	04:39AM	05:52AM	1,391	1,363
NORTHEAST	07/25/2010	SHUMWAY	6	WEATHER-LIGHTNING	12:59PM	03:42PM	03:42PM	1,122	413
NORTHWEST	07/22/2010	BALD MOUNTAIN	9	EQUIPMENT FAILURE	02:17PM	03:14PM	03:14PM	1,195	1,258
SOUTHEAST	07/19/2010	FAIRVIEW	3	WEATHER-LIGHTNING	05:42PM	01:48AM (7/20)	01:48AM (7/20)	1,531	189

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

9/2/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(07/19/2010 – 07/25/2010)

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/2/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(07/26/2010 – 08/01/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	07/29/2010	VALENCIA	10	EQUIPMENT FAILURE	03:06AM	04:01AM	09:05AM	1173	1129
METRO	07/29/2010	TEMPE	18	WEATHER	03:27PM	04:51PM	04:51PM	3210	2293
METRO	07/29/2010	MARINETTE	13	EQUIPMENT FAILURE	04:16PM	05:18PM	07:46PM	3690	2584
METRO	07/29/2010	RIO VISTA	13	WEATHER	04:18PM	04:47PM	05:32PM	1483	2432
METRO	07/29/2010	HEDGEPETH HILLS	5	EQUIPMENT FAILURE	05:02PM	05:55PM	06:57PM	1509	1366
METRO	07/29/2010	WINTERSBURG	12	WEATHER	05:22PM	08:59PM	08:59PM	4680	1294
METRO	07/29/2010	WINTERSBURG	12	WEATHER	09:04PM	09:13PM	05:03AM (7/30)	2074	875
METRO	07/31/2010	ORANGEWOOD	29	EQUIPMENT FAILURE	10:15AM	10:39AM	06:33PM	1854	1413

1000 HOUR CUSTOMER OUTAGE REPORT
(07/26/2010 – 08/01/2010)

METRO	07/31/2010	PIMA	3	WEATHER	12:47PM	02:32PM	03:28PM	1365	616
NORTHEAST	07/27/2010	TONTO	14	WEATHER	03:56PM	04:45PM	09:30PM	3973	1031
NORTHEAST	07/27/2010	PREACHER CANYON	2	WEATHER	04:38PM	02:19PM (7/28)	02:19PM (7/28)	1258	58
NORTHEAST	07/31/2010	MAZATZAL TEMPORARY	6	WEATHER	12:34PM	04:05PM (8/5)	04:05PM (8/5)	1482	12
NORTHWEST	07/31/2010	SEDONA	6	VEGETATION CONTACT	11:27PM	01:02AM (8/1)	01:02AM (8/1)	2117	1337
SOUTHEAST	07/28/2010	KEARNY	2	WEATHER	06:47PM	08:20PM	08:20PM	1479	954
SOUTHEAST	07/29/2010	CASA GRANDE	7	WEATHER	02:56PM	03:18PM	04:11PM	1545	2209
SOUTHEAST	07/30/2010	FAIRVIEW	3	WEATHER	06:18PM	07:16PM	07:16PM	1305	440

1000 HOUR CUSTOMER OUTAGE REPORT
(07/26/2010 – 08/01/2010)

Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(08/02/2010 – 08/08/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/03/2010	NORTH VALLEY	10	UNDERGROUND CABLE	03:04PM	03:43PM	04:55PM	1305	1429
METRO	08/07/2010	TARTESSO TEMPORARY	4	TRANSMISSION RELATED	08:24AM	12:57PM	12:57PM	4441	976
METRO	08/07/2010	SPANISH GARDENS	12	UNDERGROUND CABLE	03:56PM	04:22PM	04:51PM	1170	1419
NORTHEAST	08/02/2010	MAZATZAL TEMPORARY	6	EQUIPMENT FAILURE	01:13PM	02:53PM	02:53PM	2510	1506
NORTHEAST	08/06/2010	TUBA CITY	3	WEATHER	01:58PM	05:58PM	05:58PM	1392	348
NORTHEAST	08/07/2010	COCONINO	24	WEATHER	09:12AM	11:30AM	02:30PM	2615	1133
NORTHWEST	08/02/2010	DELANO	10	EQUIPMENT FAILURE	06:37AM	10:30AM	10:30AM	1355	349
SOUTHEAST	08/02/2010	MURAL	2	EQUIPMENT FAILURE	04:20PM	05:33PM	10:31PM	2725	1457
SOUTHEAST	08/06/2010	SAN MANUEL	29	WEATHER (STORM RELATED)	06:06PM	06:46PM	06:46PM	1111	1667

9/16/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(08/02/2010 – 08/08/2010)

SOUTHEAST	08/06/2010	SAN MANUEL	29	WEATHER (STORM RELATED)	08:59PM	09:14PM	04:18AM 8/7/10	6633	1667

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(08/09/2010 – 08/15/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/09/2010	PALM VALLEY	13	EQUIPMENT FAILURE	05:59PM	07:07PM	07:07PM	1140	1006
METRO	08/13/2010	ALTADENA	13	FOREIGN INTERFERENCE - ANIMAL	09:15AM	09:35AM	10:52AM	1004	1485
NORTHWEST	08/15/2010	OAK CREEK	6	EQUIPMENT FAILURE	01:04AM	03:38AM	07:50AM	5233	1389
NORTHWEST	08/15/2010	CORNVILLE	2	VEGETATION CONTACT (STORM RELATED)	08:45PM	10:11PM	02:01AM 08/16/10	1804	1131
SOUTHEAST	08/15/2010	KEARNY	2	WEATHER	05:41PM	10:22PM	10:50PM	4646	946

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/28/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(08/16/2010 – 08/22/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/18/2010	CIELO GRANDE	10	EQUIPMENT FAILURE	02:23AM	04:01AM	11:10AM	1653	1000
METRO	08/21/2010	GLENDALE	6	EQUIPMENT FAILURE	10:12PM	11:10PM	12:38AM 08/22/10	2874	1290
METRO	08/21/2010	GAVILAN PEAK	42	FOREIGN INTERFERENCE - VEHICLE	11:08PM	12:40AM 08/22/10	01:11AM 08/22/10	2108	1311
METRO	08/21/2010	ADOBE	9	EQUIPMENT FAILURE (STORM RELATED)	11:54PM	01:39AM 08/22/10	05:40AM 08/22/10	1566	890
METRO	08/22/2010	DIXILETA	13	EQUIPMENT FAILURE (STORM RELATED)	06:36AM	08:44AM	11:30AM	2523	1141
NORTHEAST	08/17/2010	KACHINA	4	FOREIGN INTERFERENCE - VEHICLE	02:28PM	03:15PM	07:22PM	2137	2729
NORTHEAST	08/21/2010	SHUMWAY	6	WEATHER - LIGHTNING	06:46AM	10:30AM	10:30AM	1590	426
NORTHEAST	08/21/2010	TONTO	14	WEATHER - LIGHTNING	04:42PM	06:21PM	06:21PM	1701	1031

9/22/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(08/16/2010 – 08/22/2010)

NORTHWEST	08/21/2010	CHINO VALLEY	6	WEATHER - LIGHTNING	12:29AM	02:14AM	02:14AM	1941	1109
SOUTHEAST	08/21/2010	SAGUARO	13	EQUIPMENT FAILURE	07:58PM	12:12AM 08/22/10	12:12AM 08/22/10	2922	180
SOUTHWEST	08/17/2010	SALOME	1	WEATHER/STORM RELATED	05:04PM	09:29PM	09:29PM	1572	356
SOUTHWEST	08/17/2010	SALOME	1	WEATHER/STORM RELATED	09:39PM	10:44AM 08/19/10	06:00PM 8/19/10	1676	43

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

9/22/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(08/23/2010 – 08/29/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	08/24/2010	DALE	9	EQUIPMENT FAILURE	06:26AM	07:02AM	09:24AM	1032	1130
METRO	08/24/2010	CIELO GRANDE	9	SUBSTATION RELATED (STORM)	04:08PM	05:04PM	05:04PM	1728	1882
METRO	08/24/2010	CIELO GRANDE	10	SUBSTATION RELATED (STORM)	04:08PM	05:14PM	05:14PM	1101	1001
METRO	08/24/2010	CIELO GRANDE	12	SUBSTATION RELATED (STORM)	04:08PM	05:05PM	05:05PM	1183	1268
METRO	08/24/2010	INDIAN BEND	10	EQUIPMENT FAILURE (STORM)	04:39PM	06:20PM	06:20PM	3951	2347
METRO	08/24/2010	DOUBLE TREE	2	WEATHER	04:41PM	05:52PM	05:52PM	1421	1201
METRO	08/24/2010	ORANGEWOOD	17	VEGETATION CONTACT (STORM)	04:47PM	05:54PM	06:49PM	1209	1032
METRO	08/24/2010	MUMMY MOUNTAIN	9	EQUIPMENT FAILURE (STORM)	04:51PM	06:25PM	11:45PM	1512	897

1000 HOUR CUSTOMER OUTAGE REPORT
(08/23/2010 – 08/29/2010)

METRO	08/24/2010	HONEYWELL	9	EQUIPMENT FAILURE (STORM)	06:07PM	07:25PM	10:46PM	2119	1584
METRO	08/27/2010	MOUNTAIN VIEW	4	UNDERGROUND CABLE	12:37AM	01:34AM	02:15AM	1696	1452
METRO	08/27/2010	SPANISH GARDENS	12	FOREIGN INTERFERENCE – DIG IN	02:47PM	03:20PM	04:21PM	1672	1409
METRO	08/28/2010	GLENDALE	6	EQUIPMENT FAILURE (STORM)	05:58PM	06:38PM	07:09PM	1360	1280
METRO	08/29/2010	PIONEER	22	FOREIGN INTERFERENCE – VEHICLES	12:30PM	01:44PM	01:44PM	1027	844
METRO	08/29/2010	MOON VALLEY	5	UNDERGROUND CABLE	05:10PM	05:56PM	07:28PM	1435	1812
NORTHWEST	08/24/2010	MORRISTOWN	6	WEATHER – STORM RELATED	05:02PM	05:56PM	06:36PM	1111	1095
NORTHWEST	08/24/2010	MORRISTOWN	2	EQUIPMENT FAILURE (STORM)	05:35PM	09:05PM	06:30PM 08/25/10	3771	598
SOUTHEAST	08/27/2010	TOLTEC	4	UNDERGROUND CABLE	10:49AM	11:36AM	12:03PM 8/30/10	1729	77

1000 HOUR CUSTOMER OUTAGE REPORT
(08/23/2010 – 08/29/2010)

SOUTHEAST	08/28/2010	FARRELL	6	LOSS OF SUPPLY – OTHER UTILITY (STORM)	02:50PM	05:31PM	05:31PM	2029	756
SOUTHWEST	08/25/2010	QUARTZSITE	2	TRANSMISSION RELATED (STORM)	02:52AM	02:07PM	02:07PM	9630	856
SOUTHWEST	08/25/2010	QUARTZSITE	6	TRANSMISSION RELATED (STORM)	02:52AM	02:07PM	02:07PM	13455	1196
SOUTHWEST	08/25/2010	COCOPAH	2	UNKNOWN/OTHER	03:12AM	04:24PM 08/27/10	04:24PM 08/27/10	111384	1820
SOUTHWEST	08/26/2010	COCOPAH	12	SUBSTATION RELATED (STORM)	02:24PM	03:04PM	03:04PM	1024	1576
SOUTHWEST	08/26/2010	COCOPAH	13	SUBSTATION RELATED (STORM)	02:24PM	15:04PM	03:04PM	1221	1879
SOUTHWEST	08/26/2010	COCOPAH	14	SUBSTATION RELATED (STORM)	02:24PM	03:05PM	03:05PM	1030	1545
SOUTHWEST	08/26/2010	TENTH STREET	6	EQUIPMENT FAILURE	07:37PM	05:56PM 08/27/10	05:56PM 08/27/10	32045	1437
SOUTHWEST	08/26/2010	COCOPAH	5	WEATHER (STORM)	07:42PM	09:45PM	09:45PM	4122	2027

1000 HOUR CUSTOMER OUTAGE REPORT
(08/23/2010 – 08/29/2010)

SOUTHWEST	08/26/2010	TENTH STREET	7	EQUIPMENT FAILURE (STORM)	07:42PM	01:18AM 08/27/10	01:18AM 08/27/10	12261	2196
SOUTHWEST	08/26/2010	QUECHAN	21	EQUIPMENT FAILURE (STORM)	07:43PM	02:41AM 08/27/10	02:41AM 08/27/10	6325	910
SOUTHWEST	08/26/2010	COCOPAH	13	EQUIPMENT FAILURE (STORM)	07:45PM	09:59PM	09:59PM	4297	1924
SOUTHWEST	08/26/2010	COCOPAH	12	WEATHER (STORM)	07:57PM	09:11PM	09:11PM	1917	1576
SOUTHWEST	08/26/2010	THIRTY-SECOND ST	2	EQUIPMENT FAILURE (STORM)	07:59PM	07:33AM 08/27/10	07:33AM 08/27/10	14898	1288
SOUTHWEST	08/26/2010	COCOPAH	14	EQUIPMENT FAILURE (STORM)	08:02PM	02:06AM 08/27/10	02:06AM 08/27/10	9347	1545
SOUTHWEST	08/26/2010	COCOPAH	1	WEATHER (STORM)	08:03PM	10:15PM	10:15PM	3910	1791
SOUTHWEST	08/26/2010	LAGUNA	1	EQUIPMENT FAILURE (STORM)	08:05PM	03:15AM 08/27/10	03:15AM 08/27/10	1390	194
SOUTHWEST	08/26/2010	THIRTY-SECOND ST	1	WEATHER (STORM)	08:27PM	09:13PM	09:13PM	1106	1443
SOUTHWEST	08/26/2010	COCOPAH	5	WEATHER (STORM)	11:26PM	12:20AM 08/27/10	12:20AM 08/27/10	1824	2027

1000 HOUR CUSTOMER OUTAGE REPORT
(08/23/2010 – 08/29/2010)

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

10/21/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(08/30/2010 – 09/05/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/01/2010	ALTADENA	13	UNKNOWN/OTHER	04:44AM	05:56AM	05:56AM	1784	1487
METRO	09/04/2010	PALM VALLEY	2	FOREIGN INTERFERENCE - VEHICLES	07:30AM	08:32AM	10:45PM	1715	673
SOUTHEAST	08/31/2010	TOLTEC	5	EQUIPMENT FAILURE	03:10AM	05:19AM	07:34AM	1938	645
SOUTHWEST	09/04/2010	FOOTHILLS	10	EQUIPMENT FAILURE	03:30PM	04:37PM	04:37PM	1828	1637

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(09/06/2010 – 09/12/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/12/2010	ALTADENA	13	UNDERGROUND CABLE	02:10AM	03:04AM	04:38AM	2314	1487

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(09/13/2010 – 09/19/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/17/2010	ALTADENA	17	FOREIGN INTERFERENCE – ANIMALS	05:31AM	06:07AM	08:20AM	1263	1325
METRO	09/19/2010	NEW RIVER	12	EQUIPMENT FAILURE	05:52PM	06:49PM	08:44PM	1405	1202
NORTHEAST	09/16/2010	SWITZER CANYON	13	UNDERGROUND CABLE	06:50AM	07:40AM	07:48AM	5522	5768
NORTHEAST	09/16/2010	SWITZER CANYON	13	UNDERGROUND CABLE	09:26AM	09:44AM	09:44AM	1712	5708
NORTHEAST	09/17/2010	KEAMS CANYON	3	EQUIPMENT FAILURE	01:33PM	01:50PM	06:49PM	7401	1549
NORTHWEST	09/17/2010	LONESOME VALLEY	6	EQUIPMENT FAILURE	01:10PM	01:55PM	05:06PM	1921	1969

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

10/26/2010

1000 HOUR CUSTOMER OUTAGE REPORT
(9/20/2010 – 9/26/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	09/21/2010	GILA BEND	22	WEATHER – STORM RELATED	04:16PM	05:29PM	08:50AM 9/22/10	2202	260
METRO	09/22/2010	STAGECOACH	9	UNKNOWN/OTHER	07:25PM	08:15PM	10:07PM	1285	910
METRO	09/25/2010	DALE	4	FOREIGN INTERFERENCE – DIG IN CUSTOMER	11:16AM	12:06PM	12:32PM	1172	1157
METRO	09/25/2010	SPANISH GARDENS	5	EQUIPMENT FAILURE	04:40PM	05:38PM	06:55PM	2258	2162
NORTHEAST	09/22/2010	COCONINO	12	WEATHER-STORM RELATED	04:10AM	04:59AM	10:37AM	5202	770
NORTHWEST	09/22/2010	QUAIL SPRINGS	2	WEATHER-STORM RELATED	05:45PM	10:37PM	10:37PM	5762	1184

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(9/27/2010 – 10/03/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/02/2010	BASELINE	1	FOREIGN INTERFERENCE – VEHICLES	09:27AM	10:20AM	07:08PM	1248	373
NORTHEAST	09/30/2010	KEAMS CANYON	3	EQUIPMENT FAILURE – STORM RELATED	09:30AM	12:26PM	04:33PM	10299	1549
SOUTHEAST	10/02/2010	CASA GRANDE	2	EQUIPMENT FAILURE – STORM RELATED	08:15PM	08:55PM	11:15PM	2031	1514
SOUTHWEST	09/30/2010	THIRTY-SECOND ST.	1	EQUIPMENT FAILURE – STORM RELATED	04:52PM	05:05PM	11:25PM	1516	1448
SOUTHWEST	10/02/2010	COCOPAH	12	WEATHER-STORM RELATED	12:30PM	01:29PM	01:29PM	1550	1576
SOUTHWEST	10/02/2010	BLUEWATER	2	EQUIPMENT FAILURE - STORM RELATED	06:02PM	08:19PM	08:19PM	2292	1004

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(9/27/2010 – 10/03/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/02/2010	BASELINE	1	FOREIGN INTERFERENCE – VEHICLES	09:27AM	10:20AM	07:08PM	1248	373
NORTHEAST	09/30/2010	KEAMS CANYON	3	EQUIPMENT FAILURE – STORM RELATED	09:30AM	12:26PM	04:33PM	10299	1549
SOUTHEAST	10/02/2010	CASA GRANDE	2	EQUIPMENT FAILURE – STORM RELATED	08:15PM	08:55PM	11:15PM	2085	1514
SOUTHWEST	09/30/2010	THIRTY-SECOND ST.	1	EQUIPMENT FAILURE – STORM RELATED	04:52PM	05:05PM	11:25PM	1516	1448
SOUTHWEST	10/02/2010	COCOPAH	12	WEATHER-STORM RELATED	12:30PM	01:29PM	01:29PM	1550	1576
SOUTHWEST	10/02/2010	BLUEWATER	2	EQUIPMENT FAILURE - STORM RELATED	06:02PM	08:19PM	08:19PM	2292	1004

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(10/04/2010 – 10/10/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/04/2010	TONOPAH	1	TRANSMISSION RELATED	02:50PM	07:05PM	07:21PM	2222	515
METRO	10/04/2010	TONOPAH	3	TRANSMISSION RELATED	02:50PM	12:26AM 10/05/10	12:26AM 10/05/10	3389	353
METRO	10/04/2010	PIMA	3	WEATHER-STORM RELATED	03:27PM	07:05PM	08:26PM	2037	516
METRO	10/04/2010	TONOPAH	1	EQUIPMENT FAILURE – STORM	07:21PM	12:59PM 10/06/10	12:59PM 10/06/10	2998	72
METRO	10/05/2010	ENCANTO	9	EQUIPMENT FAILURE – STORM	04:06AM	11:43AM	11:43AM	2925	384
METRO	10/05/2010	INDIANOLA	19	WEATHER-STORM RELATED	12:28PM	01:20PM	01:54PM	1246	1140
METRO	10/05/2010	ROADRUNNER	9	EQUIPMENT FAILURE – STORM	12:43PM	01:19PM	05:00PM	1282	1176
METRO	10/05/2010	DURANGO	1	EQUIPMENT FAILURE – STORM	03:22PM	07:31PM 10/05/10	04:22PM 10/06/10	6102	978

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(10/04/2010 – 10/10/2010)

METRO	10/05/2010	SHERMAN STREET	13	EQUIPMENT FAILURE – STORM	04:49PM	08:31PM	10:00PM	3130	623
METRO	10/05/2010	MCDOWELL	14	WEATHER-STORM RELATED	04:50PM	11:00PM 10/05/10	11:11PM 10/07/10	4687	237
METRO	10/05/2010	ENCANTO	5	WEATHER-STORM RELATED	04:51PM	11:23PM	11:23PM	3829	586
METRO	10/05/2010	ENCANTO	10	WEATHER-STORM RELATED	04:51PM	11:01PM	11:01PM	4853	787
METRO	10/05/2010	ENCANTO	4	WEATHER-STORM RELATED	04:51PM	12:26AM 10/06/10	09:15PM 10/06/10	2488	287
METRO	10/05/2010	ENCANTO	12	VEGETATION CONTACT	04:51PM	11:08PM	11:08PM	5567	886
METRO	10/05/2010	MCDOWELL	17	WEATHER-STORM RELATED	05:07PM	03:03PM	03:23PM	7030	696
METRO	10/06/2010	MCDOWELL	20	WEATHER-STORM RELATED	10:34PM	11:23PM	11:23PM	1412	17:29
METRO	10/06/2010	LONE PEAK	12	UNDERGROUND CABLE	11:14AM	01:42PM	03:16PM	5615	1694
METRO	10/10/2010	PEORIA	4	UNDERGROUND CABLE	09:24PM	09:58PM	10:32PM	1913	2063

1000 HOUR CUSTOMER OUTAGE REPORT
(10/04/2010 – 10/10/2010)

NORTHEAST	10/04/2010	GRAND CANYON	1	TRANSMISSION RELATED - STORM	02:08AM	04:24AM	04:24AM	1043	460
NORTHEAST	10/04/2010	GRAND CANYON	3	TRANSMISSION RELATED - STORM	02:08AM	04:24AM	04:24AM	1319	582
NORTHEAST	10/04/2010	RED LAKE	2	TRANSMISSION RELATED - STORM	02:08AM	04:24AM	04:24AM	1736	766
NORTHEAST	10/04/2010	TUBA CITY	3	WEATHER-STORM RELATED	08:29PM	09:39PM	09:39PM	1897	1626
NORTHEAST	10/06/2010	BLUE RIDGE	12	EQUIPMENT FAILURE - STORM	02:58AM	02:30PM	02:30PM	1246	108
NORTHEAST	10/06/2010	PARKS	14	TRANSMISSION RELATED - STORM	06:20AM	07:33AM	07:33AM	1020	838
NORTHWEST	10/06/2010	POLAND JUNCTION	1	EQUIPMENT FAILURE – STORM	03:39AM	10:42AM	10:42AM	1008	143
SOUTHEAST	10/05/2010	CASA GRANDE	7	FOREIGN INTERFERENCE	03:52PM	04:25PM	04:25PM	1201	2183

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(10/04/2010 – 10/10/2010)
REVISED

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/04/2010	TONOPAH	1	TRANSMISSION RELATED	02:50PM	07:05PM	07:21PM	2222	515
METRO	10/04/2010	TONOPAH	3	TRANSMISSION RELATED	02:50PM	12:26AM 10/05/2010	12:26AM 10/05/2010	3389	353
METRO	10/04/2010	PIMA	3	WEATHER-STORM RELATED	03:27PM	07:05PM	08:26PM	2037	516
METRO	10/04/2010	TONOPAH	1	EQUIPMENT FAILURE – STORM	07:21PM	12:59PM 10/06/2010	12:59PM 10/06/2010	2998	72
METRO	10/05/2010	ENCANTO	9	EQUIPMENT FAILURE – STORM	04:06AM	11:43AM	11:43AM	2925	384
METRO	10/05/2010	INDIANOLA	19	WEATHER-STORM RELATED	12:28PM	01:20PM	01:54PM	1246	1140
METRO	10/05/2010	ROADRUNNER	9	EQUIPMENT FAILURE – STORM	12:43PM	01:19PM	05:00PM	1282	1176
METRO	10/05/2010	DURANGO	1	EQUIPMENT FAILURE – STORM	03:22PM	07:31PM 10/05/2010	04:22PM 10/06/2010	6102	978

1000 HOUR CUSTOMER OUTAGE REPORT
(10/04/2010 – 10/10/2010)
REVISED

METRO	10/05/2010	SHERMAN STREET	13	EQUIPMENT FAILURE – STORM	04:49PM	08:31PM	10:00PM	3130	623
METRO	10/05/2010	MCDOWELL	14	WEATHER-STORM RELATED	04:50PM	11:00PM 10/05/2010	11:11PM 10/07/2010	4687	237
METRO	10/05/2010	ENCANTO	5	WEATHER-STORM RELATED	04:51PM	11:23PM	11:23PM	3829	586
METRO	10/05/2010	ENCANTO	10	WEATHER-STORM RELATED	04:51PM	11:01PM	11:01PM	4853	787
METRO	10/05/2010	ENCANTO	4	WEATHER-STORM RELATED	04:51PM	12:26AM 10/06/2010	09:15PM 10/06/2010	2488	287
METRO	10/05/2010	ENCANTO	12	VEGETATION CONTACT	04:51PM	11:08PM	11:08PM	5567	886
METRO	10/05/2010	MCDOWELL	17	WEATHER-STORM RELATED	05:07PM	03:03PM	03:23PM	7030	696
METRO	10/06/2010	MCDOWELL	20	WEATHER-STORM RELATED	10:34PM	11:23PM	11:23PM	1412	1729
METRO	10/06/2010	LONE PEAK	12	UNDERGROUND CABLE	11:14AM	01:42PM	03:18PM	5615	1694
METRO	10/10/2010	PEORIA	4	UNDERGROUND CABLE	09:24PM	09:58PM	10:32PM	1913	2063

2/16/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(10/04/2010 – 10/10/2010)
REVISED

NORTHEAST	10/04/2010	GRAND CANYON	1	TRANSMISSION RELATED - STORM	02:08AM	04:24AM	04:24AM	1043	460
NORTHEAST	10/04/2010	GRAND CANYON	3	TRANSMISSION RELATED - STORM	02:08AM	04:24AM	04:24AM	1319	582
NORTHEAST	10/04/2010	RED LAKE	2	TRANSMISSION RELATED - STORM	02:08AM	04:24AM	04:24AM	1736	766
NORTHEAST	10/04/2010	TUBA CITY	3	WEATHER-STORM RELATED	08:29PM	09:39PM	09:39PM	1897	1626
NORTHEAST	10/06/2010	BLUE RIDGE	12	EQUIPMENT FAILURE - STORM	02:58AM	02:30PM	02:30PM	1246	108
NORTHEAST	10/06/2010	PARKS	14	TRANSMISSION RELATED - STORM	06:20AM	07:33AM	07:33AM	1020	838
NORTHWEST	10/06/2010	POLAND JUNCTION	1	EQUIPMENT FAILURE – STORM	03:39AM	10:42AM	10:42AM	1008	143
SOUTHEAST	10/05/2010	CASA GRANDE	7	FOREIGN INTERFERENCE	03:52PM	04:25PM	04:25PM	1201	2183

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(10/11/2010 – 10/17/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/11/2010	PARADISE	19	FOREIGN INTERFERENCE	05:59PM	06:45PM	07:01PM	2027	2056
NORTHWEST	10/11/2010	DEWEY	10	EQUIPMENT FAILURE	05:35PM	11:34PM	12:13AM	14796	2243
NORTHWEST	10/14/2010	LONESOME VALLEY	2	UNKNOWN/OTHER	08:19AM	08:38AM	08:38AM	1255	3964
NORTHWEST	10/17/2010	LONESOME VALLEY	2	EQUIPMENT FAILURE	02:54PM	04:47PM	04:47PM	1428	758
SOUTHWEST	10/12/2010	LAGUNA	5	UNKNOWN/OTHER	09:46AM	10:47AM	10:47AM	1868	1837
SOUTHWEST	10/12/2010	COCOPAH	12	EQUIPMENT FAILURE	05:11PM	05:25PM	08:49PM	1004	1576
SOUTHWEST	10/15/2010	SAN LUIS	1	SUBSTATION RELATED	08:31AM	09:42AM	09:42AM	1575	1331
SOUTHWEST	10/15/2010	SAN LUIS	2	SUBSTATION RELATED	08:31AM	09:43AM	09:43AM	1998	1665
SOUTHWEST	10/15/2010	SAN LUIS	10	SUBSTATION RELATED	08:31AM	09:43AM	09:43AM	2693	2244

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(10/11/2010 – 10/17/2010)

SOUTHWEST	10/15/2010	SAN LUIS	14	SUBSTATION RELATED	08:31AM	09:51AM	09:51AM	1659	1244

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(10/18/2010 – 10/24/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/20/2010	BUFFALO	2	FOREIGN INTERFERENCE	01:47AM	02:30AM	02:30AM	1205	1681
METRO	10/20/2010	JOMAX	9	EQUIPMENT FAILURE	07:08AM	08:12AM	02:55PM	1833	982
METRO	10/20/2010	SURPRISE	21	FOREIGN INTERFERENCE	10:32AM	10:56AM	04:25PM	1007	2451
METRO	10/20/2010	EL SOL	12	EQUIPMENT FAILURE	11:23PM	12:41AM	10:21PM 10/21/10	3320	2071

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(10/25/2010 – 10/31/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	10/25/2010	SKUNK CREEK	2	SUBSTATION RELATED	12:55AM	06:26AM	06:26AM	6261	1135
METRO	10/25/2010	SKUNK CREEK	4	SUBSTATION RELATED	12:55AM	06:26AM	06:26AM	4926	893
METRO	10/25/2010	SKUNK CREEK	6	SUBSTATION RELATED	12:55AM	06:26AM	06:26AM	10746	1948
METRO	10/25/2010	SKUNK CREEK	10	SUNSTATION RELATED	12:55AM	06:26AM	06:26AM	1318	239
METRO	10/25/2010	SKUNK CREEK	12	SUBSTATION RELATED	12:55AM	06:26AM	06:26AM	5930	1075
METRO	10/25/2010	SKUNK CREEK	13	SUBSTATION RELATED	12:55AM	06:26AM	06:26AM	5599	1015
METRO	10/25/2010	SKUNK CREEK	14	SUBSTATION RELATED	12:55AM	06:26AM	06:26AM	6739	1221
METRO	10/30/2010	CHANDLER	13	EQUIPMENT FAILURE	12:23AM	03:43AM	03:43AM	1117	335

1000 HOUR CUSTOMER OUTAGE REPORT
(10/25/2010 – 10/31/2010)

NORTHEAST	10/31/2010	TUBA CITY	2	TRANSMISSION RELATED	11:51AM	09:30PM	09:30PM	7672	795
NORTHEAST	10/31/2010	TUBA CITY	3	TRANSMISSION RELATED	11:51AM	09:31PM	09:31PM	15718	1626
NORTHWEST	10/31/2010	DEWEY	14	EQUIPMENT FAILURE	04:48AM	10:46PM	10:46PM	3312	555
NORTHWEST	10/31/2010	COPPER CANYON	6	EQUIPMENT FAILURE	07:29AM	09:08AM	09:08AM	3252	1971

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(11/01/2010 – 11/07/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/01/2010	TURF	4	UNDERGROUND CABLE	02:44AM	03:36AM	04:16AM	1405	1413

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(11/08/2010 – 11/14/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/09/2010	DEER VALLEY	13	UNDERGROUND CABLE	04:07AM	05:13AM	06:10AM	1023	503
METRO	11/11/2010	FILLMORE	19	FOREIGN INTERFERENCE	08:11AM	08:49AM	12:40PM	1245	1302
METRO	11/14/2010	ENCANTO	10	FOREIGN INTERFERENCE	12:43AM	01:27AM	09:20AM	2437	787

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/26/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(11/15/2010 – 11/21/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHEAST	11/19/2010	ELDEN	12	UNDERGROUND CABLE	08:40AM	08:54AM	10:07AM	1604	3208
NORTHWEST	11/21/2010	MCGUIREVILLE	10	UKNOWN/OTHER	12:13AM	01:13AM	01:13AM	1065	1065

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(11/22/2010 – 11/28/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	11/23/2010	JOMAX	9	EQUIPMENT FAILURE - WIRE DOWN	05:03PM	08:05PM	08:05PM	2275	750
METRO	11/25/2010	GREENBRIER	2	EQUIPMENT FAILURE -	11:43PM	01:01AM	01:07AM 11/26/10	2244	1662
METRO	11/27/2010	PARADISE	2	EQUIPMENT FAILURE – WIRE DOWM	08:53AM	09:48AM	01:20PM	3885	2414
METRO	11/27/2010	CHANDLER	13	SUBSTATION RELATED -	09:09AM	09:47AM	09:47AM	1284	2028
METRO	11/28/2010	STOUT	1	EQUIPMENT FAILURE -	09:32PM	10:10PM	10:49PM	1592	1860
SOUTHEAST	11/26/2010	FAIRVIEW	4	SUBSTATION RELATED –WIRE DOWN	05:32AM	07:17AM	07:17AM	1516	866
SOUTHEAST	11/26/2010	FAIRVIEW	6	SUBSTATION RELATED –WIRE DOWN	05:32AM	07:17AM	07:17AM	1883	1076
SOUTHWEST	11/25/2010	HAVASU	1	WEATHER -WIND	12:09AM	01:50AM	01:50AM	1247	741

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(11/22/2010 – 11/28/2010)

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(11/29/2010 – 12/05/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/03/2010	SKUNK CREEK	6	FOREIGN INTERFERENCE – ANIMALS	04:28PM	05:07PM	07:06PM	1385	1948
METRO	12/04/2010	HEDGEPETH HILLS	13	FOREIGN INTERFERENCE – VEHICLES	09:42PM	10:41PM	11:41PM	1479	1398
NORTHEAST	11/30/2010	STRAWBERRY	2	UNKNOWN / OTHER	01:57PM	02:56PM	02:56PM	1525	1551
NORTHWEST	12/04/2010	OAK CREEK	6	UNDERGROUND CABLE	05:42AM	07:06AM	09:48AM	2212	1389
SOUTHWEST	12/04/2010	EHRENBERG	4	UNKNOWN / OTHER	02:23AM	04:02AM	04:02AM	1046	634

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/24/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(12/13/2010 – 12/19/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/13/2010	RIO VISTA	2	UNDERGROUND CABLE	02:31PM	03:44PM	06:43PM	3740	2031
METRO	12/15/2010	DURANGO	14	EQUIPMENT FAILURE	01:20PM	01:58PM	15:11PM	1118	1308
NORTHEAST	12/14/2010	ELDEN	12	UNKNOWN / OTHER	11:46AM	12:37PM	12:37PM	2550	3000
NORTHEAST	12/18/2010	COCONINO	12	WEATHER-STORM RELATED	03:53PM	04:13PM	11:35PM	1609	409
NORTHEAST	12/19/2010	SANDVIG	14	WEATHER-STORM RELATED	03:45AM	02:15PM	02:15PM	1755	30
SOUTHWEST	12/16/2010	THIRTY-SECOND ST	12	WEATHER-STORM RELATED	07:37AM	08:08AM	10:35AM	1036	1275
SOUTHWEST	12/19/2010	LAGUNA	9	EQUIPMENT FAILURE	02:22AM	04:04AM	06:47AM	5148	1762

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1000 HOUR CUSTOMER OUTAGE REPORT
(12/06/2010 – 12/12/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
NORTHWEST	12/07/2010	LONESOME VALLEY	6	UKNOWN/OTHER	04:05PM	05:10PM	05:10PM	2124	1961

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

1/26/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(12/20/2010 – 12/26/2010)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/22/2010	ORANGEWOOD	32	WEATHER-STORM RELATED	07:54PM	08:33PM	10:59PM	2267	974
METRO	12/22/2010	BUTTE	28	EQUIPMENT FAILURE	11:26PM	12:16AM 12/23/2010	04:48AM 12/23/2010	2173	1616
METRO	12/22/2010	ENCANTO	12	EQUIPMENT FAILURE	11:27PM	12:16AM 12/23/2010	03:47AM 12/23/2010	1863	886
METRO	12/22/2010	MEADOWBROOK	22	VEGETATION CONTACT	11:34PM	01:56AM 12/23/2010	01:56AM 12/23/2010	1117	472
METRO	12/26/2010	COLDWATER	12	SUBSTATION RELATED	10:12PM	11:09PM	11:09PM	1660	1747
METRO	12/26/2010	COLDWATER	18	SUBSTATION RELATED	10:12PM	11:09PM	11:09PM	1690	1779
METRO	12/26/2010	COLDWATER	22	SUBSTATION RELATED	10:12PM	11:09PM	11:09PM	1140	1200
NORTHEAST	12/22/2010	COCONINO	14	WEATHER-STORM RELATED	12:43AM	02:45AM	02:45AM	4764	183
NORTHEAST	12/23/2010	RED LAKE	2	WEATHER-STORM RELATED	05:36AM	07:20AM	07:20AM	1284	741

2/16/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(12/20/2010 – 12/26/2010)

NORTHEAST	12/23/2010	RED LAKE	2	WEATHER-STORM RELATED	07:35AM	10:00AM	10:58AM	1961	741
SOUTHWEST	12/21/2010	LAGUNA	5	WEATHER-STORM RELATED	05:05PM	06:37PM	06:37PM	2817	1837
SOUTHWEST	12/22/2010	QUECHAN	30	EQUIPMENT FAILURE	04:19AM	07:02AM	09:06AM	3285	1203
SOUTHWEST	12/22/2010	UTTING	1	WEATHER-STORM RELATED	08:43PM	11:54PM	11:54PM	2689	841
SOUTHWEST	12/26/2010	THIRTY-SECOND ST	4	FOREIGN INTERFERENCE	07:21AM	08:20AM	08:20AM	1057	1075

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

2/16/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(12/27/2010-01/02/2011)

Division	Date	Substation	FDR#	Cause	Time of Outage	Time of First Restoration	Time of Final Restoration	Customer Hours off *	Customer Count**
METRO	12/30/2010	PEORIA	13	WEATHER – STORM RELATED	01:35AM	02:18AM	03:39AM	1600	1416
METRO	12/30/2010	ENCANTO	2	WEATHER – STORM RELATED	03:39AM	04:26AM	05:05AM	1733	1680
METRO	12/31/2010	HAPPY VALLEY TEMPORARY	4	EQUIPMENT FAILURE	08:27AM	09:54AM	09:54AM	1972	1360
NORTHEAST	12/29/2010	STRAWBERRY	2	WEATHER – STORM RELATED	06:22PM	08:08PM	9:20PM	2683	1368
NORTHEAST	12/29/2010	TONTO	14	WEATHER – STORM RELATED	06:53PM	09:40PM	09:40PM	1216	437
NORTHEAST	12/30/2010	SNOWFLAKE	2	WEATHER- STORM RELATED	05:06AM	07:56AM	07:56AM	6078	2145
NORTHEAST	12/30/2010	SNOWFLAKE	14	WEATHER- STORM RELATED	05:07AM	07:42AM	07:42AM	4436	1717
NORTHEAST	12/30/2010	STRAWBERRY	2	WEATHER- STORM RELATED	04:30PM	07:25PM	10:53PM	2464	560

2/21/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(12/27/2010-01/02/2011)

NORTHEAST	12/30/2010	PREACHER CANYON	6	WEATHER-STORM RELATED	06:36PM	07:57PM	08:18PM	1504	981
NORTHEAST	01/01/2011	WOODRUFF	2	EQUIPMENT FAILURE – STORM RELATED	01:33AM	03:31AM	12:19PM	1920	262
NORTHEAST	01/01/2011	COCONINO	12	EQUIPMENT FAILURE – STORM RELATED	05:03AM	03:14PM	03:14PM	4603	452
NORTHEAST	01/01/2011	MUNDS PARK	5	WEATHER-STORM RELATED	10:25AM	02:36PM	02:36PM	1255	300
NORTHEAST	01/01/2011	PREACHER CANYON	6	UNKNOWN	12:17PM	02:37PM	02:37PM	7121	3052
NORTHWEST	12/29/2010	WHITE SPAR	12	WEATHER-STORM RELATED	09:26PM	10:43AM 12/30/2010	10:43AM 12/30/2010	1461	110
NORTHWEST	12/30/2010	PAULDEN	2	EQUIPMENT FAILURE – STORM RELATED	02:30AM	10:47AM	10:47AM	2800	338
NORTHWEST	12/30/2010	WHITE SPAR	10	WEATHER – STORM RELATED	05:47PM	01:09AM 12/31/2010	01:09AM 12/31/10	2173	295
SOUTHEAST	12/29/2010	FAIRVIEW	14	TRANSMISSION RELATED-STORM	07:50PM	08:15PM	08:15PM	1011	2426

2/21/2011

1000 HOUR CUSTOMER OUTAGE REPORT
(12/27/2010-01/02/2011)

*Individual customer hours may vary as portions of the feeder may have been brought on line sequentially. Outage data is reviewed monthly and is subject to change as additional information is received. Any revision resulting in a change greater than 10% in customer hours will be resubmitted.

** Based on the definition of "Customer" contained in A.A.C. R-14-2-201 (9).

2/21/2011

Attachment B

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	1/22/07 14:16		1/22/07 18:31		Unplanned
Cholla 2	1/22/07 1:30		1/22/07 3:58		Unplanned
Cholla 3	1/23/07 7:18		1/23/07 12:06		Unplanned
Douglas	No Outages				
Four Corners 1	1/13/07 17:11		1/13/07 21:58		Unplanned
Four Corners 2	1/10/07 22:59		1/13/07 18:16		Unplanned
Four Corners 3	1/16/07 7:00		1/16/07 9:59		Unplanned
Four Corners 4	1/4/07 3:16		1/7/07 17:46		Unplanned
Four Corners 5	1/6/07 4:51		1/8/07 17:17		Unplanned
	1/15/07 3:31		1/16/07 1:00		Unplanned
Navajo 1	No Outages				
Navajo 2	1/1/07 0:00	(1)	1/6/07 23:49		Unplanned
	1/27/07 14:00		2/1/07 0:00	(2)	Planned
Navajo 3	1/13/07 0:13		1/16/07 1:23		Unplanned
	1/18/07 12:05		1/18/07 13:34		Unplanned
	1/20/07 10:22		1/20/07 12:26		Unplanned
	1/20/07 13:35		1/20/07 15:16		Unplanned
	1/24/07 23:55		1/27/07 3:22		Maintenance
	1/27/07 3:52		1/27/07 4:10		Unplanned
Ocotillo CT1	1/15/07 7:38		1/15/07 9:10		Unplanned
	1/15/07 10:30		1/15/07 16:05		Unplanned
Ocotillo CT2	No Outages				
Ocotillo ST1	1/16/07 3:40		1/16/07 4:38		Unplanned
	1/16/07 6:42		1/16/07 19:05		Unplanned
	1/27/07 0:01		2/1/07 0:00	(2)	Planned
Ocotillo ST2	No Outages				
Palo Verde 1	No Outages				
Palo Verde 2	No Outages				
Palo Verde 3	1/27/07 0:00		1/31/07 23:07		Maintenance
Redhawk CT1A	1/15/07 8:05		1/15/07 8:30		Unplanned
	1/27/07 23:54		1/28/07 0:58		Unplanned
Redhawk CT1B	1/15/07 8:05		1/15/07 8:44		Unplanned
	1/26/07 9:56		1/27/07 10:08		Unplanned
Redhawk CT2A	1/4/07 4:00		1/4/07 12:15		Unplanned
	1/8/07 15:25		1/8/07 16:48		Unplanned
Redhawk CT2B	No Outages				
Redhawk ST1	1/15/07 7:24		1/15/07 11:05		Unplanned
	1/17/07 8:18		1/17/07 9:23		Unplanned
	1/26/07 6:30		1/27/07 18:09		Unplanned
	1/27/07 23:54		1/28/07 0:58		Unplanned
Redhawk ST2	No Outages				
Saguaro CT1	1/24/07 0:01		1/31/07 16:20		Planned
Saguaro CT2	No Outages				
Saguaro CT3	1/22/07 10:00		1/22/07 15:50		Unplanned
	1/23/07 10:38		1/23/07 14:00		Unplanned
Saguaro ST1	No Outages				
Saguaro ST2	No Outages				

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2007

Plant and Unit	Outage Start: Date/Time	Outage End: Date/Time		Description (3)
Sundance CT1	No Outages			
Sundance CT2	No Outages			
Sundance CT3	No Outages			
Sundance CT4	No Outages			
Sundance CT5	No Outages			
Sundance CT6	No Outages			
Sundance CT7	No Outages			
Sundance CT8	No Outages			
Sundance CT9	No Outages			
Sundance CT10	No Outages			
West Phoenix CC1	1/4/07 4:53	1/4/07 5:16		Unplanned
	1/10/07 15:50	1/14/07 19:30		Unplanned
	1/15/07 6:46	1/18/07 7:15		Unplanned
	1/18/07 16:00	1/19/07 17:00		Unplanned
	1/21/07 22:58	1/22/07 10:40		Unplanned
	1/22/07 23:53	1/23/07 10:15		Unplanned
West Phoenix CC2	1/9/07 11:30	1/9/07 12:20		Unplanned
	1/13/07 0:01	2/1/07 0:00	(2)	Planned
West Phoenix CC3	1/13/07 16:20	1/14/07 16:05		Unplanned
	1/15/07 5:08	1/15/07 17:17		Unplanned
	1/15/07 17:35	1/15/07 18:15		Unplanned
	1/22/07 5:23	1/22/07 10:00		Unplanned
	1/24/07 16:55	1/25/07 4:56		Unplanned
	1/25/07 12:04	1/25/07 15:23		Unplanned
	1/31/07 17:47	1/31/07 18:20		Unplanned
West Phoenix CC4	1/15/07 9:00	1/15/07 11:13		Unplanned
	1/17/07 20:00	1/18/07 12:30		Unplanned
	1/19/07 14:34	1/22/07 19:25		Unplanned
West Phoenix CT1	1/15/07 7:10	1/15/07 12:46		Unplanned
West Phoenix CT2	1/4/07 6:00	1/8/07 15:19		Maintenance
	1/9/07 11:00	1/11/07 13:00		Maintenance
	1/15/07 7:25	1/15/07 16:08		Unplanned
West Phoenix CT5A	1/14/07 14:25	1/14/07 18:15		Unplanned
West Phoenix CT5B	1/14/07 15:40	1/14/07 18:15		Unplanned
	1/14/07 19:06	1/17/07 17:17		Unplanned
West Phoenix ST5	1/4/07 10:03	1/4/07 13:58		Unplanned
	1/14/07 15:40	1/14/07 18:15		Unplanned
	1/21/07 4:58	1/21/07 12:30		Unplanned
Yucca CT1	1/28/07 0:30	1/28/07 2:52		Maintenance
	1/29/07 4:00	2/1/07 0:00	(2)	Planned
Yucca CT2	No Outages			
Yucca CT3	1/23/07 8:36	1/23/07 16:45		Unplanned
	1/28/07 0:10	1/28/07 1:27		Unplanned
Yucca CT4	No Outages			

(1) Designations of 1/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 2/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	No Outages				
Cholla 2	2/1/07 10:07		2/3/07 22:35		Unplanned
Cholla 3	No Outages				
Douglas	No Outages				
Four Corners 1	2/27/07 12:02		2/27/07 15:59		Unplanned
Four Corners 2	2/6/07 18:55		3/1/07 0:00	(2)	Planned
Four Corners 3	No Outages				
Four Corners 4	2/11/07 3:34		2/11/07 17:57		Unplanned
Four Corners 5	2/12/07 6:19		2/16/07 16:05		Unplanned
	2/20/07 7:13		2/23/07 5:34		Unplanned
Navajo 1	2/6/07 23:14		2/7/07 0:00		Unplanned
Navajo 2	2/1/07 0:00	(1)	2/19/07 6:49		Planned
	2/19/07 14:03		2/22/07 21.07		Planned
Navajo 3	2/9/07 23:49		2/11/07 15:19		Maintenance
	2/11/07 17:59		2/11/07 20:56		Unplanned
Ocotillo CT1	No Outages				
Ocotillo CT2	No Outages				
Ocotillo ST1	2/1/07 0:00	(1)	2/16/07 14:35		Planned
Ocotillo ST2	No Outages				
Palo Verde 1	No Outages				
Palo Verde 2	2/7/07 1:58		2/9/07 6:16		Maintenance
	2/19/07 16:45		2/26/07 6:02		Maintenance
Palo Verde 3	No Outages				
Redhawk CT1A	2/8/07 0:00		2/9/07 2:00		Unplanned
	2/9/07 5:35		2/9/07 10:27		Unplanned
	2/9/07 14:30		2/10/07 18:30		Unplanned
	2/28/07 22:55		3/1/07 0:00	(2)	Unplanned
Redhawk CT1B	2/8/07 0:00		2/9/07 2:00		Unplanned
	2/9/07 4:30		2/9/07 10:27		Unplanned
	2/9/07 14:35		2/10/07 18:30		Unplanned
	2/28/07 22:55		3/1/07 0:00	(2)	Unplanned
Redhawk CT2A	2/22/07 2:19		2/22/07 2:39		Unplanned
	2/28/07 9:59		3/1/07 0:00	(2)	Unplanned
Redhawk CT2B	No Outages				
Redhawk ST1	2/5/07 9:20		2/5/07 16:50		Unplanned
	2/6/07 2:08		2/6/08 7:30		Unplanned
	2/6/07 16:10		2/9/07 2:00		
	2/9/07 4:30		2/9/07 10:27		Unplanned
	2/9/07 14:35		2/10/07 18:30		Unplanned
	2/11/07 7:30		2/11/07 8:07		Unplanned
	2/28/07 22:55		3/1/07 0:00	(2)	Unplanned
Redhawk ST2	2/28/07 10:11		2/28/07 12:31		Unplanned
Saguaro CT1	No Outages				
Saguaro CT2	No Outages				
Saguaro CT3	2/16/07 7:00		2/16/07 13:40		Maintenance
Saguaro ST1	2/26/07 0:00		3/1/07 0:00	(2)	Planned
Saguaro ST2	No Outages				

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Sundance CT1	No Outages				
Sundance CT2	No Outages				
Sundance CT3	2/26/07 7:00		3/1/07 0:00	(2)	Planned
Sundance CT4	2/26/07 7:00		3/1/07 0:00	(2)	Planned
Sundance CT5	No Outages				
Sundance CT6	No Outages				
Sundance CT7	No Outages				
Sundance CT8	No Outages				
Sundance CT9	No Outages				
Sundance CT10	No Outages				
West Phoenix CC1	2/9/07 5:49		2/9/07 6:49		Unplanned
	2/18/07 15:00		2/26/07 5:10		Planned
	2/26/07 17:10		2/26/07 17:46		Unplanned
West Phoenix CC2	2/1/07 0:00	(1)	3/1/07 0:00	(2)	Planned
West Phoenix CC3	2/2/07 5:16		2/2/07 6:18		Unplanned
	2/18/07 15:00		2/26/07 5:10		Planned
West Phoenix CC4	2/8/07 20:35		2/8/07 22:00		Unplanned
	2/20/07 6:18		2/20/07 7:31		Unplanned
West Phoenix CT1	2/12/07 5:26		2/13/07 6:30		Unplanned
	2/22/07 23:30		2/23/07 0:30		Unplanned
West Phoenix CT2	2/12/07 5:33		2/12/07 17:43		Unplanned
	2/22/07 23:30		2/23/07 0:30		Unplanned
West Phoenix CT5A	2/21/07 23:55		2/24/07 16:45		Unplanned
West Phoenix CT5B	No Outages				
West Phoenix ST5	No Outages				
Yucca CT1	2/1/07 0:00	(1)	2/2/07 11:43		Planned
	2/28/07 6:50		2/28/07 7:23		Unplanned
Yucca CT2	2/5/07 4:00		2/9/07 12:02		Planned
Yucca CT3	No Outages				
Yucca CT4	2/12/07 4:30		2/18/07 17:07		Planned

(1) Designations of 2/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 3/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	3/2/07 23:58		3/6/07 10:20		Planned
	3/6/07 10:58		3/6/07 12:51		Unplanned
	3/7/07 13:33		3/7/07 17:06		Unplanned
	3/9/07 3:57		3/9/07 6:53		Unplanned
	3/9/07 10:59		3/9/07 13:44		Unplanned
	3/15/07 13:12		3/15/07 18:54		Unplanned
	3/22/07 1:42		3/22/07 12:19		Unplanned
	3/29/07 9:37		3/29/07 21:54		Unplanned
Cholla 2	No Outages				
Cholla 3	3/20/07 22:01		3/23/07 22:46		Unplanned
Douglas	No Outages				
Four Corners 1	3/31/07 22:10		4/1/07 0:00	(2)	Unplanned
Four Corners 2	3/1/07 0:00	(1)	3/13/07 18:55		Planned
	3/13/07 18:55		3/15/07 12:35		Planned
	3/15/07 16:25		3/15/07 21:58		Unplanned
Four Corners 3	No Outages				
Four Corners 4	No Outages				
Four Corners 5	3/11/07 19:33		4/1/07 0:00	(2)	Unplanned
Navajo 1	3/31/07 0:25		4/1/07 0:00	(2)	Maintenance
Navajo 2	No Outages				
Navajo 3	No Outages				
Ocotillo CT1	No Outages				
Ocotillo CT2	No Outages				
Ocotillo ST1	No Outages				
Ocotillo ST2	3/5/07 0:00		3/23/07 15:20		Planned
Palo Verde 1	No Outages				
Palo Verde 2	No Outages				
Palo Verde 3	No Outages				
Redhawk CT1A	3/1/07 0:00	(1)	3/18/07 2:45		Unplanned
Redhawk CT1B	3/1/07 0:00	(1)	3/1/07 10:39		Unplanned
Redhawk CT2A	3/1/07 0:00	(1)	3/2/07 19:00		Unplanned
Redhawk CT2B	No Outages				
Redhawk ST1	3/1/07 0:00	(1)	3/1/07 10:39		Unplanned
	3/1/07 17:44		3/1/07 17:48		Unplanned
	3/12/07 9:50		3/12/07 10:13		Unplanned
	3/18/07 18:46		3/18/07 18:56		Unplanned
	3/20/07 20:03		3/20/07 20:17		Unplanned
	3/23/07 6:56		3/23/07 7:15		Unplanned
Redhawk ST2	No Outages				
Saguaro CT1	3/12/07 13:21		3/12/07 23:00		Unplanned
	3/13/07 3:16		3/13/07 15:00		Unplanned
Saguaro CT2	3/12/07 13:21		3/12/07 23:00		Unplanned
	3/13/07 3:16		3/13/07 15:00		Unplanned
	3/26/07 0:00		4/1/07 0:00	(2)	Planned
Saguaro CT3	3/1/07 7:30		3/1/07 11:00		Unplanned
Saguaro ST1	3/1/07 0:00	(1)	3/16/07 10:00		Planned
Saguaro ST2	No Outages				

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Sundance CT1	No Outages				
Sundance CT2	No Outages				
Sundance CT3	3/1/07 0:00	(1)	3/7/07 16:05		Planned
Sundance CT4	3/1/07 0:00	(1)	3/7/07 16:05		Planned
Sundance CT5	3/12/07 0:00		3/21/07 11:33		Planned
Sundance CT6	3/12/07 0:00		3/21/07 11:33		Planned
	3/28/07 9:50		3/28/07 13:30		Maintenance
Sundance CT7	No Outages				
Sundance CT8	No Outages				
Sundance CT9	3/21/07 19:50		3/21/07 21:15		Unplanned
Sundance CT10	No Outages				
West Phoenix CC1	3/26/07 0:00		3/29/07 19:00		Maintenance
West Phoenix CC2	3/1/07 0:00	(1)	4/1/07 0:00	(2)	Planned
West Phoenix CC3	3/1/07 5:23		3/1/07 8:15		Unplanned
	3/29/07 6:09		3/29/07 21:15		Unplanned
West Phoenix CC4	No Outages				
West Phoenix CT1	No Outages				
West Phoenix CT2	No Outages				
West Phoenix CT5A	3/29/07 21:55		3/30/07 0:10		Unplanned
West Phoenix CT5B	3/30/07 6:00		3/30/07 15:45		Maintenance
West Phoenix ST5	No Outages				
Yucca CT1	No Outages				
Yucca CT2	No Outages				
Yucca CT3	3/5/07 0:00		4/1/07 0:00	(2)	Planned
Yucca CT4	No Outages				

(1) Designations of 3/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 4/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
Apr-07

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	4/20/07 8:05		4/20/07 10:03		Unplanned
Cholla 2	No Outages				
Cholla 3	4/19/07 23:08		4/20/07 5:32		Unplanned
	4/20/07 7:51		4/20/07 11:46		Unplanned
Douglas	No Outages				
Four Corners 1	4/1/07 0:00	(1)	4/9/07 13:43		Unplanned
	4/10/07 15:04		4/10/07 19:22		Unplanned
	4/10/07 23:19		4/11/07 2:57		Unplanned
Four Corners 2	No Outages				
Four Corners 3	4/25/07 22:57		4/28/07 7:18		Unplanned
Four Corners 4	No Outages				
Four Corners 5	4/1/07 0:00	(1)	5/1/07 0:00	(2)	Unplanned
Navajo 1	4/1/07 0:00	(1)	4/5/07 14:23		Maintenance
Navajo 2	No Outages				
Navajo 3	4/28/07 0:48		4/30/07 8:12		Unplanned
Ocotillo CT1	No Outages				
Ocotillo CT2	4/9/07 6:32		4/17/07 14:39		Planned
Ocotillo ST1	No Outages				
Ocotillo ST2	4/27/07 18:11		4/27/07 20:50		Unplanned
Palo Verde 1	No Outages				
Palo Verde 2	No Outages				
Palo Verde 3	4/12/07 3:40		5/1/07 0:00	(2)	Unplanned
Redhawk CT1A	4/10/07 15:59		4/10/07 17:30		Unplanned
	4/22/07 9:06		4/22/07 10:22		Unplanned
Redhawk CT1B	No Outages				
Redhawk CT2A	No Outages				
Redhawk CT2B	4/7/07 7:41		4/7/07 14:38		Unplanned
Redhawk ST1	4/13/07 6:20		4/13/07 6:37		Unplanned
	4/24/07 20:49		4/24/07 21:04		Unplanned
Redhawk ST2	No Outages				
Saguaro CT1	No Outages				
Saguaro CT2	4/1/07 0:00	(1)	4/30/07 13:33		Planned
Saguaro CT3	4/27/07 15:15		4/29/07 16:58		Unplanned
Saguaro ST1	No Outages				
Saguaro ST2	No Outages				
Sundance CT1	No Outages				
Sundance CT2	No Outages				
Sundance CT3	No Outages				
Sundance CT4	No Outages				
Sundance CT5	No Outages				
Sundance CT6	No Outages				
Sundance CT7	No Outages				
Sundance CT8	No Outages				
Sundance CT9	No Outages				
Sundance CT10	No Outages				
West Phoenix CC1	No Outages				
West Phoenix CC2	4/1/07 0:00	(1)	4/13/07 16:00		Planned
	4/14/07 21:00		4/19/07 6:00		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
Apr-07

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
	4/19/07 15:36		4/21/07 15:00		Unplanned
	4/24/07 15:01		4/24/07 15:20		Unplanned
	4/25/07 1:00		4/25/07 17:23		Unplanned
	4/26/07 7:52		4/26/07 15:40		Unplanned
	4/26/07 17:36		4/27/07 14:20		Unplanned
	4/27/07 15:18		4/27/07 15:26		Unplanned
	4/27/07 17:00		4/28/07 7:30		Unplanned
	4/29/07 16:19		4/30/07 8:00		Unplanned
West Phoenix CC3	4/25/07 13:51		4/25/07 13:57		Unplanned
West Phoenix CC4	4/9/07 0:01		4/27/07 0:00		Planned
	4/27/07 0:00		5/1/07 0:00	(2)	Unplanned
West Phoenix CT1	No Outages				
West Phoenix CT2	No Outages				
West Phoenix CT5A	4/26/07 5:53		4/26/07 6:19		Unplanned
West Phoenix CT5B	4/29/07 23:59		5/1/07 0:00	(2)	Planned
West Phoenix ST5	4/6/07 8:07		4/6/07 8:29		Unplanned
	4/7/07 11:18		4/7/07 11:46		Unplanned
	4/18/07 11:34		4/18/07 11:56		Unplanned
Yucca CT1	No Outages				
Yucca CT2	No Outages				
Yucca CT3	4/1/07 0:00	(1)	5/1/07 0:00	(2)	Planned
Yucca CT4	No Outages				

(1) Designations of 4/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 5/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
May-07

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	5/23/07 23:03		5/24/07 17:49		Unplanned
Cholla 2	No Outages				
Cholla 3	No Outages				
Douglas	5/1/07 13:30		5/1/07 16:00		Maintenance
	5/3/07 9:41		5/9/07 14:06		Maintenance
Four Corners 1	5/15/07 23:58		5/17/07 5:25		Unplanned
Four Corners 2	No Outages				
Four Corners 3	5/10/07 4:57		5/10/07 7:22		Unplanned
Four Corners 4	5/10/07 0:03		6/1/07 0:00	(2)	Planned
Four Corners 5	5/1/07 0:00	(1)	5/4/07 21:34		Unplanned
	5/4/07 23:51		5/5/07 7:10		Unplanned
	5/5/07 10:01		5/5/07 13:13		Unplanned
	5/21/07 20:23		5/24/07 17:48		Unplanned
Navajo 1	No Outages				
Navajo 2	No Outages				
Navajo 3	5/12/07 0:31		5/14/07 3:04		Maintenance
	5/25/07 23:50		5/30/07 21:10		Maintenance
	5/30/07 21:12		5/30/07 22:06		Unplanned
	5/31/07 0:11		5/31/07 1:03		Unplanned
Ocotillo CT1	No Outages				
Ocotillo CT2	5/10/07 19:20		5/11/07 0:00		Unplanned
	5/11/07 0:00		5/24/07 14:40		Maintenance
Ocotillo ST1	No Outages				
Ocotillo ST2	No Outages				
Palo Verde 1	5/19/07 0:00		6/1/07 0:00	(2)	Planned
Palo Verde 2	No Outages				
Palo Verde 3	5/1/07 0:00	(1)	5/2/07 1:15		Unplanned
	5/2/07 9:25		5/7/07 11:15		Unplanned
Redhawk CT1A	5/27/07 8:04		5/27/07 14:39		Unplanned
Redhawk CT1B	5/25/07 10:07		5/26/07 3:52		Unplanned
Redhawk CT2A	5/1/07 0:00	(1)	5/4/07 0:00		Planned
	5/4/07 0:00		5/26/07 4:42		Unplanned
	5/31/07 18:51		5/31/07 19:36		Unplanned
Redhawk CT2B	5/1/07 0:00	(1)	5/4/07 0:00		Planned
	5/4/07 0:00		6/1/07 0:00	(2)	Unplanned
Redhawk ST1	5/2/07 0:42		5/2/07 0:53		Unplanned
	5/24/07 11:49		5/24/07 12:33		Unplanned
Redhawk ST2	5/1/07 0:00	(1)	5/4/07 0:00		Planned
	5/4/07 0:00		5/26/07 18:00		Unplanned
	5/31/07 18:53		5/31/07 20:03		Unplanned
Saguaro CT1	5/5/07 8:00		5/5/07 13:00		Unplanned
Saguaro CT2	No Outages				
Saguaro CT3	No Outages				
Saguaro ST1	5/8/07 10:21		5/8/07 11:40		Unplanned
	5/19/07 5:26		5/19/07 7:29		Unplanned
Saguaro ST2	5/18/07 18:15		5/20/07 20:30		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
May-07

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time	Description (3)
Sundance CT1	No Outages			
Sundance CT2	No Outages			
Sundance CT3	No Outages			
Sundance CT4	5/25/07 17:25		5/26/07 6:30	Unplanned
Sundance CT5	No Outages			
Sundance CT6	No Outages			
Sundance CT7	5/12/07 14:29		5/13/07 8:14	Unplanned
Sundance CT8	No Outages			
Sundance CT9	5/24/07 14:39		5/24/07 23:59	Unplanned
	5/26/07 16:01		5/27/07 20:11	Unplanned
Sundance CT10	5/26/07 16:16		5/27/07 19:48	Unplanned
West Phoenix CC1	5/19/07 1:00		5/21/07 1:00	Maintenance
West Phoenix CC2	5/1/07 9:38		5/1/07 9:49	Unplanned
	5/13/07 0:00		5/12/07 5:00	Unplanned
	5/28/07 21:10		5/29/07 8:25	Unplanned
West Phoenix CC3	5/1/07 7:39		5/1/07 8:18	Unplanned
	5/1/07 8:40		5/2/07 0:00	Unplanned
	5/2/07 10:30		5/2/07 13:29	Unplanned
	5/26/07 0:01		5/27/07 18:00	Unplanned
West Phoenix CC4	5/1/07 0:00	(1)	5/30/07 15:32	Unplanned
	5/30/07 17:07		5/30/07 20:00	Unplanned
West Phoenix CT1	5/7/07 6:00		5/11/07 20:30	Planned
West Phoenix CT2	5/10/07 17:47		5/10/07 21:26	Unplanned
West Phoenix CT5A	5/4/07 0:00		5/7/07 22:00	Planned
	5/11/07 19:42		5/12/07 0:00	Unplanned
	5/12/07 0:00		5/28/07 19:30	Unplanned
	5/29/07 22:40		5/29/07 22:57	Unplanned
West Phoenix CT5B	5/1/07 0:00	(1)	5/18/07 0:00	Planned
	5/18/07 0:00		5/29/07 20:33	Unplanned
	5/29/07 20:53		5/29/07 21:33	Unplanned
	5/30/07 13:22		5/30/07 15:36	Unplanned
	5/30/07 17:33		5/30/07 19:20	Unplanned
	5/30/07 0:54		5/30/07 8:30	Unplanned
	5/31/07 7:57		5/31/07 8:58	Unplanned
West Phoenix ST5	5/4/07 0:00		5/7/07 22:00	Planned
	5/9/07 15:00		5/28/07 19:30	Unplanned
	5/29/07 22:32		5/29/07 23:30	Unplanned
Yucca CT1	No Outages			
Yucca CT2	No Outages			
Yucca CT3	5/1/07 0:00	(1)	5/22/07 19:07	Planned
	5/26/07 9:22		5/26/07 15:43	Maintenance
	5/26/07 15:43		5/26/07 19:30	Unplanned
Yucca CT4	5/26/07 9:22		5/26/07 15:43	Maintenance
	5/31/07 5:00		5/31/07 11:15	Maintenance

(1) Designations of 5/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 6/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	No Outages				
Cholla 2	No Outages				
Cholla 3	6/1/07 3:43		6/4/07 7:20		Unplanned
Douglas	6/14/07 10:45		6/14/07 15:22		Unplanned
Four Corners 1	6/3/07 23:42		6/4/07 1:11		Unplanned
	6/14/07 22:42		6/15/07 11:00		Unplanned
	6/15/07 11:00		6/16/07 8:27		Unplanned
Four Corners 2	6/9/07 21:41		6/13/07 4:20		Unplanned
Four Corners 3	6/1/07 7:03		6/1/07 8:42		Unplanned
	6/1/07 23:00		6/3/07 8:20		Unplanned
Four Corners 4	6/1/07 0:00	(1)	6/7/07 0:00		Planned
	6/7/07 0:00		6/23/07 18:53		Planned
	6/23/07 23:36		6/24/07 2:22		Planned
Four Corners 5	No Outages				
Navajo 1	No Outages				
Navajo 2	6/20/07 15:47		6/20/07 17:49		Unplanned
Navajo 3	No Outages				
Ocotillo CT1	No Outages				
Ocotillo CT2	6/19/07 14:52		6/19/07 15:48		Unplanned
Ocotillo ST1	No Outages				
Ocotillo ST2	No Outages				
Palo Verde 1	6/1/01 0:00	(1)	6/27/07 23:59		Planned
	6/27/07 23:59		7/1/07 0:00	(2)	Planned
Palo Verde 2	No Outages				
Palo Verde 3	No Outages				
Redhawk CT1A	No Outages				
Redhawk CT1B	No Outages				
Redhawk CT2A	6/9/07 7:00		6/9/07 9:39		Unplanned
	6/12/07 7:15		6/12/07 9:26		Unplanned
Redhawk CT2B	6/1/07 0:00	(1)	6/3/07 20:00		Unplanned
	6/4/07 0:20		6/4/07 5:12		Unplanned
Redhawk ST1	6/9/07 17:15		6/9/07 17:28		Unplanned
	6/14/07 22:16		6/14/07 22:31		Unplanned
Redhawk ST2	6/21/07 1:14		6/21/07 1:32		Unplanned
Saguaro CT1	6/26/07 15:17		6/26/07 20:12		Unplanned
Saguaro CT2	6/24/07 1:10		6/25/07 6:45		Unplanned
	6/29/07 18:00		7/1/07 0:00	(2)	Unplanned
Saguaro CT3	No Outages				
Saguaro ST1	No Outages				
Saguaro ST2	6/29/07 10:00		6/29/07 18:30		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2007

Plant and Unit	Outage Start: Date/Time	Outage End: Date/Time	Description (3)
Sundance CT1	No Outages		
Sundance CT2	No Outages		
Sundance CT3	6/9/07 18:10	6/10/07 9:00	Unplanned
	6/25/07 15:26	6/25/07 15:56	Unplanned
Sundance CT4	6/9/07 18:10	6/10/07 9:00	Unplanned
	6/26/07 15:26	6/26/07 17:08	Unplanned
Sundance CT5	No Outages		
Sundance CT6	No Outages		
Sundance CT7	No Outages		
Sundance CT8	No Outages		
Sundance CT9	No Outages		
Sundance CT10	No Outages		
West Phoenix CC1	6/9/07 6:00	6/10/07 17:30	Maintenance
	6/13/07 14:03	6/13/07 14:39	Unplanned
West Phoenix CC2	6/25/07 10:28	6/25/07 11:31	Unplanned
West Phoenix CC3	No Outages		
West Phoenix CC4	6/26/07 15:15	6/26/07 16:02	Unplanned
West Phoenix CT1	No Outages		
West Phoenix CT2	6/26/06 12:25	6/26/07 14:42	Unplanned
West Phoenix CT5A	6/1/07 7:54	6/1/07 8:51	Unplanned
	6/19/07 1:00	6/19/07 14:00	Maintenance
	6/19/07 21:20	6/20/07 3:30	Unplanned
	6/26/07 16:07	6/26/07 18:05	Unplanned
West Phoenix CT5B	6/7/07 14:30	6/8/07 16:10	Unplanned
	6/12/07 7:30	6/12/07 7:34	Unplanned
	6/19/07 1:00	6/19/07 14:00	Maintenance
	6/26/07 16:07	6/26/07 18:05	Unplanned
	6/27/07 7:04	6/27/07 8:00	Unplanned
West Phoenix ST5	6/8/07 12:36	6/8/07 15:22	Unplanned
	6/19/07 1:00	6/19/07 14:00	Maintenance
	6/25/07 22:24	6/25/07 23:08	Unplanned
	6/26/07 14:07	6/26/07 15:23	Unplanned
	6/26/07 15:58	6/26/07 18:05	Unplanned
	6/27/07 6:55	6/27/07 7:19	Unplanned
Yucca CT1	No Outages		
Yucca CT2	No Outages		
Yucca CT3	No Outages		
Yucca CT4	6/26/07 16:15	6/26/07 17:03	Unplanned

(1) Designations of 6/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 7/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time	Description [2]
Cholla 1	7/14/07 1:21		7/15/07 22:43	Unplanned
Cholla 2	No Outages			
Cholla 3	7/21/07 18:30		7/24/07 21:32	Unplanned
Douglas	No Outages			
Four Corners 1	7/7/07 3:33		7/7/07 6:49	Unplanned
Four Corners 2	No Outages			
Four Corners 3	7/15/07 18:38		7/18/07 3:45	Unplanned
	7/19/07 10:50		7/19/07 15:21	Unplanned
Four Corners 4	No Outages			
Four Corners 5	7/22/07 12:58		7/26/07 0:00	Unplanned
	7/26/07 0:00		7/28/07 13:31	Unplanned
Navajo 1	7/21/07 23:16		7/26/07 21:46	Unplanned
	7/26/07 23:58		7/27/07 1:29	Unplanned
	7/27/07 13:58		7/27/07 15:17	Unplanned
Navajo 2	7/13/07 18:32		7/13/07 23:57	Unplanned
	7/19/07 10:57		7/21/07 14:42	Unplanned
Navajo 3	7/7/07 23:57		7/10/07 3:27	Unplanned
Ocotillo CT1	7/17/07 20:30		7/20/07 0:00	Unplanned
Ocotillo CT2	No Outages			
Ocotillo ST1	7/12/07 8:37		7/13/07 16:21	Unplanned
Ocotillo ST2	7/19/07 16:20		7/19/07 19:35	Unplanned
Palo Verde 1	7/1/07 0:00	(1)	7/19/07 3:32	Planned
	7/19/07 9:05		7/19/07 10:50	Planned
Palo Verde 2	No Outages			
Palo Verde 3	No Outages			
Redhawk CT1A	7/7/07 1:29		7/7/07 6:00	Maintenance
	7/7/07 10:07		7/7/07 10:22	Unplanned
Redhawk CT1B	7/7/07 7:38		7/7/07 12:33	Unplanned
	7/8/07 1:38		7/8/07 6:00	Maintenance
Redhawk CT2A	7/7/07 1:03		7/7/07 6:00	Maintenance
	7/11/07 18:33		7/11/07 22:44	Unplanned
Redhawk CT2B	7/8/07 2:20		7/8/07 6:00	Maintenance
	7/8/07 8:04		7/8/07 9:55	Unplanned
Redhawk ST1	7/6/07 18:27		7/6/07 18:57	Unplanned
	7/7/07 1:14		7/7/07 6:00	Maintenance
	7/19/07 1:30		7/19/07 1:46	Unplanned
Redhawk ST2	7/8/07 1:59		7/8/07 6:00	Maintenance
	7/6/07 16:18		7/6/07 18:33	Unplanned
Saguaro CT1	No Outages			
Saguaro CT2	7/1/07 0:00	(1)	7/2/07 7:25	Unplanned
	7/3/07 14:14		7/4/07 18:00	Unplanned
Saguaro CT3	No Outages			
Saguaro ST1	7/7/07 8:30		7/7/07 10:32	Unplanned
	7/17/07 18:20		7/17/07 21:23	Unplanned
Saguaro ST2	7/21/07 15:30		7/22/07 21:00	Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2007

Plant and Unit	Outage Start: Date/Time	Outage End: Date/Time	Description [2]
Sundance CT1	7/16/07 13:25	7/16/07 15:43	Unplanned
	7/17/07 15:10	7/17/07 17:24	Unplanned
	7/27/07 14:42	7/27/07 16:26	Maintenance
	7/27/07 16:37	7/28/07 10:29	Unplanned
	7/28/07 10:44	7/28/07 15:50	Unplanned
Sundance CT2	No Outages		
Sundance CT3	7/14/07 20:54	7/14/07 20:58	Unplanned
	7/27/07 9:46	7/27/07 11:31	Unplanned
Sundance CT4	7/26/07 13:41	7/26/07 14:42	Unplanned
	7/26/07 15:27	7/27/07 7:00	Unplanned
Sundance CT5	No Outages		
Sundance CT6	No Outages		
Sundance CT7	7/2/07 16:52	7/2/07 23:59	Unplanned
	7/8/07 21:22	7/9/07 13:30	Unplanned
Sundance CT8	7/2/07 16:52	7/2/07 20:00	Unplanned
	7/8/07 21:22	7/9/07 13:30	Unplanned
	7/26/07 16:24	7/26/07 17:30	Unplanned
Sundance CT9	7/25/07 3:00	7/25/07 10:00	Unplanned
	7/26/07 15:06	7/26/07 16:21	Unplanned
Sundance CT10	7/24/07 22:20	7/25/07 7:00	Unplanned
West Phoenix CC1	7/16/07 5:31	7/16/07 5:41	Unplanned
	7/16/07 21:15	7/17/07 12:10	Unplanned
	7/25/07 6:00	7/27/07 17:45	Unplanned
West Phoenix CC2	7/1/07 12:25	7/1/07 14:36	Unplanned
	7/7/07 20:39	7/8/07 9:15	Unplanned
	7/19/07 7:46	7/19/07 10:30	Unplanned
	7/19/07 10:51	7/19/07 11:26	Unplanned
West Phoenix CC3	No Outages		
West Phoenix CC4	No Outages		
West Phoenix CT1	7/3/07 15:30	7/3/07 17:50	Unplanned
West Phoenix CT2	7/6/07 14:00	7/6/07 14:02	Unplanned
	7/7/07 10:26	7/7/07 13:17	Unplanned
West Phoenix CT5A	7/5/07 8:05	7/5/07 8:26	Unplanned
	7/24/07 4:47	7/24/07 4:51	Unplanned
	7/25/07 11:30	7/25/07 12:50	Unplanned
	7/25/07 13:53	7/25/07 17:10	Unplanned
	7/26/07 7:54	7/26/07 20:33	Unplanned
	7/26/07 20:54	7/27/07 11:25	Unplanned
	7/27/07 23:59	7/30/07 7:00	Maintenance
West Phoenix CT5B	No Outages		
West Phoenix ST5	No Outages		
Yucca CT1	No Outages		
Yucca CT2	No Outages		
Yucca CT3	7/4/07 15:04	7/4/07 17:55	Unplanned
	7/5/07 14:11	7/5/07 17:13	Unplanned
	7/6/07 16:57	7/6/07 18:30	Unplanned
	7/15/07 16:25	7/15/07 19:35	Unplanned
Yucca CT4	No Outages		

(1) Designations of 7/1/07 00:00 mean that the outage began in the prior month.

(2) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2007

Plant and Unit	Outage Start: Date/Time	Outage End: Date/Time		Description (3)
Cholla 1	8/9/07 8:34	8/10/07 16:54		Unplanned
Cholla 2	No Outages			
Cholla 3	No Outages			
Douglas	No Outages			
Four Corners 1	8/5/07 23:23	8/10/07 10:10		Unplanned
	8/28/07 11:00	8/31/07 10:44		Unplanned
Four Corners 2	No Outages			
Four Corners 3	No Outages			
Four Corners 4	8/25/07 3:32	8/28/07 13:23		Unplanned
	8/31/07 20:53	9/1/07 0:00	(2)	Unplanned
Four Corners 5	8/9/07 18:17	8/10/07 0:56		Unplanned
	8/19/07 4:24	8/19/07 17:09		Unplanned
	8/25/07 3:36	8/26/07 21:12		Unplanned
Navajo 1	No Outages			
Navajo 2	No Outages			
Navajo 3	No Outages			
Ocotillo CT1	8/14/07 0:00	8/14/07 6:15		Unplanned
	8/28/07 9:39	8/28/07 10:25		Unplanned
Ocotillo CT2	8/30/07 8:57	8/31/07 23:06		Unplanned
Ocotillo ST1	8/21/07 7:21	8/21/07 7:53		Unplanned
Ocotillo ST2	No Outages			
Palo Verde 1	No Outages			
Palo Verde 2	No Outages			
Palo Verde 3	No Outages			
Redhawk CT1A	8/23/07 8:40	8/23/07 9:40		Unplanned
Redhawk CT1B	8/9/07 16:22	8/9/07 17:48		Unplanned
Redhawk CT2A	No Outages			
Redhawk CT2B	8/18/07 17:39	8/18/07 18:30		Unplanned
Redhawk ST1	8/4/07 10:26	8/4/07 10:41		Unplanned
	8/13/07 9:28	8/13/07 9:42		Unplanned
	8/14/07 10:03	8/14/07 10:47		Unplanned
	8/23/07 4:50	8/23/07 5:02		Unplanned
Redhawk ST2	No Outages			
Saguaro CT1	No Outages			
Saguaro CT2	No Outages			
Saguaro CT3	8/31/07 10:48	8/31/07 13:30		Unplanned
Saguaro ST1	8/24/07 16:47	8/24/07 17:30		Unplanned
	8/25/07 19:55	8/25/07 22:30		Unplanned
Saguaro ST2	8/31/07 12:10	8/31/07 12:24		Unplanned
	8/31/07 15:34	8/31/07 15:40		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2007

Plant and Unit	Outage Start: Date/Time	Outage End: Date/Time		Description (3)
Sundance CT1	No Outages			
Sundance CT2	8/12/07 10:33	8/12/07 15:00		Unplanned
	8/13/07 15:55	8/13/07 16:02		Unplanned
Sundance CT3	No Outages			
Sundance CT4	No Outages			
Sundance CT5	No Outages			
Sundance CT6	No Outages			
Sundance CT7	No Outages			
Sundance CT8	No Outages			
Sundance CT9	No Outages			
Sundance CT10	No Outages			
West Phoenix CC1	8/3/07 14:29	8/3/07 14:39		Unplanned
West Phoenix CC2	8/3/07 15:08	8/4/07 13:13		Unplanned
	8/7/07 9:45	8/7/07 15:17		Unplanned
	8/12/07 7:37	8/12/07 10:15		Unplanned
	8/13/07 23:35	8/13/07 23:54		Unplanned
West Phoenix CC3	8/1/07 0:01	8/2/07 11:00		Maintenance
	8/4/07 6:18	8/4/07 20:45		Unplanned
	8/5/07 8:06	8/5/07 10:30		Unplanned
	8/10/07 10:12	8/10/07 16:50		Unplanned
	8/20/07 14:29	8/20/07 17:58		Unplanned
	8/24/07 11:09	8/26/07 16:00		Unplanned
West Phoenix CC4	8/25/07 5:15	8/25/07 8:00		Unplanned
West Phoenix CT1	No Outages			
West Phoenix CT2	8/30/07 14:44	8/30/07 16:48		Unplanned
	8/30/07 20:44	8/31/07 15:18		Unplanned
West Phoenix CT5A	8/4/07 1:00	8/5/07 23:15		Maintenance
West Phoenix CT5B	8/1/07 11:27	8/2/07 10:33		Unplanned
	8/4/07 1:00	8/5/07 23:15		Maintenance
West Phoenix ST5	8/4/07 1:00	8/5/07 23:15		Maintenance
	8/7/07 12:22	8/7/07 15:08		Unplanned
Yucca CT1	No Outages			
Yucca CT2	8/9/07 16:37	8/9/07 17:29		Unplanned
	8/14/07 13:48	8/14/07 14:08		Unplanned
Yucca CT3	8/14/07 13:04	8/14/07 14:49		Unplanned
Yucca CT4	8/31/07 15:45	9/1/07 0:00	(2)	Unplanned

(1) Designations of 8/1/07 00:00 mean that the outage began in the prior month.

(2) Designations of 9/1/07 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	No Outages				
Cholla 2	No Outages				
Cholla 3	No Outages				
Douglas	No Outages				
Four Corners 1	No Outages				
Four Corners 2	9/14/07 23:01		9/15/07 23:13		Unplanned
	9/30/07 4:00		9/30/07 13:42		Unplanned
Four Corners 3	9/5/07 3:35		9/7/07 10:56		Unplanned
Four Corners 4	9/1/07 0:00	(1)	9/2/07 21:15		Unplanned
Four Corners 5	No Outages				
Navajo 1	9/30/07 23:43		9/30/07 23:59		Unplanned
Navajo 2	No Outages				
Navajo 3	9/16/07 0:13		9/17/07 1:02		Unplanned
	9/17/07 3:32		9/17/07 7:35		Unplanned
	9/17/07 7:37		9/17/07 7:48		Unplanned
	9/17/07 10:25		9/17/07 12:03		Unplanned
	9/17/07 13:03		9/17/07 16:52		Unplanned
	9/20/07 12:37		9/23/07 11:12		Unplanned
Ocotillo CT1	No Outages				
Ocotillo CT2	No Outages				
Ocotillo ST1	9/9/07 19:03		9/9/07 22:40		Unplanned
	9/11/07 6:30		9/15/07 14:00		Maintenance
	9/16/07 12:00		9/16/07 19:30		Unplanned
Ocotillo ST2	9/6/07 9:32		9/6/07 10:03		Unplanned
	9/7/07 13:35		9/7/07 16:26		Unplanned
	9/10/07 9:35		9/10/07 10:29		Unplanned
	9/12/07 6:35		9/12/07 7:33		Unplanned
	9/18/07 6:00		9/21/07 22:45		Maintenance
Palo Verde 1	No Outages				
Palo Verde 2	No Outages				
Palo Verde 3	9/29/07 0:00		10/1/07 0:00	(2)	Planned
Redhawk CT1A	9/6/07 18:21		9/6/07 18:35		Unplanned
	9/26/07 12:56		9/27/07 2:50		Unplanned
Redhawk CT1B	9/6/07 18:18		9/6/07 18:35		Unplanned
	9/26/07 13:09		9/27/07 2:50		Unplanned
Redhawk CT2A	9/25/07 9:04		9/25/07 20:15		Unplanned
	9/26/07 11:05		9/26/07 11:24		Unplanned
	9/29/07 8:37		9/29/07 10:20		Unplanned
	9/29/07 13:05		9/29/07 13:47		Unplanned
Redhawk CT2B	9/25/07 11:06		9/25/07 11:46		Unplanned
Redhawk ST1	9/6/07 17:59		9/6/07 18:35		Unplanned
	9/12/07 15:11		9/12/07 15:31		Unplanned
	9/13/07 3:08		9/13/07 3:16		Unplanned
	9/18/07 10:11		9/18/07 10:22		Unplanned
	9/18/07 5:00		9/18/07 7:01		Unplanned
	9/26/07 13:01		9/27/07 2:50		Unplanned
Redhawk ST2	9/25/07 11:15		9/25/07 12:13		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time	Description (3)
Saguaro CT1	No Outages			
Saguaro CT2	9/5/07 8:00		9/11/07 17:10	Unplanned
	9/12/07 15:15		9/14/07 13:46	Unplanned
Saguaro CT3	9/4/07 14:36		9/4/07 14:42	Unplanned
Saguaro ST1	9/5/07 17:59		9/5/07 18:25	Unplanned
Saguaro ST2	9/4/07 12:00		9/4/07 12:17	Unplanned
	9/15/07 9:10		9/15/07 11:11	Unplanned
	9/19/07 5:00		9/22/07 14:30	Unplanned
Sundance CT1	No Outages			
Sundance CT2	No Outages			
Sundance CT3	No Outages			
Sundance CT4	No Outages			
Sundance CT5	No Outages			
Sundance CT6	No Outages			
Sundance CT7	No Outages			
Sundance CT8	No Outages			
Sundance CT9	No Outages			
Sundance CT10	9/24/07 17:50		9/25/07 15:00	Unplanned
West Phoenix CC1	9/7/07 9:09		9/7/07 10:14	Unplanned
West Phoenix CC2	9/3/07 7:05		9/3/07 13:30	Unplanned
	9/6/07 7:30		9/6/07 10:48	Unplanned
	9/16/07 10:49		9/16/07 13:00	Unplanned
	9/18/07 6:45		9/18/07 15:15	Maintenance
West Phoenix CC3	9/12/07 21:11		9/13/07 10:00	Unplanned
	9/26/07 14:24		9/26/07 17:17	Unplanned
West Phoenix CC4	9/26/07 15:49		9/26/07 16:42	Unplanned
	9/26/07 23:00		9/27/07 3:00	Unplanned
	9/27/07 7:50		9/27/07 13:10	Unplanned
West Phoenix CT1	No Outages			
West Phoenix CT2	No Outages			
West Phoenix CT5A	9/7/07 8:07		9/12/07 3:40	Unplanned
	9/14/07 7:52		9/14/07 7:58	Unplanned
	9/15/07 6:58		9/15/07 7:05	Unplanned
West Phoenix CT5B	9/3/07 3:36		9/5/07 17:30	Unplanned
	9/12/07 6:29		9/12/07 6:54	Unplanned
West Phoenix ST5	9/8/07 9:27		9/10/07 21:00	Unplanned
	9/21/07 7:19		9/21/07 7:59	Unplanned
	9/22/07 7:08		9/22/07 9:13	Unplanned
	9/23/07 9:14		9/23/07 9:56	Unplanned
Yucca CT1	No Outages			
Yucca CT2	No Outages			
Yucca CT3	9/19/07 12:30		9/21/07 10:10	Unplanned
Yucca CT4	9/1/07 0:00	(1)	9/1/07 8:15	Unplanned

(1) Designations of 9/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 10/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	10/12/07 23:14		11/1/07 0:00	(2)	Planned
Cholla 2	No Outages				
Cholla 3	No Outages				
Douglas	10/1/07 0:00	(1)	10/12/07 8:24		Planned
Four Corners 1	10/8/07 11:01		10/8/07 17:13		Unplanned
Four Corners 2	10/8/07 11:01		10/8/07 13:33		Unplanned
Four Corners 3	10/8/07 11:01		10/8/07 13:28		Unplanned
	10/8/07 15:11		10/8/07 16:00		Unplanned
	10/17/07 20:29		10/17/07 23:21		Unplanned
	10/31/07 22:48		11/1/07 0:00	(2)	Unplanned
Four Corners 4	No Outages				
Four Corners 5	10/16/07 2:45		10/20/07 4:09		Unplanned
Navajo 1	10/1/07 0:00	(1)	10/4/07 6:15		Unplanned
	10/4/07 12:01		10/6/07 13:54		Unplanned
	10/7/07 18:41		10/10/07 7:09		Unplanned
Navajo 2	10/2/07 0:51		10/5/07 8:43		Unplanned
	10/20/07 0:42		10/22/07 13:48		Unplanned
Navajo 3	No Outages				
Ocotillo CT1	No Outages				
Ocotillo CT2	No Outages				
Ocotillo ST1	No Outages				
Ocotillo ST2	10/22/07 11:00		10/22/07 12:00		Unplanned
	10/22/07 17:37		10/22/07 22:24		Unplanned
Palo Verde 1	10/22/07 5:04		10/30/07 1:33		Maintenance
	10/30/07 1:33		10/31/07 23:59		Unplanned
Palo Verde 2	10/6/07 10:59		10/8/07 3:02		Unplanned
	10/8/07 3:02		10/12/07 16:04		Maintenance
	10/12/07 16:04		10/13/07 8:58		Unplanned
Palo Verde 3	10/1/07 0:00	(1)	11/1/07 0:00	(2)	Planned
Redhawk CT1A	10/7/07 10:13		10/8/07 1:00		Unplanned
	10/22/07 10:51		10/23/07 10:35		Unplanned
Redhawk CT1B	10/7/07 11:08		10/7/07 11:14		Unplanned
	10/22/07 15:09		10/23/07 9:45		Unplanned
Redhawk CT2A	No Outages				
Redhawk CT2B	No Outages				
Redhawk ST1	10/20/07 19:05		10/20/07 19:18		Unplanned
	10/22/07 15:11		10/23/07 9:45		Unplanned
	10/25/07 8:18		10/25/07 8:34		Unplanned
Redhawk ST2	No Outages				
Saguaro CT1	10/8/07 13:05		10/8/07 13:45		Unplanned
Saguaro CT2	No Outages				
Saguaro CT3	No Outages				
Saguaro ST1	10/25/07 13:33		10/25/07 13:58		Unplanned
Saguaro ST2	10/29/07 0:00		11/1/07 0:00	(2)	Plannned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2007

Plant and Unit	Outage Start: Date/Time	Outage End: Date/Time		Description (3)
Sundance CT1	No Outages			
Sundance CT2	No Outages			
Sundance CT3	No Outages			
Sundance CT4	No Outages			
Sundance CT5	No Outages			
Sundance CT6	No Outages			
Sundance CT7	10/29/07 7:00	11/1/07 0:00	(2)	Maintenance
Sundance CT8	10/29/07 7:00	11/1/07 0:00	(2)	Maintenance
Sundance CT9	No Outages			
Sundance CT10	No Outages			
West Phoenix CC1	10/9/07 6:42	10/9/07 11:17		Unplanned
	10/21/07 5:00	10/21/07 12:00		Unplanned
	10/30/07 11:32	10/30/07 13:28		Unplanned
West Phoenix CC2	10/10/07 12:38	10/10/07 14:50		Unplanned
	10/21/07 5:00	10/21/07 12:00		Unplanned
	10/26/07 11:41	10/26/07 11:49		Unplanned
	10/28/07 11:59	10/28/07 12:26		Unplanned
	10/29/07 7:17	10/29/07 7:32		Unplanned
West Phoenix CC3	10/8/07 12:25	10/8/07 13:05		Unplanned
	10/8/07 13:26	10/8/07 14:01		Unplanned
	10/21/07 5:00	10/21/07 12:00		Unplanned
West Phoenix CC4	10/4/07 0:15	10/4/07 8:50		Unplanned
	10/9/07 4:20	10/9/07 4:50		Unplanned
	10/20/07 5:29	10/20/07 13:09		Unplanned
	10/21/07 5:00	10/21/07 12:00		Unplanned
West Phoenix CT1	10/8/07 6:00	10/12/07 14:15		Unplanned
	10/12/07 15:30	10/12/07 16:53		Unplanned
	10/19/07 9:55	10/19/07 10:18		Unplanned
	10/21/07 5:00	10/21/07 12:00		Unplanned
	10/26/07 6:40	10/26/07 12:20		Maintenance
West Phoenix CT2	10/2/07 14:40	10/2/07 16:39		Unplanned
	10/8/07 13:19	10/8/07 13:23		Unplanned
	10/8/07 17:45	10/11/07 19:00		Unplanned
	10/21/07 5:00	10/21/07 12:00		Unplanned
West Phoenix CT5A	10/7/07 15:30	10/9/07 8:00		Unplanned
	10/9/07 9:53	10/9/07 12:43		Unplanned
	10/20/07 0:00	11/1/07 0:00	(2)	Planned
West Phoenix CT5B	10/3/07 5:33	10/3/07 6:42		Unplanned
	10/20/07 0:38	10/24/07 23:59		Planned
	10/26/07 0:00	11/1/07 0:00	(2)	Unplanned
West Phoenix ST5	10/1/07 5:05	10/1/07 5:41		Unplanned
	10/20/07 0:24	10/24/07 23:59		Planned
	10/25/07 10:41	11/1/07 0:00	(2)	Unplanned
Yucca CT1	10/2/07 9:00	10/2/07 11:10		Maintenance
	10/3/07 8:00	10/3/07 10:05		Maintenance
	10/5/07 9:20	10/5/07 11:35		Maintenance
	10/16/07 6:25	10/16/07 13:56		Maintenance
	10/18/07 6:00	10/29/07 14:56		Maintenance
	10/29/07 14:56	10/31/07 6:42		Maintenance
	10/31/07 9:13	10/31/07 9:44		Maintenance
Yucca CT2	10/2/07 9:00	10/2/07 11:10		Maintenance
	10/3/07 8:00	10/3/07 10:05		Maintenance
	10/5/07 9:20	10/5/07 11:35		Maintenance
	10/16/07 6:25	10/16/07 13:51		Maintenance
	10/18/07 6:00	10/30/07 15:29		Maintenance
	10/30/07 15:29	10/31/07 9:27		Maintenance
	10/31/07 9:38	10/31/07 9:44		Maintenance
Yucca CT3	10/16/07 6:25	10/16/07 13:58		Maintenance
	10/26/07 12:30	10/26/07 13:28		Maintenance
	10/31/07 9:45	11/1/07 0:00	(2)	Maintenance
Yucca CT4	10/2/07 20:19	10/3/07 11:09		Unplanned
	10/16/07 6:25	10/16/07 14:08		Maintenance
	10/26/07 12:30	10/26/07 13:28		Maintenance
	10/31/07 9:45	11/1/07 0:00	(2)	Maintenance

(1) Designations of 10/1/07 00:00 mean that the outage began in the prior month.
(2) Designations of 11/1/07 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Cholla 1	11/1/07 0:00	(1)	11/26/07 10:54		Planned
	11/26/07 12:21		11/26/07 15:04		Unplanned
Cholla 2	No Outages				
Cholla 3	11/16/07 23:33		11/20/07 6:04		Unplanned
Douglas	No Outages				
Four Corners 1	11/15/07 23:00		11/17/07 14:06		Unplanned
Four Corners 2	11/17/07 22:45		11/21/07 5:01		Unplanned
Four Corners 3	11/1/07 0:00	(1)	11/5/07 12:44		Unplanned
	11/10/07 1:50		11/10/07 4:00		Unplanned
	11/20/07 10:04		11/21/07 12:07		Unplanned
Four Corners 4	No Outages				
Four Corners 5	11/15/07 4:30		11/15/07 11:09		Unplanned
Navajo 1	No Outages				
Navajo 2	No Outages				
Navajo 3	11/28/07 19:56		12/1/07 0:00	(2)	Unplanned
Ocotillo CT1	No Outages				
Ocotillo CT2	No Outages				
Ocotillo ST1	11/12/07 6:00		11/17/07 17:00		Maintenance
Ocotillo ST2	No Outages				
Palo Verde 1	11/1/07 0:00	(1)	11/3/07 16:33		Maintenance
	11/24/07 0:21		11/30/07 12:19		Unplanned
Palo Verde 2	No Outages				
Palo Verde 3	11/1/07 0:00	(1)	12/1/07 0:00	(2)	Planned
Redhawk CT1A	11/10/07 0:00		11/16/07 6:36		Maintenance
	11/16/07 12:36		11/16/07 16:10		Unplanned
	11/16/07 18:21		11/16/07 22:36		Unplanned
Redhawk CT1B	11/10/07 0:00		11/16/07 6:36		Maintenance
	11/30/07 20:43		12/1/07 0:00	(2)	Unplanned
Redhawk CT2A	No Outages				
Redhawk CT2B	11/8/07 7:40		11/8/07 9:43		Unplanned
Redhawk ST1	11/10/07 0:00		11/16/07 9:50		Maintenance
Redhawk ST2	No Outages				
Saguaro CT1	No Outages				
Saguaro CT2	No Outages				
Saguaro CT3	11/26/07 0:01		11/30/07 13:00		Plannned
Saguaro ST1	11/5/07 7:00		11/13/07 10:00		Unplanned
Saguaro ST2	11/1/07 0:00	(1)	11/16/07 14:00		Plannned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2007

Plant and Unit	Outage Start: Date/Time		Outage End: Date/Time		Description (3)
Sundance CT1	11/27/07 5:50		11/27/07 14:30		Maintenance
Sundance CT2	11/27/07 5:50		11/27/07 14:30		Maintenance
Sundance CT3	11/27/07 9:30		11/27/07 15:58		Maintenance
Sundance CT4	11/28/07 7:00		11/28/07 8:45		Maintenance
Sundance CT5	11/28/07 8:45		11/28/07 12:25		Maintenance
Sundance CT6	11/28/07 12:25		11/28/07 13:56		Maintenance
Sundance CT7	11/1/07 0:00	(1)	11/7/07 19:04		Maintenance
	11/13/07 14:25		11/13/07 16:12		Unplanned
	11/29/07 6:40		11/29/07 11:00		Maintenance
Sundance CT8	11/1/07 0:00	(1)	11/7/07 19:04		Maintenance
	11/29/07 6:40		11/29/07 11:00		Maintenance
	11/30/07 17:05		11/30/07 19:25		Unplanned
Sundance CT9	11/26/07 7:00		12/1/07 0:00	(2)	
Sundance CT10	11/26/07 7:00		12/1/07 0:00	(2)	
West Phoenix CC1	11/14/07 0:00		11/16/07 16:30		Maintenance
	11/30/07 19:11		12/1/07 0:00	(2)	Unplanned
West Phoenix CC2	11/1/07 11:39		11/1/07 9:10		Unplanned
	11/14/07 0:00		1/16/07 16:25		Maintenance
	11/19/07 23:00		11/21/07 18:40		Unplanned
	11/22/07 20:08		11/22/08 22:30		Unplanned
	11/26/07 8:16		11/26/07 17:41		Unplanned
	11/30/07 19:11		12/1/07 0:00	(2)	Unplanned
West Phoenix CC3	11/17/07 0:00		11/19/07 16:00		Maintenance
West Phoenix CC4	No Outages				
West Phoenix CT1	No Outages				
West Phoenix CT2	No Outages				
West Phoenix CT5A	11/1/07 0:00	(1)	11/9/07 23:30		Planned
	11/30/07 6:29		11/30/07 15:47		Unplanned
	11/30/07 18:53		12/1/07 0:00	(2)	Unplanned
West Phoenix CT5B	11/1/07 0:00	(1)	11/8/07 15:00		Unplanned
West Phoenix ST5	11/1/07 0:00	(1)	11/8/07 15:00		Unplanned
	11/8/07 19:31		11/8/07 22:46		Unplanned
	11/16/07 4:55		11/16/07 22:24		Unplanned
Yucca CT1	No Outages				
Yucca CT2	No Outages				
Yucca CT3	11/1/07 0:00	(1)	11/6/07 16:23		Maintenance
	11/30/07 18:40		11/30/07 19:42		Unplanned
Yucca CT4	11/1/07 0:00	(1)	11/6/07 16:23		Maintenance
	11/14/07 7:34		11/14/07 10:45		Maintenance
	11/30/07 17:23		11/30/07 18:40		Unplanned

(1) Designations of 11/1/07 00:00 mean that the outage began in the prior month.

(2) Designations of 12/1/07 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2007

Plant and Unit	Outage Start: Date/Time			Outage End: Date/Time			Description (3)
CHOLLA 1	12/12/07	07:51		12/12/07	11:25		Unplanned
	12/14/07	23:36		12/18/07	21:20		Unplanned
CHOLLA 2	12/10/07	16:45		12/11/07	00:16		Unplanned
	12/15/07	00:20		12/15/07	14:30		Unplanned
CHOLLA 3	12/20/07	07:42		12/20/07	09:29		Unplanned
CHOLLA 4	No Outages						
DOUGLAS	No Outages						
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	12/12/07	03:57		12/21/07	04:50		Unplanned
FOUR CORNERS 4	12/18/07	03:07		12/25/07	01:08		Unplanned
	12/26/07	04:04		12/29/07	19:14		Unplanned
	12/29/07	19:53		12/29/07	21:38		Unplanned
FOUR CORNERS 5	No Outages						
NAVAJO 1	No Outages						
NAVAJO 2	No Outages						
NAVAJO 3	12/01/07	00:00	(1)	12/01/07	13:20		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
OCOTILLO ST1	No Outages						
OCOTILLO ST2	12/28/07	03:00		12/28/07	06:00		Unplanned
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	12/01/07	00:00		12/14/07	00:00		Planned
	12/14/07	00:00		01/01/08	00:00	(2)	Planned
REDHAWK CT 1A	12/27/07	07:33		12/28/07	04:15		Unplanned
REDHAWK CT 1B	12/01/07	00:00	(1)	12/01/07	05:05		Unplanned
	12/01/07	05:50		12/01/07	09:09		Unplanned
	12/27/07	07:37		12/28/07	04:15		Unplanned
REDHAWK CT 2A	No Outages						
REDHAWK CT 2B	No Outages						
REDHAWK Steam 1	12/27/07	07:12		12/28/07	04:15		Unplanned
REDHAWK Steam 2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	12/01/07	11:00		12/01/07	15:15		Unplanned
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						
SUNDANCE 1	No Outages						
SUNDANCE 2	No Outages						
SUNDANCE 3	No Outages						
SUNDANCE 4	No Outages						
SUNDANCE 5	No Outages						
SUNDANCE 6	No Outages						
SUNDANCE 7	No Outages						
SUNDANCE 8	No Outages						
SUNDANCE 9	12/01/07	00:00	(1)	12/05/07	07:00		Plannned
SUNDANCE 10	12/01/07	00:00	(1)	12/05/07	07:00		Plannned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2007

Plant and Unit	Outage Start: Date/Time			Outage End: Date/Time			Description (3)
WEST PHOENIX CC1	12/01/07	00:00	(1)	12/03/07	21:00		Unplanned
	12/09/07	14:45		12/09/07	15:48		Unplanned
	12/09/07	17:06		12/09/07	19:42		Unplanned
	12/09/07	22:30		12/10/07	04:20		Unplanned
	12/10/07	05:49		12/10/07	17:00		Unplanned
	12/13/07	10:05		12/13/07	14:29		Unplanned
WEST PHOENIX CC2	12/01/07	00:00	(1)	01/01/08	00:00	(2)	Unplanned
WEST PHOENIX CC3	12/03/07	06:00		12/10/07	19:45		Maintenance
	12/15/07	04:00		12/15/07	07:55		Maintenance
WEST PHOENIX CC4	12/01/07	00:05		12/01/07	15:52		Unplanned
	12/10/07	12:58		12/10/07	14:30		Unplanned
	12/11/07	06:09		12/11/07	10:38		Unplanned
	12/11/07	12:32		12/11/07	13:39		Unplanned
	12/14/07	00:39		12/14/07	05:50		Unplanned
	12/26/07	04:10		12/26/07	15:00		Unplanned
	12/27/07	10:08		12/27/07	11:45		Unplanned
WEST PHOENIX CT1	12/11/07	17:19		12/12/07	20:00		Unplanned
	12/21/07	08:00		12/21/07	19:40		Maintenance
WEST PHOENIX CT2	12/11/07	17:09		12/12/07	11:45		Unplanned
	12/21/07	08:00		12/21/07	19:40		Maintenance
WEST PHOENIX CT5A	12/01/07	00:00	(1)	12/01/07	13:00		Unplanned
	12/12/07	16:30		12/15/07	16:00		Unplanned
WEST PHOENIX CT5B	12/12/07	16:30		12/15/07	16:00		Unplanned
	12/18/07	10:56		12/18/07	15:40		Unplanned
	12/28/07	14:46		12/28/07	15:50		Unplanned
	12/28/07	07:36		12/28/07	12:18		Unplanned
WEST PHOENIX ST 5	12/11/07	04:32		12/15/07	16:00		Unplanned
YUCCA CT1	12/28/07	09:35		12/28/07	11:03		Maintenance
YUCCA CT2	12/28/07	09:35		12/28/07	11:26		Maintenance
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						

(1) Designations of 12/1/07 00:00 mean that the outage began in the prior month.

(2) Designations of 1/1/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	01/04/08	09:37		01/04/08	17:21		Unplanned
	01/31/08	06:02		02/01/08	00:00	(2)	Unplanned
CHOLLA 2	01/15/08	07:14		01/15/08	09:09		Unplanned
	01/15/08	22:30		01/16/08	04:19		Unplanned
	01/19/08	22:48		01/20/08	23:16		Unplanned
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	01/04/08	22:39		02/01/08	00:00	(2)	Planned
FOUR CORNERS 2	01/18/08	04:29		01/18/08	11:01		Unplanned
FOUR CORNERS 3	01/12/08	20:37		01/17/08	18:19		Unplanned
FOUR CORNERS 4	01/17/08	10:00		01/18/08	12:40		Unplanned
FOUR CORNERS 5	01/17/08	10:00		01/20/08	09:05		Unplanned
	01/20/08	23:27		01/21/08	16:53		Unplanned
	01/29/08	21:41		02/01/08	00:00	(2)	Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	01/03/08	23:31		01/05/08	03:57		Unplanned
NAVAJO 3	01/05/08	23:34		01/08/08	20:51		Unplanned
OCOTILLO CT1	01/07/08	06:00		02/01/08	00:00	(2)	Planned
OCOTILLO CT2	No Outages						
OCOTILLO ST1	No Outages						
OCOTILLO ST2	01/18/08	04:04		01/18/08	09:16		Unplanned
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	01/01/08	00:00	(1)	01/17/08	22:20		Planned
	01/17/08	22:27		01/18/08	05:01		Planned
	01/18/08	05:35		01/18/08	12:21		Planned
	01/18/08	17:18		01/19/08	00:58		Planned
REDHAWK CT 1A	01/03/08	19:06		01/03/08	20:15		Unplanned
	01/12/08	17:34		01/12/08	19:05		Unplanned
REDHAWK CT 1B	01/03/08	19:01		01/03/08	20:15		Unplanned
	01/04/08	15:45		01/05/08	02:22		Unplanned
	01/27/08	15:53		01/27/08	21:00		Unplanned
REDHAWK CT 2A	01/10/08	04:16		01/10/08	10:22		Unplanned
	01/28/08	04:00		02/01/08	00:00	(2)	Planned
REDHAWK CT 2B	01/28/08	04:00		02/01/08	00:00	(2)	Planned
REDHAWK ST1	01/03/08	18:47		01/03/08	20:15		Unplanned
REDHAWK ST2	01/18/08	10:07		01/28/08	04:00		Unplanned
	01/28/08	04:00		02/01/08	00:00	(2)	Planned
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						
SUNDANCE 1	No Outages						
SUNDANCE 2	No Outages						
SUNDANCE 3	No Outages						
SUNDANCE 4	No Outages						
SUNDANCE 5	No Outages						
SUNDANCE 6	No Outages						
SUNDANCE 7	No Outages						
SUNDANCE 8	No Outages						
SUNDANCE 9	No Outages						
SUNDANCE 10	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
WEST PHOENIX CC1	01/03/08	06:00		02/01/08	00:00	(2)	Planned
WEST PHOENIX CC2	01/01/08	00:00	(1)	01/16/08	14:45		Unplanned
	01/16/08	16:40		01/16/08	18:00		Unplanned
	01/16/08	19:45		01/17/08	15:40		Unplanned
	01/17/08	16:52		01/17/08	21:25		Unplanned
	01/17/08	23:13		01/18/08	08:57		Unplanned
	01/18/08	10:14		01/21/08	16:56		Unplanned
	01/21/08	18:02		01/22/08	18:43		Unplanned
	01/24/08	06:22		01/30/08	06:54		Unplanned
WEST PHOENIX CC3	01/12/08	04:00		01/12/08	13:00		Unplanned
	01/19/08	05:51		01/19/08	08:00		Unplanned
	01/24/08	05:07		01/24/08	07:00		Unplanned
WEST PHOENIX CC4	No Outages						
WEST PHOENIX CT1	01/08/08	06:00		01/18/08	17:53		Planned
WEST PHOENIX CT2	01/28/08	06:00		02/01/08	00:00	(2)	Planned
WEST PHOENIX CT5A	01/02/08	14:45		01/02/08	16:04		Unplanned
	01/04/08	18:19		01/05/08	13:31		Unplanned
	01/27/08	14:30		01/27/08	16:35		Unplanned
	01/31/08	04:29		01/31/08	19:00		Unplanned
WEST PHOENIX ST5	01/02/08	05:44		01/02/08	07:45		Unplanned
	01/12/08	05:36		01/12/08	07:13		Unplanned
	01/19/08	23:26		01/20/08	00:00		Unplanned
YUCCA CT1	No Outages						
YUCCA CT2	No Outages						
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						

(1) Designations of 01/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 02/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less that 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	02/01/08	0:00	(1)	02/02/08	18:01		Unplanned
	02/06/08	9:21		02/06/08	12:40		Unplanned
	02/08/08	23:01		02/09/08	8:07		Unplanned
	02/14/08	12:47		02/14/08	16:23		Unplanned
	02/23/08	13:14		02/23/08	17:59		Unplanned
	02/23/08	19:03		02/23/08	22:07		Unplanned
CHOLLA 2	02/09/08	0:23		03/01/08	0:00	(2)	Planned
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	02/01/08	0:00	(1)	02/06/08	6:49		Planned
	02/06/08	14:02		02/06/08	18:13		Planned
	02/07/08	19:56		02/07/08	22:21		Unplanned
	02/09/08	22:28		02/10/08	11:11		Unplanned
	02/10/08	14:44		02/10/08	15:47		Unplanned
	02/10/08	20:58		02/10/08	22:38		Unplanned
FOUR CORNERS 2	02/04/08	2:09		02/04/08	16:52		Unplanned
	02/05/08	21:23		02/06/08	2:48		Unplanned
	02/07/08	19:49		02/07/08	22:05		Unplanned
	02/08/08	16:24		02/09/08	2:52		Unplanned
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	02/01/08	0:00	(1)	02/01/08	8:06		Unplanned
	02/19/08	0:57		03/01/08	0:00	(2)	Planned
NAVAJO 1	02/01/08	22:23		02/28/08	12:39		Planned
NAVAJO 2	02/10/08	1:00		02/12/08	20:00		Unplanned
NAVAJO 3	No Outages						
OCOTILLO CT1	02/01/08	0:00	(1)	03/01/08	0:00	(2)	Planned
OCOTILLO CT2	No Outages						
OCOTILLO ST1	02/25/08	6:34		03/01/08	0:00	(2)	Planned
OCOTILLO ST2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	02/03/08	11:48		02/03/08	13:43		Unplanned
REDHAWK CT1B	No Outages						
REDHAWK CT2A	02/01/08	0:00	(1)	02/03/08	4:12		Planned
	02/11/08	6:17		02/12/08	6:20		Unplanned
REDHAWK CT2B	02/01/08	0:00	(1)	02/03/08	16:12		Planned
	02/11/08	6:17		02/12/08	6:20		Unplanned
REDHAWK ST1	No Outages						
REDHAWK ST2	02/01/08	0:00	(1)	02/03/08	16:12		Planned
	02/03/08	16:12		02/12/08	8:48		Unplanned
	02/12/08	20:47		02/12/08	22:12		Unplanned
SAGUARO CT1	02/18/08	0:01		02/22/08	12:51		Planned
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
SAGUARO ST1	No Outages						
SAGUARO ST2	02/21/08	10:09		02/21/08	16:33		Maintenance

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SUNDANCE 1	02/11/08	7:00		02/21/08	16:06		Planned
SUNDANCE 2	02/11/08	7:00		02/21/08	17:57		Planned
SUNDANCE 3	No Outages						
SUNDANCE 4	No Outages						
SUNDANCE 5	No Outages						
SUNDANCE 6	02/05/08	7:31		02/05/08	8:31		Unplanned
SUNDANCE 7	No Outages						
SUNDANCE 8	No Outages						
SUNDANCE 9	No Outages						
SUNDANCE 10	No Outages						
WEST PHOENIX CC1	02/01/08	0:00	(1)	03/01/08	0:00	(2)	Planned
WEST PHOENIX CC2	02/07/08	4:28		02/07/08	8:00		Unplanned
	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/08/08	11:05		02/08/08	12:15		Unplanned
	02/19/08	0:00		02/20/08	22:00		Planned
	02/24/08	8:30		02/27/08	0:00		Unplanned
WEST PHOENIX CC3	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/08/08	11:05		02/08/08	12:15		Unplanned
	02/19/08	0:00		02/20/08	22:00		Planned
WEST PHOENIX CC4	02/04/08	5:53		02/04/08	7:50		Unplanned
	02/05/08	1:19		02/05/08	8:58		Unplanned
	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/08/08	11:05		02/08/08	12:15		Unplanned
WEST PHOENIX CT1	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/07/08	15:32		02/14/08	13:30		Unplanned
WEST PHOENIX CT2	02/01/08	0:00	(1)	02/01/08	16:30		Planned
	02/01/08	16:30		02/05/08	20:18		Unplanned
	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/08/08	11:05		02/08/08	12:15		Unplanned
WEST PHOENIX CT5A	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/08/08	4:07		02/08/08	9:00		Unplanned
	02/08/08	11:05		02/08/08	12:15		Unplanned
	02/10/08	7:54		02/10/08	10:15		Unplanned
WEST PHOENIX CT5B	02/05/08	4:05		02/05/08	7:50		Unplanned
	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/08/08	11:05		02/08/08	12:15		Unplanned
WEST PHOENIX ST5	02/07/08	11:00		02/07/08	14:30		Unplanned
	02/08/08	11:05		02/08/08	12:15		Unplanned
YUCCA CT1	No Outages						
YUCCA CT2	No Outages						
YUCCA CT3	02/18/08	0:00		02/21/08	20:06		Planned
	02/22/08	0:00		02/22/08	15:06		Planned
	02/26/08	13:40		02/26/08	15:26		Maintenance
	02/27/08	10:16		02/27/08	12:30		Maintenance
YUCCA CT4	02/04/08	1:16		02/08/08	16:30		Planned

(1) Designations of 02/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 03/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less that 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	03/15/08	14:51		03/15/08	17:18		Unplanned
	03/16/08	01:24		03/16/08	22:30		Unplanned
	03/27/08	07:10		03/27/08	09:07		Unplanned
CHOLLA 2	03/01/08	00:00	(1)	03/18/08	08:20		Planned
	03/18/08	13:00		03/18/08	17:50		Unplanned
	03/19/08	08:47		03/19/08	17:55		Unplanned
	03/19/08	17:55		03/20/08	00:16		Unplanned
	03/20/08	19:17		03/21/08	19:48		Unplanned
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	03/05/08	02:06		03/08/08	05:07		Unplanned
	03/08/08	17:44		03/12/08	04:33		Unplanned
	03/17/08	03:03		03/17/08	15:35		Unplanned
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	03/03/08	19:06		03/04/08	18:59		Unplanned
	03/26/08	02:11		04/01/08	00:00	(2)	Unplanned
FOUR CORNERS 5	03/01/08	00:00	(1)	04/01/08	00:00	(2)	Planned
NAVAJO 1	03/07/08	23:18		03/08/08	02:00		Unplanned
NAVAJO 2	No Outages						
NAVAJO 3	No Outages						
OCOTILLO CT1	03/01/08	00:00		03/15/08	16:15		Planned
OCOTILLO CT2	No Outages						
OCOTILLO ST1	03/01/08	00:00	(1)	04/01/08	00:00	(2)	Planned
OCOTILLO ST2	03/24/08	06:00		04/01/08	00:00	(2)	Planned
PALO VERDE 1	No Outages						
PALO VERDE 2	03/29/08	00:01		04/01/08	00:00	(2)	Planned
PALO VERDE 3	No Outages						
REDHAWK CT1A	No Outages						
REDHAWK CT1B	No Outages						
REDHAWK CT2A	No Outages						
REDHAWK CT2B	03/04/08	04:16		03/04/08	07:06		Unplanned
REDHAWK ST1	No Outages						
REDHAWK ST2	No Outages						
SAGUARO CT1	03/03/08	06:30		03/03/08	15:30		Maintenance
	03/05/08	07:00		03/05/08	10:40		Maintenance
	03/08/08	06:30		03/08/08	18:39		Maintenance
	03/16/08	05:43		03/19/08	12:11		Unplanned
SAGUARO CT2	03/10/08	00:01		03/14/08	15:17		Planned
SAGUARO CT3	03/03/08	06:30		03/03/08	15:30		Maintenance
	03/05/08	07:00		03/05/08	10:40		Maintenance
	03/08/08	06:30		03/08/08	18:39		Maintenance
	03/16/08	05:43		03/19/08	13:23		Unplanned
SAGUARO ST1	03/16/08	05:43		03/16/08	06:43		Unplanned
	03/24/08	00:01		04/01/08	00:00	(2)	Planned
SAGUARO ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SUNDANCE 1	03/08/08	00:45		03/09/08	11:50		Maintenance
SUNDANCE 2	03/08/08	00:45		03/09/08	11:50		Maintenance
SUNDANCE 3	03/03/08	00:00		03/13/08	00:00		Planned
SUNDANCE 4	03/03/08	00:00		03/13/08	00:00		Planned
SUNDANCE 5	03/08/08	00:00		03/09/08	11:50		Maintenance
SUNDANCE 6	03/08/08	00:45		03/09/08	11:50		Maintenance
SUNDANCE 7	03/08/08	00:45		03/09/08	11:50		Maintenance
SUNDANCE 8	03/08/08	00:45		03/09/08	11:50		Maintenance
SUNDANCE 9	03/08/08	00:45		03/09/08	23:20		Maintenance
SUNDANCE 10	03/08/08	00:45		03/09/08	11:50		Maintenance
WEST PHOENIX CC1	03/01/08	00:00	(1)	04/01/08	00:00	(2)	Planned
WEST PHOENIX CC2	03/16/08	06:00		03/17/08	01:05		Unplanned
	03/18/08	04:01		03/18/08	19:36		Maintenance
	03/19/08	09:59		03/20/08	05:22		Unplanned
WEST PHOENIX CC3	No Outages						
WEST PHOENIX CC4	03/03/08	00:00		03/12/08	19:30		Planned
	03/14/08	11:16		03/14/08	13:30		Unplanned
	03/26/08	00:00		03/26/08	01:22		Unplanned
WEST PHOENIX CT5A	03/10/08	23:33		03/11/08	05:00		Unplanned
	03/11/08	11:46		03/11/08	13:30		Unplanned
WEST PHOENIX CT5B	03/11/08	00:15		03/11/08	05:00		Unplanned
WEST PHOENIX ST5	03/01/08	11:45		03/01/08	22:30		Unplanned
WEST PHOENIX CT1	No Outages						
WEST PHOENIX CT2	No Outages						
YUCCA CT1	No Outages						
YUCCA CT2	No Outages						
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						

(1) Designations of 03/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 04/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
April-08

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
CHOLLA 1	No Outages				
CHOLLA 2	05-Apr-08	23:52	07-Apr-08	00:28	Unplanned
CHOLLA 3	18-Apr-08	23:38	20-Apr-08	16:36	Unplanned
	20-Apr-08	20:08	20-Apr-08	22:59	Unplanned
	24-Apr-08	05:16	24-Apr-08	06:17	Unplanned
	24-Apr-08	10:33	24-Apr-08	11:45	Unplanned
DOUGLAS (FAIRVIEW) 1	21-Apr-08	00:01	25-Apr-08	18:00	Planned
	28-Apr-08	17:00	01-May-08	00:00 (2)	Unplanned
FOUR CORNERS 1	22-Apr-08	00:53	25-Apr-08	03:02	Unplanned
	25-Apr-08	06:43	25-Apr-08	12:59	Unplanned
FOUR CORNERS 2	22-Apr-08	16:21	22-Apr-08	22:48	Unplanned
FOUR CORNERS 3	05-Apr-08	23:52	06-Apr-08	08:23	Unplanned
FOUR CORNERS 4	01-Apr-08	00:00 (1)	01-Apr-08	09:35	Unplanned
	01-Apr-08	14:27	01-Apr-08	19:49	Unplanned
	10-Apr-08	12:46	15-Apr-08	00:00	Unplanned
	15-Apr-08	00:00	16-Apr-08	09:37	Unplanned
	23-Apr-08	15:32	23-Apr-08	19:54	Unplanned
FOUR CORNERS 5	01-Apr-08	00:00 (1)	01-May-08	00:00 (2)	Planned
NAVAJO 1	No Outages				
NAVAJO 2	No Outages				
NAVAJO 3	No Outages				
OCOTILLO CT1	16-Apr-08	21:49	17-Apr-08	05:06	Planned
OCOTILLO CT2	28-Apr-08	06:00	29-Apr-08	00:00	Planned
	29-Apr-08	00:00	01-May-08	00:00 (2)	Planned
OCOTILLO ST1	01-Apr-08	00:00 (1)	07-Apr-08	06:20	Planned
	29-Apr-08	13:12	30-Apr-08	00:00	Unplanned
	30-Apr-08	00:00	30-Apr-08	15:11	Unplanned
OCOTILLO ST2	01-Apr-08	00:00 (1)	21-Apr-08	00:00	Planned
	21-Apr-08	00:00	30-Apr-08	09:08	Planned
PALO VERDE 1	No Outages				
PALO VERDE 2	01-Apr-08	00:00 (1)	01-May-08	00:00 (2)	Planned
PALO VERDE 3	No Outages				
REDHAWK CT1A	05-Apr-08	05:11	05-Apr-08	16:44	Maintenance
REDHAWK CT1B	05-Apr-08	05:11	05-Apr-08	16:44	Maintenance
	23-Apr-08	09:31	23-Apr-08	12:01	Unplanned
REDHAWK CT2A	06-Apr-08	05:00	06-Apr-08	14:35	Maintenance
REDHAWK CT2B	06-Apr-08	05:00	06-Apr-08	14:35	Maintenance
	14-Apr-08	08:52	14-Apr-08	12:15	Unplanned
REDHAWK ST1	05-Apr-08	05:11	05-Apr-08	16:44	Maintenance
	10-Apr-08	12:45	15-Apr-08	14:50	Unplanned
REDHAWK ST2	06-Apr-08	05:00	06-Apr-08	14:35	Maintenance
SAGUARO CT1	No Outages				
SAGUARO CT2	22-Apr-08	07:00	22-Apr-08	17:50	Maintenance
SAGUARO CT3	No Outages				
SAGUARO ST1	01-Apr-08	00:00 (1)	13-Apr-08	00:01	Planned
SAGUARO ST2	22-Apr-08	07:00	22-Apr-08	17:50	Maintenance

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
April-08

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SUNDANCE 1	30-Apr-08	23:00	30-Apr-08	23:59	Unplanned
SUNDANCE 2	30-Apr-08	23:00	30-Apr-08	23:59	Unplanned
SUNDANCE 3	No Outages				
SUNDANCE 4	No Outages				
SUNDANCE 5	No Outages				
SUNDANCE 6	No Outages				
SUNDANCE 7	No Outages				
SUNDANCE 8	No Outages				
SUNDANCE 9	27-Apr-08	16:12	27-Apr-08	23:00	Unplanned
SUNDANCE 10	27-Apr-08	16:12	27-Apr-08	23:00	Unplanned
WEST PHOENIX ST5	06-Apr-08	03:00	06-Apr-08	04:45	Unplanned
	07-Apr-08	06:00	16-Apr-08	00:00	Planned
	16-Apr-08	00:00	20-Apr-08	15:30	Unplanned
WEST PHOENIX CC1	01-Apr-08	00:00 (1)	17-Apr-08	00:00	Planned
	17-Apr-08	00:00	25-Apr-08	14:30	Unplanned
WEST PHOENIX CC2	11-Apr-08	03:00	11-Apr-08	14:24	Unplanned
	30-Apr-08	00:00	01-May-08	00:00 (2)	Planned
WEST PHOENIX CC3	24-Apr-08	06:00	01-May-08	00:00 (2)	Planned
WEST PHOENIX CC4	12-Apr-08	09:42	12-Apr-08	12:19	Unplanned
	15-Apr-08	14:24	16-Apr-08	13:45	Unplanned
WEST PHOENIX CT1	No Outages				
WEST PHOENIX CT2	No Outages				
WEST PHOENIX CT5A	07-Apr-08	06:00	18-Apr-08	00:00	Planned
	18-Apr-08	00:00	20-Apr-08	15:30	Unplanned
WEST PHOENIX CT5B	07-Apr-08	06:00	16-Apr-08	00:00	Planned
	16-Apr-08	00:00	20-Apr-08	15:30	Unplanned
	21-Apr-08	12:45	21-Apr-08	15:33	Unplanned
	23-Apr-08	08:48	25-Apr-08	16:30	Unplanned
	29-Apr-08	09:02	29-Apr-08	16:00	Unplanned
YUCCA CT1	No Outages				
YUCCA CT2	No Outages				
YUCCA CT3	14-Apr-08	06:00	14-Apr-08	18:00	Maintenance
	15-Apr-08	05:00	15-Apr-08	17:00	Maintenance
	16-Apr-08	05:00	16-Apr-08	11:30	Maintenance
	17-Apr-08	14:00	17-Apr-08	17:45	Maintenance
	18-Apr-08	12:00	18-Apr-08	13:00	Maintenance
YUCCA CT4	14-Apr-08	06:00	14-Apr-08	18:00	Maintenance
	23-Apr-08	09:20	23-Apr-08	14:05	Maintenance

(1) Designations of 04/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 05/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MAY 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	No Outages						
CHOLLA 3	05/14/08	00:34		05/16/08	01:03		Unplanned
DOUGLAS (FAIRVIEW) 1	05/01/08	00:00	(1)	05/03/08	17:20		Unplanned
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	05/01/08	00:00	(1)	05/20/08	12:01		Planned
	05/20/08	22:38		05/22/08	12:57		Unplanned
	05/22/08	23:20		05/31/08	17:37		Unplanned
	05/31/08	21:26		06/01/08	00:00	(2)	Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	05/13/08	09:51		05/13/08	12:03		Unplanned
NAVAJO 3	05/17/08	00:10		05/19/08	12:25		Unplanned
OCOTILLO ST1	05/19/08	10:00		05/19/08	13:03		Unplanned
OCOTILLO ST2	05/18/08	12:13		05/18/08	23:54		Unplanned
	05/28/08	12:00		05/29/08	13:30		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	05/01/08	00:00	(1)	05/02/08	14:05		Planned
	05/24/08	17:48		05/24/08	21:23		Unplanned
PALO VERDE 1	No Outages						
PALO VERDE 2	05/01/08	00:00	(1)	06/01/08	00:00	(2)	Planned
PALO VERDE 3	No Outages						
REDHAWK CT1A	05/17/08	15:06		05/17/08	16:11		Unplanned
REDHAWK CT1B	No Outages						
REDHAWK ST1	05/15/08	22:55		05/18/08	00:45		Unplanned
REDHAWK CT2A	05/25/08	06:48		05/25/08	08:00		Unplanned
	05/31/08	06:00		06/01/08	00:00	(2)	Unplanned
REDHAWK CT2B	05/31/08	06:00		06/01/08	00:00	(2)	Unplanned
REDHAWK ST2	05/31/08	06:00		06/01/08	00:00	(2)	Unplanned
SAGUARO ST1	No Outages						
SAGUARO ST2	05/27/08	08:27		05/27/08	15:46		Maintenance
SAGUARO CT1	No Outages						
SAGUARO CT2	05/27/08	08:27		05/27/08	15:46		Maintenance
SAGUARO CT3	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MAY 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
SUNDANCE 1	No Outages					
SUNDANCE 2	No Outages					
SUNDANCE 3	No Outages					
SUNDANCE 4	05/19/08	15:25		05/21/08	14:00	Unplanned
SUNDANCE 5	No Outages					
SUNDANCE 6	No Outages					
SUNDANCE 7	No Outages					
SUNDANCE 8	No Outages					
SUNDANCE 9	No Outages					
SUNDANCE 10	No Outages					
WEST PHOENIX CC1	05/14/08	06:00		05/14/08	13:10	Maintenance
	05/18/08	07:57		05/18/08	09:14	Unplanned
	05/19/08	00:00		05/19/08	16:45	Unplanned
	05/27/08	06:00		05/27/08	19:00	Unplanned
WEST PHOENIX CC2	05/01/08	00:00	(1)	05/08/08	00:00	Planned
	05/08/08	00:00		05/20/08	17:30	Unplanned
WEST PHOENIX CC3	05/01/08	00:00	(1)	05/09/08	05:00	Planned
	05/17/08	07:30		05/18/08	19:45	Unplanned
WEST PHOENIX CC4	05/17/08	09:32		05/18/08	14:59	Unplanned
	05/18/08	16:40		05/19/08	14:08	Unplanned
	05/19/08	15:52		05/21/08	16:30	Unplanned
WEST PHOENIX CT5A	05/12/08	15:40		05/13/08	05:28	Unplanned
	05/14/08	04:13		05/14/08	09:58	Unplanned
WEST PHOENIX CT5B	No Outages					
WEST PHOENIX ST5	No Outages					
WEST PHOENIX CT1	No Outages					
WEST PHOENIX CT2	05/24/08	06:00		05/27/08	13:35	Unplanned
YUCCA CT1	No Outages					
YUCCA CT2	05/18/08	01:00		05/18/08	17:40	Unplanned
YUCCA CT3	05/15/08	15:58		05/18/08	11:50	Unplanned
	05/22/08	07:20		05/22/08	14:23	Maintenance
	05/29/08	16:18		05/29/08	19:50	Unplanned
YUCCA CT4	No Outages					

(1) Designations of 05/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 06/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	06/20/08	12:51		06/24/08	06:45		Unplanned
CHOLLA 2	No Outages						
CHOLLA 3	06/07/08	19:31		06/09/08	05:19		Unplanned
	06/29/08	00:35		07/01/08	00:00	(2)	Unplanned
DOUGLAS (FAIRVIEW) 1	06/23/08	18:30		06/24/08	13:25		Unplanned
FOUR CORNERS 1	06/13/08	23:00		06/15/08	02:25		Unplanned
FOUR CORNERS 2	06/06/08	17:06		06/08/08	15:19		Unplanned
FOUR CORNERS 3	06/09/08	21:55		06/10/08	05:27		Unplanned
	06/17/08	00:00		06/21/08	21:12		Unplanned
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	06/01/08	00:00	(1)	06/01/08	03:07		Unplanned
	06/19/08	03:40		06/21/08	04:48		Unplanned
	06/21/08	08:11		06/21/08	12:41		Unplanned
	06/21/08	17:17		06/22/08	00:42		Unplanned
	06/22/08	17:24		06/24/08	12:44		Unplanned
NAVAJO 1	06/27/08	23:00		06/30/08	02:00		Unplanned
NAVAJO 2	No Outages						
NAVAJO 3	No Outages						
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
OCOTILLO ST1	No Outages						
OCOTILLO ST2	06/25/08	13:02		06/25/08	15:00		Unplanned
	06/26/08	12:02		06/26/08	16:00		Unplanned
PALO VERDE 1	06/06/08	01:48		06/08/08	21:45		Unplanned
PALO VERDE 2	06/01/08	00:00	(1)	06/05/08	09:50		Planned
	06/05/08	15:12		06/05/08	17:22		Planned
PALO VERDE 3	No Outages						
REDHAWK CT1A	No Outages						
REDHAWK CT1B	06/23/08	05:33		06/23/08	07:52		Unplanned
REDHAWK ST1	No Outages						
REDHAWK CT2A	06/01/08	00:00	(1)	06/03/08	00:00		Unplanned
REDHAWK CT2B	06/01/08	00:00	(1)	06/03/08	00:00		Unplanned
REDHAWK ST2	06/01/08	00:00	(1)	06/03/08	00:00		Unplanned
SAGUARO CT1	06/22/08	10:00		06/23/08	16:27		Unplanned
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
SAGUARO ST1	06/21/08	11:20		06/21/08	14:38		Unplanned
SAGUARO ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SUNDANCE 1	No Outages				
SUNDANCE 2	No Outages				
SUNDANCE 3	No Outages				
SUNDANCE 4	No Outages				
SUNDANCE 5	No Outages				
SUNDANCE 6	No Outages				
SUNDANCE 7	06/17/08	16:41	06/17/08	22:54	Unplanned
SUNDANCE 8	06/17/08	16:41	06/17/08	22:54	Unplanned
SUNDANCE 9	No Outages				
SUNDANCE 10	06/21/08	16:30	06/21/08	17:40	Unplanned
WEST PHOENIX CC1	06/04/08	20:00	06/05/08	20:30	Maintenance
WEST PHOENIX CC2	06/04/08	07:30	06/12/08	12:57	Unplanned
	06/22/08	10:55	06/22/08	12:53	Unplanned
	06/23/08	06:50	06/23/08	09:40	Unplanned
	06/28/08	16:56	06/28/08	19:12	Unplanned
WEST PHOENIX CC3	06/12/08	06:00	06/12/08	17:09	Maintenance
	06/30/08	12:06	06/30/08	14:29	Unplanned
WEST PHOENIX CC4	06/10/08	14:22	06/10/08	15:52	Unplanned
	06/26/08	07:21	06/26/08	08:25	Unplanned
	06/28/08	11:24	06/28/08	12:37	Unplanned
WEST PHOENIX CT5A	06/08/08	09:33	06/08/08	12:12	Unplanned
	06/08/08	12:39	06/08/08	13:53	Unplanned
	06/16/08	09:33	06/16/08	11:32	Unplanned
WEST PHOENIX CT5B	06/20/08	23:28	06/22/08	17:45	Maintenance
	06/26/08	11:35	06/26/08	13:25	Unplanned
WEST PHOENIX ST5	No Outages				
WEST PHOENIX CT1	No Outages				
WEST PHOENIX CT2	No Outages				
YUCCA CT1	No Outages				
YUCCA CT2	No Outages				
YUCCA CT3	06/21/08	00:00	06/21/08	02:06	Maintenance
	06/23/08	16:15	06/23/08	18:31	Maintenance
	06/30/08	22:25	06/30/08	23:30	Maintenance
YUCCA CT4	No Outages				
YUCCA CT5	06/12/08	13:00	06/12/08	15:10	Unplanned
	06/15/08	01:55	06/15/08	06:50	Unplanned
	06/16/08	13:01	06/16/08	16:15	Unplanned
	06/18/08	12:35	06/18/08	16:16	Maintenance
	06/19/08	00:00	06/19/08	01:30	Maintenance
	06/21/08	22:46	06/22/08	02:20	Unplanned
	06/23/08	16:00	06/24/08	09:25	Unplanned
	06/28/08	06:00	06/28/08	10:00	Unplanned
	06/29/08	09:00	06/29/08	10:15	Unplanned
YUCCA CT6	06/23/08	16:00	06/23/08	21:45	Unplanned
	06/25/08	14:57	06/25/08	18:17	Unplanned
	06/28/08	06:00	06/28/08	10:00	Unplanned
	06/29/08	09:00	06/29/08	10:15	Maintenance

(1) Designations of 06/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 07/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
CHOLLA 1	No Outages					
CHOLLA 2	07/16/08	19:05		07/16/08	21:00	Unplanned
CHOLLA 3	07/01/08	00:00	(1)	07/01/08	15:23	Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages					
FOUR CORNERS 1	07/13/08	04:05		07/13/08	08:09	Unplanned
	07/14/08	23:10		07/16/08	12:30	Unplanned
	07/25/08	14:18		07/25/08	17:18	Unplanned
FOUR CORNERS 2	07/10/08	22:44		07/13/08	20:57	Unplanned
	07/14/08	06:59		07/14/08	08:53	Unplanned
	07/25/08	14:23		07/25/08	22:30	Unplanned
FOUR CORNERS 3	No Outages					
FOUR CORNERS 4	No Outages					
FOUR CORNERS 5	07/19/08	22:17		07/23/08	10:10	Unplanned
NAVAJO 1	07/18/08	23:27		07/20/08	03:47	Maintenance
NAVAJO 2	07/12/08	00:04		07/14/08	15:15	Maintenance
	07/15/08	00:56		07/15/08	02:18	Unplanned
NAVAJO 3	No Outages					
OCOTILLO CT1	No Outages					
OCOTILLO CT2	No Outages					
OCOTILLO ST1	No Outages					
OCOTILLO ST2	07/26/08	06:00		07/28/08	12:10	Maintenance
PALO VERDE 1	No Outages					
PALO VERDE 2	No Outages					
PALO VERDE 3	No Outages					
REDHAWK CT1A	No Outages					
REDHAWK CT1B	No Outages					
REDHAWK ST1	No Outages					
REDHAWK CT2A	No Outages					
REDHAWK CT2B	No Outages					
REDHAWK ST2	No Outages					
SAGUARO CT1	07/31/08	14:52		07/31/08	22:55	Unplanned
SAGUARO CT2	No Outages					
SAGUARO CT3	No Outages					
SAGUARO ST1	07/01/08	10:21		07/01/08	12:15	Unplanned
SAGUARO ST2	07/14/08	07:00		07/17/08	22:30	Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
SUNDANCE 1	No Outages					
SUNDANCE 2	No Outages					
SUNDANCE 3	No Outages					
SUNDANCE 4	No Outages					
SUNDANCE 5	07/04/08	09:35	07/07/08	18:00		Unplanned
	07/16/08	06:27	07/18/08	13:20		Unplanned
	07/28/08	03:30	07/28/08	22:00		Unplanned
SUNDANCE 6	07/04/08	09:35	07/05/08	12:00		Unplanned
	07/28/08	03:30	07/28/08	22:00		Unplanned
SUNDANCE 7	No Outages					
SUNDANCE 8	No Outages					
SUNDANCE 9	No Outages					
SUNDANCE 10	No Outages					
WEST PHOENIX CC1	07/16/08	09:02	07/16/08	16:15		Unplanned
WEST PHOENIX CC2	07/07/08	17:35	07/07/08	19:45		Unplanned
	07/15/08	15:30	07/15/08	22:00		Unplanned
	07/20/08	09:56	07/20/08	12:30		Unplanned
WEST PHOENIX CC3	07/19/08	02:30	07/19/08	06:15		Unplanned
	07/29/08	11:20	07/29/08	19:00		Unplanned
WEST PHOENIX CC4	07/11/08	00:00	07/12/08	00:00		Unplanned
	07/12/08	08:10	07/12/08	11:40		Unplanned
WEST PHOENIX CT5A	07/07/08	09:37	07/07/08	11:58		Unplanned
	07/15/08	07:55	07/15/08	10:33		Unplanned
	07/16/08	04:00	07/16/08	08:00		Maintenance
WEST PHOENIX CT5B	07/31/08	06:33	07/31/08	12:45		Unplanned
	07/31/08	13:16	07/31/08	15:45		Unplanned
	07/31/08	16:13	07/31/08	20:20		Unplanned
WEST PHOENIX ST5	07/08/08	13:51	07/08/08	15:08		Unplanned
WEST PHOENIX CT1	07/03/08	09:44	07/03/08	15:29		Unplanned
WEST PHOENIX CT2	No Outages					
YUCCA CT1	No Outages					
YUCCA CT2	No Outages					
YUCCA CT3	07/20/08	19:00	07/21/08	09:00		Maintenance
	07/23/08	09:00	07/23/08	11:58		Maintenance
	07/23/08	13:26	07/23/08	14:30		Unplanned
	07/23/08	20:35	07/24/08	21:58		Maintenance
YUCCA CT4	No Outages					
YUCCA CT5	07/14/08	14:55	07/14/08	16:49		Maintenance
	07/22/08	01:56	07/22/08	03:00		Maintenance
	07/22/08	19:51	07/23/08	13:55		Unplanned
	07/23/08	14:05	08/01/08	00:00	(2)	Maintenance
YUCCA CT6	07/02/08	04:00	07/02/08	06:00		Maintenance
	07/10/08	06:33	07/10/08	14:35		Maintenance
	07/16/08	14:07	07/16/08	19:10		Unplanned
	07/17/08	07:30	07/17/08	10:55		Maintenance
	07/22/08	01:56	07/22/08	03:00		Maintenance

(1) Designations of 07/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 08/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
CHOLLA 1	No Outages				
CHOLLA 2	08/16/08	02:32	08/18/08	04:21	Unplanned
CHOLLA 3	08/12/08	06:50	08/15/08	22:12	Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages				
FOUR CORNERS 1	08/05/08	23:00	08/07/08	13:28	Unplanned
FOUR CORNERS 2	No Outages				
FOUR CORNERS 3	No Outages				
FOUR CORNERS 4	08/01/08	15:52	08/05/08	09:44	Unplanned
	08/16/08	21:51	08/19/08	09:15	Unplanned
FOUR CORNERS 5	08/28/08	16:17	08/29/08	00:16	Unplanned
NAVAJO 1	08/01/08	22:18	08/04/08	03:36	Maintenance
NAVAJO 2	No Outages				
NAVAJO 3	No Outages				
OCOTILLO CT1	No Outages				
OCOTILLO CT2	No Outages				
OCOTILLO ST1	08/28/08	12:54	08/28/08	20:48	Unplanned
	08/29/08	14:00	08/30/08	13:57	Unplanned
OCOTILLO ST2	08/28/08	11:15	08/28/08	13:57	Unplanned
PALO VERDE 1	No Outages				
PALO VERDE 2	No Outages				
PALO VERDE 3	No Outages				
REDHAWK CT1A	08/10/08	21:55	08/11/08	18:15	Unplanned
REDHAWK CT1B	08/15/08	01:02	08/20/08	20:46	Unplanned
REDHAWK ST1	08/17/08	21:02	08/17/08	22:06	Unplanned
REDHAWK CT2A	No Outages				
REDHAWK CT2B	No Outages				
REDHAWK ST2	No Outages				
SAGUARO ST1	08/27/08	06:38	08/27/08	15:37	Unplanned
SAGUARO ST2	No Outages				
SAGUARO CT1	No Outages				
SAGUARO CT2	No Outages				
SAGUARO CT3	08/06/08	06:00	08/06/08	21:12	Maintenance

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SUNDANCE 1	No Outages				
SUNDANCE 2	No Outages				
SUNDANCE 3	No Outages				
SUNDANCE 4	No Outages				
SUNDANCE 5	08/05/08	10:21	08/08/08	05:30	Unplanned
SUNDANCE 6	08/11/08	14:14	08/18/08	04:16	Unplanned
SUNDANCE 7	No Outages				
SUNDANCE 8	No Outages				
SUNDANCE 9	No Outages				
SUNDANCE 10	No Outages				
WEST PHOENIX CC1	No Outages				
WEST PHOENIX CC2	No Outages				
WEST PHOENIX CC3	08/10/08	07:30	08/10/08	09:12	Unplanned
WEST PHOENIX CC4	08/20/08	04:00	08/20/08	12:30	Unplanned
WEST PHOENIX CT5A	08/06/08	04:36	08/07/08	14:00	Unplanned
	08/09/08	06:58	08/09/08	08:11	Unplanned
	08/28/08	09:01	08/28/08	11:15	Unplanned
WEST PHOENIX CT5B	08/09/08	08:21	08/09/08	09:41	Unplanned
	08/10/08	06:58	08/10/08	10:34	Unplanned
WEST PHOENIX ST5	No Outages				
WEST PHOENIX CT1	No Outages				
WEST PHOENIX CT2	No Outages				
YUCCA CT1	No Outages				
YUCCA CT2	No Outages				
YUCCA CT3	08/28/08	07:58	08/28/08	09:55	Maintenance
	08/29/08	03:30	08/29/08	06:30	Maintenance
YUCCA CT4	No Outages				
YUCCA CT5	08/07/08	00:00	08/07/08	08:37	Maintenance
	08/08/08	00:16	08/08/08	06:35	Maintenance
	08/10/08	21:40	08/11/08	00:12	Maintenance
	08/16/08	21:27	08/17/08	07:42	Maintenance
	08/21/08	23:21	08/23/08	19:27	Maintenance
YUCCA CT6	08/06/08	07:21	08/06/08	13:27	Maintenance
	08/07/08	07:00	08/07/08	08:10	Maintenance
	08/07/08	08:38	08/17/08	07:42	Maintenance
	08/17/08	11:31	08/19/08	23:09	Maintenance
	08/20/08	00:04	08/20/08	12:51	Maintenance
	08/21/08	23:21	08/23/08	19:27	Maintenance

(1) Designations of 08/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 09/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages					
CHOLLA 2	No Outages					
CHOLLA 3	04-Sep-08	15:29	04-Sep-08	16:26		Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages					
FOUR CORNERS 1	29-Sep-08	22:59	01-Oct-08	00:00	(2)	Unplanned
FOUR CORNERS 2	08-Sep-08	23:00	12-Sep-08	01:28		Unplanned
FOUR CORNERS 3	No Outages					
FOUR CORNERS 4	No Outages					
FOUR CORNERS 5	19-Sep-08	13:36	22-Sep-08	13:30		Unplanned
NAVAJO 1	No Outages					
NAVAJO 2	30-Sep-08	13:33	30-Sep-08	14:54		Unplanned
NAVAJO 3	No Outages					
OCOTILLO CT1	No Outages					
OCOTILLO CT2	No Outages					
OCOTILLO ST1	No Outages					
OCOTILLO ST2	No Outages					
PALO VERDE 1	No Outages					
PALO VERDE 2	No Outages					
PALO VERDE 3	16-Sep-08	14:00	20-Sep-08	16:24		Unplanned
	27-Sep-08	21:51	30-Sep-08	00:05		Unplanned
	30-Sep-08	00:34	30-Sep-08	10:34		Unplanned
REDHAWK CT1A	No Outages					
REDHAWK CT1B	11-Sep-08	18:18	11-Sep-08	21:20		Unplanned
REDHAWK ST1	11-Sep-08	18:18	11-Sep-08	21:20		Unplanned
REDHAWK CT2A	No Outages					
REDHAWK CT2B	11-Sep-08	18:18	11-Sep-08	21:20		Unplanned
	25-Sep-08	08:59	25-Sep-08	10:36		Unplanned
REDHAWK ST2	11-Sep-08	18:18	11-Sep-08	21:20		Unplanned
SAGUARO ST1	No Outages					
SAGUARO ST2	22-Sep-08	07:30	25-Sep-08	18:30		Maintenance
SAGUARO CT1	25-Sep-08	20:00	26-Sep-08	06:45		Maintenance
SAGUARO CT2	No Outages					
SAGUARO CT3	14-Sep-08	14:48	15-Sep-08	08:45		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SUNDANCE 1	01-Sep-08	19:33	02-Sep-08	05:30	Unplanned
SUNDANCE 2	01-Sep-08	19:33	02-Sep-08	05:30	Unplanned
SUNDANCE 3	No Outages				
SUNDANCE 4	No Outages				
SUNDANCE 5	No Outages				
SUNDANCE 6	No Outages				
SUNDANCE 7	No Outages				
SUNDANCE 8	12-Sep-08	16:15	13-Sep-08	06:45	Unplanned
SUNDANCE 9	No Outages				
SUNDANCE 10	No Outages				
WEST PHOENIX CC1	11-Sep-08	20:30	12-Sep-08	16:45	Unplanned
WEST PHOENIX CC2	26-Sep-08	14:56	27-Sep-08	18:00	Unplanned
WEST PHOENIX CC3	No Outages				
WEST PHOENIX CC4	07-Sep-08	07:16	07-Sep-08	10:39	Unplanned
WEST PHOENIX CT1	10-Sep-08	09:15	10-Sep-08	10:15	Maintenance
WEST PHOENIX CT2	10-Sep-08	08:00	10-Sep-08	09:00	Maintenance
WEST PHOENIX CT5A	11-Sep-08	13:06	11-Sep-08	16:45	Unplanned
	12-Sep-08	12:00	12-Sep-08	16:56	Unplanned
WEST PHOENIX CT5B	25-Sep-08	09:54	25-Sep-08	11:30	Unplanned
WEST PHOENIX ST5	04-Sep-08	09:42	06-Sep-08	14:13	Unplanned
	12-Sep-08	01:22	14-Sep-08	18:48	Unplanned
	15-Sep-08	10:35	15-Sep-08	11:43	Unplanned
YUCCA CT1	No Outages				
YUCCA CT2	No Outages				
YUCCA CT3	No Outages				
YUCCA CT4	11-Sep-08	18:35	11-Sep-08	19:35	Unplanned
YUCCA CT5	02-Sep-08	15:58	05-Sep-08	08:49	Unplanned
	17-Sep-08	15:02	18-Sep-08	05:30	Maintenance
	19-Sep-08	03:05	19-Sep-08	08:44	Maintenance
YUCCA CT6	01-Sep-08	15:10	02-Sep-08	16:01	Maintenance
	04-Sep-08	07:30	04-Sep-08	13:20	Maintenance
	19-Sep-08	09:26	19-Sep-08	11:33	Maintenance

(1) Designations of 09/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 10/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
CHOLLA 1	10/16/08	14:05	10/18/08	02:11	Unplanned
	10/22/08	21:02	10/23/08	00:40	Unplanned
CHOLLA 2	No Outages				
CHOLLA 3	10/29/08	12:18	11/01/08	00:00 (2)	Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages				
FOUR CORNERS 1	10/01/08	00:00 (1)	10/01/08	08:37	Unplanned
	10/23/08	16:22	10/26/08	15:11	Unplanned
FOUR CORNERS 2	No Outages				
FOUR CORNERS 3	10/17/08	11:34	10/20/08	13:00	Unplanned
	10/20/08	13:00	10/21/08	09:59	Unplanned
FOUR CORNERS 4	10/03/08	05:24	10/06/08	09:47	Unplanned
FOUR CORNERS 5	No Outages				
NAVAJO 1	10/24/08	23:07	10/27/08	20:18	Maintenance
NAVAJO 2	No Outages				
NAVAJO 3	No Outages				
OCOTILLO ST1	No Outages				
OCOTILLO ST2	10/09/08	11:40	10/10/08	12:55	Unplanned
OCOTILLO CT1	No Outages				
OCOTILLO CT2	No Outages				
PALO VERDE 1	10/04/08	00:00	11/01/08	00:00 (2)	Planned
PALO VERDE 2	No Outages				
PALO VERDE 3	No Outages				
REDHAWK CT1A	No Outages				
REDHAWK CT1B	No Outages				
REDHAWK ST1	10/26/08	00:00	10/26/08	06:12	Unplanned
REDHAWK CT2A	10/18/08	00:00	10/18/08	07:57	Maintenance
	10/24/08	23:00	10/25/08	14:04	Unplanned
REDHAWK CT2B	10/14/08	21:44	10/14/08	23:09	Unplanned
	10/24/08	23:00	10/25/08	14:04	Unplanned
REDHAWK ST2	10/14/08	21:54	10/14/08	22:03	Unplanned
	10/24/08	23:00	10/25/08	14:04	Unplanned
SAGUARO ST1	No Outages				
SAGUARO ST2	No Outages				
SAGUARO CT1	No Outages				
SAGUARO CT2	No Outages				
SAGUARO CT3	10/20/08	00:01	10/24/08	16:18	Planned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
SUNDANCE 1	10/29/08	10:00	10/29/08	16:12		Maintenance
	10/31/08	07:20	10/31/08	10:54		Unplanned
SUNDANCE 2	10/29/08	10:00	10/29/08	16:12		Maintenance
	10/31/08	07:20	10/31/08	10:54		Unplanned
SUNDANCE 3	10/09/08	16:39	10/10/08	12:33		Unplanned
	10/30/08	08:00	10/30/08	09:03		Unplanned
	10/31/08	07:20	10/31/08	10:54		Unplanned
SUNDANCE 4	10/09/08	16:39	10/10/08	12:33		Unplanned
	10/31/08	07:20	10/31/08	10:54		Unplanned
SUNDANCE 5	No Outages					
SUNDANCE 6	No Outages					
SUNDANCE 7	10/08/08	10:33	10/08/08	16:45		Unplanned
	10/31/08	07:20	10/31/08	10:54		Unplanned
SUNDANCE 8	10/06/08	05:31	10/06/08	13:15		Unplanned
	10/08/08	10:15	10/09/08	09:45		Unplanned
	10/31/08	07:20	10/31/08	10:54		Unplanned
SUNDANCE 9	10/06/08	05:49	10/06/08	07:50		Unplanned
	10/06/08	15:19	10/06/08	23:28		Unplanned
	10/08/08	10:39	10/08/08	16:30		Unplanned
	10/31/08	07:20	10/31/08	12:32		Unplanned
SUNDANCE 10	10/31/08	07:20	10/31/08	12:32		Unplanned
WEST PHOENIX CC1	10/25/08	16:36	10/26/08	00:00		Unplanned
	10/25/08	15:00	10/25/08	16:36		Unplanned
	10/26/08	00:00	11/01/08	00:00	(2)	Unplanned
WEST PHOENIX CC2	10/06/08	06:00	11/01/08	00:00	(2)	Maintenance
WEST PHOENIX CC3	10/06/08	16:30	10/09/08	14:26		Unplanned
WEST PHOENIX CC3	10/25/08	16:36	10/26/08	16:58		Unplanned
WEST PHOENIX CC4	10/06/08	12:37	10/06/08	13:43		Unplanned
	10/25/08	17:52	10/26/08	09:00		Unplanned
	10/27/08	13:19	10/27/08	16:15		Unplanned
	10/28/08	01:20	10/28/08	10:29		Unplanned
WEST PHOENIX CT5A	10/26/08	08:00	10/26/08	09:36		Unplanned
	10/27/08	00:00	11/01/08	00:00	(2)	Planned
WEST PHOENIX CT5B	10/28/08	00:00	11/01/08	00:00	(2)	Planned
WEST PHOENIX ST5	10/28/08	00:00	11/01/08	00:00	(2)	Planned
WEST PHOENIX CT1	No Outages					
WEST PHOENIX CT2	No Outages					
YUCCA CT1	10/20/08	15:00	10/21/08	09:15		Unplanned
YUCCA CT2	No Outages					
YUCCA CT3	No Outages					
YUCCA CT4	No Outages					
YUCCA CT5	10/01/08	19:00	10/02/08	07:00		Maintenance
	10/02/08	22:00	10/03/08	05:40		Maintenance
YUCCA CT6	10/01/08	19:00	10/02/08	07:00		Maintenance
	10/02/08	22:00	10/03/08	05:40		Maintenance
	10/02/08	07:00	10/02/08	17:41		Maintenance
	10/04/08	13:25	10/10/08	10:20		Maintenance
	10/15/08	06:02	10/16/08	13:06		Maintenance
	10/16/08	14:25	10/22/08	16:12		Maintenance
	10/25/08	14:48	10/25/08	15:15		Maintenance

(1) Designations of 10/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 11/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
PALO VERDE 1	11/01/08	00:00	(1)	11/12/08	23:59		Planned
	11/12/08	23:59		11/18/08	18:39		Planned
	11/18/08	23:52		11/19/08	00:52		Planned
PALO VERDE 2	11/22/08	00:00		12/01/08	00:00	(2)	Maintenance
PALO VERDE 3	No Outages						
CHOLLA 1	No Outages						
CHOLLA 2	No Outages						
CHOLLA 3	11/01/08	00:00	(1)	11/01/08	12:51		Unplanned
CHOLLA 4	11/01/08	14:16		11/01/08	22:31		Unplanned
	11/21/08	23:59		11/25/08	21:03		Unplanned
FOUR CORNERS 1	11/19/08	10:18		11/19/08	13:32		Unplanned
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	11/14/08	08:41		11/14/08	10:30		Unplanned
	11/28/08	00:34		11/30/08	05:44		Unplanned
	11/30/08	18:40		11/30/08	20:55		Unplanned
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	11/26/08	13:00		11/26/08	17:43		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	11/14/08	09:47		11/17/08	07:03		Unplanned
NAVAJO 3	11/12/08	15:19		11/15/08	17:50		Unplanned
OCOTILLO ST1	11/01/08	14:30		11/01/08	18:34		Unplanned
OCOTILLO ST2	No Outages						
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
REDHAWK CT1A	11/08/08	20:00		11/09/08	03:00		Maintenance
	11/18/08	13:59		11/18/08	15:18		Unplanned
	11/18/08	16:00		11/19/08	01:36		Unplanned
	11/19/08	06:32		11/19/08	09:12		Unplanned
	11/28/08	12:10		11/28/08	14:05		Unplanned
REDHAWK CT1B	11/08/08	20:35		11/09/08	06:12		Maintenance
	11/28/08	12:10		11/28/08	14:05		Unplanned
REDHAWK ST1	11/08/08	20:37		11/09/08	06:12		Maintenance
	11/28/08	12:12		11/28/08	14:05		Unplanned
REDHAWK CT2A	11/06/08	17:47		11/07/08	01:00		Unplanned
	11/09/08	20:00		11/09/08	22:24		Maintenance
REDHAWK CT2B	11/09/08	20:00		11/10/08	03:20		Unplanned
	11/30/08	12:00		12/01/08	00:05		Unplanned
REDHAWK ST2	11/09/08	20:00		11/10/08	03:20		Maintenance
SAGUARO ST1	No Outages						
SAGUARO ST2	11/01/08	00:01		11/21/08	13:30		Planned
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	11/08/08	08:00		11/08/08	15:00		Maintenance
DOUGLAS (FAIRVIEW) 1	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
SUNDANCE 1	11/07/08	10:55		11/14/08	18:30	Unplanned
SUNDANCE 2	11/07/08	10:55		11/14/08	18:30	Unplanned
SUNDANCE 3	No Outages					
SUNDANCE 4	No Outages					
SUNDANCE 5	11/01/08	00:00	(1)	11/02/08	15:30	Planned
SUNDANCE 6	11/01/08	00:00	(1)	11/02/08	15:30	Planned
SUNDANCE 7	11/03/08	00:00		11/09/08	09:00	Planned
SUNDANCE 8	11/03/08	00:00		11/08/08	20:20	Planned
SUNDANCE 9	11/15/08	02:00		11/19/08	15:12	Maintenance
SUNDANCE 10	11/15/08	02:00		11/19/08	15:12	Maintenance
WEST PHOENIX CC1	11/01/08	00:00	(1)	11/20/08	00:00	Unplanned
WEST PHOENIX CC2	11/01/08	00:00	(1)	11/20/08	00:00	Maintenance
WEST PHOENIX CC3	No Outages					
WEST PHOENIX CC4	No Outages					
WEST PHOENIX CT5A	11/01/08	00:00	(1)	11/15/08	00:00	Planned
	11/15/08	00:00		11/20/08	13:30	Planned
	11/24/08	10:05		11/24/08	14:11	Unplanned
WEST PHOENIX CT5B	11/01/08	00:00	(1)	11/07/08	14:45	Planned
	11/14/08	11:58		11/14/08	12:33	Unplanned
WEST PHOENIX ST5	11/01/08	00:00	(1)	11/07/08	14:45	Planned
WEST PHOENIX CT1	No Outages					
WEST PHOENIX CT2	No Outages					
YUCCA CT1	11/01/08	05:00		11/01/08	13:09	Maintenance
	11/19/08	14:04		11/19/08	16:02	Maintenance
YUCCA CT2	11/01/08	05:00		11/01/08	13:09	Maintenance
YUCCA CT3	11/01/08	05:00		11/01/08	13:09	Maintenance
YUCCA CT4	No Outages					
YUCCA CT5	11/01/08	05:00		11/01/08	13:20	Maintenance
	11/14/08	06:50		11/14/08	08:23	Maintenance
YUCCA CT6	11/01/08	05:00		11/01/08	13:20	Maintenance
	11/14/08	06:50		11/14/08	08:23	Maintenance

(1) Designations of 11/01/08 00:00 mean that the outage began in the prior month

(2) Designations of 12/01/08 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2008

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
PALO VERDE 1	No Outages						
PALO VERDE 2	12/01/08	00:00	(1)	12/15/08	10:54		Maintenance
PALO VERDE 3	No Outages						
CHOLLA 1	No Outages						
CHOLLA 2	No Outages						
CHOLLA 3	No Outages						
CHOLLA 4	No Outages						
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	12/03/08	01:00		12/05/08	13:00		Unplanned
	12/05/08	13:00		12/08/08	03:39		Unplanned
	12/09/08	03:26		12/10/08	17:00		Unplanned
	12/17/08	21:54		12/22/08	00:00		Unplanned
	12/22/08	00:00		12/23/08	03:00		Unplanned
	12/23/08	03:00		12/25/08	17:11		Unplanned
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	12/07/08	13:28		12/07/08	17:16		Unplanned
	12/07/08	17:58		12/07/08	19:27		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	12/19/08	11:39		12/21/08	19:10		Unplanned
	12/29/08	12:47		01/01/09	00:00	(2)	Unplanned
NAVAJO 3	12/15/08	11:06		12/18/08	00:45		Unplanned
	12/26/08	06:53		12/31/08	23:44		Unplanned
OCOTILLO ST1	No Outages						
OCOTILLO ST2	12/08/08	07:20		12/09/08	00:00		Maintenance
	12/09/08	06:00		12/15/08	15:00		Maintenance
	12/15/08	15:00		12/22/08	13:15		Unplanned
OCOTILLO CT1	12/01/08	09:14		12/04/08	13:35		Maintenance
OCOTILLO CT2	No Outages						
REDHAWK CT1A	12/14/08	04:48		12/14/08	12:22		Unplanned
REDHAWK CT1B	12/14/08	04:48		12/14/08	12:22		Unplanned
REDHAWK ST1	12/14/08	04:48		12/14/08	12:22		Unplanned
REDHAWK CT2A	12/19/08	16:44		12/20/08	13:30		Unplanned
REDHAWK CT2B	12/01/08	00:00	(1)	12/03/08	20:33		Unplanned
	12/11/08	08:33		12/11/08	09:48		Unplanned
	12/23/08	09:54		12/23/08	09:55		Unplanned
REDHAWK ST2	No Outages						
SAGUARO ST1	12/31/08	16:00		01/01/09	00:00	(2)	Unplanned
SAGUARO ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2008

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SUNDANCE 1	No Outages				
SUNDANCE 2	No Outages				
SUNDANCE 3	No Outages				
SUNDANCE 4	No Outages				
SUNDANCE 5	No Outages				
SUNDANCE 6	No Outages				
SUNDANCE 7	No Outages				
SUNDANCE 8	No Outages				
SUNDANCE 9	No Outages				
SUNDANCE 10	No Outages				
WEST PHOENIX CC1	12/05/08	17:12	12/05/08	18:45	Unplanned
	12/06/08	05:24	12/06/08	15:24	Unplanned
WEST PHOENIX CC2	12/01/08	16:59	12/03/08	15:10	Unplanned
	12/24/08	17:01	12/31/08	13:30	Unplanned
WEST PHOENIX CC3	12/03/08	00:00	12/10/08	19:00	Planned
WEST PHOENIX CC4	12/05/08	06:15	12/05/08	08:55	Unplanned
WEST PHOENIX CT1	No Outages				
WEST PHOENIX CT2	No Outages				
WEST PHOENIX CT5A	12/16/08	06:00	12/16/08	18:00	Maintenance
WEST PHOENIX CT5B	No Outages				
WEST PHOENIX ST5	No Outages				
YUCCA CT1	12/12/08	13:00	12/12/08	15:43	Maintenance
	12/29/08	07:43	12/29/08	13:52	Maintenance
YUCCA CT2	12/12/08	13:00	12/12/08	15:43	Maintenance
	12/29/08	07:43	12/29/08	13:52	Maintenance
YUCCA CT3	12/29/08	07:43	12/29/08	13:52	Maintenance
YUCCA CT4	No Outages				
YUCCA CT5	12/11/08	08:45	12/11/08	10:00	Maintenance
YUCCA CT6	No Outages				

(1) Designations of 12/01/08 00:00 mean that the outage began in the prior month
(2) Designations of 01/01/09 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.
(1) Designations of 11/01/08 00:00 mean that the outage began in the prior month
(2) Designations of 12/01/08 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
CHOLLA 1	01/06/09	23:13		01/07/09	07:01		Unplanned
CHOLLA 2	No Outages						
CHOLLA 3	No Outages						
FOUR CORNERS 1	01/01/09	23:26		01/05/09	11:22		Unplanned
	01/05/09	15:31		01/07/09	06:44		Unplanned
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	01/17/09	14:05		01/19/09	02:11		Unplanned
	01/19/09	03:12		01/19/09	10:17		Unplanned
	01/19/09	12:33		01/19/09	21:34		Unplanned
FOUR CORNERS 5	01/06/09	00:39		01/08/09	20:39		Unplanned
	01/17/09	14:05		01/18/09	04:00		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	01/01/09	01:00		01/02/09	12:00		Unplanned
	01/06/09	13:00		01/06/09	23:00		Unplanned
	01/16/09	01:00		01/18/09	18:00		Unplanned
NAVAJO 3	01/01/09	13:00		01/01/09	21:00		Unplanned
	01/23/09	22:59		01/31/09	23:59		Planned
OCOTILLO ST1	No Outages						
OCOTILLO ST2	No Outages						
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
REDHAWK CT1A	01/09/09	00:00		01/24/09	19:00		Planned
	01/25/09	05:00		01/25/09	15:00		Unplanned
	01/27/09	10:43		01/27/09	15:01		Unplanned
REDHAWK CT1B	01/09/09	00:00		01/26/09	11:37		Planned
	01/27/09	10:17		01/27/09	16:48		Unplanned
REDHAWK ST1	01/09/09	00:00		01/24/09	19:00		Planned
	01/27/09	10:48		01/27/09	16:03		Unplanned
REDHAWK CT2A	01/31/09	00:00		02/01/09	00:00	(2)	Planned
REDHAWK CT2B	01/31/09	00:00		02/01/09	00:00	(2)	Planned
REDHAWK ST2	01/31/09	00:00		02/01/09	00:00	(2)	Planned
SAGUARO ST1	01/01/09	00:00	(1)	01/09/09	16:30		Unplanned
SAGUARO ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2009

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
SUNDANCE 1	No Outages					
SUNDANCE 2	No Outages					
SUNDANCE 3	No Outages					
SUNDANCE 4	01/05/09	00:30	01/05/09	18:58		Unplanned
SUNDANCE 5	No Outages					
SUNDANCE 6	No Outages					
SUNDANCE 7	No Outages					
SUNDANCE 8	No Outages					
SUNDANCE 9	No Outages					
SUNDANCE 10	No Outages					
WEST PHOENIX CC1	01/16/09	05:11	01/17/09	18:00		Unplanned
	01/24/09	00:00	02/01/09	00:00	(2)	Planned
WEST PHOENIX CC2	No Outages					
WEST PHOENIX CC3	No Outages					
WEST PHOENIX CC4	No Outages					
WEST PHOENIX CT5A	No Outages					
WEST PHOENIX CT5B	No Outages					
WEST PHOENIX ST5	No Outages					
WEST PHOENIX CT1	01/11/09	00:00	02/01/09	00:00	(2)	Planned
WEST PHOENIX CT2	No Outages					
YUCCA CT1	01/02/09	09:48	01/02/09	10:03		Maintenance
	01/05/09	00:00	02/01/09	00:00	(2)	Planned
YUCCA CT2	01/05/09	00:00	02/01/09	00:00	(2)	Planned
YUCCA CT3	01/15/09	07:00	01/15/09	15:08		Maintenance
	01/24/09	01:50	01/24/09	02:45		Unplanned
	01/25/09	12:05	01/27/09	09:05		Maintenance
YUCCA CT4	01/14/09	07:00	01/14/09	15:15		Maintenance
YUCCA CT5	01/04/09	20:50	01/05/09	03:00		Unplanned
	01/05/09	06:56	01/05/09	07:58		Maintenance
	01/07/09	16:10	01/07/09	18:20		Maintenance
	01/08/09	10:05	01/08/09	15:35		Maintenance
	01/29/09	08:15	01/31/09	17:11		Maintenance
YUCCA CT6	01/07/09	15:00	01/08/09	10:05		Maintenance
	01/08/09	15:35	01/08/09	18:05		Maintenance

(1) Designations of 01/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 02/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
CHOLLA 1	02/04/09	00:21		02/06/09	15:25		Unplanned
	02/15/09	16:33		02/15/09	18:12		Unplanned
CHOLLA 2	02/13/09	07:25		02/14/09	20:57		Unplanned
CHOLLA 3	No Outages						
FOUR CORNERS 1	02/10/09	09:41		02/10/09	19:44		Unplanned
FOUR CORNERS 2	02/10/09	09:41		02/10/09	21:51		Unplanned
FOUR CORNERS 3	02/01/09	17:12		02/01/09	18:25		Unplanned
	02/10/09	12:41		02/10/09	13:52		Unplanned
	02/20/09	19:00		03/01/09	00:00	(2)	Planned
FOUR CORNERS 4	02/03/09	00:05		02/12/09	23:27		Planned
	02/13/09	08:43		02/13/09	14:11		Planned
FOUR CORNERS 5	No Outages						
NAVAJO 1	No Outages						
NAVAJO 2	No Outages						
NAVAJO 3	02/01/09	00:00	(1)	03/01/09	00:00	(2)	Planned
OCOTILLO ST1	02/09/09	06:00		03/01/09	00:00	(2)	Planned
OCOTILLO ST2	02/19/09	07:00		02/19/09	18:13		Unplanned
OCOTILLO CT1	02/19/09	07:00		02/19/09	18:13		Unplanned
OCOTILLO CT2	No Outages						
REDHAWK CT1A	No Outages						
REDHAWK CT1B	No Outages						
REDHAWK ST1	No Outages						
REDHAWK CT2A	02/01/09	00:00	(1)	02/07/09	03:50		Planned
	02/08/09	03:14		02/08/09	05:03		Unplanned
	02/08/09	14:43		02/08/09	17:05		Unplanned
REDHAWK CT2B	02/01/09	00:00	(1)	02/09/09	16:43		Planned
	02/09/09	20:24		02/10/09	05:32		Unplanned
	02/10/09	11:24		02/10/09	14:32		Unplanned
REDHAWK ST2	02/01/09	00:00	(1)	02/07/09	03:50		Planned
SAGUARO ST1	No Outages						
SAGUARO ST2	02/07/09	00:01		03/01/09	00:00	(2)	Planned
SAGUARO CT1	No Outages						
SAGUARO CT2	02/10/09	12:43		02/10/09	13:33		Unplanned
SAGUARO CT3	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
DOUGLAS (FAIRVIEW) 1	No Outages						
SUNDANCE 1	No Outages						
SUNDANCE 2	No Outages						
SUNDANCE 3	No Outages						
SUNDANCE 4	No Outages						
SUNDANCE 5	No Outages						
SUNDANCE 6	No Outages						
SUNDANCE 7	02/27/09	10:28		02/27/09	18:20		Maintenance
SUNDANCE 8	02/27/09	10:28		02/27/09	18:20		Maintenance
SUNDANCE 9	02/23/09	00:00		03/01/09	00:00	(2)	Planned
SUNDANCE 10	02/23/09	00:00		03/01/09	00:00	(2)	Planned
WEST PHOENIX CC1	02/01/09	00:00	(1)	02/13/09	18:00		Planned
	02/14/09	05:00		02/14/09	10:00		Unplanned
	02/14/09	16:20		02/15/09	07:57		Unplanned
	02/15/09	16:59		02/26/09	18:36		Unplanned
WEST PHOENIX CC2	02/03/09	00:00		02/03/09	13:20		Unplanned
	02/14/09	00:00		02/28/09	00:00		Planned
	02/28/09	00:00		03/01/09	00:00	(2)	Unplanned
WEST PHOENIX CC3	02/17/09	17:59		02/18/09	15:35		Unplanned
WEST PHOENIX CC4	No Outages						
WEST PHOENIX CT5A	02/17/09	04:01		02/17/09	06:34		Unplanned
	02/26/09	22:54		02/27/09	10:30		Unplanned
WEST PHOENIX ST5	02/11/09	06:00		02/13/09	16:00		Unplanned
WEST PHOENIX CT1	02/01/09	00:00	(1)	03/01/09	00:00	(2)	Planned
WEST PHOENIX CT2	No Outages						
YUCCA CT1	02/01/09	00:00	(1)	02/07/09	00:00		Planned
	02/07/09	00:00		03/01/09	00:00	(2)	Planned
YUCCA CT2	02/01/09	00:00	(1)	02/07/09	00:00		Planned
	02/07/09	00:00		03/01/09	00:00	(2)	Planned
YUCCA CT3	02/11/09	00:00		03/01/09	00:00	(2)	Planned
YUCCA CT4	No Outages						
YUCCA CT5	02/04/09	07:35		02/04/09	13:22		Maintenance
	02/11/09	06:50		02/11/09	09:28		Unplanned
	02/24/09	19:00		02/24/09	21:09		Unplanned
YUCCA CT6	02/01/09	00:00	(1)	02/01/09	18:23		Maintenance
	02/11/09	06:50		02/11/09	09:36		Unplanned
	02/17/09	05:25		02/18/09	12:50		Unplanned

(1) Designations of 02/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 03/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	03/30/09	15:10		03/30/09	16:14		Unplanned
CHOLLA 3	03/20/09	23:52		04/01/09	00:00	(2)	Planned
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	03/03/09	07:23		03/03/09	11:47		Unplanned
	03/04/09	14:16		03/04/09	16:38		Unplanned
	03/21/09	07:17		03/27/09	03:40		Unplanned
	03/27/09	04:29		03/27/09	10:33		Unplanned
	03/27/09	11:42		03/27/09	20:19		Unplanned
	03/27/09	21:02		03/27/09	23:18		Unplanned
	03/28/09	00:55		03/28/09	07:14		Unplanned
FOUR CORNERS 3	03/01/09	00:00	(1)	03/28/09	07:05		Planned
	03/28/09	13:48		03/28/09	16:17		Planned
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	03/19/09	00:19		03/19/09	10:30		Unplanned
	03/30/09	23:59		03/31/09	09:28		Unplanned
NAVAJO 1	03/07/09	00:34		03/10/09	04:32		Unplanned
NAVAJO 2	03/02/09	11:36		03/05/09	17:24		Unplanned
NAVAJO 3	03/01/09	00:00	(1)	03/28/09	15:32		Planned
	03/29/09	00:23		03/29/09	22:29		Planned
	03/31/09	07:18		04/01/09	00:00	(2)	Unplanned
OCOTILLO CT1	03/11/09	15:30		03/13/09	17:30		Unplanned
	03/27/09	07:15		03/27/09	15:40		Unplanned
OCOTILLO CT2	03/11/09	15:30		03/23/09	14:35		Unplanned
	03/26/09	06:00		04/01/09	00:00	(2)	Planned
OCOTILLO ST1	03/01/09	00:00	(1)	04/01/09	00:00	(2)	Planned
OCOTILLO ST2	03/02/09	00:00		04/01/09	00:00	(2)	Planned
PALO VERDE 1	03/26/09	23:26		03/29/09	04:13		Unplanned
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	03/31/09	04:08		03/31/09	05:11		Unplanned
REDHAWK CT1B	03/15/09	07:17		03/15/09	15:37		Unplanned
	03/31/09	04:08		03/31/09	05:11		Unplanned
REDHAWK ST1	03/31/09	04:08		03/31/09	05:11		Unplanned
REDHAWK CT2A	03/20/09	23:01		03/21/09	04:55		Unplanned
REDHAWK CT2B	03/23/09	09:57		03/24/09	08:34		Unplanned
REDHAWK ST2	No Outages						
SAGUARO ST1	03/02/09	00:01		03/31/09	19:00		Planned
SAGUARO ST2	03/01/09	00:00	(1)	03/07/09	16:36		Planned
SAGUARO CT1	03/27/09	06:09		03/27/09	08:30		Unplanned
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SUNDANCE 1	03/09/09	06:00		03/16/09	22:04		Planned
SUNDANCE 2	03/09/09	06:00		03/16/09	22:04		Planned
SUNDANCE 3	03/16/09	13:30		03/16/09	22:04		Unplanned
SUNDANCE 4	03/16/09	13:30		03/16/09	22:04		Unplanned
SUNDANCE 5	03/16/09	13:30		03/16/09	22:04		Unplanned
SUNDANCE 6	03/16/09	13:30		03/16/09	22:04		Unplanned
SUNDANCE 7	03/23/09	15:00		03/23/09	18:20		Unplanned
	03/27/09	05:49		03/27/09	12:51		Unplanned
SUNDANCE 8	No Outages						
SUNDANCE 9	No Outages						
SUNDANCE 10	No Outages						
WEST PHOENIX CC1	03/20/09	14:56		03/20/09	17:24		Unplanned
WEST PHOENIX CC2	03/01/09	00:00	(1)	03/02/09	19:00		Unplanned
	03/20/09	14:56		03/20/09	17:24		Unplanned
WEST PHOENIX CC3	No Outages						
WEST PHOENIX CC4	03/02/09	00:00		03/13/09	06:00		Planned
	03/20/09	06:27		03/20/09	08:01		Unplanned
	03/20/09	09:22		03/20/09	11:00		Unplanned
WEST PHOENIX CT5A	No Outages						
WEST PHOENIX CT5B	03/05/09	04:35		03/05/09	06:19		Unplanned
	03/27/09	05:06		03/27/09	07:00		Unplanned
WEST PHOENIX ST5	No Outages						
WEST PHOENIX CT1	03/01/09	00:00	(1)	04/01/09	00:00	(2)	Planned
WEST PHOENIX CT2	No Outages						
YUCCA CT1	03/01/09	00:00	(1)	03/02/09	17:20		Planned
	03/05/09	08:00		03/05/09	17:42		Maintenance
	03/10/09	10:45		03/10/09	15:17		Maintenance
YUCCA CT2	03/01/09	00:00	(1)	03/02/09	17:20		Planned
	03/05/09	08:00		03/05/09	17:42		Maintenance
	03/10/09	10:45		03/10/09	15:17		Maintenance
YUCCA CT3	03/01/09	00:00	(1)	03/12/09	16:15		Planned
YUCCA CT4	No Outages						
YUCCA CT5	03/28/09	07:00		03/28/09	11:10		Maintenance
YUCCA CT6	No Outages						

(1) Designations of 03/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 04/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
APRIL 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	04/10/09	22:38		05/01/09	00:00	(2)	Planned
CHOLLA 2	04/01/09	00:58		04/05/09	08:08		Unplanned
	04/08/09	13:44		04/08/09	14:45		Unplanned
	04/18/09	16:17		04/20/09	07:01		Unplanned
CHOLLA 3	04/01/09	00:00	(1)	05/01/09	00:00	(2)	Planned
FOUR CORNERS 1	04/03/09	20:52		04/04/09	08:04		Unplanned
	04/25/09	01:10		04/26/09	13:07		Unplanned
FOUR CORNERS 2	04/17/09	21:14		04/18/09	10:08		Unplanned
	04/25/09	01:40		04/26/09	03:02		Unplanned
FOUR CORNERS 3	04/02/09	08:23		04/02/09	21:05		Unplanned
	04/06/09	10:32		04/06/09	13:15		Unplanned
	04/23/09	13:32		04/23/09	19:12		Unplanned
FOUR CORNERS 4	04/23/09	01:15		04/23/09	04:33		Unplanned
FOUR CORNERS 5	04/07/09	00:07		04/07/09	15:45		Unplanned
	04/23/09	22:52		04/24/09	20:21		Unplanned
	04/25/09	23:45		04/26/09	13:55		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	04/05/09	10:48		04/08/09	09:13		Unplanned
	04/08/09	09:13		04/09/09	03:25		Unplanned
	04/09/09	03:25		04/09/09	10:14		Unplanned
NAVAJO 3	04/01/09	00:00	(1)	04/05/09	23:13		Unplanned
	04/06/09	01:33		04/06/09	04:18		Unplanned
	04/11/09	18:47		04/11/09	22:18		Unplanned
	04/23/09	23:39		04/25/09	01:05		Unplanned
	04/25/09	01:05		04/26/09	04:40		Unplanned
OCOTILLO ST1	04/01/09	00:00	(1)	05/01/09	00:00	(2)	Planned
OCOTILLO ST2	04/01/09	00:00	(1)	04/25/09	17:00		Planned
	04/30/09	16:00		04/30/09	20:00		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	04/01/09	00:00	(1)	05/01/09	00:00	(2)	Planned
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	04/03/09	23:34		05/01/09	00:00	(2)	Planned
REDHAWK CT1A	04/05/09	19:05		04/05/09	20:30		Unplanned
REDHAWK CT1B	No Outages						
REDHAWK ST1	No Outages						
REDHAWK CT2A	04/04/09	01:01		04/05/09	13:00		Unplanned
	04/06/09	09:54		04/14/09	22:20		Unplanned
	04/21/09	00:18		04/21/09	20:52		Unplanned
REDHAWK CT2B	04/04/09	01:05		04/05/09	13:00		Unplanned
	04/06/09	09:54		04/14/09	22:20		Unplanned
	04/21/09	00:18		04/21/09	23:32		Unplanned
REDHAWK ST2	04/03/09	18:00		05/01/09	00:00	(2)	Unplanned
SAGUARO ST1	04/07/09	07:00		04/10/09	16:20		Maintenance
SAGUARO ST2	04/10/09	15:41		04/11/09	17:00		Maintenance
	04/26/09	03:45		04/26/09	05:00		Unplanned
SAGUARO CT1	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
APRIL 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SAGUARO CT2	04/10/09	15:48		04/11/09	17:00		Maintenance
SAGUARO CT3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
SUNDANCE 1	No Outages						
SUNDANCE 2	No Outages						
SUNDANCE 3	No Outages						
SUNDANCE 4	No Outages						
SUNDANCE 5	No Outages						
SUNDANCE 6	No Outages						
SUNDANCE 7	No Outages						
SUNDANCE 8	No Outages						
SUNDANCE 9	No Outages						
SUNDANCE 10	No Outages						
WEST PHOENIX CC1	No Outages						
WEST PHOENIX CC2	04/23/09	06:00		04/23/09	09:11		Unplanned
WEST PHOENIX CC3	No Outages						
WEST PHOENIX CC4	04/05/09	20:12		04/06/09	10:45		Unplanned
	04/07/09	07:39		04/07/09	09:00		Unplanned
	04/13/09	04:00		04/13/09	08:15		Unplanned
WEST PHOENIX CT5A	04/04/09	00:00		04/26/09	00:00		Planned
	04/26/09	00:00		05/01/09	00:00	(2)	Unplanned
WEST PHOENIX CT5B	04/04/09	00:00		04/26/09	00:00		Planned
	04/26/09	00:00		05/01/09	00:00	(2)	Unplanned
WEST PHOENIX ST5	04/04/09	00:00		04/26/09	00:00		Planned
	04/26/09	00:00		05/01/09	00:00	(2)	Unplanned
WEST PHOENIX CT1	04/01/09	00:00	(1)	05/01/09	00:00	(2)	Planned
WEST PHOENIX CT2	No Outages						
YUCCA CT1	No Outages						
YUCCA CT2	No Outages						
YUCCA CT3	04/21/09	18:28		04/21/09	20:21		Unplanned
YUCCA CT4	No Outages						
YUCCA CT5	04/19/09	13:08		04/22/09	18:14		Unplanned
	04/29/09	00:00		04/29/09	08:56		Unplanned
YUCCA CT6	04/21/09	06:00		04/22/09	18:14		Unplanned
	04/29/09	00:00		04/29/09	09:37		Unplanned

(1) Designations of 04/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 05/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MAY 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	05/01/09	00:00	(1)	05/30/09	07:39		Planned
	05/30/09	13:21		05/30/09	16:35		Unplanned
	05/30/09	16:50		05/30/09	18:20		Unplanned
	05/30/09	19:14		05/30/09	21:03		Unplanned
	05/31/09	04:03		05/31/09	05:37		Unplanned
	05/31/09	15:03		06/01/09	00:00	(2)	Unplanned
CHOLLA 2	No Outages						
CHOLLA 3	05/01/09	00:00	(1)	05/15/09	17:11		Planned
	05/15/09	23:05		05/16/09	00:31		Unplanned
	05/19/09	17:26		05/20/09	03:06		Unplanned
	05/20/09	16:40		05/21/09	23:50		Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	05/01/09	09:27		05/01/09	14:53		Unplanned
	05/07/09	07:12		05/11/09	10:20		Unplanned
FOUR CORNERS 5	05/09/09	01:44		05/16/09	16:20		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	No Outages						
NAVAJO 3	No Outages						
OCOTILLO ST1	05/01/09	00:00	(1)	06/01/09	00:00	(2)	Planned
OCOTILLO ST2	05/02/09	16:50		05/02/09	19:02		Unplanned
	05/03/09	11:12		05/03/09	12:42		Unplanned
	05/06/09	17:10		05/06/09	20:38		Unplanned
	05/17/09	08:17		05/18/09	15:32		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	05/01/09	00:00	(1)	05/09/09	15:00		Planned
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	05/01/09	00:00	(1)	05/18/09	00:00		Planned
	05/18/09	00:00		05/27/09	17:53		Planned
	05/28/09	00:36		05/28/09	01:37		Planned
REDHAWK CT1A	05/27/09	23:28		05/28/09	06:23		Unplanned
	05/30/09	18:05		06/01/09	00:00	(2)	Maintenance
REDHAWK CT1B	05/16/09	23:22		05/17/09	02:55		Unplanned
	05/30/09	18:59		06/01/09	00:00	(2)	Maintenance
REDHAWK ST1	05/08/09	00:57		05/08/09	01:03		Unplanned
	05/30/09	19:01		06/01/09	00:00	(2)	Maintenance
REDHAWK CT2A	05/18/09	10:10		05/24/09	15:58		Unplanned
REDHAWK CT2B	05/18/09	10:10		05/24/09	15:58		Unplanned
	05/25/09	15:41		05/27/09	18:43		Unplanned
	05/27/09	22:39		05/29/09	00:00		Unplanned
REDHAWK ST2	05/01/09	00:00	(1)	05/24/09	15:58		Unplanned
	05/24/09	21:20		05/25/09	15:10		Unplanned
	05/25/09	23:14		05/29/09	20:44		Unplanned
	05/29/09	21:15		05/30/09	00:00		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MAY 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SAGUARO ST1	05/06/09	12:45		05/07/09	11:47		Unplanned
	05/20/09	05:23		05/20/09	11:51		Unplanned
SAGUARO ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
SUNDANCE 1	No Outages						
SUNDANCE 2	No Outages						
SUNDANCE 3	05/27/09	09:58		05/27/09	13:42		Unplanned
SUNDANCE 4	No Outages						
SUNDANCE 5	05/08/09	06:20		05/08/09	08:10		Unplanned
	05/08/09	18:13		05/09/09	02:02		Unplanned
SUNDANCE 6	05/08/09	06:20		05/08/09	08:10		Unplanned
SUNDANCE 7	05/05/09	20:00		05/05/09	21:00		Unplanned
SUNDANCE 8	05/05/09	20:00		05/05/09	21:00		Unplanned
SUNDANCE 9	No Outages						
SUNDANCE 10	No Outages						
WEST PHOENIX CC1	No Outages						
WEST PHOENIX CC2	05/04/09	08:16		05/04/09	10:17		Unplanned
	05/18/09	15:33		05/19/09	11:30		Unplanned
	05/19/09	12:57		05/21/09	13:45		Unplanned
WEST PHOENIX CC3	05/14/09	10:58		05/14/09	13:41		Unplanned
WEST PHOENIX CC4	No Outages						
WEST PHOENIX CT5A	05/01/09	00:00	(1)	05/17/09	06:00		Unplanned
	05/27/09	08:20		05/30/09	18:08		Unplanned
WEST PHOENIX CT5B	05/01/09	00:00	(1)	05/20/09	15:20		Unplanned
	05/20/09	19:17		05/21/09	16:31		Unplanned
	05/21/09	18:15		05/22/09	00:00		Unplanned
	05/24/09	06:30		05/24/09	10:20		Unplanned
	05/27/09	08:20		05/30/09	18:08		Unplanned
WEST PHOENIX ST5	05/01/09	00:00	(1)	05/18/09	21:11		Unplanned
	05/20/09	15:26		05/20/09	17:33		Unplanned
	05/22/09	07:23		05/22/09	15:00		Unplanned
	05/22/09	15:42		05/22/09	18:00		Unplanned
	05/22/09	18:37		05/22/09	19:58		Unplanned
	05/24/09	13:21		05/24/09	19:30		Unplanned
	05/27/09	08:00		05/30/09	18:08		Unplanned
	05/31/09	02:29		05/31/09	16:00		Unplanned
	05/31/09	21:45		05/31/09	22:45		Unplanned
WEST PHOENIX CT1	05/01/09	00:00	(1)	06/01/09	00:00	(2)	Planned
WEST PHOENIX CT2	05/04/09	13:15		05/06/09	09:00		Unplanned
	05/19/09	10:53		05/19/09	13:18		Unplanned
YUCCA CT1	05/08/09	20:45		05/09/09	10:00		Unplanned
YUCCA CT2	No Outages						
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						
YUCCA CT5	05/04/09	00:00		05/07/09	21:00		Planned
	05/10/09	07:24		05/10/09	10:00		Maintenance

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MAY 2009

Plant and Unit	Outage Start: Date	/ Time	Outage End: Date	/ Time	Description (3)
YUCCA CT6	05/04/09	00:00	05/07/09	21:00	Planned
	05/08/09	08:11	05/10/09	20:55	Unplanned
	05/14/09	17:37	05/14/09	18:47	Unplanned
	05/16/09	21:54	05/16/09	23:30	Unplanned

(1) Designations of 05/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 06/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	06/01/09	00:00	(1)	06/01/09	17:52		Unplanned
	06/01/09	18:18		06/02/09	03:54		Unplanned
	06/03/09	03:47		06/05/09	11:59		Unplanned
CHOLLA 2	No Outages						
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	06/24/09	06:21		06/27/09	05:37		Unplanned
	06/30/09	08:26		07/01/09	00:00	(2)	Unplanned
FOUR CORNERS 2	06/02/09	02:05		06/05/09	08:36		Unplanned
	06/30/09	05:26		07/01/09	00:00	(2)	Unplanned
FOUR CORNERS 3	06/05/09	07:57		06/08/09	22:35		Unplanned
	06/09/09	02:50		06/09/09	03:50		Unplanned
FOUR CORNERS 4	06/04/09	01:02		06/06/09	05:02		Unplanned
	06/22/09	23:16		06/24/09	02:44		Unplanned
	06/24/09	11:31		06/24/09	19:58		Unplanned
FOUR CORNERS 5	No Outages						
NAVAJO 1	06/13/09	00:40		06/15/09	07:28		Unplanned
	06/16/09	17:07		06/16/09	19:31		Unplanned
NAVAJO 2	06/22/09	08:03		06/22/09	09:26		Unplanned
NAVAJO 3	06/06/09	00:42		06/09/09	13:33		Maintenance
	06/09/09	13:51		06/09/09	15:54		Unplanned
	06/09/09	17:00		06/09/09	18:28		Unplanned
	06/10/09	15:15		06/10/09	16:34		Unplanned
	06/10/09	18:21		06/13/09	00:09		Unplanned
OCOTILLO ST1	06/01/09	00:00	(1)	06/29/09	20:35		Planned
OCOTILLO ST2	No Outages						
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	06/01/09	00:00	(1)	06/06/09	22:42		Maintenance
REDHAWK CT1B	06/01/09	00:00	(1)	06/06/09	22:42		Maintenance
	06/07/09	08:47		06/07/09	13:48		Unplanned
REDHAWK ST1	06/01/09	00:00	(1)	06/06/09	22:42		Maintenance
REDHAWK CT2A	No Outages						
REDHAWK CT2B	No Outages						
REDHAWK ST2	No Outages						
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SAGUARO CT3	06/15/09	08:00		06/15/09	10:55		Unplanned
SUNDANCE 1	No Outages						
SUNDANCE 2	No Outages						
SUNDANCE 3	No Outages						
SUNDANCE 4	No Outages						
SUNDANCE 5	06/17/09	15:30		06/17/09	17:00		Unplanned
SUNDANCE 6	06/17/09	15:30		06/17/09	18:48		Unplanned
	06/19/09	21:16		06/20/09	01:07		Unplanned
SUNDANCE 7	No Outages						
SUNDANCE 8	No Outages						
SUNDANCE 9	No Outages						
SUNDANCE 10	No Outages						
WEST PHOENIX CC1	06/01/09	16:10		06/01/09	17:10		Unplanned
	06/06/09	19:30		06/07/09	12:00		Unplanned
	06/20/09	04:00		06/21/09	05:27		Maintenance
	06/21/09	05:27		06/22/09	04:18		Unplanned
WEST PHOENIX CC2	06/20/09	04:00		06/21/09	05:27		Maintenance
	06/21/09	05:27		06/22/09	04:18		Unplanned
	06/22/09	14:28		06/22/09	16:39		Unplanned
WEST PHOENIX CC3	06/10/09	00:00		06/11/09	11:30		Maintenance
	06/27/09	06:00		06/27/09	21:00		Maintenance
WEST PHOENIX CC4	06/01/09	10:45		06/01/09	13:49		Unplanned
	06/27/09	10:30		06/27/09	21:45		Unplanned
WEST PHOENIX CT1	06/01/09	00:00	(1)	06/04/09	09:00		Planned
	06/04/09	09:00		06/05/09	16:20		Unplanned
	06/08/09	14:45		06/10/09	15:39		Unplanned
WEST PHOENIX CT2	06/27/09	16:23		07/01/09	00:00	(2)	Unplanned
WEST PHOENIX CT5A	No Outages						
WEST PHOENIX CT5B	No Outages						
WEST PHOENIX ST5	06/02/09	06:50		06/02/09	09:15		Unplanned
	06/13/09	09:11		06/13/09	18:16		Unplanned
	06/26/09	09:55		06/26/09	11:10		Unplanned
	06/27/09	14:29		06/27/09	18:25		Unplanned
	06/28/09	18:56		06/28/09	20:18		Unplanned
YUCCA CT1	No Outages						
YUCCA CT2	No Outages						
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						
YUCCA CT5	06/23/09	08:35		06/23/09	11:20		Maintenance
YUCCA CT6	06/02/09	16:53		06/03/09	13:42		Unplanned
	06/02/09	10:30		06/02/09	16:26		Unplanned

(1) Designations of 06/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 07/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
CHOLLA 1	07/02/09	16:01		07/04/09	02:46	Unplanned
	07/10/09	23:03		07/11/09	17:21	Unplanned
	07/12/09	16:22		07/13/09	10:49	Unplanned
	07/16/09	01:56		07/16/09	14:17	Unplanned
	07/18/09	09:56		07/18/09	14:10	Unplanned
	07/25/09	01:57		07/27/09	02:57	Unplanned
CHOLLA 2	07/06/09	13:22		07/07/09	23:11	Unplanned
	07/08/09	03:03		07/08/09	04:00	Unplanned
	07/30/09	09:51		07/30/09	19:58	Unplanned
CHOLLA 3	07/10/09	23:23		07/16/09	15:20	Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages					
FOUR CORNERS 1	07/01/09	00:00	(1)	07/01/09	05:55	Unplanned
FOUR CORNERS 2	07/01/09	00:00	(1)	07/03/09	03:05	Unplanned
	07/03/09	04:26		07/03/09	06:14	Unplanned
FOUR CORNERS 3	No Outages					
FOUR CORNERS 4	No Outages					
FOUR CORNERS 5	07/14/09	10:00		07/18/09	23:48	Unplanned
	07/19/09	01:05		07/20/09	10:47	Unplanned
	07/20/09	18:50		07/25/09	17:10	Unplanned
NAVAJO 1	No Outages					
NAVAJO 2	No Outages					
NAVAJO 3	07/09/09	20:25		07/14/09	16:06	Maintenance
OCOTILLO ST1	07/05/09	15:28		07/05/09	18:07	Unplanned
	07/10/09	17:48		07/11/09	01:00	Unplanned
	07/22/09	13:28		07/22/09	21:23	Unplanned
	07/26/09	13:00		07/26/09	17:55	Unplanned
OCOTILLO ST2	07/05/09	15:33		07/05/09	16:30	Unplanned
	07/21/09	06:10		07/21/09	14:11	Unplanned
OCOTILLO CT1	07/21/09	06:10		07/21/09	14:11	Unplanned
OCOTILLO CT2	07/27/09	16:16		07/28/09	10:40	Unplanned
PALO VERDE 1	No Outages					
PALO VERDE 2	No Outages					
PALO VERDE 3	No Outages					
REDHAWK CT1A	07/05/09	10:36		07/07/09	21:15	Unplanned
	07/07/09	23:05		07/08/09	01:20	Unplanned
	07/08/09	02:15		07/08/09	07:27	Unplanned
	07/08/09	09:10		07/08/09	20:00	Unplanned
	07/28/09	07:06		07/28/09	08:45	Unplanned
REDHAWK CT1B	No Outages					
REDHAWK ST1	No Outages					
	07/19/09	09:34		07/19/09	20:53	Unplanned
REDHAWK CT2A	No Outages					
REDHAWK CT2B	07/29/09	01:47		07/29/09	03:50	Unplanned
REDHAWK ST2	No Outages					

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
SAGUARO ST1	No Outages					
SAGUARO ST2	No Outages					
SAGUARO CT1	No Outages					
SAGUARO CT2	No Outages					
SAGUARO CT3	No Outages					
SUNDANCE 1	No Outages					
SUNDANCE 2	No Outages					
SUNDANCE 3	No Outages					
SUNDANCE 4	07/12/09	09:30		07/12/09	11:05	Unplanned
SUNDANCE 5	No Outages					
SUNDANCE 6	07/28/09	07:20		07/29/09	17:00	Unplanned
SUNDANCE 7	07/14/09	17:00		07/14/09	19:15	Unplanned
SUNDANCE 8	No Outages					
SUNDANCE 9	No Outages					
SUNDANCE 10	No Outages					
WEST PHOENIX CC1	07/15/09	11:24		07/15/09	13:13	Unplanned
	07/23/09	03:00		07/23/09	21:50	Unplanned
	07/24/09	14:04		07/25/09	09:50	Unplanned
	07/25/09	11:34		07/26/09	16:00	Unplanned
WEST PHOENIX CC2	07/02/09	13:27		07/02/09	14:36	Unplanned
	07/05/09	17:23		07/05/09	18:24	Unplanned
	07/05/09	15:35		07/05/09	17:02	Unplanned
	07/05/09	18:55		07/06/09	08:20	Unplanned
WEST PHOENIX CC3	07/04/09	14:23		07/06/09	12:11	Unplanned
	07/25/09	09:18		07/25/09	12:37	Unplanned
WEST PHOENIX CC4	07/10/09	09:10		07/10/09	11:46	Unplanned
	07/16/09	09:24		07/16/09	13:03	Unplanned
	07/26/09	09:36		07/26/09	11:51	Unplanned
	07/26/09	12:54		07/26/09	20:04	Unplanned
	07/28/09	09:48		07/28/09	11:45	Unplanned
WEST PHOENIX CT5A	No Outages					
WEST PHOENIX CT5B	No Outages					
WEST PHOENIX ST5	07/05/09	09:04		07/05/09	17:23	Unplanned
WEST PHOENIX CT1	07/13/09	09:30		07/13/09	16:10	Unplanned
WEST PHOENIX CT2	07/01/09	00:00	(1)	07/02/09	16:35	Unplanned
YUCCA CT1	07/19/09	18:32		07/25/09	11:30	Unplanned
YUCCA CT2	No Outages					
YUCCA CT3	07/17/09	18:35		07/17/09	19:44	Unplanned
	07/19/09	20:40		07/20/09	13:23	Unplanned
YUCCA CT4	07/21/09	10:55		07/21/09	13:12	Maintenance
YUCCA CT5	07/02/09	20:00		07/03/09	00:18	Maintenance
	07/08/09	05:00		07/08/09	12:38	Maintenance
YUCCA CT6	07/01/09	13:11		07/01/09	14:24	Unplanned
	07/07/09	05:00		07/07/09	14:55	Maintenance
	07/19/09	00:00		07/19/09	08:45	Maintenance

(1) Designations of 07/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 08/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2009

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
CHOLLA 1	08/29/09	00:33	08/29/09	01:57		Unplanned
CHOLLA 2	No Outages					
CHOLLA 3	08/17/09	13:49	08/17/09	16:31		Unplanned
DOUGLAS (FAIRVIEW) 1	08/14/09	12:06	08/14/09	17:10		Unplanned
FOUR CORNERS 1	08/02/09	22:01	08/06/09	13:52		Unplanned
FOUR CORNERS 2	No Outages					
FOUR CORNERS 3	08/12/09	23:10	08/13/09	00:31		Unplanned
	08/13/09	01:21	08/13/09	09:29		Unplanned
FOUR CORNERS 4	08/12/09	01:39	08/13/09	01:18		Unplanned
	08/31/09	00:53	09/01/09	00:00	(2)	Unplanned
FOUR CORNERS 5	No Outages					
NAVAJO 1	08/25/09	23:59	08/26/09	04:54		Unplanned
NAVAJO 2	08/07/09	21:39	08/11/09	07:27		Unplanned
NAVAJO 3	No Outages					
OCOTILLO ST1	08/19/09	08:40	09/01/09	00:00	(2)	Unplanned
OCOTILLO ST2	No Outages					
OCOTILLO CT1	No Outages					
OCOTILLO CT2	08/12/09	12:48	08/13/09	00:00		Unplanned
	08/28/09	15:36	08/28/09	16:52		Unplanned
PALO VERDE 1	No Outages					
PALO VERDE 2	No Outages					
PALO VERDE 3	No Outages					
REDHAWK CT1A	08/07/09	08:35	08/08/09	01:00		Unplanned
	08/14/09	05:33	08/14/09	06:40		Unplanned
REDHAWK CT1B	No Outages					
REDHAWK ST1	No Outages					
REDHAWK CT2A	08/11/09	23:06	08/24/09	15:56		Maintenance
REDHAWK CT2B	No Outages					
REDHAWK ST2	No Outages					
SAGUARO ST1	No Outages					
SAGUARO ST2	No Outages					
SAGUARO CT1	No Outages					
SAGUARO CT2	No Outages					
SAGUARO CT3	No Outages					

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2009

Plant and Unit	Outage Start: Date	/ Time	Outage End: Date	/ Time	Description (3)
SUNDANCE 1	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/31/09	05:38	08/31/09	09:45	Unplanned
SUNDANCE 2	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/31/09	05:38	08/31/09	09:45	Unplanned
SUNDANCE 3	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/31/09	05:38	08/31/09	09:45	Unplanned
SUNDANCE 4	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/31/09	05:38	08/31/09	09:45	Unplanned
SUNDANCE 5	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/12/09	15:40	08/12/09	21:22	Unplanned
	08/31/09	05:38	08/31/09	09:45	Unplanned
SUNDANCE 6	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/31/09	05:38	08/31/09	09:45	Unplanned
SUNDANCE 7	08/07/09	05:05	08/07/09	07:16	Unplanned
SUNDANCE 8	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/12/09	15:34	08/12/09	21:22	Unplanned
SUNDANCE 9	08/07/09	05:05	08/07/09	07:16	Unplanned
	08/14/09	15:45	08/14/09	17:53	Unplanned
SUNDANCE 10	08/05/09	15:29	08/08/09	15:28	Unplanned
	08/31/09	05:38	08/31/09	09:45	Unplanned
WEST PHOENIX CC1	No Outages				
WEST PHOENIX CC2	No Outages				
WEST PHOENIX CC3	08/12/09	13:06	08/12/09	20:30	Unplanned
WEST PHOENIX CC4	08/14/09	00:00	08/14/09	22:00	Maintenance
	08/15/09	09:13	08/15/09	10:40	Unplanned
	08/23/09	06:00	08/23/09	08:00	Maintenance
WEST PHOENIX CT1	No Outages				
WEST PHOENIX CT2	08/12/09	15:52	08/13/09	10:27	Unplanned
	08/17/09	15:01	08/17/09	18:12	Unplanned
WEST PHOENIX CT5A	08/14/09	08:54	08/14/09	10:30	Unplanned
	08/30/09	09:00	08/30/09	12:02	Unplanned
WEST PHOENIX CT5B	08/14/09	09:22	08/14/09	09:24	Unplanned
WEST PHOENIX ST5	No Outages				
YUCCA CT1	No Outages				
YUCCA CT2	No Outages				
YUCCA CT3	No Outages				
YUCCA CT4	08/12/09	14:56	08/12/09	20:32	Unplanned
	08/15/09	02:30	08/15/09	10:50	Maintenance
YUCCA CT5	08/04/09	04:30	08/04/09	09:54	Maintenance
	08/12/09	07:30	08/12/09	09:57	Unplanned
	08/13/09	07:00	08/13/09	09:50	Maintenance
	08/17/09	00:00	08/17/09	19:22	Unplanned
	08/26/09	07:30	08/26/09	11:00	Maintenance
	08/27/09	07:00	08/27/09	11:07	Maintenance
YUCCA CT6	08/02/09	12:06	08/02/09	13:39	Unplanned
	08/13/09	07:00	08/13/09	09:50	Maintenance
	08/16/09	14:17	08/17/09	00:00	Unplanned
	08/23/09	16:02	08/23/09	19:01	Maintenance

(1) Designations of 08/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 09/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	No Outages						
CHOLLA 3	09/29/09	18:48		10/01/09	00:00	(2)	Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	09/14/09	19:10		09/16/09	15:53		Unplanned
FOUR CORNERS 2	09/07/09	07:32		09/10/09	02:51		Unplanned
FOUR CORNERS 3	09/14/09	19:10		09/16/09	01:33		Unplanned
	09/16/09	05:11		09/16/09	06:53		Unplanned
FOUR CORNERS 4	09/01/09	00:00	(1)	09/02/09	10:46		Unplanned
	09/20/09	16:45		09/21/09	09:00		Unplanned
	09/21/09	09:00		09/30/09	23:59		Maintenance
FOUR CORNERS 5	09/20/09	16:45		09/21/09	04:30		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	09/07/09	17:34		09/07/09	22:55		Unplanned
NAVAJO 3	09/03/09	07:48		09/03/09	10:12		Unplanned
	09/08/09	21:32		09/09/09	02:25		Unplanned
OCOTILLO ST1	09/01/09	00:00	(1)	09/01/09	11:20		Unplanned
	09/08/09	08:14		09/08/09	11:31		Unplanned
OCOTILLO ST2	09/08/09	08:14		09/08/09	11:31		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	09/17/09	06:30		09/18/09	10:17		Unplanned
	09/21/09	22:50		09/23/09	03:35		Unplanned
	09/23/09	09:32		09/24/09	23:22		Unplanned
REDHAWK CT1B	09/17/09	06:30		09/18/09	13:17		Unplanned
	09/21/09	23:32		09/23/09	03:35		Unplanned
	09/23/09	09:32		09/24/09	23:22		Unplanned
REDHAWK ST1	09/17/09	06:30		09/18/09	12:35		Unplanned
	09/21/09	23:35		09/23/09	03:35		Unplanned
	09/23/09	09:34		09/24/09	23:22		Unplanned
REDHAWK CT2A	No Outages						
REDHAWK CT2B	09/18/09	20:08		09/20/09	06:59		Unplanned
REDHAWK ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2009

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
SAGUARO ST1	No Outages					
SAGUARO ST2	No Outages					
SAGUARO CT1	No Outages					
SAGUARO CT2	No Outages					
SAGUARO CT3	No Outages					
SUNDANCE 1	No Outages					
SUNDANCE 2	09/04/09	16:20	09/04/09	17:20		Unplanned
SUNDANCE 3	No Outages					
SUNDANCE 4	No Outages					
SUNDANCE 5	No Outages					
SUNDANCE 6	No Outages					
SUNDANCE 7	No Outages					
SUNDANCE 8	No Outages					
SUNDANCE 9	No Outages					
SUNDANCE 10	No Outages					
WEST PHOENIX CC1	No Outages					
WEST PHOENIX CC2	No Outages					
WEST PHOENIX CC3	09/17/09	08:43	09/17/09	10:51		Unplanned
WEST PHOENIX CC4	09/26/09	12:21	09/26/09	19:00		Unplanned
	09/28/09	07:25	09/28/09	11:25		Unplanned
	09/29/09	08:33	10/01/09	00:00	(2)	Unplanned
WEST PHOENIX CT5A	09/05/09	18:16	09/05/09	19:41		Unplanned
	09/18/09	15:49	09/18/09	16:59		Unplanned
	09/18/09	17:20	09/21/09	14:33		Unplanned
WEST PHOENIX CT5B	No Outages					
WEST PHOENIX ST5	No Outages					
WEST PHOENIX CT1	09/23/09	00:00	09/25/09	16:26		Unplanned
WEST PHOENIX CT2	No Outages					
YUCCA CT1	No Outages					
YUCCA CT2	No Outages					
YUCCA CT3	No Outages					
YUCCA CT4	No Outages					
YUCCA CT5	09/04/09	16:47	09/05/09	21:10		Unplanned
	09/25/09	08:00	09/25/09	10:54		Maintenance
	09/30/09	15:58	09/30/09	17:05		Maintenance
YUCCA CT6	09/03/09	14:07	09/03/09	15:13		Unplanned
	09/04/09	16:53	09/05/09	21:10		Maintenance
	09/10/09	16:22	09/11/09	12:17		Unplanned
	09/28/09	17:33	09/28/09	18:57		Unplanned
	09/30/09	09:40	09/30/09	15:31		Maintenance

(1) Designations of 09/01/09 00:00 mean that the outage began in the prior month
(2) Designations of 10/01/09 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	10/03/09	03:27		10/03/09	10:12		Unplanned
	10/14/09	17:09		10/16/09	18:18		Unplanned
	10/24/09	23:59		11/01/09	00:00	(2)	Planned
CHOLLA 3	10/01/09	00:00	(1)	10/01/09	22:24		Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	10/07/09	16:30		10/07/09	21:41		Unplanned
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	10/09/09	21:59		10/11/09	06:35		Unplanned
FOUR CORNERS 4	10/16/09	22:51		10/18/09	10:13		Unplanned
FOUR CORNERS 5	10/09/09	10:01		10/11/09	22:44		Unplanned
	10/20/09	05:24		10/30/09	00:00		Planned
	10/30/09	00:00		10/31/09	11:38		Planned
NAVAJO 1	10/25/09	00:16		10/26/09	21:30		Unplanned
	10/26/09	21:30		10/28/09	17:34		Unplanned
NAVAJO 2	10/20/09	18:46		10/20/09	22:04		Unplanned
	10/31/09	23:00		11/01/09	00:00	(2)	Unplanned
NAVAJO 3	10/06/09	23:36		10/08/09	22:11		Unplanned
	10/09/09	02:00		10/09/09	08:35		Unplanned
	10/09/09	11:36		10/10/09	03:49		Unplanned
	10/10/09	11:35		10/29/09	13:02		Unplanned
	10/29/09	13:49		11/01/09	00:00	(2)	Unplanned
OCOTILLO ST1	No Outages						
OCOTILLO ST2	No Outages						
OCOTILLO CT1	10/26/09	13:20		10/28/09	13:32		Unplanned
OCOTILLO CT2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	10/03/09	00:00		11/01/09	00:00	(2)	Planned
PALO VERDE 3	No Outages						
REDHAWK CT1A	No Outages						
REDHAWK CT1B	No Outages						
REDHAWK CT2A	No Outages						
REDHAWK CT2B	No Outages						
REDHAWK ST1	No Outages						
REDHAWK ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	10/19/09	00:01		10/21/09	14:53		Planned
SUNDANCE 1	10/25/09	14:33		10/26/09	14:00		Unplanned
	10/27/09	18:20		10/27/09	19:19		Unplanned
SUNDANCE 2	10/27/09	18:20		10/27/09	19:19		Unplanned
SUNDANCE 3	10/12/09	06:16		10/20/09	23:55		Planned
SUNDANCE 4	10/12/09	06:16		10/20/09	23:55		Planned
SUNDANCE 5	No Outages						
SUNDANCE 6	No Outages						
SUNDANCE 7	No Outages						
SUNDANCE 8	No Outages						
SUNDANCE 9	No Outages						
SUNDANCE 10	No Outages						
WEST PHOENIX CC1	10/15/09	13:59		10/15/09	16:39		Unplanned
	10/15/09	12:25		10/15/09	13:55		Unplanned
WEST PHOENIX CC2	10/12/09	00:00		11/01/09	00:00	(2)	Maintenance
WEST PHOENIX CC3	10/26/09	00:01		11/01/09	00:00	(2)	Planned
WEST PHOENIX CC4	10/01/09	00:00	(1)	10/02/09	22:30		Unplanned
	10/22/09	01:50		10/22/09	12:00		Unplanned
WEST PHOENIX CT5A	10/01/09	10:00		10/02/09	16:00		Maintenance
	10/29/09	08:42		10/29/09	10:07		Unplanned
	10/29/09	06:26		10/29/09	07:57		Unplanned
WEST PHOENIX CT5B	No Outages						
WEST PHOENIX ST5	10/01/09	13:25		10/01/09	19:06		Unplanned
	10/16/09	14:38		10/16/09	15:50		Unplanned
WEST PHOENIX CT1	10/06/09	01:00		10/14/09	16:00		Unplanned
WEST PHOENIX CT2	10/05/09	01:00		10/11/09	00:00		Planned
	10/11/09	00:00		10/15/09	08:20		Unplanned
YUCCA CT1	No Outages						
YUCCA CT2	10/07/09	06:47		10/07/09	07:44		Maintenance
YUCCA CT3	10/16/09	15:10		10/17/09	11:55		Unplanned
YUCCA CT4	No Outages						
YUCCA CT5	10/20/09	09:00		10/22/09	17:57		Maintenance
	10/30/09	07:00		10/30/09	13:25		Maintenance
YUCCA CT6	10/20/09	09:00		10/22/09	21:48		Maintenance
	10/29/09	07:15		10/29/09	08:50		Unplanned
	10/30/09	07:00		10/30/09	13:25		Maintenance

(1) Designations of 10/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 11/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	11/01/09	00:00	(1)	11/04/09	08:50		Planned
	11/04/09	11:22		11/04/09	18:46		Unplanned
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	11/16/09	00:01		11/18/09	10:15		Maintenance
	11/18/09	10:15		11/21/09	09:49		Unplanned
FOUR CORNERS 1	11/12/09	17:37		11/17/09	00:52		Unplanned
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	11/09/09	23:59		11/13/09	01:54		Unplanned
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	11/27/09	23:45		11/28/09	13:20		Unplanned
	11/28/09	18:23		11/29/09	06:59		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	11/02/09	04:00		11/03/09	03:25		Unplanned
	11/03/09	03:25		11/03/09	15:42		Unplanned
	11/18/09	10:32		11/20/09	19:12		Unplanned
NAVAJO 3	11/04/09	12:25		11/04/09	13:50		Unplanned
	11/15/09	21:33		11/16/09	02:15		Unplanned
	11/16/09	02:15		11/16/09	04:49		Unplanned
OCOTILLO ST1	11/02/09	06:00		12/01/09	00:00	(2)	Planned
OCOTILLO ST2	No Outages						
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	11/01/09	00:00	(1)	12/01/09	00:00	(2)	Planned
PALO VERDE 3	No Outages						
REDHAWK CT1A	11/13/09	22:42		11/23/09	00:00		Maintenance
	11/23/09	00:00		12/01/09	00:00	(2)	Unplanned
REDHAWK CT1B	11/02/09	03:47		11/02/09	07:18		Unplanned
	11/13/09	23:17		11/23/09	00:00		Maintenance
	11/23/09	00:00		12/01/09	00:00	(2)	Unplanned
REDHAWK ST1	11/13/09	23:20		11/23/09	00:00		Maintenance
	11/23/09	00:00		12/01/09	00:00	(2)	Unplanned
REDHAWK CT2A	No Outages						
REDHAWK CT2B	No Outages						
REDHAWK ST2	No Outages						
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SUNDANCE 1	11/07/09	23:59		11/08/09	07:10		Unplanned
	11/10/09	10:20		11/10/09	13:30		Unplanned
SUNDANCE 2	11/07/09	23:59		11/08/09	07:10		Unplanned
	11/10/09	10:20		11/10/09	13:30		Unplanned
	11/20/09	13:45		11/21/09	05:30		Unplanned
SUNDANCE 3	11/07/09	23:59		11/08/09	07:10		Unplanned
	11/10/09	10:20		11/10/09	13:30		Unplanned
SUNDANCE 4	11/07/09	23:59		11/08/09	07:10		Unplanned
	11/10/09	10:20		11/10/09	13:30		Unplanned
SUNDANCE 5	11/02/09	00:01		11/10/09	20:55		Planned
SUNDANCE 6	11/02/09	00:01		11/10/09	20:55		Planned
SUNDANCE 7	11/07/09	23:59		11/08/09	07:10		Unplanned
SUNDANCE 8	11/07/09	23:59		11/08/09	07:10		Unplanned
SUNDANCE 9	11/07/09	23:59		11/08/09	07:10		Unplanned
SUNDANCE 10	11/07/09	23:59		11/08/09	07:10		Unplanned
WEST PHOENIX CC1	11/12/09	05:00		11/13/09	18:41		Planned
	11/13/09	18:41		11/14/09	21:26		Unplanned
WEST PHOENIX CC2	11/01/09	00:00	(1)	12/01/09	00:00	(2)	Maintenance
WEST PHOENIX CC3	11/01/09	00:00	(1)	11/06/09	19:30		Planned
	11/08/09	18:02		11/10/09	21:00		Unplanned
WEST PHOENIX CC4	11/24/09	21:38		12/01/09	00:00	(2)	Maintenance
WEST PHOENIX CT5A	11/02/09	04:45		11/06/09	03:30		Unplanned
	11/26/09	12:37		11/29/09	22:03		Unplanned
WEST PHOENIX CT5B	11/02/09	23:17		11/07/09	23:10		Unplanned
	11/16/09	13:05		11/16/09	14:30		Unplanned
	11/26/09	12:37		11/29/09	22:03		Unplanned
WEST PHOENIX ST5	11/02/09	23:09		11/06/09	03:30		Unplanned
	11/08/09	15:07		11/09/09	02:20		Unplanned
	11/11/09	02:08		11/13/09	19:30		Unplanned
	11/17/09	05:52		11/19/09	22:35		Unplanned
	11/26/09	07:32		11/29/09	22:03		Unplanned
WEST PHOENIX CT1	No Outages						
WEST PHOENIX CT2	No Outages						
YUCCA CT1	No Outages						
YUCCA CT2	No Outages						
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						
YUCCA CT5	11/16/09	13:38		11/16/09	15:02		Maintenance
YUCCA CT6	11/23/09	18:12		11/23/09	19:12		Unplanned

(1) Designations of 11/01/09 00:00 mean that the outage began in the prior month

(2) Designations of 12/01/09 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	12/22/09	21:28		12/27/09	19:14		Unplanned
	12/27/09	20:38		12/27/09	23:20		Unplanned
	12/27/09	23:29		12/28/09	01:19		Unplanned
CHOLLA 2	No Outages						
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	12/22/09	22:30		12/23/09	17:24		Unplanned
	12/27/09	18:28		12/28/09	01:50		Unplanned
	12/30/09	12:53		12/31/09	15:37		Unplanned
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	12/18/09	23:00		12/22/09	06:58		Unplanned
	12/25/09	07:45		12/25/09	12:34		Unplanned
FOUR CORNERS 3	12/08/09	08:10		12/08/09	22:22		Unplanned
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	12/17/09	19:17		12/20/09	04:09		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	No Outages						
NAVAJO 3	No Outages						
OCOTILLO ST1	12/01/09	00:00	(1)	12/11/09	18:54		Maintenance
	12/14/09	17:00		12/18/09	19:26		Unplanned
OCOTILLO ST2	12/09/09	06:39		12/09/09	18:58		Unplanned
	12/10/09	16:27		12/12/09	16:45		Unplanned
OCOTILLO CT1	12/14/09	10:25		12/18/09	17:45		Planned
OCOTILLO CT2	12/14/09	10:25		12/18/09	17:45		Maintenance
PALO VERDE 1	No Outages						
PALO VERDE 2	12/01/09	00:00	(1)	12/02/09	12:43		Planned
	12/12/09	00:25		12/14/09	04:53		Maintenance
PALO VERDE 3	12/03/09	04:31		12/09/09	18:19		Unplanned
REDHAWK CT1A	12/01/09	00:00	(1)	12/18/09	08:41		Unplanned
	12/27/09	07:48		12/27/09	08:55		Unplanned
	12/30/09	04:20		01/01/10	00:00	(2)	Unplanned
REDHAWK CT1B	12/01/09	00:00	(1)	12/01/09	19:36		Unplanned
	12/30/09	04:20		01/01/10	00:00	(2)	Unplanned
REDHAWK ST1	12/01/09	00:00	(1)	12/18/09	18:07		Unplanned
	12/30/09	04:20		01/01/10	00:00	(2)	Unplanned
REDHAWK CT2A	12/27/09	06:19		12/27/09	08:46		Unplanned
	12/30/09	06:58		12/30/09	10:12		Unplanned
REDHAWK CT2B	12/22/09	15:15		12/23/09	03:30		Unplanned
	12/30/09	06:47		12/30/09	07:52		Unplanned
	12/30/09	08:01		12/30/09	19:54		Unplanned
	12/30/09	20:13		12/30/09	22:39		Unplanned
REDHAWK ST2	12/21/09	05:36		12/21/09	08:12		Unplanned
	12/21/09	21:12		12/22/09	03:00		Unplanned
	12/22/09	07:53		12/22/09	15:22		Unplanned
	12/30/09	06:58		12/30/09	10:12		Unplanned
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	12/03/09	06:43		12/03/09	08:25		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2009

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SUNDANCE 1	No Outages						
SUNDANCE 2	No Outages						
SUNDANCE 3	No Outages						
SUNDANCE 4	No Outages						
SUNDANCE 5	No Outages						
SUNDANCE 6	No Outages						
SUNDANCE 7	No Outages						
SUNDANCE 8	No Outages						
SUNDANCE 9	No Outages						
SUNDANCE 10	12/03/09	04:54		12/08/09	18:19		Unplanned
WEST PHOENIX CC1	12/11/09	05:33		12/11/09	07:22		Unplanned
	12/19/09	05:30		12/19/09	18:00		Unplanned
WEST PHOENIX CC2	12/01/09	00:00	(1)	12/17/09	16:00		Maintenance
	12/18/09	04:35		12/20/09	23:00		Unplanned
	12/21/09	08:38		12/21/09	10:15		Unplanned
	12/22/09	18:17		12/22/09	21:00		Unplanned
	12/23/09	09:05		12/24/09	15:01		Unplanned
	12/30/09	16:12		12/31/09	10:55		Unplanned
WEST PHOENIX CC3	12/05/09	06:10		12/05/09	08:00		Unplanned
	12/12/09	06:00		12/12/09	14:40		Maintenance
	12/12/09	14:40		12/12/09	18:05		Unplanned
WEST PHOENIX CC4	12/01/09	00:00	(1)	12/03/09	16:22		Maintenance
	12/03/09	19:30		12/04/09	01:49		Unplanned
	12/04/09	04:51		12/04/09	15:35		Unplanned
	12/22/09	22:10		12/23/09	08:00		Unplanned
	12/24/09	03:52		12/24/09	04:16		Unplanned
WEST PHOENIX CT5A	No Outages						
WEST PHOENIX CT5B	No Outages						
WEST PHOENIX ST5	12/07/09	07:04		12/08/09	23:03		
	12/17/09	00:00		12/19/09	16:40		
	12/22/09	17:34		12/22/09	18:07		
	12/24/09	21:50		12/27/09	19:15		
	12/30/09	10:55		12/30/09	11:15		
	12/30/09	12:32		12/30/09	15:20		
	12/31/09	20:15		01/01/10	00:00	(2)	
WEST PHOENIX CT1	12/10/09	14:00		12/17/09	16:09		
WEST PHOENIX CT2	No Outages						
YUCCA CT1	12/03/09	11:00		12/03/09	16:30		
	12/18/09	06:00		12/19/09	15:31		
	12/21/09	12:00		12/21/09	15:31		
YUCCA CT2	12/18/09	06:00		12/19/09	15:31		
	12/21/09	12:00		12/21/09	15:31		
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						
YUCCA CT5	12/11/09	17:10		12/11/09	20:21		
YUCCA CT6	12/06/09	12:45		12/06/09	15:38		

(1) Designations of 12/01/09 00:00 mean that the outage began in the prior month
(2) Designations of 01/01/10 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

(1) Designations of 12/01/09 00:00 mean that the outage began in the prior month
(2) Designations of 01/01/10 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
CHOLLA 1	01/10/10	12:34	01/14/10	11:38		Unplanned
CHOLLA 2	No Outages					
CHOLLA 3	No Outages					
DOUGLAS (FAIRVIEW) 1	No Outages					
FOUR CORNERS 1	01/11/10	23:40	01/13/10	13:37		Unplanned
FOUR CORNERS 2	No Outages					
FOUR CORNERS 3	No Outages					
FOUR CORNERS 4	01/02/10	01:32	01/03/10	04:07		Unplanned
	01/11/10	23:02	02/01/10	00:00	(2)	Planned
FOUR CORNERS 5	No Outages					
NAVAJO 1	No Outages					
NAVAJO 2	01/23/10	00:42	01/24/10	11:52		Unplanned
	01/29/10	22:59	02/01/10	00:00	(2)	Planned
NAVAJO 3	No Outages					
OCOTILLO CT1	No Outages					
OCOTILLO CT2	No Outages					
OCOTILLO ST1	No Outages					
OCOTILLO ST2	No Outages					
PALO VERDE 1	No Outages					
PALO VERDE 2	No Outages					
PALO VERDE 3	No Outages					
REDHAWK CT1A	01/24/10	17:06	01/26/10	20:32		Unplanned
REDHAWK CT1B	01/03/10	17:48	01/03/10	18:07		Unplanned
	01/16/10	16:19	01/16/10	16:38		Unplanned
	01/24/10	01:25	01/27/10	20:26		Unplanned
REDHAWK CT2A	01/09/10	13:42	01/11/10	00:00		Unplanned
REDHAWK CT2B	01/09/10	13:42	01/11/10	00:00		Unplanned
REDHAWK ST1	01/15/10	10:07	01/15/10	10:20		Unplanned
	01/21/10	19:43	02/01/10	00:00	(2)	Unplanned
REDHAWK ST2	01/09/10	13:42	01/11/10	00:00		Unplanned
	01/21/10	17:12	01/24/10	19:30		Unplanned
SAGUARO CT1	No Outages					
SAGUARO CT2	No Outages					
SAGUARO CT3	01/25/10	09:46	02/01/10	00:00	(2)	Unplanned
SAGUARO ST1	No Outages					
SAGUARO ST2	No Outages					

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JANUARY 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
SUNDANCE 1	No Outages					
SUNDANCE 10	No Outages					
SUNDANCE 2	No Outages					
SUNDANCE 3	No Outages					
SUNDANCE 4	No Outages					
SUNDANCE 5	No Outages					
SUNDANCE 6	No Outages					
SUNDANCE 7	No Outages					
SUNDANCE 8	No Outages					
SUNDANCE 9	No Outages					
WEST PHOENIX ST5	01/14/10	14:25	01/17/10	11:00		Unplanned
	01/28/10	08:24	01/31/10	01:00		Unplanned
WEST PHOENIX CC1	No Outages					
WEST PHOENIX CC2	01/13/10	06:34	01/14/10	08:00		Unplanned
WEST PHOENIX CC3	01/08/10	00:00	01/10/10	11:20		Maintenance
	01/28/10	18:38	01/31/10	14:05		Unplanned
WEST PHOENIX CC4	No Outages					
WEST PHOENIX CT1	01/23/10	00:00	01/29/10	15:54		Planned
	01/30/10	17:00	02/01/10	00:00	(2)	Unplanned
WEST PHOENIX CT2	No Outages					
WEST PHOENIX CT5A	01/25/10	08:24	01/25/10	09:00		Unplanned
WEST PHOENIX CT5B	01/10/10	21:16	01/12/10	15:22		Unplanned
	01/12/10	16:34	01/13/10	15:45		Unplanned
	01/26/10	10:45	01/27/10	19:30		Unplanned
YUCCA CT1	No Outages					
YUCCA CT2	01/20/10	22:00	01/22/10	17:05		Unplanned
YUCCA CT3	No Outages					
YUCCA CT4	No Outages					
YUCCA CT5	01/25/10	00:01	01/29/10	17:55		Planned
YUCCA CT6	01/12/10	07:14	01/13/10	13:28		Unplanned
	01/25/10	00:01	01/29/10	17:55		Planned

(1) Designations of 01/01/10 00:00 mean that the outage began in the prior month
(2) Designations of 02/01/10 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	No Outages						
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	02/27/10	00:00		03/01/10	00:00	(2)	Unplanned
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	02/01/10	00:00	(1)	03/01/10	00:00	(2)	Planned
FOUR CORNERS 5	No Outages						
NAVAJO 1	02/12/10	08:32		02/15/10	16:45		Unplanned
	02/15/10	16:45		02/16/10	16:41		Unplanned
	02/16/10	17:26		02/16/10	20:24		Unplanned
	02/17/10	00:45		02/17/10	03:06		Unplanned
	02/17/10	10:15		02/17/10	13:15		Unplanned
	02/20/10	23:34		02/21/10	04:26		Unplanned
NAVAJO 2	01/29/10	22:59		03/01/10	00:00	(2)	Planned
NAVAJO 3	02/09/10	23:09		02/12/10	14:28		Unplanned
	02/12/10	14:28		02/12/10	21:11		Unplanned
	02/12/10	23:56		02/13/10	02:33		Unplanned
	02/15/10	16:39		02/15/10	20:31		Unplanned
	02/26/10	22:07		02/28/10	11:27		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
OCOTILLO ST1	No Outages						
OCOTILLO ST2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	No Outages						
REDHAWK CT1B	02/26/10	13:56		02/26/10	18:24		Unplanned
REDHAWK CT2A	02/12/10	22:27		02/13/10	14:30		Unplanned
	02/15/10	08:39		02/15/10	09:47		Unplanned
REDHAWK CT2B	02/01/10	14:03		02/01/10	15:19		Unplanned
REDHAWK ST1	02/01/10	00:00	(1)	02/15/10	10:22		Unplanned
	02/28/10	00:16		03/01/10	00:00	(2)	Unplanned
REDHAWK ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	02/08/10	00:01		02/12/10	17:00		Planned
SAGUARO CT3	02/01/10	00:00	(1)	02/11/10	15:44		Unplanned
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
FEBRUARY 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SUNDANCE 1 No Outages							
SUNDANCE 10	02/08/10	02:00		02/08/10	03:41		Planned
	02/15/10	11:00		02/15/10	14:10		Planned
SUNDANCE 2 No Outages							
SUNDANCE 3 No Outages							
SUNDANCE 4 No Outages							
SUNDANCE 5 No Outages							
SUNDANCE 6 No Outages							
SUNDANCE 7	02/08/10	02:00		02/16/10	23:45		Planned
SUNDANCE 8	02/08/10	02:00		02/15/10	23:45		Planned
SUNDANCE 9	02/08/10	02:00		02/08/10	03:41		Planned
	02/15/10	11:00		02/15/10	14:10		Planned
WEST PHOENIX ST5	02/19/10	18:29		03/01/10	00:00	(2)	Unplanned
WEST PHOENIX CC1	02/24/10	13:00		02/24/10	19:25		Unplanned
	02/25/10	06:26		02/25/10	08:00		Unplanned
WEST PHOENIX CC2	02/09/10	17:08		02/09/10	22:21		Unplanned
	02/24/10	13:00		02/24/10	19:25		Unplanned
WEST PHOENIX CC3	02/04/10	21:00		02/04/10	23:55		Unplanned
	02/14/10	00:00		02/14/10	13:08		Unplanned
	02/18/10	00:00		02/18/10	21:00		Unplanned
	02/20/10	16:16		02/20/10	17:27		Unplanned
WEST PHOENIX CC4	02/17/10	00:00		02/17/10	21:00		Unplanned
WEST PHOENIX CT1	02/01/10	00:00	(1)	02/02/10	08:52		Unplanned
WEST PHOENIX CT2 No Outages							
WEST PHOENIX CT5A	02/09/10	18:49		02/09/10	22:00		Unplanned
	02/20/10	00:01		03/01/10	00:00	(2)	Planned
WEST PHOENIX CT5B	02/20/10	00:01		03/01/10	00:00	(2)	Planned
YUCCA CT1	02/18/10	10:54		02/24/10	18:55		Unplanned
YUCCA CT2 No Outages							
YUCCA CT3 No Outages							
YUCCA CT4 No Outages							
YUCCA CT5	02/07/10	05:25		02/07/10	07:50		Unplanned
	02/28/10	06:00		03/01/10	00:00	(2)	Planned
YUCCA CT6	02/07/10	05:25		02/07/10	07:50		Unplanned
	02/09/10	20:45		02/11/10	14:11		Unplanned
	02/20/10	10:06		02/21/10	10:30		Unplanned
	02/25/10	05:57		02/25/10	09:51		Unplanned
	02/28/10	06:00		03/01/10	00:00	(2)	Planned

(1) Designations of 02/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 03/01/10 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	03/23/10	01:04		03/23/10	10:11		Unplanned
CHOLLA 2	03/27/10	00:43		03/31/10	05:19		Unplanned
CHOLLA 3	03/05/10	23:50		03/10/10	12:20		Unplanned
DOUGLAS (FAIRVIEW) 1	03/01/10	06:00		03/02/10	17:30		Unplanned
FOUR CORNERS 1	03/01/10	00:00	(1)	03/01/10	00:59		Unplanned
	03/11/10	07:53		03/12/10	10:52		Unplanned
FOUR CORNERS 2	03/01/10	06:43		03/04/10	14:31		Unplanned
	03/11/10	23:48		03/13/10	13:59		Unplanned
FOUR CORNERS 3	03/20/10	23:59		03/24/10	11:03		Unplanned
	03/25/10	05:20		03/25/10	09:13		Unplanned
FOUR CORNERS 4	03/01/10	00:00	(1)	04/01/10	00:00	(2)	Planned
FOUR CORNERS 5	No Outages						
NAVAJO 1	No Outages						
NAVAJO 2	03/01/10	00:00	(1)	04/01/10	00:00	(2)	Planned
NAVAJO 3	03/20/10	00:42		03/23/10	18:33		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	03/08/10	08:02		03/12/10	12:10		Planned
OCOTILLO ST1	No Outages						
OCOTILLO ST2	03/22/10	07:30		04/01/10	00:00	(2)	Planned
PALO VERDE 1	03/07/10	11:17		03/20/10	01:43		Unplanned
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	No Outages						
REDHAWK CT1B	No Outages						
REDHAWK CT2A	03/13/10	00:00		03/19/10	00:00		Planned
	03/19/10	00:00		04/01/10	00:00	(2)	Unplanned
REDHAWK CT2B	03/10/10	20:10		03/10/10	23:50		Unplanned
	03/13/10	00:00		03/19/10	00:00		Planned
	03/19/10	00:00		04/01/10	00:00	(2)	Unplanned
REDHAWK ST1	03/01/10	00:00	(1)	03/03/10	03:16		Unplanned
REDHAWK ST2	03/13/10	00:00		03/19/10	00:00		Planned
	03/19/10	00:00		04/01/10	00:00	(2)	Unplanned
SAGUARO CT1	03/22/10	07:00		03/26/10	15:25		Planned
SAGUARO CT2	No Outages						
SAGUARO CT3	No Outages						
SAGUARO ST1	No Outages						
SAGUARO ST2	03/30/10	00:01		04/01/10	00:00	(2)	Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MARCH 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
SUNDANCE 1	03/14/10	07:30		03/14/10	16:03	Planned
SUNDANCE 10	03/08/10	04:05		03/16/10	23:59	Planned
SUNDANCE 2	03/14/10	07:30		03/14/10	16:03	Planned
SUNDANCE 3	03/14/10	07:30		03/14/10	16:03	Planned
SUNDANCE 4	03/14/10	07:30		03/14/10	16:03	Planned
SUNDANCE 5	03/14/10	07:30		03/14/10	16:03	Planned
SUNDANCE 6	03/14/10	07:30		03/14/10	17:10	Planned
SUNDANCE 7	03/14/10	07:30		03/14/10	16:18	Planned
SUNDANCE 8	03/14/10	07:30		03/14/10	16:18	Planned
SUNDANCE 9	03/08/10	04:05		03/16/10	23:59	Planned
WEST PHOENIX ST5	03/01/10	00:00	(1)	03/06/10	16:39	Planned
WEST PHOENIX CC1	03/02/10	13:30		03/06/10	14:30	Unplanned
WEST PHOENIX CC2	03/02/10	13:30		03/06/10	16:50	Unplanned
WEST PHOENIX CC3	03/02/10	13:50		03/06/10	18:35	Unplanned
	03/30/10	16:34		03/30/10	19:00	Unplanned
WEST PHOENIX CC4	03/02/10	13:30		03/06/10	10:00	Unplanned
WEST PHOENIX CT1	No Outages					
WEST PHOENIX CT2	No Outages					
WEST PHOENIX CT5A	03/01/10	00:00	(1)	03/03/10	16:39	Planned
	03/15/10	17:24		03/15/10	20:40	Unplanned
	03/26/10	01:49		03/26/10	15:39	Unplanned
WEST PHOENIX CT5B	03/01/10	00:00	(1)	03/06/10	16:39	Planned
	03/08/10	01:55		03/08/10	05:05	Unplanned
YUCCA CT1	03/01/10	10:45		03/01/10	16:30	Maintenance
YUCCA CT2	03/01/10	10:45		03/01/10	16:30	Maintenance
YUCCA CT3	03/29/10	09:50		03/29/10	14:50	Unplanned
YUCCA CT4	No Outages					
YUCCA CT5	03/01/10	00:00	(1)	03/06/10	22:00	Planned
YUCCA CT6	03/01/10	00:00	(1)	03/06/10	22:00	Planned
	03/07/10	11:56		03/11/10	17:13	Unplanned

(1) Designations of 03/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 04/01/10 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
APRIL 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	No Outages						
CHOLLA 3	04/06/10	22:18		04/08/10	02:32		Unplanned
DOUGLAS (FAIRVIEW) 1	04/07/10	07:00		04/07/10	12:31		Unplanned
FOUR CORNERS 1	04/03/10	00:00		04/07/10	00:00		Planned
	04/07/10	00:00		04/10/10	08:05		Unplanned
	04/10/10	19:04		04/10/10	20:20		Planned
FOUR CORNERS 2	04/19/10	02:59		05/01/10	00:00	(2)	Planned
FOUR CORNERS 3	No Outages						
FOUR CORNERS 4	04/01/10	00:00	(1)	04/10/10	00:00		Planned
	04/10/10	00:00		04/12/10	15:42		Unplanned
	04/12/10	17:35		04/17/10	16:24		Unplanned
	04/17/10	22:24		04/18/10	01:52		Unplanned
	04/18/10	09:43		04/18/10	13:52		Unplanned
	04/19/10	02:19		04/19/10	20:46		Unplanned
	04/20/10	21:18		04/21/10	09:55		Unplanned
FOUR CORNERS 5	04/13/10	19:00		04/14/10	02:35		Unplanned
	04/13/10	02:08		04/13/10	19:00		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	04/01/10	08:48		04/02/10	07:45		Planned
	04/02/10	10:26		04/05/10	13:43		Planned
	04/05/10	22:54		04/06/10	01:29		Planned
	04/06/10	01:46		04/06/10	14:55		Planned
	04/07/10	15:09		04/07/10	21:32		Unplanned
	04/07/10	09:23		04/07/10	13:09		Unplanned
	04/08/10	00:45		04/08/10	14:04		Unplanned
	04/11/10	17:31		04/11/10	19:32		Unplanned
	04/12/10	06:54		04/12/10	08:44		Unplanned
	04/14/10	21:57		04/15/10	00:13		Unplanned
	04/18/10	00:28		04/21/10	14:40		Planned
NAVAJO 3	04/06/10	08:38		04/07/10	15:01		Unplanned
	04/08/10	04:51		04/10/10	05:15		Unplanned
	04/10/10	05:15		04/12/10	15:15		Unplanned
	04/12/10	15:15		04/17/10	05:38		Unplanned
	04/26/10	19:18		04/28/10	23:37		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	No Outages						
OCOTILLO ST1	No Outages						
OCOTILLO ST2	04/01/10	00:00	(1)	04/16/10	16:30		Planned
OCOTILLO ST2	04/26/10	06:30		04/27/10	09:08		Unplanned
PALO VERDE 1	04/03/10	00:00		05/01/10	00:00	(2)	Planned
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	No Outages						
REDHAWK CT1B	No Outages						
REDHAWK CT2A	04/01/10	00:00	(1)	04/09/10	19:39		Unplanned
REDHAWK CT2B	04/01/10	00:00	(1)	04/10/10	18:09		Unplanned
	04/16/10	05:52		04/17/10	12:25		Unplanned
REDHAWK ST1	No Outages						
REDHAWK ST2	04/01/10	00:00	(1)	04/10/10	02:44		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
APRIL 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SAGUARO CT1	No Outages						
SAGUARO CT2	04/09/10	04:34		04/09/10	06:57		Unplanned
SAGUARO CT3	04/07/10	10:00		04/08/10	15:30		Unplanned
	04/12/10	14:43		04/12/10	17:40		Unplanned
SAGUARO ST1	04/06/10	00:01		04/09/10	23:30		Unplanned
	04/12/10	14:43		04/12/10	17:40		Unplanned
SAGUARO ST2	04/01/10	00:00	(1)	04/02/10	15:25		Unplanned
SAGUARO ST2	04/12/10	14:43		04/12/10	17:40		Unplanned
SUNDANCE 1	04/23/10	14:20		04/23/10	16:25		Unplanned
SUNDANCE 10	04/23/10	14:20		04/23/10	16:25		Unplanned
SUNDANCE 2	04/23/10	14:20		04/23/10	16:25		Unplanned
SUNDANCE 3	04/23/10	14:20		04/23/10	16:25		Unplanned
	04/23/10	08:00		04/23/10	11:00		Maintenance
SUNDANCE 4	04/23/10	14:20		04/23/10	16:25		Unplanned
	04/23/10	11:00		04/23/10	14:20		Maintenance
SUNDANCE 5	04/23/10	14:20		04/23/10	16:25		Unplanned
SUNDANCE 6	04/23/10	14:20		04/23/10	16:25		Unplanned
SUNDANCE 7	04/23/10	14:20		04/23/10	16:25		Unplanned
SUNDANCE 8	04/23/10	14:20		04/23/10	16:25		Unplanned
SUNDANCE 9	04/23/10	14:20		04/23/10	16:25		Unplanned
WEST PHOENIX ST5	04/06/10	04:00		04/06/10	10:42		Unplanned
	04/24/10	00:00		05/01/10	00:00	(2)	Maintenance
WEST PHOENIX CC1	No Outages						
WEST PHOENIX CC2	04/09/10	13:02		05/01/10	00:00	(2)	Unplanned
WEST PHOENIX CC3	No Outages						
WEST PHOENIX CC4	04/19/10	00:00		04/24/10	00:30		Unplanned
WEST PHOENIX CT1	04/05/10	06:00		04/07/10	12:42		Planned
WEST PHOENIX CT2	04/03/10	00:00		04/09/10	18:00		Planned
	04/12/10	19:40		04/13/10	14:53		Unplanned
WEST PHOENIX CT5A	04/06/10	04:00		04/06/10	10:42		Unplanned
	04/24/10	00:00		05/01/10	00:00	(2)	Maintenance
WEST PHOENIX CT5B	04/06/10	04:00		04/06/10	10:42		Unplanned
	04/24/10	00:00		05/01/10	00:00	(2)	Maintenance
YUCCA CT1	No Outages						
YUCCA CT2	No Outages						
YUCCA CT21	No Outages						
YUCCA CT4	04/15/10	00:00		04/15/10	15:33		Unplanned
YUCCA CT5	No Outages						
YUCCA CT6	No Outages						

(1) Designations of 04/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 05/01/10 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MAY 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
CHOLLA 1	No Outages					
CHOLLA 2	05/08/10	05:46		05/08/10	17:43	Unplanned
CHOLLA 3	No Outages					
DOUGLAS (FAIRVIEW) 1	05/17/10	07:00		05/21/10	10:05	Planned
FOUR CORNERS 1	05/30/10	03:23		05/31/10	23:16	Unplanned
FOUR CORNERS 2	05/01/10	00:00	(1)	05/24/10	00:00	Planned
	05/24/10	00:00		05/25/10	23:01	Unplanned
	05/26/10	05:49		05/29/10	04:04	Unplanned
	05/29/10	12:26		05/29/10	15:36	Unplanned
FOUR CORNERS 3	No Outages					
FOUR CORNERS 4	05/03/10	10:24		05/03/10	18:11	Unplanned
FOUR CORNERS 5	No Outages					
NAVAJO 1	No Outages					
NAVAJO 2	05/22/10	00:36		05/28/10	10:48	Unplanned
	05/28/10	13:30		05/28/10	19:54	Unplanned
NAVAJO 3	05/21/10	04:40		05/21/10	07:47	Unplanned
OCOTILLO CT1	05/06/10	07:00		05/06/10	09:00	Unplanned
	05/13/10	09:00		05/13/10	11:00	Maintenance
	05/28/10	20:00		05/29/10	10:20	Unplanned
OCOTILLO CT2	05/06/10	07:00		05/06/10	09:00	Unplanned
	05/13/10	11:00		05/13/10	13:00	Maintenance
OCOTILLO ST1	05/06/10	07:00		05/06/10	09:00	Unplanned
	05/17/10	11:30		05/22/10	16:30	Maintenance
OCOTILLO ST2	05/06/10	07:00		05/06/10	09:00	Unplanned
	05/14/10	13:00		05/14/10	19:05	Unplanned
	05/18/10	16:42		05/19/10	16:00	Maintenance
PALO VERDE 1	05/01/10	00:00	(1)	05/23/10	04:23	Planned
PALO VERDE 2	No Outages					
PALO VERDE 3	No Outages					
REDHAWK CT1A	05/21/10	00:00		05/25/10	09:17	Maintenance
REDHAWK CT1B	No Outages					
REDHAWK CT2A	05/29/10	07:00		05/29/10	22:00	Unplanned
REDHAWK CT2B	05/29/10	07:00		05/29/10	22:00	Unplanned
REDHAWK ST1	No Outages					
REDHAWK ST2	05/29/10	07:00		05/29/10	22:00	Unplanned
SAGUARO CT1	05/13/10	09:00		05/13/10	13:00	Maintenance
	05/14/10	08:30		05/14/10	09:30	Maintenance
	05/19/10	13:40		05/20/10	17:22	Unplanned
SAGUARO CT2	05/13/10	11:00		05/13/10	13:00	Maintenance
SAGUARO CT3	No Outages					
SAGUARO ST1	No Outages					
SAGUARO ST2	No Outages					

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
MAY 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
SUNDANCE 1	No Outages					
SUNDANCE 10	05/12/10	09:43		05/12/10	11:19	Maintenance
SUNDANCE 2	No Outages					
SUNDANCE 3	No Outages					
SUNDANCE 4	No Outages					
SUNDANCE 5	No Outages					
SUNDANCE 6	No Outages					
SUNDANCE 7	No Outages					
SUNDANCE 8	05/11/10	07:30		05/11/10	10:00	Maintenance
SUNDANCE 9	05/11/10	11:45		05/11/10	13:05	Maintenance
WEST PHOENIX ST5	05/01/10	00:00	(1)	05/16/10	14:00	Maintenance
	05/17/10	08:53		05/17/10	10:00	Unplanned
WEST PHOENIX CC1	05/09/10	00:01		05/10/10	21:05	Planned
	05/14/10	12:30		05/15/10	12:15	Unplanned
WEST PHOENIX CC2	05/01/10	00:00	(1)	05/23/10	17:00	Unplanned
	05/31/10	12:01		06/01/10	00:00	Unplanned
WEST PHOENIX CC3	05/06/10	06:00		05/06/10	08:00	Unplanned
WEST PHOENIX CC4	No Outages					
WEST PHOENIX CT1	No Outages					
WEST PHOENIX CT2	05/19/10	17:26		05/20/10	00:00	Unplanned
	05/20/10	00:00		05/20/10	10:50	Unplanned
WEST PHOENIX CT5A	05/01/10	00:00	(1)	05/16/10	17:00	Maintenance
WEST PHOENIX CT5B	05/01/10	00:00	(1)	05/16/10	14:00	Maintenance
YUCCA CT1	No Outages					
YUCCA CT2	No Outages					
YUCCA CT3	No Outages					
YUCCA CT4	No Outages					
YUCCA CT5	05/09/10	07:00		05/09/10	12:40	Maintenance
	05/10/10	11:20		05/13/10	21:52	Unplanned
YUCCA CT6	05/10/10	11:20		05/13/10	21:52	Unplanned

(1) Designations of 05/01/10 00:00 mean that the outage began in the prior month
(2) Designations of 06/01/10 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
CHOLLA 1	06/20/10	02:31	06/23/10	07:52	Unplanned
	06/26/10	20:33	06/26/10	21:51	Unplanned
CHOLLA 2	No Outages				
CHOLLA 3	06/02/10	16:44	06/06/10	14:15	Unplanned
	06/11/10	23:59	06/12/10	01:48	Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages				
FOUR CORNERS 1	No Outages				
FOUR CORNERS 2	No Outages				
FOUR CORNERS 3	06/01/10	13:32	06/04/10	08:40	Unplanned
FOUR CORNERS 4	No Outages				
FOUR CORNERS 5	06/14/10	12:06	06/18/10	22:27	Unplanned
	06/21/10	14:08	06/23/10	07:02	Unplanned
	06/24/10	01:02	06/28/10	07:44	Unplanned
NAVAJO 1	06/07/10	21:15	06/07/10	23:54	Unplanned
	06/14/10	23:47	06/17/10	12:21	Unplanned
NAVAJO 2	06/06/10	19:40	06/08/10	15:01	Unplanned
NAVAJO 3	No Outages				
OCOTILLO CT1	No Outages				
OCOTILLO CT2	06/23/10	12:51	06/24/10	15:00	Unplanned
OCOTILLO ST1	No Outages				
OCOTILLO ST2	No Outages				
PALO VERDE 1	06/18/10	08:07	06/19/10	18:31	Unplanned
PALO VERDE 2	No Outages				
PALO VERDE 3	No Outages				
REDHAWK CT1A	No Outages				
REDHAWK CT1B	No Outages				
REDHAWK CT2A	No Outages				
REDHAWK CT2B	No Outages				
REDHAWK ST1	No Outages				
REDHAWK ST2	No Outages				
SAGUARO CT1	06/03/10	07:00	06/03/10	08:45	Unplanned
SAGUARO CT2	06/03/10	07:00	06/03/10	08:45	Unplanned
SAGUARO CT3	No Outages				
SAGUARO ST1	06/03/10	07:00	06/03/10	08:45	Unplanned
SAGUARO ST2	06/03/10	07:00	06/03/10	08:45	Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JUNE 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SUNDANCE 1	No Outages				
SUNDANCE 10	06/30/10	16:36	06/30/10	20:00	Unplanned
SUNDANCE 2	No Outages				
SUNDANCE 3	No Outages				
SUNDANCE 4	No Outages				
SUNDANCE 5	No Outages				
SUNDANCE 6	No Outages				
SUNDANCE 7	No Outages				
SUNDANCE 8	06/17/10	05:30	06/17/10	08:15	Maintenance
SUNDANCE 9	No Outages				
WEST PHOENIX ST5	06/20/10	14:11	06/20/10	19:40	Unplanned
WEST PHOENIX CC1	06/14/10	09:24	06/14/10	11:00	Unplanned
	06/20/10	02:30	06/20/10	10:22	Unplanned
	06/20/10	15:30	06/20/10	17:32	Unplanned
WEST PHOENIX CC2	06/20/10	02:30	06/20/10	10:22	Unplanned
WEST PHOENIX CC3	No Outages				
WEST PHOENIX CC4	06/06/10	09:32	06/06/10	11:07	Unplanned
WEST PHOENIX CC4	06/24/10	15:12	06/24/10	20:59	Unplanned
	06/29/10	13:37	07/03/10	20:00	Unplanned
WEST PHOENIX CT1	06/23/10	12:54	06/24/10	00:00	Unplanned
WEST PHOENIX CT2	No Outages				
WEST PHOENIX CT5A	No Outages				
WEST PHOENIX CT5B	06/06/10	20:25	06/07/10	16:00	Unplanned
YUCCA CT1	No Outages				
YUCCA CT2	No Outages				
YUCCA CT3	No Outages				
YUCCA CT4	No Outages				
YUCCA CT5	No Outages				
YUCCA CT6	No Outages				

(1) Designations of 06/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 07/01/10 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages					
CHOLLA 2	No Outages					
CHOLLA 3	07/06/10	18:41	07/10/10	00:32		Unplanned
	07/20/10	16:14	07/22/10	22:27		Unplanned
DOUGLAS (FAIRVIEW) 1	No Outages					
FOUR CORNERS 1	07/31/10	03:00	08/01/10	00:00	(2)	Unplanned
FOUR CORNERS 2	07/01/10	03:30	07/03/10	06:24		Unplanned
	07/11/10	22:14	07/14/10	19:00		Unplanned
FOUR CORNERS 3	07/02/10	22:00	07/05/10	06:01		Unplanned
	07/15/10	19:11	07/19/10	04:46		Unplanned
FOUR CORNERS 4	07/17/10	02:39	07/20/10	00:00		Unplanned
	07/20/10	00:00	07/23/10	08:13		Unplanned
	07/23/10	08:23	07/23/10	11:48		Unplanned
	07/23/10	15:16	07/23/10	20:49		Unplanned
	07/28/10	17:49	07/30/10	07:55		Unplanned
	07/30/10	09:57	07/30/10	13:30		Unplanned
FOUR CORNERS 5	07/25/10	22:55	07/31/10	14:27		Unplanned
NAVAJO 1	07/09/10	23:25	07/11/10	15:21		Maintenance
	07/11/10	15:21	07/12/10	16:50		Maintenance
	07/14/10	09:46	07/17/10	00:06		Unplanned
	07/17/10	00:29	07/17/10	21:22		Unplanned
NAVAJO 2	07/30/10	22:58	08/01/10	00:00	(2)	Maintenance
NAVAJO 3	No Outages					
OCOTILLO CT1	07/08/10	09:06	07/08/10	18:20		Unplanned
	07/17/10	09:00	07/17/10	14:40		Unplanned
	07/20/10	14:03	07/21/10	11:09		Unplanned
OCOTILLO CT2	07/01/10	17:11	07/03/10	17:10		Unplanned
	07/14/10	14:27	07/16/10	00:44		Unplanned
OCOTILLO ST1	07/12/10	11:45	07/13/10	06:45		Unplanned
	07/13/10	23:15	07/14/10	02:30		Unplanned
	07/17/10	02:00	07/17/10	08:25		Unplanned
	07/20/10	11:18	07/20/10	19:06		Unplanned
	07/20/10	04:50	07/20/10	09:35		Maintenance
	07/21/10	09:22	07/23/10	17:30		Unplanned
OCOTILLO ST2	07/13/10	23:15	07/20/10	09:35		Unplanned
PALO VERDE 1	No Outages					
PALO VERDE 2	No Outages					
PALO VERDE 3	No Outages					
REDHAWK CT1A	07/24/10	06:00	07/26/10	05:30		Unplanned
REDHAWK CT1B	No Outages					
REDHAWK CT2A	No Outages					
REDHAWK CT2B	No Outages					
REDHAWK ST1	No Outages					
REDHAWK ST2	No Outages					

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
JULY 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
SAGUARO CT1	07/14/10	14:48		07/14/10	16:17	
SAGUARO CT2	07/14/10	14:48		07/14/10	16:47	Maintenance
SAGUARO CT3	07/09/10	09:58		07/09/10	12:10	Unplanned
	07/10/10	15:00		07/10/10	16:17	
SAGUARO ST1	No Outages					
SAGUARO ST2	No Outages					
SUNDANCE 1	No Outages					
SUNDANCE 10	No Outages					
SUNDANCE 2	No Outages					
SUNDANCE 3	No Outages					
SUNDANCE 4	No Outages					
SUNDANCE 5	07/01/10	15:07		07/01/10	22:00	Unplanned
	07/23/10	08:10		07/23/10	10:59	Unplanned
SUNDANCE 6	07/10/10	16:35		07/10/10	19:45	Unplanned
	07/12/10	15:16		07/12/10	18:56	Unplanned
	07/12/10	19:17		07/13/10	09:11	Unplanned
SUNDANCE 7	No Outages					
SUNDANCE 8	No Outages					
SUNDANCE 9	No Outages					
WEST PHOENIX ST5	07/20/10	08:08		7/20/10	17:43	Unplanned
WEST PHOENIX CC1	No Outages					
WEST PHOENIX CC2	07/08/10	14:20		07/08/10	19:53	
	07/14/10	08:20		07/14/10	09:20	
WEST PHOENIX CC3	07/08/10	14:20		07/08/10	22:13	
	07/09/10	12:56		07/09/10	13:46	
	07/09/10	13:58		07/09/10	19:33	
WEST PHOENIX CC4	07/06/10	08:41		07/06/10	11:27	
	07/24/10	12:10		07/24/10	13:04	
WEST PHOENIX CT1	No Outages					
WEST PHOENIX CT2	No Outages					
WEST PHOENIX CT5A	07/20/10	08:17		07/20/10	17:43	
	07/23/10	19:09		07/27/10	09:00	
WEST PHOENIX CT5B	07/01/10	00:00	(1)	07/01/10	09:18	
	07/20/10	06:45		07/20/10	17:43	
	07/30/10	13:22		07/30/10	13:31	
YUCCA CT1	No Outages					
YUCCA CT2	No Outages					
YUCCA CT3	No Outages					
YUCCA CT4	No Outages					
YUCCA CT5	07/08/10	09:20		07/08/10	13:05	
YUCCA CT6	No Outages					

(1) Designations of 07/01/10 00:00 mean that the outage began in the prior month
(2) Designations of 08/01/10 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
CHOLLA 1	28-Aug-10	22:30	30-Aug-10	09:08	Unplanned
CHOLLA 2	9-Aug-10	14:59	1-Sep-10	00:00 **(2)**	Unplanned
CHOLLA 3	11-Aug-10	23:11	12-Aug-10	01:55	Unplanned
DOUGLAS (FAIRVIEW) 1	6-Aug-10	07:13	6-Aug-10	16:10	Unplanned
	7-Aug-10	13:15	7-Aug-10	15:30	Unplanned
	10-Aug-10	09:00	10-Aug-10	11:27	Unplanned
	10-Aug-10	14:30	12-Aug-10	15:12	Unplanned
FOUR CORNERS 1	1-Aug-10	00:00 **(1)**	1-Aug-10	15:18	Unplanned
FOUR CORNERS 2	9-Aug-10	21:01	15-Aug-10	01:15	Unplanned
FOUR CORNERS 3	21-Aug-10	03:19	21-Aug-10	04:59	Unplanned
	23-Aug-10	19:52	27-Aug-10	17:15	Unplanned
FOUR CORNERS 4	12-Aug-10	04:10	15-Aug-10	04:00	Unplanned
	15-Aug-10	13:35	15-Aug-10	20:34	Unplanned
	15-Aug-10	04:00	15-Aug-10	13:05	Unplanned
	16-Aug-10	08:42	16-Aug-10	15:06	Unplanned
	17-Aug-10	22:00	21-Aug-10	23:03	Unplanned
	24-Aug-10	22:57	28-Aug-10	21:51	Unplanned
FOUR CORNERS 5	24-Aug-10	02:33	1-Sep-10	00:00 **(2)**	Unplanned
NAVAJO 1	11-Aug-10	10:17	11-Aug-10	14:46	Unplanned
	11-Aug-10	17:00	11-Aug-10	22:00	Unplanned
	14-Aug-10	01:17	14-Aug-10	11:00	Unplanned
	14-Aug-10	17:41	14-Aug-10	21:26	Unplanned
NAVAJO 2	2-Aug-10	15:00	2-Aug-10	19:01	Unplanned
NAVAJO 3	No Outages				
OCOTILLO CT1	12-Aug-10	17:45	13-Aug-10	15:05	Unplanned
OCOTILLO CT2	No Outages				
OCOTILLO ST1	4-Aug-10	05:00	5-Aug-10	20:45	Maintenance
	19-Aug-10	11:22	19-Aug-10	19:34	Unplanned
	23-Aug-10	17:19	24-Aug-10	00:49	Unplanned
	28-Aug-10	00:00	29-Aug-10	21:30	Maintenance
OCOTILLO ST2	18-Aug-10	12:00	18-Aug-10	13:58	Unplanned
	26-Aug-10	09:00	26-Aug-10	10:01	Unplanned
PALO VERDE 1	No Outages				
PALO VERDE 2	No Outages				
PALO VERDE 3	No Outages				
REDHAWK CT1A	No Outages				
REDHAWK CT1B	28-Aug-10	00:00	29-Aug-10	21:00	Unplanned
REDHAWK CT2A	1-Aug-10	21:15	2-Aug-10	02:00	Unplanned
	5-Aug-10	23:31	6-Aug-10	12:38	Unplanned
	9-Aug-10	05:50	9-Aug-10	23:30	Unplanned
	28-Aug-10	22:30	29-Aug-10	20:30	Unplanned
REDHAWK CT2B	26-Aug-10	14:16	26-Aug-10	17:31	Unplanned
	28-Aug-10	22:30	29-Aug-10	20:30	Unplanned
REDHAWK ST1	5-Aug-10	16:07	6-Aug-10	01:24	Unplanned
REDHAWK ST2	23-Aug-10	10:41	23-Aug-10	13:30	Unplanned
	28-Aug-10	22:30	29-Aug-10	20:30	Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
AUGUST 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SAGUARO CT1	19-Aug-10	18:11	19-Aug-10	23:46	Unplanned
SAGUARO CT2 No Outages					
SAGUARO CT3 No Outages					
SAGUARO ST1 No Outages					
SAGUARO ST2 No Outages					
SUNDANCE 1	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
	19-Aug-10	00:30	19-Aug-10	02:00	Unplanned
SUNDANCE 10	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
	19-Aug-10	22:23	20-Aug-10	02:30	Unplanned
SUNDANCE 2	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
	19-Aug-10	00:30	19-Aug-10	02:00	Unplanned
SUNDANCE 3	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
	5-Aug-10	16:15	5-Aug-10	23:00	Unplanned
SUNDANCE 4	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
SUNDANCE 5	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
	28-Aug-10	06:00	28-Aug-10	07:11	Maintenance
SUNDANCE 6	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
	28-Aug-10	06:00	28-Aug-10	07:11	Maintenance
SUNDANCE 7	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
SUNDANCE 8	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
	23-Aug-10	20:27	23-Aug-10	21:30	Unplanned
SUNDANCE 9	2-Aug-10	16:54	2-Aug-10	17:55	Unplanned
WEST PHOENIX ST5 No Outages					
WEST PHOENIX CC1	13-Aug-10	09:49	13-Aug-10	11:02	Unplanned
	14-Aug-10	06:00	14-Aug-10	14:10	Unplanned
	15-Aug-10	10:26	15-Aug-10	10:48	Unplanned
	15-Aug-10	11:32	15-Aug-10	17:30	Unplanned
WEST PHOENIX CC2	9-Aug-10	10:33	9-Aug-10	12:40	Unplanned
WEST PHOENIX CC3	23-Aug-10	09:02	23-Aug-10	22:00	Unplanned
WEST PHOENIX CC4	11-Aug-10	12:18	12-Aug-10	16:15	Unplanned
	23-Aug-10	13:20	23-Aug-10	14:15	Unplanned
	24-Aug-10	14:44	24-Aug-10	16:05	Unplanned
WEST PHOENIX CT1 No Outages					
WEST PHOENIX CT2	23-Aug-10	13:05	23-Aug-10	14:10	Unplanned
WEST PHOENIX CT5A No Outages					
WEST PHOENIX CT5B	2-Aug-10	09:29	2-Aug-10	11:44	Unplanned
YUCCA CT1	5-Aug-10	17:22	7-Aug-10	11:27	Unplanned
YUCCA CT2	25-Aug-10	13:40	26-Aug-10	13:00	Unplanned
YUCCA CT3	17-Aug-10	11:32	18-Aug-10	11:40	Unplanned
YUCCA CT4	26-Aug-10	19:53	15-Sep-10	00:00	Unplanned
YUCCA CT5	25-Aug-10	10:00	25-Aug-10	17:12	Unplanned
YUCCA CT6 No Outages					

(1) Designations of 08/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 09/01/10 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	09/05/10	10:32		09/05/10	12:02		Unplanned
CHOLLA 2	09/01/10	00:00	(1)	10/01/10	00:00	(2)	Unplanned
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	09/29/10	08:00		10/01/10	00:00	(2)	Unplanned
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	09/16/10	16:33		09/17/10	22:03		Unplanned
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	09/01/10	00:00	(1)	09/02/10	14:08		Unplanned
	09/02/10	16:23		09/02/10	17:50		Unplanned
NAVAJO 1	No Outages						
NAVAJO 2	No Outages						
NAVAJO 3	09/24/10	22:57		09/25/10	00:20		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	09/16/10	15:49		09/16/10	18:40		Unplanned
OCOTILLO ST1	No Outages						
OCOTILLO ST2	09/28/10	13:20		09/28/10	15:40		Unplanned
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	09/06/10	05:00		09/06/10	23:00		Unplanned
	09/07/10	06:20		09/07/10	09:13		Unplanned
	09/21/10	21:14		09/22/10	17:40		Unplanned
REDHAWK CT1B	09/21/10	21:43		09/22/10	17:40		Unplanned
REDHAWK CT2A	09/16/10	09:20		09/16/10	20:45		Unplanned
	09/29/10	06:43		09/30/10	02:11		Unplanned
REDHAWK CT2B	09/29/10	07:43		09/30/10	02:11		Unplanned
REDHAWK ST1	09/21/10	21:45		09/22/10	17:40		Unplanned
REDHAWK ST2	09/29/10	07:46		09/30/10	02:11		Unplanned
SAGUARO CT1	09/10/10	08:31		09/10/10	12:25		Unplanned
SAGUARO CT1	09/18/10	08:59		09/18/10	14:58		Unplanned
SAGUARO CT2	09/18/10	08:59		09/18/10	14:58		Unplanned
	09/24/10	20:49		09/25/10	00:30		Unplanned
	09/27/10	13:29		09/27/10	14:30		
	09/27/10	17:55		09/27/10	20:45		Unplanned
SAGUARO CT3	09/03/10	15:57		09/03/10	17:20		Unplanned
	09/19/10	14:46		09/20/10	09:08		Unplanned
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
SEPTEMBER 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time		Description (3)
SUNDANCE 1	No Outages					
SUNDANCE 10	09/03/10	22:30		09/04/10	00:25	Maintenance
SUNDANCE 2	09/03/10	20:17		09/03/10	22:30	Maintenance
SUNDANCE 3	09/03/10	13:38		09/04/10	14:13	Unplanned
	09/15/10	14:52		09/15/10	23:10	Unplanned
SUNDANCE 4	09/24/10	11:43		09/25/10	11:03	Unplanned
	09/29/10	06:37		09/29/10	09:10	Unplanned
SUNDANCE 5	09/06/10	12:26		09/06/10	18:30	Unplanned
SUNDANCE 6	No Outages					
SUNDANCE 7	No Outages					
SUNDANCE 8	09/26/10	17:00		09/26/10	21:00	Unplanned
SUNDANCE 9	No Outages					
WEST PHOENIX ST5	No Outages					
WEST PHOENIX CC1	09/01/10	15:15		09/02/10	11:20	Unplanned
	09/15/10	03:00		09/15/10	15:15	Unplanned
WEST PHOENIX CC2	09/02/10	12:51		09/02/10	20:00	Unplanned
WEST PHOENIX CC3	No Outages					
WEST PHOENIX CC4	09/29/10	06:49		09/29/10	07:50	Unplanned
WEST PHOENIX CT1	No Outages					
WEST PHOENIX CT2	09/27/10	14:06		09/27/10	14:51	Unplanned
WEST PHOENIX CT5A	No Outages					
WEST PHOENIX CT5B	No Outages					
YUCCA CT1	No Outages					
YUCCA CT2	No Outages					
YUCCA CT3	09/04/10	06:00		09/04/10	08:00	Unplanned
YUCCA CT4	09/01/10	00:00	(1)	09/23/10	14:16	Unplanned
YUCCA CT5	09/30/10	15:00		09/30/10	16:49	Unplanned
YUCCA CT6	No Outages					

(1) Designations of 09/01/10 00:00 mean that the outage began in the prior month
(2) Designations of 10/01/10 00:00 mean that the outage continues into the following month.
(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	10/01/10	00:00	(1)	10/15/10	00:00		Planned
	10/15/10	00:00		10/28/10	01:47		Unplanned
	10/28/10	05:45		10/28/10	06:55		Unplanned
CHOLLA 3	No Outages						
DOUGLAS (FAIRVIEW) 1	No Outages						
FOUR CORNERS 1	10/01/10	00:00	(1)	10/04/10	20:55		Unplanned
FOUR CORNERS 2	10/08/10	06:29		10/11/10	16:25		Unplanned
FOUR CORNERS 3	10/06/10	23:38		10/10/10	01:18		Unplanned
FOUR CORNERS 4	No Outages						
FOUR CORNERS 5	No Outages						
NAVAJO 1	No Outages						
NAVAJO 2	No Outages						
NAVAJO 3	10/09/10	01:05		10/11/10	14:46		Unplanned
	10/12/10	00:45		10/13/10	03:11		Unplanned
	10/27/10	15:19		10/28/10	17:30		Unplanned
OCOTILLO CT1	No Outages						
OCOTILLO CT2	10/19/10	10:35		10/19/10	11:24		Unplanned
OCOTILLO ST1	10/10/10	12:25		10/13/10	22:15		Unplanned
OCOTILLO ST2	10/11/10	06:00		10/14/10	14:30		Maintenance
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	10/02/10	00:00		11/01/10	00:00	(2)	Planned
REDHAWK CT1A	10/02/10	00:00		11/01/10	00:00	(2)	Planned
REDHAWK CT1B	10/02/10	00:00		11/01/10	00:00	(2)	Planned
REDHAWK CT2A	No Outages						
REDHAWK CT2B	No Outages						
REDHAWK ST1	10/02/10	00:00		11/01/10	00:00	(2)	Planned
REDHAWK ST2	No Outages						
SAGUARO CT1	No Outages						
SAGUARO CT2	No Outages						
SAGUARO CT3	10/18/10	11:55		10/22/10	18:09		Planned
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
OCTOBER 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time		Description (3)
SUNDANCE 1	10/04/10	00:01	10/12/10	22:47	Planned
SUNDANCE 10	10/01/10	20:00	10/01/10	20:45	Unplanned
SUNDANCE 2	10/04/10	00:01	10/12/10	22:47	Planned
SUNDANCE 3	10/05/10	07:00	10/05/10	07:59	Maintenance
	10/11/10	11:00	10/11/10	12:00	Unplanned
	10/18/10	18:13	10/21/10	12:13	Unplanned
SUNDANCE 4	10/05/10	07:00	10/05/10	07:59	Maintenance
	10/11/10	11:00	10/11/10	12:00	Maintenance
SUNDANCE 5	10/02/10	14:05	10/03/10	14:35	Unplanned
	10/05/10	07:00	10/05/10	07:59	Maintenance
	10/11/10	11:00	10/11/10	12:00	Maintenance
SUNDANCE 6	10/05/10	07:00	10/05/10	07:59	Maintenance
	10/11/10	11:00	10/11/10	12:00	Maintenance
SUNDANCE 7	No Outages				
SUNDANCE 8	10/08/10	06:34	10/08/10	06:36	Unplanned
SUNDANCE 9	10/21/10	09:06	10/21/10	09:40	Unplanned
WEST PHOENIX ST5	10/18/10	05:47	10/18/10	06:27	Unplanned
WEST PHOENIX CC1	No Outages				
WEST PHOENIX CC2	10/24/10	15:25	10/28/10	15:30	Unplanned
	10/29/10	15:15	10/29/10	15:43	Unplanned
WEST PHOENIX CC3	No Outages				
WEST PHOENIX CC4	10/09/10	07:55	10/09/10	08:18	Unplanned
	10/14/10	09:20	10/14/10	10:00	Unplanned
WEST PHOENIX CT1	No Outages				
WEST PHOENIX CT2	No Outages				
WEST PHOENIX CT5A	10/25/10	14:21	10/28/10	04:00	Unplanned
WEST PHOENIX CT5B	10/06/10	12:46	10/06/10	13:23	Unplanned
	10/24/10	10:41	10/27/10	10:33	Unplanned
YUCCA CT1	No Outages				
YUCCA CT2	No Outages				
YUCCA CT3	No Outages				
YUCCA CT4	No Outages				
YUCCA CT5	No Outages				
YUCCA CT6	No Outages				

(1) Designations of 10/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 10/01/10 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	No Outages						
CHOLLA 3	11/01/10	23:57		11/08/10	08:46		Maintenance
DOUGLAS (FAIRVIEW) 1	11/15/10	13:15		11/15/10	15:00		Unplanned
	11/26/10	05:34		11/26/10	09:00		Unplanned
FOUR CORNERS 1	11/24/10	12:56		11/24/10	23:46		Unplanned
	11/25/10	02:57		11/25/10	15:27		Unplanned
FOUR CORNERS 2	No Outages						
FOUR CORNERS 3	11/01/10	00:00	(1)	11/04/10	13:05		Unplanned
	11/07/10	03:35		11/07/10	08:06		Unplanned
	11/26/10	21:01		11/27/10	02:02		Unplanned
	11/27/10	10:25		11/27/10	20:00		Unplanned
	11/27/10	21:00		11/28/10	13:47		Unplanned
FOUR CORNERS 4	11/05/10	15:11		11/06/10	12:26		Unplanned
	11/25/10	20:15		11/26/10	09:23		Unplanned
FOUR CORNERS 5	No Outages						
NAVAJO 1	No Outages						
NAVAJO 2	11/27/10	00:29		11/29/10	20:29		Maintenance
	11/29/10	21:44		11/30/10	02:21		Maintenance
NAVAJO 3	No Outages						
OCOTILLO CT1	11/15/10	06:00		11/22/10	16:30		Planned
	11/22/10	16:30		12/01/10	00:00	(2)	Planned
OCOTILLO CT2	No Outages						
OCOTILLO ST1	11/08/10	08:00		11/10/10	15:52		Planned
OCOTILLO ST2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	11/01/10	00:00	(1)	11/10/10	21:22		Planned
REDHAWK CT1A	11/01/10	00:00	(1)	11/28/10	10:47		Planned
REDHAWK CT1B	11/01/10	00:00	(1)	11/27/10	10:02		Planned
	11/27/10	10:10		11/27/10	16:29		Unplanned
REDHAWK CT2A	No Outages						
REDHAWK CT2B	11/08/10	05:22		11/10/10	21:22		Unplanned
	11/11/10	22:57		11/12/10	02:01		Unplanned
	11/30/10	06:00		11/30/10	16:30		Unplanned
REDHAWK ST1	11/01/10	00:00	(1)	11/27/10	22:56		Planned
	11/27/10	23:01		11/28/10	12:43		Unplanned
REDHAWK ST2	No Outages						

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
NOVEMBER 2010

Plant and Unit	Outage Start: Date / Time		Outage End: Date / Time			Description (3)
SAGUARO CT1	11/18/10	08:00	11/18/10	20:00		Maintenance
SAGUARO CT2	11/30/10	22:16	12/01/10	00:00	(2)	Unplanned
SAGUARO CT3	No Outages					
SAGUARO ST1	No Outages					
SAGUARO ST2	No Outages					
SUNDANCE 1	11/08/10	10:30	11/08/10	14:27		Unplanned
	11/09/10	10:10	11/09/10	14:30		Maintenance
SUNDANCE 2	11/08/10	10:30	11/08/10	14:27		Unplanned
	11/10/10	08:41	11/10/10	11:57		Maintenance
SUNDANCE 3	11/08/10	02:00	11/16/10	23:45		Planned
	11/20/10	06:51	11/20/10	17:00		Unplanned
SUNDANCE 4	11/08/10	02:00	11/16/10	23:45		Planned
	11/17/10	08:25	11/17/10	15:15		Unplanned
	11/26/10	21:49	11/27/10	11:50		Unplanned
	11/27/10	18:31	11/28/10	17:30		Unplanned
	11/28/10	18:06	12/01/10	00:00	(2)	Unplanned
SUNDANCE 5	11/08/10	10:30	11/08/10	16:00		Unplanned
	11/10/10	12:43	11/10/10	15:00		Maintenance
SUNDANCE 6	11/06/10	10:45	11/06/10	12:00		Unplanned
	11/08/10	10:30	11/08/10	16:00		Unplanned
	11/10/10	15:00	11/10/10	19:30		Maintenance
SUNDANCE 7	11/11/10	07:54	11/11/10	11:00		Maintenance
SUNDANCE 8	11/11/10	11:15	11/11/10	14:30		Maintenance
	11/20/10	06:51	11/20/10	17:00		Unplanned
SUNDANCE 9	11/12/10	07:45	11/12/10	10:45		Maintenance
SUNDANCE 10	11/12/10	10:45	11/12/10	13:45		Maintenance
WEST PHOENIX ST5	No Outages					
WEST PHOENIX CC1	No Outages					
WEST PHOENIX CC2	No Outages					
WEST PHOENIX CC3	11/09/10	06:08	11/09/10	09:23		Unplanned
WEST PHOENIX CC4	11/04/10	14:52	11/07/10	13:54		Unplanned
	11/09/10	07:10	11/09/10	08:07		Unplanned
WEST PHOENIX CT1	11/29/10	06:37	12/01/10	19:39		Unplanned
WEST PHOENIX CT2	11/24/10	17:55	11/25/10	11:00		Unplanned
	11/29/10	06:48	11/29/10	08:00		Unplanned
	11/30/10	16:00	12/01/10	15:23		Unplanned
WEST PHOENIX CT5A	11/20/10	07:45	11/21/10	15:00		Unplanned
WEST PHOENIX CT5B	11/18/10	02:00	11/22/10	17:30		Unplanned
	11/30/10	06:31	11/30/10	15:12		Unplanned
YUCCA CT1	No Outages					
YUCCA CT2	No Outages					
YUCCA CT3	No Outages					
YUCCA CT4	No Outages					
YUCCA CT5	No Outages					
YUCCA CT6	No Outages					

(1) Designations of 11/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 12/01/10 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
CHOLLA 1	No Outages						
CHOLLA 2	12/16/10	19:29		12/18/10	14:15		Unplanned
CHOLLA 3	12/07/10	10:43		12/09/10	00:43		Unplanned
DOUGLAS (FAIRVIEW) 1	12/29/10	20:15		12/30/10	18:04		Unplanned
FOUR CORNERS 1	No Outages						
FOUR CORNERS 2	12/08/10	03:00		12/10/10	00:00		Unplanned
	12/10/10	10:39		12/10/10	13:34		Unplanned
	12/10/10	00:00		12/10/10	06:46		Unplanned
FOUR CORNERS 3	12/01/10	22:34		12/07/10	17:29		Unplanned
FOUR CORNERS 4	12/08/10	03:07		12/16/10	05:44		Unplanned
	12/22/10	02:55		12/24/10	10:40		Unplanned
FOUR CORNERS 5	12/01/10	20:06		12/02/10	14:12		Unplanned
	12/24/10	22:28		12/28/10	15:08		Unplanned
NAVAJO 1	12/17/10	21:10		12/18/10	09:02		Unplanned
	12/18/10	12:00		12/18/10	14:30		Unplanned
	12/18/10	16:25		12/18/10	17:42		Unplanned
	12/18/10	19:09		12/18/10	20:23		Unplanned
	12/18/10	10:15		12/18/10	11:33		Unplanned
NAVAJO 2	12/11/10	22:51		12/12/10	03:30		Unplanned
	12/15/10	23:02		12/17/10	23:37		Maintenance
	12/18/10	12:00		12/18/10	14:30		Unplanned
NAVAJO 3	No Outages						
OCOTILLO CT1	12/01/10	00:00	(1)	01/01/11	00:00	(2)	Planned
OCOTILLO CT2	12/29/10	17:40		12/30/10	18:50		Unplanned
OCOTILLO ST1	12/07/10	09:00		12/10/10	15:30		Maintenance
OCOTILLO ST2	No Outages						
PALO VERDE 1	No Outages						
PALO VERDE 2	No Outages						
PALO VERDE 3	No Outages						
REDHAWK CT1A	12/08/10	05:08		12/15/10	18:30		Unplanned
REDHAWK CT1B	12/28/10	06:10		12/28/10	14:30		Unplanned
REDHAWK CT2A	12/23/10	11:11		12/23/10	13:20		Unplanned
	12/23/10	14:20		12/23/10	17:40		Unplanned
	12/28/10	07:00		12/28/10	12:30		Unplanned
REDHAWK CT2B	12/02/10	13:52		12/06/10	20:48		Unplanned
	12/28/10	07:00		12/28/10	12:30		Unplanned
REDHAWK ST1	12/14/10	07:27		12/14/10	08:31		Unplanned
	12/14/10	10:39		12/15/10	18:30		Unplanned
REDHAWK ST2	12/02/10	13:52		12/06/10	20:48		Unplanned
	12/28/10	07:00		12/28/10	12:30		Unplanned

ARIZONA PUBLIC SERVICE COMPANY

GENERATING UNIT OUTAGES
FOR THE MONTH OF:
DECEMBER 2010

Plant and Unit	Outage Start: Date / Time			Outage End: Date / Time			Description (3)
SAGUARO CT1	12/29/10	18:00		01/01/11	00:00	(2)	Maintenance
SAGUARO CT2	12/01/10	00:00	(1)	12/01/10	07:30		Unplanned
	12/01/10	17:00		12/02/10	17:45		Unplanned
	12/30/10	13:07		01/01/11	00:00	(2)	Maintenance
SAGUARO CT3	12/28/10	07:30		12/28/10	15:45		Unplanned
SAGUARO ST1	No Outages						
SAGUARO ST2	No Outages						
SUNDANCE 1	12/06/10	10:50		12/06/10	11:55		Maintenance
SUNDANCE 10	12/07/10	10:55		12/08/10	02:00		Unplanned
	12/10/10	09:11		12/10/10	10:33		Maintenance
SUNDANCE 2	12/17/10	02:00		12/17/10	16:33		Unplanned
	12/20/10	17:55		12/20/10	21:00		Unplanned
SUNDANCE 3	No Outages						
SUNDANCE 4	12/01/10	00:00	(1)	12/03/10	09:00		Unplanned
SUNDANCE 5	No Outages						
SUNDANCE 6	12/04/10	18:15		12/04/10	22:45		Unplanned
SUNDANCE 7	12/08/10	11:57		12/08/10	13:13		Maintenance
	12/28/10	18:30		12/28/10	19:45		Unplanned
SUNDANCE 8	12/08/10	19:33		12/08/10	21:30		Unplanned
SUNDANCE 9	12/07/10	10:55		12/08/10	02:00		Unplanned
WEST PHOENIX ST5	12/19/10	17:10		12/20/10	08:00		Unplanned
WEST PHOENIX CC1	12/13/10	00:22		12/17/10	18:00		Unplanned
WEST PHOENIX CC2	12/11/10	08:15		12/11/10	17:30		Unplanned
	12/19/10	17:47		12/21/10	16:15		Unplanned
	12/19/10	04:25		12/19/10	15:10		Unplanned
	12/24/10	21:06		12/26/10	18:15		Unplanned
WEST PHOENIX CC3	12/06/10	09:45		12/06/10	12:32		Unplanned
	12/13/10	05:13		12/13/10	07:23		Unplanned
	12/31/10	06:25		12/31/10	08:15		Unplanned
WEST PHOENIX CC4	12/04/10	13:13		12/04/10	14:59		Unplanned
	12/28/10	07:36		12/28/10	10:30		Unplanned
WEST PHOENIX CT1	No Outages						
WEST PHOENIX CT2	No Outages						
WEST PHOENIX CT5A	12/27/10	14:16		12/27/10	15:33		Unplanned
	12/31/10	10:00		12/31/10	23:45		Unplanned
WEST PHOENIX CT5B	12/08/10	16:02		12/08/10	18:30		Unplanned
	12/29/10	19:32		12/30/10	00:15		Unplanned
	12/31/10	10:00		12/31/10	23:45		Unplanned
YUCCA CT1	12/23/10	22:15		12/28/10	14:27		Unplanned
YUCCA CT2	No Outages						
YUCCA CT3	No Outages						
YUCCA CT4	No Outages						
YUCCA CT5	12/05/10	18:16		12/07/10	17:48		Unplanned
	12/07/10	18:29		12/09/10	00:52		Unplanned
YUCCA CT6	12/10/10	10:00		12/10/10	12:15		Unplanned

(1) Designations of 12/01/10 00:00 mean that the outage began in the prior month

(2) Designations of 01/01/11 00:00 mean that the outage continues into the following month.

(3) Outage descriptions conform to the official NERC/GADS outage descriptions. Note that all outages less than 1 hour have been excluded from this report.

Attachment C

APS - 2008 EE Participation Levels

Residential Programs	No. of Units
Consumer Products Program	
Number of CFL bulbs sold	2,618,975
Energy Star Home Program	
No. of incentives paid for homes completed	3,183
HVAC Replacement Program	
Number of rebates paid:	
14 SEER	4,061
16 SEER	433
Quality Install	1,252
Duct Testing and Repair	485
Non-Residential Programs	
Solutions for Business Program	
Number of incentives paid:	
Large existing customers	316
Small business customers	55
New construction	113
Energy Information Services Program	
Number of customers in program to date	20
Number of meters (signed-up)	110

APS - 2009 EE Participation Levels

Residential Programs	No. of Units
Consumer Products Program	
Number of CFL bulbs sold	2,275,644
Energy Star Home Program	
No. of incentives paid for homes completed	1,425
HVAC Replacement Program	
Number of rebates paid:	
14 SEER (Includes 13 - 16 SEER new reb.)	6,611
16 SEER (Includes 17+ Seer New Reb	1,256
Quality Install	534
Duct Testing and Repair	1,784

Non-Residential Programs	
Solutions for Business Program	
Number of incentives paid:	
Large existing customers	619
Small business customers	90
New construction	90
Energy Information Services Program	
Number of customers in program to date	27
Number of meters (signed-up)	166

APS - 2010 EE Participation Levels

RESIDENTIAL PROGRAMS:	No. of Units
Consumer Products Program	
Number of CFL bulbs sold	3,279,041
Pool Pump Motors/Smart Timers	
Two Speed Motors	22
Variable Speed Motors	390
TightWatt Smart Timers	89
Refrigerator Recycling	
Refrigerators	7,016
Freezers	1,050
Energy Star Homes Program	
No. of incentives paid for homes completed	1,542
Energy Star Homes Program - HERS 70	
No. of incentives paid for homes completed	144
Home Performance w/ ENERGY STAR	
Audits	2,363
LF Shower Heads	1,418
LF Aerators	3,547
CFLS	18,904
Air Sealing Only	204
Duct Test & Repair	1,098
Insulation Only	148
Insulation and Airsealing	419
Shade Screens	81
HVAC Replacement Program	
Number of rebates paid:	
13 SEER	1,797
14 - 16 SEER	9,078
17+ SEER	1,339
Duct Testing and Repair (Just Repairs)	2,009
NON-RESIDENTIAL PROGRAMS:	
Large Existing Program - Applications Paid	803

APS - 2010 EE Participation Levels

New Construction - Applications Paid	99
Small Business - Applications Paid	1,217
Schools Program - No. of Schools Participating	157
Energy Information Services Program	
Number of customers in program to date	37
Number of meters (signed-up)	236

Attachment D

Demand Response Programs – Enrollment Levels

APS Peak Solutions

Event #	Event Date	# of Customers in Event
1	07/20/2010	375

Peak Event Pricing (formally Critical Peak Pricing)

Event #	Event Date	# of Customers in Event
1	07/15/2010	755
2	07/20/2010	731
3	08/04/2010	712
4	08/06/2010	708
5	08/12/2010	696
6	08/25/2010	683

Attachment E

Low Income Programs – Enrollment Levels

	2007	2008	2009	2010
E-3/E-4 Enrollment*	44,195	46,579	54,966	64,132
Crisis Bill Assistance	1,176	1,055	789	596
150% to 200% Crisis Bill Assistance	N/A	N/A	N/A	99
Weatherization	363	402	203	448

**Annualized number of participating customers*

Attachment F

RES Programs – New Customer Enrollment Levels

	2007	2008	2009	2010
Residential Up Front Incentive ("UFI")	524	793	2,980	4,941
Non-Residential Up Front Incentive ("UFI")	13	35	74	89
Non-Residential Performance Based Incentive ("PBI")	1	4	16	59
Non-Residential Performance Based Incentive ("PBI")	N/A	16	73	163*
Green Choice Program	370	1,556	2,301	3,277

**Includes three customers through the DE RFP*