

ORIGINAL

STUMP PROPOSED AMENDMENT NO. 1



0000126490

DATE PREPARED: June 20, 2011

COMPANY: Southwest Transmission Cooperative, Inc. AGENDA ITEM NO.: 13

DOCKET NO(S): L-00000CC-11-0127-00161

OPEN MEETING DATE: 06/21/2011-06/22/2011

Arizona Corporation Commission
DOCKETED

JUN 20 2011

Page 2

DOCKETED BY

Line 4:

INSERT New Condition to Sample Order 2 as Condition No. 13:

“Before commencing construction of Project facilities located parallel to and within 100 feet of any existing natural gas or hazardous liquid pipeline, the Applicant or its assignees shall:

- (a) Perform the appropriate grounding and cathodic protection studies to show that the Project's location parallel to and within 100 feet of such pipeline results in no material adverse impacts to the pipeline or to public safety when both the pipeline and the Project are in operation. If material adverse impacts are noted in the studies, Applicant shall take appropriate steps to ensure that such material adverse impacts are mitigated. Applicant shall provide to Commission Staff and Docket Control reports of studies performed; and
- (b) Perform a technical study simulating an outage of the Project that may be caused by the collocation of the Project parallel to and within 100 feet of the existing natural gas or hazardous liquid pipeline. This study should either: i) show that such outage does not result in customer outages; or ii) include operating plans to minimize any resulting customer outages. Applicant shall provide a copy of this study to Commission Staff and Docket Control.

Make all conforming changes.

AZ CORP COMMISSION
DOCKET CONTROL

2011 JUN 20 A 11: 54

THIS AMENDMENT:			RECEIVED
_____ Passed _____	Passed as amended by _____		
_____ Failed _____	Not Offered _____	_____ Withdrawn _____	