

ORIGINAL



414 North Court Avenue
Tucson, Arizona 85701
(520) 623-2366
FAX (520) 623-2302




0000128496

Arizona Corporation Commission

DOCKETED

AUG 22 2011



August 12, 2011

Arizona Corporation Commission
Utilities Division
1200 West Washington Street
Phoenix, AZ 85007-2927
Attn: Docket Control

RE: Docket #W-01380A-09-0106

To Whom It May Concern:

As per the Opinion and Order in the above-referenced matter, enclosed is a copy of the Certificate of Approval to Construct the water facilities which are the subject of the subject long term financing application.

Please contact me if you have any questions or comments.

Best Regards,

Rhonda Mallis Rosenbaum
General Manager
Ray Water Company
414 N. Court Avenue
Tucson, AZ 85701

raywaterco@gmail.com

Enclosure

RECEIVED
2011 AUG 22 P 1:46
AZ CORPORATION COMMISSION
DOCKET CONTROL

PIMA COUNTY DEPARTMENT ENVIRONMENTAL QUALITY
TECHNICAL SERVICES DIVISION
33 N. Stone Ave., Suite 700, Tucson, Arizona 85701-1429
Telephone: (520) 243-7400

**CERTIFICATE OF APPROVAL TO CONSTRUCT
Water Facilities**

System Name: RAY WATER COMPANY System No.: 10-095

Project Owner: RAY WATER COMPANY

Address: 414 N. COURT AVENUE, TUCSON, AZ 85701

Location: T-15-S, R-14-E, SECTION 10 Latitude: 32° 08' 28.66" Longitude: -110° 53' 50.03" County: Pima

Description: NEW WELL NUMBER 8 (ADWR NO. 55-219154) AND 6-INCH MAIN EXTENSION

Approval to construct the above, described facilities as represented in the approved plan on file with the Pima County Department of Environmental Quality is hereby given subject to the following provisions:

AFTER COMPLETION OF CONSTRUCTION, A PROFESSIONAL ENGINEER, REGISTERED IN THE STATE OF ARIZONA SHALL COMPLETE A FINAL INSPECTION AND SUBMIT AN ENGINEER'S CERTIFICATE OF COMPLETION, ACCURATE "AS BUILT" PLANS, PRESSURE TEST RESULTS, CHLORINATION RESULTS AND MICROBIOLOGICAL TESTING RESULTS TO PIMA COUNTY DEPARTMENT OF ENVIRONMENTAL QUALITY IN ORDER TO OBTAIN AN APPROVAL OF CONSTRUCTION. THOSE PLANS MUST BE CLEAR BLUELINE PRINTS SUITABLE FOR MICROFILMING AND SHALL CLEARLY AND ADEQUATELY REPRESENT THE FACILITIES AS THEY ARE CONSTRUCTED.

The State law, A.R.S. 49-353, requires that construction of the project must be in accordance with the rules and regulations of the Arizona Department of Environmental Quality and the Pima County Department of Environmental Quality. For the purposes of Licensing Time Frames, under AAC Title 18, Chapter 1, Article 5, this Approval to Construct suspends the licensing time frames and constitutes a Notice of Deficiencies. According to AAC R18-9-A301(D)(f), the applicant, after completion of construction of the facility specified herein, is required to submit all applicable documents. The submittal of all the required documents restarts the licensing time frames. Construction shall conform with the approved design documents.


If this project includes trenching, land stripping, earthmoving or road construction, an air quality activity permit may be required pursuant to P. C. C. Title 17.12.470. For inquiries, regarding air quality activity permits, please call (520) 243-7400.

If construction has not started within one year, this certificate will be void and a written extension of time shall be required within 90 days of the expiration of the approval date.

Date Approved: March 3, 2011

Ursula Kramer, P.E.
Director

cc: P-File No. PO02911
P-ADEQ, SRO
Engineer: WestLand Resources, Inc.

By: 
David Amash, P.E.
Civil Engineer