

ORIGINAL



0000130357

GRANITE MOUNTAIN WATER COMPANY,

RECEIVED

2011 OCT -7 A 9: 35

AZ CORP COMMISSION  
DOCKET CONTROL

Arizona Corporation Commission

DOCKETED

OCT 7 2011

October 4, 2011

DOCKETED BY	
-------------	--

Arizona Corporation Commission  
Docket Control  
1200 West Washington  
Phoenix, AZ 85007

Re: Compliance item related to Granite Mountain Water Company's Financing Application  
Docket No: W-02467A-10-0483  
Decision 72377

Honorable Commissioner(s),

As a matter of compliance, the Company has received the Approval to Construct the new 50,000 gallons storage tank ("Tank #3") from the Arizona Department of Environmental Quality on September 27, 2011. Please find it attached as Exhibit 1.

Regards,

Matthew Lauterbach  
Chief Operating Officer  
Granite Mountain Water Company  
(928) 717-2616

Cc: Paul D. Levie, President, Granite Mountain Water Company  
Docket Control (13 copies)  
Carmel Hood, Compliance, Arizona Corporation Commission

Physical Address  
2465 Shane Drive  
Prescott, AZ 86305

Mailing Address  
PO Box 350  
Chino Valley, AZ 86323

Phone (928) 717-2616  
Fax (928) 717-2621  
Email gmwc@leviegroupp.com



ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY  
CERTIFICATE OF APPROVAL TO CONSTRUCT  
WATER FACILITIES

Page 1 Of 3

<b>ADEQ File No:</b> 20110161	<b>LTF No:</b> 54492
<b>System Name:</b> Granite Mountain Water Co	<b>System Number:</b> 13-150
<b>Project Owner:</b> Granite Mountain Water Company	
<b>Address:</b> P O Box 350, Chino Valley, AZ 86323	
<b>Project Location:</b> Prescott	<b>County:</b> Yavapai
<b>Description:</b> GRANITE MOUNTAIN WATER COMPANY. ATC PERMIT TO CONSTRUCT 1-50,000 GALLON WATER STORAGE TANK (#3) AND ASSOCIATED YARD PIPING. TO SERVE 175 SINGLE-FAMILY RESIDENTIAL LOTS IN THE COMMUNITY OF PRESCOTT VALLEY.	

*Approval to construct the above-described facilities as represented in the approved documents on file with the Arizona Department of Environmental Quality is hereby given subject to provisions 1 through 6 continued on page 2 through 3*

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Central Regional Office located in Phoenix. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin. Code. At the project owner's request, the Department may conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.
3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-5-507(A), Ariz. Admin. Code.

Reviewed by: FMS

By: Janak K. Desai 7/27/2011  
Janak K. Desai, P.E. Unit Manager Date  
Engineering Review Section  
Water Quality Division

cc: File No: 20110161  
Regional Office: Central  
Owner: Granite Mountain Water Company  
County Health Department: Yavapai  
Engineer: Glen Vortherms  
Planning and Zoning/Az Corp. Commission  
Engineering Review Database - Etr021

Exhibit 1

**APPROVAL TO CONSTRUCT  
STORAGE TANK & YARD PIPING  
ADEQ FILE No. 20110161  
PAGE 2 OF 3: PROVISIONS CONTINUED**

5. Approval of Construction (AOC) will not be issued until data is obtained and verified for Pressure and Leakage Tests of waterlines and Disinfection Sampling of constructed well, storage and hydropneumatic tanks, booster pumps and potable water lines. **Engineering Bulletin No. 10, Chapter 2.E.20, Disinfection Requirements**; requires that... "Every new, modified or reconditioned groundwater source shall be disinfected after placement of final pump equipment". Information on disinfection procedures can be obtained from **"Engineering Bulletin No. 8, "Disinfection of Water Systems"**.

It is recommended that the Engineer's Certificate of Completion (ECC) Data Required Sheet be completed in full, showing actual pressures and sampling data. Data required with ECC sheet can be found under heading - Safe Drinking Water and subheading - Technical Engineering/Plan Reviews

<http://www.azdeq.gov/function/forms/appswater.html#sdw>.

6. The Arizona Department of Environmental Quality's review of this application was subject to the requirements of the licensing time frames ("LTF") statute under Arizona Revised Statutes ("A.R.S.") § 41-1072 through § 41-1079 and the LTF rules under Arizona Administrative Code ("A.A.C.") R18-1-501 through R18-1-525. This Notice is being issued within the overall time frame for your application.

ADEQ hereby approves your application for Approve to Construct Drinking Water Facilities under A.R.S. § 49-351. Your copy is enclosed.

This decision is an appealable agency action under A.R.S. § 41-1092. You have a right to request a hearing and file an appeal under A.R.S. § 41-1092.03(B). You must file a written Request for Hearing or Notice of Appeal within **30 days** of your receipt of this Notice. A Request for Hearing or Notice of Appeal is filed when it is received by ADEQ's Hearing Administrator as follows:

Office of Administrative Counsel  
Arizona Department of Environmental Quality  
1110 W. Washington Street  
Phoenix, AZ 85007

The Request for Hearing or Notice of Appeal shall identify the party, the party's address, the agency and the action being appealed and shall contain a concise statement of the reasons for the appeal.

**APPROVAL TO CONSTRUCT  
STORAGE TANK & YARD PIPING  
ADEQ FILE No. 20110161  
PAGE 3 OF 3: PROVISIONS CONTINUED**

Upon proper filing of a Request for Hearing or Notice of Appeal, ADEQ will serve a Notice of Hearing on all parties to the appeal. If you file a timely Request for Hearing or Notice of Appeal you have a right to request an informal settlement conference with ADEQ under A.R.S. § 41-1092.06. This request must be made in writing no later than **20 days** before a scheduled hearing and must be filed with the Hearing Administrator at the above address.

Please contact Frank M. Smaila at (602) 771-4237 or [fms@azdeq.gov](mailto:fms@azdeq.gov) if you have questions regarding this Notice or the Certificate of Approved to Construct.