

ORIGINAL

KENNEDY'S PROPOSED AMENDMENT NO. 1



0000131968

TIME/DATE PREPARED: November 28, 2011

COMPANY: Sonoran Solar Energy, LLC

AGENDA ITEM NO. 10

DOCKET NO(S). L-00000UU-11-0337-00162

OPEN MEETING DATE: Dec. 1, 2011

"The Commission modifies the CEC issued by the Committee by inserting a new Condition No. 20 as follows:

- 20. Before commencing construction of Project facilities located parallel to and within 100 feet of any existing natural gas or hazardous liquid pipeline, the Applicant or its assignees shall:
 - (a) Perform the appropriate grounding and cathodic protection studies to show that the Project's location parallel to and within 100 feet of such a pipeline results in no material adverse impacts to the pipeline or to public safety when both the pipeline and the Project are in operation. If material adverse impacts are noted in the studies, Applicant shall take appropriate steps to ensure that such material adverse impacts are mitigated. Applicant shall provide to Commission Staff and Docket Control reports of studies performed; and
 - (b) Perform a technical study simulating an outage of the Project that may be caused by the collocation of the Project parallel to and within 100 feet of the existing natural gas or hazardous liquid pipeline. This study should either: i) show that such outage does not result in customer outages; or ii) include operating plans to minimize any resulting customer outages. Applicant shall provide a copy of this study to Commission Staff and Docket Control."

Arizona Corporation Commission

DOCKETED

NOV 28 2011

DOCKETED BY	
-------------	--

AZ CORP COMMISSION
DOCKET CONTROL

2011 NOV 28 P 4: 29

RECEIVED

**** Make All conforming changes**

THIS AMENDMENT:			
_____ Passed	_____ Passed as amended by _____		
_____ Failed	_____ Not Offered	_____ Withdrawn	