

ORIGINAL



P.O. Box 10
Rimrock, AZ 86335
928-592-9211

Docket: W-02064A-01-787
Decision # 64665

January 30, 2012

Director of Utilities Division
Arizona Corporation Commission
1200 W. Washington St.
Phoenix, AZ 85007

To Whom It May Concern:

Enclosed is a copy of the Annual Water Use Report required per ACC Commission Decision No. 64665.

Annual percentage water loss for the year 2011 equates to ~6%. MRWC's makes efforts to reduce water loss through immediate leak repairs. Included in the 6% water loss is the amount of water that MRWC uses to flush and operate the hydrants and isolated water lines quarterly.

If there are any questions, please do not hesitate to contact me at 928-300-3291.

Sincerely,

Patricia D. Olsen
Manager

cc: Docket Control
Compliance Section

Arizona Corporation Commission
DOCKETED
JAN 30 2012

DOCKETED BY *MM*

RECEIVED
2012 JAN 30 P 2:06
AZ CORP COMMISSION
DOCKET CONTROL

WATER USE DATA SHEET

NAME OF COMPANY —————→	Montezuma Rimrock Water Company LLC
ADEQ Public Water System No. —————→	13-071

MONTH/YEAR (Last 13 Months)	NUMBER OF CUSTOMERS	GALLONS SOLD (Thousands)	GALLONS PUMPED	GALLONS PURCHASED
December 2010	203	791	791	0
January 2011	200	1089	1095	
February 2011	207	853	987	
March 2011	203	868	898	
April 2011	205	989	1174	
May 2011	201	1153	1184	
June 2011	205	1607	1645	
July 2011	201	1140	1140	
August 2011	207	1108	1151	
September 2011	206	1326	1492	
October 2011	211	883	930	
November 2011	208	967	968	
December 2011	210	786	916	

STORAGE TANK CAPACITY (Gallons)	NUMBER OF EACH	ARIZONA DEPT. OF WATER RESOURCES WELL I.D. NUMBER	WELL PRODUCTION (Gallons per Minute)
5,200	2	55-202458	15
10,000	2	55-621604	55
		55-213141	150
		55-621605	0

Other Water Sources in Gallons per Minute —————→	GPM
Fire Hydrants on System —————→	Yes ^X No
Total Water Pumped Last 13 Months (Gallons in Thousands) —————→	13,584