

ORIGINAL



0000134332

RECEIVED

EAGLETAIL WATER CO., LLC

P.O. Box 157  
Tonopah, AZ 85354  
928-372-2236

2012 FEB 16 A 9:36

February 13, 2012  
AZ CORP COMMISSION  
DOCKET CONTROL

Docket Control  
Arizona Corporation Commission  
1200 West Washington Street  
Phoenix, AZ 85007

Arizona Corporation Commission

DOCKETED

FEB 16 2012

DOCKETED BY 

Re: Docket No. W-03936A-04-0840  
Decision No. 67982

**Revised from 01/28/12 report per Docket Control request**

Yearly water loss report for 2011

Enclosed are copies of water loss and water sold for the calendar year 2011. We have repaired (18) major leaks in 2011. Our water loss has been reduced from calendar year 2010. We have had several leaks that we had trouble determining the amount of water lost. Approximately 1/3 of the leaks were the result of activating an old unused line to provide service to a newly built house.

Our water lines consist of approximately 30 miles of pipe through rural areas and a leak is not always discovered as quickly as we would like. We will continue to monitor our lines as we work towards reaching our goal of 10% or less water loss.

Our total gallons of water pumped for the year is 5,140,400gal and the gallons sold are 3,600,720gal. This shows a water loss of app 30%, a reduction of 13% from 2010. While this shows improvement we are aware this is still far short of our goal

If you have any questions regarding this report please call 928-372-2236 or contact us by mail at the address above.

Respectfully,  
Eagletail Water Co., LLC

COMPANY NAME: EagleTail Water Co. L.L.C # 04070.32 826

**WATER USE DATA SHEET BY MONTH FOR CALENDAR YEAR**

MONTH	NUMBER OF CUSTOMERS	GALLONS SOLD	GALLON PUMPED (Thousands)
JANUARY	46	212,200	326,700
FEBRUARY	46	320,192	385,400
MARCH	46	204,840	317,000
APRIL	45	216,750	324,700
MAY	47	234,570	548,000
JUNE	47	377,580	411,300
JULY	45	378,990	512,000
AUGUST	45	470,370	629,000
SEPTEMBER	48	382,350	321,900
OCTOBER	48	354,927	673,100
NOVEMBER	47	366,071	307,200
DECEMBER	47	181,880	284,100
TOTAL		3,600,720	5,140,400

Is the Water Utility located in an ADWR Active Management Area (AMA)?

( ) Yes

() No

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement?

( ) Yes

() No

If yes, provide the GPCPD amount: \_\_\_\_\_

What is the level of arsenic for each well on your system. 0.0005 mg/l

(If more than one well, please list each separately.)

Note: If you are filing for more than one system, please provide separate data sheets for each system.