

ORIGINAL



DOCKET CONTROL
FORESIGHT FLYING M
DOCKET CONTROL

2013 JAN 15 PM 2 01

Arizona Corporation Commission
DOCKETED

JAN 15 2013

DOCKETED BY

January 15, 2013

Docket Control
Arizona Corporation Commission
1200 West Washington
Phoenix, AZ 85007

Subject: Foresight Flying M LLC, "Grapevine Canyon Wind Project" Transmission Tie-Line Project
Ten Year Plan for Eighth Biennial Electric Transmission Assessment for 2014 through 2023
Docket E-00000D-13-0002

To Whom It May Concern:

Pursuant to A.R.S. 40-360.02 (A), Foresight Flying M, LLC ("FFM", "Project Company"), hereby submits its Ten Year Plan filing for the year 2013 for the Grapevine Canyon Wind Transmission Tie-Line Project ("Project"). Information requirements associated with A.R.S. § 40-360.02 (C) are included as Appendix "A" to this filing.

The Project would connect the up to 500-MW Grapevine Canyon Wind Project to the Western Area Power Administration 345-kV Glen Canyon– Pinnacle Peak No. 1 and No. 2 transmission lines. The proposed 345-kV large generation interconnection would create a new interconnection approximately 22-miles southeast of the City of Flagstaff and 18-miles south of I-40. Appendix "B" includes a map depicting the Project and interconnection location. Such facilities would allow delivery of remotely-located renewable wind energy generation to power markets in the Western interconnect.

An environmental impact statement ("EIS") pursuant to the National Environmental Policy Act was finalized in 2012. The U.S. Department of Energy, Western Area Power Administration ("Western") acted as the lead federal agency overseeing the EIS process. The U.S. Department of Agriculture, Forest Service, Coconino National Forest, and the Arizona State Land Department were cooperating agencies. Proposed and alternative transmission tie-line alignments were evaluated, as depicted on the Appendix "B" map.




Foresight Flying M, LLC
c/o Foresight Wind Energy, LLC, Manager
657 Mission Street, Suite 504 ↗ San Francisco, CA 94105
415-495-0700 ↗ Fax 415-495-0727 ↗ www.foresightwind.com

The Project Company anticipates filing an Application for a Certificate of Environmental Compatibility in the near term.

Please direct any questions that may arise from this report to the undersigned at 415-495-0700.

Sincerely,



Warren W. Byrne
Foresight Flying M, LLC
c/o Foresight Wind Energy (Manager)

cc: File

Steven M. Olea, Utilities Division, Arizona Corporation Commission
Janice Alward, Esq., Legal Division, Arizona Corporation Commission
Thomas H. Campbell, Esq., Lewis and Roca LLP

Appendix A

40-360.02 (C) (1).

The size and proposed route of any transmission lines or location of each plant proposed to be constructed.

The Grapevine Canyon Wind Transmission Tie-Line Project (Project) is a proposed 345kV generation tie line of up to 15 miles in length that will connect the Grapevine Canyon Wind Park to the existing dual circuit 345kV Flagstaff to Pinnacle Peak transmission lines owned and operated by Western Area Power Administration (“Western”).

The Grapevine Canyon Wind Park is anticipated to be built in two or more phases up to a maximum 500 megawatts nameplate capacity. The electricity generated by the wind park would be gathered at the step-up substation within the wind park area, where the voltage would be transformed from 34.5kV to 345kV. The Project would be a new 345kV double-circuit electrical transmission tie-line that would be constructed between the wind park step-up substation and Western’s existing Glen Canyon-Pinnacle Peak No. 1 and No. 2 345-kV transmission lines. The Project would be approximately 15 miles in length, extending 8.5 miles across National Forest system lands and up to approximately 6.5 miles across private lands and trust lands administered by the Arizona State Land Department. The Glen Canyon-Pinnacle Peak 345kV transmission lines are part of the regional electrical grid. Connecting into this existing electrical transmission system would allow electricity produced at the wind project to be sold and utilized by Arizona and regional utilities.

The Project would include pole structures, conductors, and associated access roads. Structures are expected to be gray steel pole structures with non-reflective finishes and would be approximately 120 feet in height and spaced approximately every 1,000 feet. Approximately 80 steel monopole structures would be erected. The Project Company would obtain a special use permit for a right-of-way from the National Forest for the portion of the tie-line that crosses Forest Service land. A minimum 50 year right-of-way, 200 feet in width, would be acquired for construction, operation, access, and maintenance. The Project is a component of the EIS. Construction of the Project is expected to temporarily disturb 345 to 413 acres and permanently disturb 19 to 25 acres of land.

40-360.02 (C) (2).

The purpose to be served by each proposed transmission line or plant.

The Project will interconnect the Grapevine Canyon Wind energy generation project to the regional electricity grid enabling clean, renewable energy to be sold to local and regional utilities.

40-360.02 (C) (3).

The estimated date by which each transmission line or plant will be in operation.

The Project is anticipated to be constructed in 2015 and to be commissioned by the end of 2015 or 2016.

40-360.02 (C) (4).

The average and maximum power output measured in megawatts of each plant to be installed.

Not applicable

40-360.02 (C) (5).

The expected capacity factor for each proposed plant.

Not applicable

40-360.02 (C) (6).

The type of fuel to be used for each proposed plant.

Not applicable

40-360.02 (C) (7).

The plans for any new facilities shall include a power flow and stability analysis report showing the effect on the current Arizona electric transmission system. Transmission owners shall provide the technical reports, analysis, or basis for projects that are included for serving customer load growth in their service territories.

FFM previously provided to ACC Staff a copy of the System Impact Study ("SIS") dated January 22, 2009. This study was conducted by K. R. Saline & Associates, PLC, at the direction of Western. The SIS was performed to identify impacts to reliability as a result of the requested large generation interconnection. Power flow, voltage stability, post transient stability, and short circuit studies were conducted to determine impacts to the existing system. Per the Study Report, the SIS results indicate that the Project has little or no impact to the existing system, and by interconnecting south of the Flagstaff 345kV bus the Project adds reliability to the Glen Canyon system.

Appendix "B"

Grapevine Canyon Wind Project Transmission Tie Line Project

