

ORIGINAL



0000143478

Docket Control Center
ACC
1200 W. Washington St.
Phoenix, AZ. 85007

Docket# W-03912A-11-0014

Dear Sirs,
During the time period that we monitored the water losses was
2/1/13 to 3/1/13.

Sunizona Water Co.
5416 E. Hwy 181
Pearce, AZ. 85625

Arizona Corporation Commission
DOCKETED

MAR 13 2013

DOCKETED BY 

2013 MAR 13 PM 10 03
AZ CORP COMMISSION
DOCKET CONTROL CENTER
RECEIVED

Sunizona Water Company
Well History Summary Report
 date:03/11/13
 Page: 1

<u>Reading Date</u>	<u>Well#1 Reading</u>	<u>Well #2 Reading</u>	<u>Well #3 Reading</u>	<u>Well#4 Reading</u>	<u>Well#5 Reading</u>	<u>Water Pumped</u>	<u>Total use Per Meter</u>	<u>System Losses</u>	<u>Loss % Diff.</u>	<u>% of Total</u>
01/01/13	4925880					24050	140618	-116568	####	35.61
01/02/13	0					-4925880	140618	-5066498	102.85	35.61
02/01/13	230540					230540	113619	116921	50.72	28.77
03/01/13	418830					188290	0	188290	100.00	0.00
% total	100.00	0.00	0.00	0.00	0.00					
Gallons:	-4483000		0		0		394855		108.81	
		0		0		-4483000		-4877855		100.00
acre-feet:	-13.76		0.00		0.00		1.21			
		0.00		0.00		-13.76		-14.97		

- Notes on formulae used:
- 1) Water Pumped is total of Well readings (this month-last month)
 - 2) Total use per Meter = Customer total usage per meter readings
 - 3) System Losses = Water Pumped-Total use per Meter by line
 - 4) Loss % Diff = System Losses this line / G.T. Water Pumped (*100%)
 - 5) % of Total = Total use per Meter this line / G.T. Total use per Meter (*100%)
 - 6) Well % total = gallons pumped by Well / Water Pumped G.T. (*100%)
 - 7) Conversion to acre-feet is 325851.42857 gallons

Docket # W-03912A-11-0014