

ORIGINAL



0000147260

1 Steve Wene, No. 019630  
2 MOYES SELLERS & HENDRICKS LTD.  
3 1850 N. Central Avenue, Suite 1100  
4 Phoenix, Arizona 85004  
5 (602)-604-2189  
6 swene@law-msh.com  
7 Attorneys for Applicant

RECEIVED

2013 AUG -9 P 3:33

CORP COMMISSION  
DOCKET CONTROL

8 **BEFORE THE ARIZONA CORPORATION COMMISSION**

9 **COMMISSIONERS**

10 BOB STUMP, CHAIRMAN  
11 GARY PIERCE  
12 BRENDA BURNS  
13 SUSAN BITTER-SMITH  
14 BOB BURNS

Arizona Corporation Commission  
**DOCKETED**

AUG - 9 2013

DOCKETED BY  
nr

15 **APPLICATION OF ESTATE OF**  
16 **WILLIAM F. RANDALL DBA VALLE**  
17 **VERDE WATER COMPANY FOR AN**  
18 **INCREASE IN ITS WATER RATES**

Docket No. W-01431A-13-0265

**AMENDED PLANT INVENTORY**

19  
20 Estate of William F. Randall dba Valle Verde Water Company (“Company” or  
21 “Applicant”), hereby files amended plant inventory pages to include:

- 22
- 23 • Emergency Interconnect to City of Nogales’ water system;
  - 24 • 100,000 gallon storage tank at Well Site No. 2; and
  - 25 • Granular Activated Carbon Filtration System at Well Site No. 2.

26 The revised plant description pages for the East System are set forth in Attachment 1.

27  
28 ////

1 RESPECTFULLY SUBMITTED this 9<sup>th</sup> day of August, 2013.

2  
3 **MOYES SELLERS & HENDRICKS LTD.**

4   
5 Steve Wene

6  
7 Original and 13 copies of the foregoing  
8 filed this 9<sup>th</sup> day of August, 2013, with:

9 Docket Control  
10 Arizona Corporation Commission  
11 1200 West Washington  
12 Phoenix, Arizona 85007

13   
14

# **Attachment 1**

Company Name: Valle Verde Water Company	Test Year Ended: 12/31/2012
Name of System: East System	

**WATER COMPANY PLANT DESCRIPTION**

**WELLS**

ADWR ID Number*	Pump Horsepower	Pump Yield (gpm)	Casing Depth (Feet)	Casing Diameter (inches)	Meter Size (inches)	Year Drilled
55-617053 (well #1)	Not in use		105	12	4	1954
55-617054 (well #2)	30	350	260	16	6	1972
55-617055 (well #3)	15	130	220	12	3	1971
55-513789 (well #4)	Not in use		203	12	3	1987
55-801847 (well #7)	Not in use		93	10	4	1933

\* Arizona Department of Water Resources Identification Number

**OTHER WATER SOURCES**

Name or Description	Capacity (gpm)	Gallons Purchased or Obtained (in thousands)
City of Nogales Interconnect	150	Emergency Only

**BOOSTER PUMPS**

Horsepower	Quantity
15.0	1
7.5	1

**FIRE HYDRANTS**

Quantity Standard	Quantity Other
13	

**STORAGE TANKS**

Capacity	Quantity
100,000 gallons (well 2)	1

**PRESSURE TANKS**

Capacity	Quantity
7,000	1
3,000	2
7,500	1
10,000	1
2,000	1
200	1

Company Name: Valle Verde Water Company	Test Year Ended: 12/31/2012
Name of System: East System	

**WATER COMPANY PLANT DESCRIPTION (CONTINUED)**

**MAINS**

Size (in inches)	Material	Length (in feet)
2	PVC	4,361
3		
4	PVC	38,391
5		
6	PVC	4,117
8		
10		
12		
6	PVC	1,600
6	PVC	2,350
4	PVC	100
6	DIP	189

**CUSTOMER METERS**

Size (in inches)	Quantity
5/8 x 3/4	319
3/4	411
1	38
1 1/2	3
2	10
Comp. 3	5
Turbo 3	
Comp. 4	
Turbo 4	
Comp. 6	
Turbo 6	

**For the following three items, please list the utility owned assets in each category.**

**TREATMENT EQUIPMENT:**

Granular Activated Carbon Filtration System at Well #2.

---



---



---



---

**STRUCTURES:**

Office 12' x 12'

Chlorinator room 3' x 5'

Well #1 building 24' x 24'

House 32' x '76

**OTHER:**

---



---



---



---