

COMMISSIONERS
BOB STUMP - Chairman
GARY PIERCE
BRENDA BURNS
BOB BURNS
SUSAN BITTER SMITH

OPEN MEETING ITEM



0000150837

ARIZONA CORPORATION COMMISSION

ORIGINAL

RECEIVED
AZ CORP COMMISSION
DOCKET CONTROL

DATE: JANUARY 16, 2014 2014 JAN 16 AM 9 29
DOCKET NO.: W-02005A-13-0201

TO ALL PARTIES:

Enclosed please find the recommendation of Administrative Law Judge Belinda A. Martin. The recommendation has been filed in the form of an Order on:

ANTELOPE WATER COMPANY
(RATES)

Pursuant to A.A.C. R14-3-110(B), you may file exceptions to the recommendation of the Administrative Law Judge by filing an original and thirteen (13) copies of the exceptions with the Commission's Docket Control at the address listed below by **4:00** p.m. on or before:

JANUARY 27, 2014

The enclosed is NOT an order of the Commission, but a recommendation of the Administrative Law Judge to the Commissioners. Consideration of this matter has tentatively been scheduled for the Commission's Open Meeting to be held on:


FEBRUARY 6, 2014 and FEBRUARY 7, 2014

For more information, you may contact Docket Control at (602) 542-3477 or the Hearing Division at (602) 542-4250. For information about the Open Meeting, contact the Executive Director's Office at (602) 542-3931.

Arizona Corporation Commission

DOCKETED

JAN 16 2014

DOCKETED BY 


JODI JERICH
EXECUTIVE DIRECTOR

1200 WEST WASHINGTON STREET; PHOENIX, ARIZONA 85007-2927 / 400 WEST CONGRESS STREET; TUCSON, ARIZONA 85701-1347
www.azcc.gov

This document is available in alternative formats by contacting Shaylin Bernal, ADA Coordinator, voice phone number 602-542-3931, E-mail SABernal@azcc.gov.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

BEFORE THE ARIZONA CORPORATION COMMISSION

COMMISSIONERS

BOB STUMP - Chairman
GARY PIERCE
BRENDA BURNS
BOB BURNS
SUSAN BITTER SMITH

IN THE MATTER OF THE APPLICATION OF
ANTELOPE WATER COMPANY FOR A
PERMANENT RATE INCREASE.

DOCKET NO. W-02005A-13-0201

DECISION NO. _____

ORDER

Open Meeting
February 6 and 7, 2014
Phoenix, Arizona

BY THE COMMISSION:

Having considered the entire record herein and being fully advised in the premises, the Arizona Corporation Commission ("Commission") finds, concludes, and orders that:

PROCEDURAL HISTORY

1. On June 20, 2013, Antelope Water Company ("AWC" or "Company") filed an application with the Commission for a permanent rate increase and on July 12, 2013, the Company filed an amendment to the application (collectively, the "Application"). AWC attached to the Application a copy of the notice provided to customers on June 18, 2013, regarding the Application. No customer comments have been filed in response to the notice.

2. On July 18, 2013, the Commission's Utilities Division ("Staff") advised AWC that its application was insufficient and provided the Company with Data Requests, to which AWC responded on July 31, 2013.

3. On August 5, 2013, Staff filed its Sufficiency Letter stating the Application was sufficient pursuant to Arizona Administrative Code ("A.A.C.") R14-2-103, and classifying AWC as a Class E utility.

...
...

1 is not metered prior to distribution to customers and AWC calculates the total water usage through its
 2 customers' service meters. The average and median water use by customers during the test year were
 3 18,880 gallons and 10,919 gallons per month, respectively.

4 10. AWC's present rates and charges, as proposed by AWC in its Application, and as
 5 recommended by Staff in its Staff Report, are as follows:

	<u>Present Rates</u>	<u>Proposed Rates Company</u>	<u>Proposed Rates Staff</u>
<u>MONTHLY USAGE CHARGE:</u>			
5/8 x 3/4-inch Meter	\$11.50	\$17.50	\$13.50
3/4-inch Meter	13.00	19.00	13.50
1-inch Meter	20.00	26.00	33.75
1 1/2-inch Meter	28.50	34.50	67.50
2-inch Meter	60.00	66.00	108.00
3-inch Meter	120.00	126.00	216.00
4-inch Meter	250.00	256.00	337.50
6-inch Meter	500.00	506.00	675.00

Gallons Included in Minimum	1,000	1,000	0
-----------------------------	-------	-------	---

13 **COMMODITY CHARGE:**
 14 **(Per 1,000 gallons)**

<u>All Meter Sizes</u>			
Over 1,000 gallons	\$1.50	\$1.50	N/A
0 to 5,000 gallons	N/A	N/A	\$1.00
5,001 to 15,000 gallons	N/A	N/A	1.40
Over 15,000 gallons	N/A	N/A	2.10

18 **SERVICE LINE AND METER INSTALLATION CHARGES:**
 19 **(Refundable Pursuant to A.A.C. R14-2-405)**

	<u>Current Charges</u>	<u>Company's Proposed Charges</u>	<u>Staff Recommended Service Line</u>	<u>Staff Recommended Meter</u>	<u>Staff Recommended Total Charges</u>
5/8" x 3/4" Meter	\$310.00	\$310.00	\$415.00	\$105.00	\$520.00
3/4" Meter	350.00	350.00	415.00	205.00	620.00
1" Meter	400.00	400.00	465.00	265.00	730.00
1-1/2" Meter	610.00	610.00	At Cost	At Cost	At Cost
2" Meter Turbine	1,025.00	1,025.00	At Cost	At Cost	At Cost
3" Meter Turbine	1,405.00	1,405.00	At Cost	At Cost	At Cost
4" Meter Turbine	2,240.00	2,240.00	At Cost	At Cost	At Cost
6" Meter Turbine	4,345.00	4,345.00	At Cost	At Cost	At Cost

26 ...
 27 ...
 28 ...

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

	<u>Present Rates</u>	<u>Proposed Rates Company</u>	<u>Proposed Rates Staff</u>
<u>SERVICE CHARGES:</u>			
Establishment	\$20.00	\$20.00	\$20.00
Establishment (After Hours)	40.00	40.00	N/A ³
Service Charge (After Hours)	N/A	N/A	\$40.00
Reconnection (Delinquent)	\$40.00	\$40.00	40.00
Meter Test (If Correct)	30.00	30.00	30.00
Meter Re-Read (If Correct)	10.00	10.00	10.00
NSF Check	15.00	15.00	15.00
Deposit	*	*	*
Deposit Interest	*	*	*
Re-establishment (Within 12 months)	**	**	**
Deferred Payment (Per Month)	1.50%	1.50%	1.50%
Late Fee (Per Month)	1.50%	1.50%	1.50%

MONTHLY SERVICE CHARGE FOR FIRE SPRINKERS:

4" or Smaller	N/A	N/A	***
6"	N/A	N/A	***
8"	N/A	N/A	***
10"	N/A	N/A	***
Larger than 10"	N/A	N/A	***

- * Per Commission Rule A.A.C. R-14-2-403(B).
- ** Months off system times the monthly minimum per Commission Rule A.A.C. R14-2-403(D).
- *** 2.00% of Monthly Minimum for a Comparable Sized Meter Connection, but no less than \$10.00 per month. The Service Charge for Fire Sprinklers is only applicable for service lines separate and distinct from the primary water service line.

11. Staff determined AWC's original cost rate base to be negative \$5,717, which is the same as its fair value rate base ("FVRB"). This is a \$208,150 increase to AWC's proposed FVRB of negative \$213,867, primarily due to Staff's \$209,050 adjustment to accumulated amortization of contribution in aid of construction. Staff also made adjustments to the Company's proposed plant-in-service, accumulated depreciation, and working capital amounts.

12. We find Staff's adjustments to AWC's FVRB are reasonable and we adopt Staff's proposed FVRB of negative \$5,717.

13. Staff increased AWC's proposed test year operating revenues by \$231, from \$29,070 to \$29,301.

...

...

³ Staff's Schedule BCA-4 lists a recommended Establishment (After Hours) Service Charge of \$40.00. However, in the Staff Report, Staff recommended the elimination of the Establishment (After Hours) Service Charge in favor of an overall After Hours Service Charge of \$40.00. (Staff Report, page 8.)

1 14. Staff made several adjustments to AWC's proposed test year operating expenses,
2 resulting in a decrease of \$13,017, from \$39,856 to \$26,839.⁴ The decrease to AWC's test year
3 operating expenses is primarily due to Staff's \$12,905 reduction in depreciation expense. Staff also
4 made adjustments to AWC's proposed repairs and maintenance expense, water testing expense, rate
5 case expense, and property tax expense.

6 15. Based on Staff's analysis, AWC's present rates and charges produced adjusted
7 operating revenues of \$29,301 and adjusted operating expenses of \$26,839, resulting in a net test year
8 operating income of \$2,462, a cash flow of \$710,⁵ and an operating margin of 8.40 percent.

9 16. AWC's proposed rates and charges produce operating revenues of \$33,606 and
10 operating expenses of \$39,856, resulting in operating loss of \$6,250, for no return on FVRB, but
11 yielding a positive cash flow of \$4,903.

12 17. Given AWC's negative FVRB, Staff was unable to determine a meaningful rate of
13 return for AWC. Instead, Staff adopted a cash flow methodology to calculate adequate revenue to
14 meet the Company's operating needs. Staff's recommended rates and charges result in a \$4,305
15 increase over adjusted test year revenues, or 14.69 percent, for total revenues of \$33,606. With
16 recommended operating expenses of \$27,029, AWC would receive \$6,577 in operating income,
17 resulting in a cash flow of \$4,825 and an operating margin of 19.57 percent.

18 18. We find Staff's operating revenue, operating expense (as revised to reflect a 19
19 percent property tax assessment ratio) and revenue recommendations reasonable and we adopt them.

20 19. AWC's proposed rates would increase the average monthly customer water bill by
21 \$7.50, or 19.6 percent, from \$38.32 to \$45.82, and increase the median monthly customer water bill
22 by \$7.50, or 28.4 percent, from \$26.38 to \$33.88.

23 ...

24 ...

25

26 ⁴ In their property tax expense calculations, both AWC and Staff used an assessment ratio of 22.5 percent. Pursuant to
27 A.R.S. § 42-15001, the current property tax assessment ratio is 19 percent. The operating expense amounts stated herein
28 are based on revisions to Staff's calculations found on Schedule BCA-3, page 4, using the current statutory assessment
ratio, and the flow through of the corrected property tax figures to Staff schedules BCA-1 and BCA-3, page 1.

⁵ In Decision No. 60166 (April 17, 1997), the Commission authorized a \$75,000 loan from the USDA Rural Development
for system improvements. The annual debt service on the 40-year loan is \$3,132.

1 20. Staff's proposed rates would increase the average monthly customer water bill by
2 \$2.33, or 6.1 percent, from \$38.32 to \$40.65, and increase the median monthly customer water bill by
3 \$0.41, or 1.5 percent, from \$26.38 to \$26.79.

4 21. AWC did not file objections to Staff's recommended rates and charges.

5 22. We find Staff's proposed rates and charges reasonable and we adopt them.

6 23. Staff recommends that AWC file with Docket Control, as a compliance item in this
7 docket, within 30 days of the effective date of this Decision, a schedule of the approved rates and
8 charges.

9 24. Staff further recommends that AWC adopt Staff's typical and customary depreciation
10 rates shown in the attached Exhibit A on a going-forward basis.

11 25. In Staff's Engineering Report, Staff stated that during an on-site inspection with AWC
12 representatives, Staff observed a new 50,000 gallon storage tank, a new hydro-pneumatic pressure
13 tank, and a building for housing new filtration equipment located on the site containing the
14 Company's water treatment plant; however, the storage tank and the pressure tank were not
15 connected to the system.

16 26. Staff learned that in 2008, a developer planned a new subdivision within the
17 Company's certificated area and constructed the infrastructure for the subdivision and two model
18 homes using loan proceeds acquired from AEA Federal Credit Union ("AEA"). The developer did
19 not obtain an Approval to Construct the system infrastructure from the Arizona Department of
20 Environmental Quality ("ADEQ"), nor was a main extension agreement submitted to the
21 Commission for approval. The developer subsequently filed for bankruptcy and AEA acquired
22 ownership of the new tanks, the building at AWC's treatment site, the subdivision and the model
23 homes. Staff noted that the plant items are not included in the Company's rate base.

24 27. According AWC, it has reached an agreement with AEA regarding the disposition of
25 the plant items under the terms of a Water Service Agreement ("Agreement"). Pursuant to the
26 Agreement, AEA will transfer possession and ownership of the storage tank, pressure tank and the

27 ...

28 ...

1 building housing the filtration system to AWC and AWC will provide water service to five lots
2 within the new subdivision. The Company states that AEA has signed the Agreement, but as of the
3 date of the Staff Report AEA had not provided a signed copy to Staff.

4 28. Staff recommends that AWC file with Docket Control, as a compliance item in this
5 docket, within 90 days of the effective date of this Decision, copies of the fully-executed Agreement.

6 29. Engineering Staff also noted that the raw water provided by WMIDD is not metered
7 and the Company accounts for the total raw water volume received by total customer usage. Because
8 the inflowing raw water is not metered, the Company cannot compute any water loss resulting from
9 leakage, theft, filter backwashing and flushing. Staff observed that AWC has an inoperable flow
10 meter on its booster pump discharge pipe that, if repaired or replaced, could provide adequate water
11 volume information.

12 30. Staff recommends that AWC repair or replace the broken flow meter on the booster
13 pump discharge pipe and file with Docket Control, as a compliance item in this docket, within 90
14 days of the effective date of this Decision, documentation demonstrating that the repair or
15 replacement of the flow meter has been completed.

16 31. Because the Company has not been able to determine levels of non-accounted for
17 water, Staff recommends that once there is a functioning flow meter, the Company should begin
18 monitoring water loss on a monthly basis by coordinating readings of the flow meter, filter backwash
19 and individual customer meters and report the water loss monitoring results in its Annual Reports to
20 the Utilities Division.

21 32. Further, in the event water loss reported in any Annual Report is greater than 10
22 percent, AWC should prepare a report containing a detailed analysis and plan to reduce water loss to
23 less than 10 percent. If the Company believes it is not cost effective to reduce the water loss to less
24 than 10 percent, the Company should submit a detailed cost/benefit analysis to support its opinion. In
25 no case should the Company allow water loss to be greater than 15 percent. The water loss reduction
26 report or the detailed analysis, whichever is submitted, should be filed with Docket Control as a
27 compliance item in this docket no later than March 31st of the year following a reported water loss of
28 greater than 10 percent.

1 33. Staff also concluded that AWC does not have adequate storage capacity and
2 recommends that the Company increase capacity by a minimum of 15,000 gallons. Staff stated that
3 installation of the storage tank transferred from AEA to AWC would resolve the storage concerns.

4 34. Staff recommends that AWC file with Docket Control, as a compliance item in this
5 docket, no later than December 31, 2014, a copy of the ADEQ Approval of Construction for the
6 additional storage capacity.

7 35. AWC is not within an Arizona Department of Water Resources ("ADWR") active
8 management area ("AMA"). In a Compliance Status Report dated July 1, 2013, ADWR determined
9 that AWC is currently in compliance with departmental requirements governing water providers
10 and/or community water systems.

11 36. Staff recommends that the Company file with Docket Control, as a compliance item in
12 this docket, within 90 days of the effective date of this Decision, at least three BMPs in the form of
13 tariffs that substantially conform to the templates available at the Commission's website, for the
14 Commission's review and consideration. Not more than two of the BMPs may come from the
15 "Public Awareness/Public Relations" or "Education and Training" categories. In its next general rate
16 application, AWC may request recovery of the actual costs incurred by BMP implementation.

17 37. In a Compliance Status Report dated August 26, 2013, ADEQ determined that AWC
18 is in full compliance with ADEQ requirements and is currently delivering water that meets water
19 quality standards required by A.A.C., Title 18, Chapter 4.

20 38. According to Staff, AWC is in compliance with Commission filing requirements and
21 is in good standing with the Corporations Division.

22 39. Staff's review of the Commission's Consumer Services records showed that between
23 January 1, 2010, and September 16, 2013, there were no inquiries, complaints or opinions filed
24 against AWC.

25 40. AWC has Commission-approved Backflow and Curtailment tariffs.

26 41. AWC is current on its property and sales tax payments.

27 42. We believe it is reasonable to allow AWC to collect from its customers a
28 proportionate share of any privilege, sales or use tax as provided for in A.A.C. R14-2-409(D).

1 43. Because an allowance for the property tax expense is included in AWC's rates and
2 will be collected from its customers, the Commission seeks assurances from AWC that any taxes
3 collected from ratepayers have been remitted to the appropriate taxing authority. It has come to the
4 Commission's attention that a number of water companies have been unwilling or unable to fulfill
5 their obligation to pay the taxes that were collected from its ratepayers, some for as many as twenty
6 years. It is reasonable, therefore, that as a preventive measure AWC shall file annually, as part of its
7 annual report, an affidavit with the Commission's Utilities Division attesting that the Company is
8 current in paying its Arizona property taxes.

9 44. Staff's recommendations, as well as the requirements stated in Findings of Fact Nos.
10 42 and 43, are reasonable and shall be adopted.

11 **CONCLUSIONS OF LAW**

12 1. AWC is a public service corporation within the meaning of Article XV of the Arizona
13 Constitution and A.R.S. §§ 40-250, 40-251.

14 2. The Commission has jurisdiction over AWC and the subject matter of the Application.

15 3. AWC gave notice of the Application in accordance with Arizona law.

16 4. The rates and charges authorized herein are just and reasonable and should be
17 approved without a hearing.

18 5. Staff's recommendations, as well as the requirements stated in Findings of Fact Nos.
19 42 and 43, are reasonable and should be adopted.

20 **ORDER**

21 IT IS THEREFORE ORDERED that Antelope Water Company is hereby directed to file with
22 Docket Control, as a compliance item in this docket, by February 28, 2014, revised schedules setting
23 forth the following rates and charges:

24 **MONTHLY USAGE CHARGE:**

25 5/8 x 3/4-inch Meter	\$ 13.50
3/4-inch Meter	13.50
26 1-inch Meter	33.75
1 1/2-inch Meter	67.50
2-inch Meter	108.00
27 3-inch Meter	216.00
4-inch Meter	337.00
28 6-inch Meter	675.00

1 COMMODITY CHARGE:
2 (Per 1,000 gallons)

3 All Meter Sizes

3 0 to 5,000 gallons	\$ 1.00
4 5,001 to 15,000 gallons	1.40
Over 15,000 gallons	2.10

5
6 SERVICE LINE AND METER INSTALLATION CHARGES:
 (Refundable Pursuant to A.A.C. R14-2-405)

	<u>Service Line</u>	<u>Meter Charge</u>	<u>Total Charges</u>
7 5/8" x 3/4" Meter	\$415.00	\$105.00	\$520.00
8 3/4" Meter	415.00	205.00	620.00
9 1" Meter	465.00	265.00	730.00
1-1/2" Meter	At Cost	At Cost	At Cost
2" Meter	At Cost	At Cost	At Cost
10 3" Meter	At Cost	At Cost	At Cost
4" Meter	At Cost	At Cost	At Cost
11 6" Meter	At Cost	At Cost	At Cost

12 SERVICE CHARGES:

13 Establishment	\$20.00
Service Charge (After Hours)	40.00
Reconnection (Delinquent)	40.00
14 Meter Test (If Correct)	30.00
Meter Re-Read (If Correct)	10.00
15 NSF Check	15.00
Deposit	*
16 Deposit Interest	*
Re-establishment (Within 12 months)	**
17 Deferred Payment (Per Month)	1.50%
18 Late Fee (Per Month)	1.50%

19 MONTHLY SERVICE CHARGE FOR FIRE SPRINKLERS:

19 4" or Smaller	***
20 6"	***
8"	***
10"	***
21 Larger than 10"	***

22 * Per Commission Rule A.A.C. R-14-2-403(B).

23 ** Months off system times the monthly minimum per Commission Rule A.A.C. R14-2-403(D).

24 *** 2.00% of Monthly Minimum for a Comparable Sized Meter Connection, but no less than \$10.00 per month. The Service Charge for Fire Sprinklers is only applicable for service lines separate and distinct from the primary water service line.

25 IT IS FURTHER ORDERED that, in addition to collection of its regular rates and charges,
26 Antelope Water Company shall collect from its customers a proportionate share of any privilege,
27 sales or use tax per A.A.C. R14-2-409(D).
28

1 IT IS FURTHER ORDERED that the above rates and charges shall be effective for all service
2 provided on and after March 1, 2014.

3 IT IS FURTHER ORDERED that Antelope Water Company shall notify its customers of the
4 authorized rates and charges and their effective date, in a form acceptable to the Commission's
5 Utilities Division Staff, by means of an insert in its next regularly scheduled billing.

6 IT IS FURTHER ORDERED that Antelope Water Company shall use the depreciation rates
7 shown in the attached Exhibit A on a going-forward basis.

8 IT IS FURTHER ORDERED that Antelope Water Company file with Docket Control, as a
9 compliance item in this docket, within 90 days of the effective date of this Decision, documentation
10 demonstrating that the repair or replacement of the flow meter on the booster pump discharge pipe
11 has been completed.

12 IT IS FURTHER ORDERED that Antelope Water Company shall begin monitoring water
13 loss on a monthly basis by coordinating readings of the flow meter, filter backwash and individual
14 customer meters and shall report the water loss monitoring results in its Annual Reports to the
15 Utilities Division.

16 IT IS FURTHER ORDERED that in the event water loss reported in any Annual Report is
17 greater than 10 percent, Antelope Water Company shall prepare a report containing a detailed
18 analysis and plan to reduce water loss to less than 10 percent. If Antelope Water Company believes it
19 is not cost effective to reduce the water loss to less than 10 percent, the Company shall submit a
20 detailed cost/benefit analysis to support its opinion. In no case shall the Company allow water loss to
21 be greater than 15 percent. The water loss reduction report or the detailed analysis, whichever is
22 submitted, shall be filed with Docket Control as a compliance item in this docket no later than March
23 31st of the year following a reported water loss of greater than 10 percent.

24 IT IS FURTHER ORDERED that Antelope Water Company shall file with Docket Control,
25 as a compliance item in this docket, within 90 days of the effective date of this Decision, a copy of
26 the executed Water Service Agreement between Antelope Water Company and AEA Federal Credit
27 Union.

28 ...

1 IT IS FURTHER ORDERED that Antelope Water Company shall file with Docket Control,
2 as a compliance item in this docket, no later than December 31, 2014, a copy of the ADEQ Approval
3 of Construction for the additional storage capacity.

4 IT IS FURTHER ORDERED that Antelope Water Company shall file with Docket Control,
5 as a compliance item in this docket, within 90 days of the effective date of this Decision, at least three
6 BMPs in the form of tariffs that substantially conform to the templates available at the Commission's
7 website, for the Commission's review and consideration. Not more than two of the BMPs may come
8 from the "Public Awareness/Public Relations" or "Education and Training" categories. In its next
9 general rate application, Antelope Water Company may request recovery of the actual costs incurred
10 by BMP implementation.

11 ...
12 ...
13 ...
14 ...
15 ...
16 ...
17 ...
18 ...
19 ...
20 ...
21 ...
22 ...
23 ...
24 ...
25 ...
26 ...
27 ...
28 ...

1 IT IS FURTHER ORDERED that Antelope Water Company shall file annually, as part of its
2 Annual Report, an affidavit with the Commission's Utilities Division attesting that it is current in
3 paying its property taxes in Arizona.

4 IT IS FURTHER ORDERED that this Decision shall become effective immediately.

5 BY ORDER OF THE ARIZONA CORPORATION COMMISSION.
6
7

8 CHAIRMAN _____ COMMISSIONER

9
10 COMMISSIONER _____ COMMISSIONER _____ COMMISSIONER

11
12 IN WITNESS WHEREOF, I, JODI JERICH, Executive
13 Director of the Arizona Corporation Commission, have
14 hereunto set my hand and caused the official seal of the
15 Commission to be affixed at the Capitol, in the City of Phoenix,
16 this _____ day of _____ 2014.

17 JODI JERICH _____
18 EXECUTIVE DIRECTOR

19 DISSENT _____

20 DISSENT _____
21 BM:tv

22
23
24
25
26
27
28

1 SERVICE LIST FOR: ANTELOPE WATER COMPANY

2 DOCKET NO.: W-02005A-13-0201

3
4 John Kulberg, Director
5 ANTELOPE WATER COMPANY
6 P. O. Box 843
7 Wellton, AZ 85356

8 Janice Alward, Chief Counsel
9 Legal Division
10 ARIZONA CORPORATION COMMISSION
11 1200 W. Washington Street
12 Phoenix, AZ 85007

13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900
901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000

EXHIBIT A

Table C. Depreciation Rate Table for Water Companies

Asset No.	Depreciable Plant	Average Service Life (Years)	Rate (%)
304	Structures & Improvements	30	3.33
305	Collecting & Impounding Reservoirs	40	2.50
306	Lake, River, Canal Intakes	40	2.50
307	Wells & Springs	30	3.33
308	Infiltration Galleries	15	6.67
309	Raw Water Supply Mains	50	2.00
310	Power Generation Equipment	20	5.00
311	Pumping Equipment	8	12.5
320	Water Treatment Equipment		
320.1	Water Treatment Plants	30	3.33
320.2	Solution Chemical Feeders	5	20.00
320.3	Point-of-Use Treatment Devices	10	10.00
330	Distribution Reservoirs & Standpipes		
330.1	Storage Tanks	45	2.22
330.2	Pressure Tanks	20	5.00
331	Transmission & Distribution Mains	50	2.00
333	Services	30	3.33
334	Meters	12	8.33
335	Hydrants	50	2.00
336	Backflow Prevention Devices	15	6.67
339	Other Plant & Misc Equipment	15	6.67
340	Office Furniture & Equipment	15	6.67
340.1	Computers & Software	5	20.00
341	Transportation Equipment	5	20.00
342	Stores Equipment	25	4.00
343	Tools, Shop & Garage Equipment	20	5.00
344	Laboratory Equipment	10	10.00
345	Power Operated Equipment	20	5.00
346	Communication Equipment	10	10.00
347	Miscellaneous Equipment	10	10.00
348	Other Tangible Plant	—	—