

ORIGINAL

NEW APPLICATION



0000154107

RECEIVED

Arizona Corporation Commission

DOCKETED

OCT 15 2014

2014 OCT 15 P 2:26

FENNEMORE CRAIG, P.C.
Jay L. Shapiro (No. 014650)
2394 E. Camelback Road, Suite 600
Phoenix, Arizona 85016
Telephone (602) 916-5000
Attorneys for Quail Creek Water Company, Inc.

CORP COMMISSION
DOCKET CONTROL

DOCKETED BY

BEFORE THE ARIZONA CORPORATION COMMISSION

IN THE MATTER OF THE APPLICATION
OF QUAIL CREEK WATER COMPANY,
INC., AN ARIZONA CORPORATION, FOR
APPROVAL OF A CROSS-CONNECTION
OR BACKFLOW TARIFF.

DOCKET NO. W-02514A-14-0370
NEW TARIFF FILING –
CROSS-CONNECTION
OR BACKFLOW TARIFF

Quail Creek Water Company, Inc. (the "Company") hereby gives notice of filing a cross-connection or backflow tariff. See **Exhibit A**. The Company respectfully requests that the Commission approve the new tariff in a timely manner.

RESPECTFULLY SUBMITTED this 15th day of October, 2014.

FENNEMORE CRAIG, P.C.

By
Jay L. Shapiro
2394 E. Camelback Road
Suite 600
Phoenix, Arizona 85016
Attorneys for Quail Creek Water
Company, Inc.

ORIGINAL and fifteen (15) copies of the foregoing were filed this 15th day of October, 2014, with:

Docket Control
Arizona Corporation Commission
1200 W. Washington St.
Phoenix, AZ 85007

1 **COPY** of the foregoing hand-delivered
2 this 15th day of October, 2014, to:

3 Steven M. Olea, Director
4 Utilities Division
5 Arizona Corporation Commission
6 1200 W. Washington Street
7 Phoenix, AZ 85007

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
By: 
9626285.1

EXHIBIT A

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Quail Creek Water Company, Inc. (the "Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6. and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

Issued: _____

ISSUED BY:

Effective: _____

Steven Soriano, Vice President
Quail Creek Water Company, Inc.
9532 E. Riggs Road
Sun Lakes, AZ 85248

DOCKET NO.

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location;
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

Issued: _____

ISSUED BY:

Effective: _____

Steven Soriano, Vice President
Quail Creek Water Company, Inc.
9532 E. Riggs Road
Sun Lakes, AZ 85248