



0000154612

1 Steve Wene, No. 019630
2 MOYES SELLERS & HENDRICKS LTD.
3 1850 N. Central Avenue, Suite 1100
4 Phoenix, Arizona 85004
5 (602)-604-2189
6 swene@law-msh.com
7 Attorneys for Applicant

RECEIVED
2014 JUL 10 A 11: 50
CORP COMMISSION
DOCKET CONTROL

ORIGINAL

BEFORE THE ARIZONA CORPORATION COMMISSION

COMMISSIONERS

10 BOB STUMP, CHAIRMAN
11 GARY PIERCE
12 BRENDA BURNS
13 SUSAN BITTER-SMITH
14 BOB BURNS

Arizona Corporation Commission
DOCKETED

JUL 10 2014

DOCKETED BY 

15 **APPLICATION OF ESTATE OF**
16 **WILLIAM F. RANDALL DBA VALLE**
17 **VERDE WATER COMPANY FOR AN**
18 **INCREASE IN ITS WATER RATES**

Docket No. W-01431A-13-0265

**NOTICE OF FILING BEST
MANAGEMENT PRACTICES
TARIFF**

19
20 Pursuant to Decision No. 74503, the Estate of William F. Randall dba Valle Verde
21 Water Company hereby files the Best Management Practices 4.2 – Meter Repair and/or
22 Replacement Tariff. See Attachment 1.


23
24 RESPECTFULLY SUBMITTED this 10th day of July, 2014.

25
26 **MOYES SELLERS & HENDRICKS LTD.**

27 
28 Steve Wene

1 Original and 13 copies of the foregoing
2 filed this 10th day of July, 2014, with:

3 Docket Control
4 Arizona Corporation Commission
5 1200 West Washington
6 Phoenix, Arizona 85007

7 
8 _____
9

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

Attachment 1

Company: Valle Verde Water Company

Decision No.: 74503

Phone: 520-623-5172

Effective Date: June 1, 2014

Meter Repair and/or Replacement Tariff – BMP 4.2

PURPOSE

A program for the Valle Verde Water Company (Company) to systematically assess all in-service water meters (including Company production meters) in its water service area to identify under-registering meters for repair or replacement (Modified Non-Per Capita Conservation Program Best Management Practice Category 4: Physical System Evaluation and Improvement 4.2 Meter Repair and/or Replacement Program).

REQUIREMENTS

The requirements of this tariff are governed by Rules of the Arizona Corporation Commission and were adapted from the Arizona Department of Water Resources' Required Public Education Program and Best Management Practices in the Modified Non-Per Capita Conservation Program.

1. On a systematic basis, the Company will inspect 100 percent of its 1-inch and smaller in-service water meters at least once every ten years for one of the following reasons (whichever occurs first):
 - a. A meter reading complaint is filed with the Company by a customer or Arizona Corporation Commission Staff,
 - b. A meter has registered 1,000,000 gallons of usage,
 - c. A meter has been in service for ten years.
2. Meters larger than 1-inch shall be inspected for one of the following reasons:
 - a. A meter reading complaint is filed with the Company by a customer or Arizona Corporation Commission Staff,
 - b. A meter has been in service for five years.
3. The inspection will be accomplished by having the meter pulled and having a Company Technician physically inspect each meter and its fittings for leaks, registers which may have become loose or are not properly attached to the meter and could be under-registering or other broken parts which need repair. In addition, meters shall be randomly selected for flow testing to identify potentially under-registering meters.
4. The Company shall also replace or reprogram any water meters that do not register in gallons. Upon the effective date of this tariff, the Company shall install all replacement meters with new:
 - a. 1-inch and smaller meters that register in 1 gallon increments,
 - b. 1-1/2-inch through 4-inch meters that register in 10 gallon increments, and
 - c. 6-inch and larger meters that register in 100 gallon increments.
5. The Company shall keep records of all inspected and replacement meters and make this information available to the Commission upon request.

Company: Valle Verde Water Company

Decision No.: 74503

Phone: 520-623-5172

Effective Date: June 1, 2014

6. The Company will replace at least (10) improperly functioning Company meters each month until all improperly functioning meters have been replaced.