



0000154958

July 15, 2014

Arizona Corporation Commission
Docket Control
1200 W. Washington St.
Phoenix, AZ 85007

RECEIVED


2014 JUL 29 11:01

ARIZONA CORPORATION COMMISSION
DOCKET CONTROL

Arizona Corporation Commission

DOCKETED

JUL 29 2014

DOCKETED BY 

Subject: Links at Coyote Wash Utilities, LLC – Docket# SW04210A-10-0392
Compliance Item – Bi-annual Update on Odor Complaints & Actions taken

ORIGINAL

Since our last update on January 20, 2014, the operators & management of Links at Coyote Wash Utilities, LLC (LACW) received one formal odor complaint, and approximately four informal odor complaints. The most recent complaint was in February.

The company has made some changes to the plant equipment in order that it better addresses odors (and improves operational performance):

- An active carbon filtration system, previously located at a remote lift station site, has been relocated and is operating at the plant site now. It has been set up to pull potentially objectionable aerosols from the flow equalization basin (where influent raw sewage enters the treatment process) through a series of filters to scrub the air.
- We also replaced the aeration diffusers and repaired some damaged airlifts in the treatment process to provide better mixing and aeration. This will allow the operator to better respond to varying flows, and better aerated mixed liquor generally has less of a potential for objectionable odor.


As mentioned previously, we have established a reporting protocol and provided a form to the customers to use in the event of an odor issue. Furthermore, we continue to flush (using a water truck) sewer mains in areas of low flows (because of very few houses on long stretches of sewer lines) to prevent raw sewage from becoming septic.

Finally, in March of 2014, the Company hired a commercial jetter-machine and crew to provide routine maintenance of the gravity collection system, focusing on areas that have generated odor complaints in the past.

In general, as manager of LACW, I continue to remind our operator and local representatives that the best policy to handling odor complaints is responsiveness.

If you have any questions, please contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. Williamson', written over a horizontal line.

Jason Williamson
Manager, Links at Coyote Wash Utilities, LLC
7581 E Academy Blvd. Suite 229
Denver, CO 80230
(720) 949-1384