



0000155865

**LAWRENCE V. ROBERTSON, RECEIVED**

ATTORNEY AT LAW

P. O. Box 1448  
TUBAC, ARIZONA 85646

(520) 398-0411  
FAX: (520) 398-0412  
EMAIL: TUBACLAWYER@AOL.COM

2014 SEP 11 A 11:05

AZ CORP COMMISSION DOCKET CONTROL  
ADMITTED TO PRACTICE IN:  
ARIZONA, COLORADO, MONTANA,  
NEVADA, TEXAS, WYOMING,  
DISTRICT OF COLUMBIA

OF COUNSEL TO  
**MUNGER CHADWICK**  
ATTORNEYS AT LAW

September 10, 2014

Docket Control  
Arizona Corporation Commission  
1200 West Washington  
Phoenix, Arizona 85007

**ORIGINAL**

Arizona Corporation Commission  
**DOCKETED**

SEP 11 2014

DOCKETED BY

Re: Red Rock Utilities, L.L.C.  
Docket No. WS-04245A-14-0316  
Amended Cross Connection or Backflow Tariff

To Whom It May Concern:

As a follow-up to a telephone conversation with a member of the ACC's Staff, enclosed for filing are fourteen (14) copies of an amended Cross Connection or Backflow Tariff ("Amended Tariff") for Red Rock Utilities, L.L.C. ("Red Rock"). The original filing of the tariff on August 29, 2014 used an old form, whereas the enclosed Amended Tariff uses the current form of Cross Connection or Backflow Tariff from the ACC's website.

Thank you for your assistance in processing the attached Amended Tariff. Please let me know if you have any questions regarding the above or the attached.

Sincerely,  
  
Angela R. Trujillo, CLA  
Certified Paralegal  
Lawrence V. Robertson, Jr.

cc: Red Rock Utilities, L.L.C.

c:\users\angela\documents\larry\diamond ventures\red rock utilities\cross-ncnction bckflw triff\dckt cntrl ltr. 9-10-14 amended tariff.doc

PHOENIX OFFICE: 2398 E. CAMELBACK RD., STE 240, PHOENIX AZ 85016 PH: (602) 358-7348 FAX: (602) 441-2779

TUCSON OFFICE: 333 N. WILMOT RD, STE 300, TUCSON AZ 85711 PH: (520) 721-1900 FAX: (520) 747-1550

## **CROSS-CONNECTION OR BACKFLOW TARIFF**

### **PURPOSE:**

The purpose of this tariff is to protect Red Rock Utilities, LLC ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

### **REQUIREMENTS:**

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the device within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

---

**\*\*FOR OFFICIAL USE ONLY\*\***

Effective Date: \_\_\_\_\_

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
  - a. assembly identification number and description;
  - b. location
  - c. date(s) of test(s);
  - d. description of repairs and recommendations for repairs made by tester; and
  - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

---

**\*\*FOR OFFICIAL USE ONLY\*\***

Effective Date: \_\_\_\_\_