



0000156521

1 Steve Wene, State Bar No. 019630  
2 MOYES SELLERS & HENDRICKS LTD.  
3 1850 N. Central Ave., Suite 1100  
4 Phoenix, Arizona 85004  
5 Telephone: 602-604-2141  
6 e-mail: swene@lawms.com

RECEIVED

2014 OCT -7 P 4: 22

ARIZONA CORP COMMISSION  
DOCKET CONTROL

ORIGINAL

BEFORE THE ARIZONA CORPORATION COMMISSION

COMMISSIONERS

10 BOB STUMP, CHAIRMAN  
11 GARY PIERCE  
12 BRENDA BURNS  
13 SUSAN BITTER-SMITH  
14 BOB BURNS

Arizona Corporation Commission

DOCKETED

OCT 07 2014

DOCKETED BY 

14 IN THE MATTER OF THE APPLICATION  
15 OF DRAGOON WATER COMPANY, INC.  
16 FOR AN INCREASE IN ITS RATES

DOCKET NO. W-01917A-14-0313

FILING OF CERTIFICATE OF COMPLIANCE

18  
19 Dragoon Water Company, Inc. ("Company") hereby files its Certificate of  
20 Compliance issued by the Arizona Department of Revenue. See Attachment 1.  
21

22 DATED this 7<sup>th</sup> day of October, 2014.

23 MOYES SELLERS & HENDRICKS

24   
25 \_\_\_\_\_  
26 Steve Wene  
27  
28

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

Original and 13 copies of the foregoing  
filed this 7<sup>th</sup> day of October, 2014, with:

Docket Control  
Arizona Corporation Commission  
1200 West Washington  
Phoenix, Arizona 85007

Bonnelly Herbert

# **ATTACHMENT 1**

## **CROSS-CONNECTION OR BACKFLOW TARIFF**

### **PURPOSE:**

The purpose of this tariff is to protect Dragoon Water Company, ("Company") from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

### **REQUIREMENTS:**

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
  - a. assembly identification number and description;
  - b. location
  - c. date(s) of test(s);
  - d. description of repairs and recommendations for repairs made by tester;
    - i. and
  - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

---

**\*\*FOR OFFICIAL USE ONLY\*\***

Effective Date: \_\_\_\_\_