



0000159775

January 25, 2015

RECEIVED

Arizona Corporation Commission

Arizona Corporation Commission
Docket Control
1200 W. Washington St.
Phoenix, AZ 85007

2015 JAN 30 P 12: 18

DOCKETED

JAN 30 2015

ARIZONA CORPORATION COMMISSION
DOCKET CONTROL

DOCKETED BY 

Subject: Links at Coyote Wash Utilities, LLC – Docket# SW04210A-10-0392
Compliance Item – Bi-annual Update on Odor Complaints & Actions taken

Since our last update on July 15, 2014, the operators & management of Links at Coyote Wash Utilities, LLC (LACW) received two formal odor complaints, and approximately six informal odor complaints. The most recent complaint was in November.

The November complaints were due to a plant equipment problem which was described by our certified operator as follows:

I would like to let you know that we did have an issue with the pumps this last week causing a high level in the plants equalization tank (tank the raw sewage enters plant). Parts had been on order and finally arrived. On Friday 11/14/14 we emptied the tank, then had to perform a confined space entry to shovel and pump approximately 14 tons of grit and debris. This is what settles out from the raw sewage. Some things removed were what you would expect, and some things removed should never be put into the sewer system. The piping system from the pumps was replaced. Now the levels and flow can be managed. It still will require repeated adjustments as flows increase with the winter population growing weekly.


Additional improvements are scheduled in 2015 to expand the plant's aeration and equalization capacity to accommodate the additional growth in the community. These improvements, in addition to the previously mentioned upgrades (on-site activated carbon filtration system, aeration upgrades & replacements), will, we hope, continue to address the communities concern about odors and plant capacity. Furthermore, the Company continues to maintain its collection system through regular maintenance/ cleaning procedures, the last of which occurred in March, 2014, focusing specific attention on areas that have generated odor complaints.

ORIGINAL

In general, as manager of LACW, I continue to remind our operator and local representatives that the best policy to handling odor complaints is responsiveness.

If you have any questions, please contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Jason Williamson', written over a horizontal line.

Jason Williamson
Manager, Links at Coyote Wash Utilities, LLC
7581 E Academy Blvd. Suite 229
Denver, CO 80230
(720) 949-1384 x301